

① Spent fuel ^{storage} degradation
capacity.

② A-40 shutdown path

NUCLEAR MANAGEMENT AND RESOURCES COUNCIL, INC.

METHODOLOGY TO EVALUATE
PLANT EQUIPMENT FOR LICENSE RENEWAL

October 6, 1989

PREPARED
FOR
UNITED STATES DEPARTMENT OF ENERGY
BY
SANDIA NATIONAL LABORATORIES

9001050205

47pp XA

ACKNOWLEDGMENTS

Preparation of this document was performed under the guidance of the NUMARC NUPLEX Working Group in cooperation with the United States Department of Energy, Electric Power Research Institute and Lead Plant Program utilities; Yankee Atomic Electric Company and Northern States Power Company. Funding for development of the document was provided by the United States Department of Energy. The document was prepared by Sandia National Laboratories.

NOTICE

Neither Nuclear Management and Resources Council, nor any of its employees, members supporting organizations, contractors or consultants or consultants make any warranty, expressed or implied, or assume any legal responsibility for accuracy or completeness of, or assume any liability for damages resulting from any use of, any information, apparatus, methods or process disclosed in this report or process disclosed in this report or that such may not infringe privately owned rights.

TABLE OF CONTENTS

	<u>Page</u>
ACKNOWLEDGMENTS.....	ii
TABLE OF CONTENTS.....	iii
LIST OF FIGURES.....	iv
EXECUTIVE SUMMARY.....	v
MAIN REPORT	
1.0 INTRODUCTION.....	1
1.1 Background.....	1
1.2 Purpose.....	2
1.3 Scope.....	2
1.4 Approach.....	2
2.0 METHODOLOGY.....	3
2.1 Step 1 - Evaluation of All Plant Systems and Structures.....	5
2.1.1 Substep 1A - Does the Plant System or Structure Contribute to Plant Safety?.....	6
2.1.2 Substep 1B - Is Degradation of the System or Structure Potentially Significant to Plant Safety....	9
2.2 Step 2 Evaluation of Components Within Systems and Structures.....	17
2.2.1 Substep 2A - Is the Component Important to System or Structure Safety Function?.....	18
2.2.2 Substep 2B - Is the Component Subject to Established Effective Replacement, Refurbishment, or Inspection Programs?.....	21
2.2.3 Substep 2C - Is the Component Subject to Potentially-Significant Age-Related Degradation?.....	26
2.2.4 Substep 2D - Options Available to Resolve Potentially-Significant Age-Related Degradation.....	32
3.0 CONCLUSION.....	35
APPENDIX A - Listing of Steps, Substeps and Criteria.....	A-1

LIST OF FIGURES

<u>Number</u>	<u>Title</u>	<u>Page</u>
1	Methodology to Evaluate Plant Equipment for License Renewal	4
2	Substep 1a Criteria For Identifying Systems/Structures Which Contribute to Plant Safety	8
3	Substep 1b Criteria For Identifying Systems/Structures For Which Degradation is Not Potentially Significant to Plant Safety	12
4	Substep 2a Criteria For Identifying Components Not Important to System/Structure Safety Function	20
5	Substep 2b Criteria For Identifying Components Subject to Established Effective Replacement, Refurbishment or Inspection Programs	23
6	Substep 2c Criteria For Identifying Components Not Subject to Potentially Significant Age-Related Degradation	29

METHODOLOGY TO EVALUATE
PLANT EQUIPMENT FOR LICENSE RENEWAL

EXECUTIVE SUMMARY

This document presents a methodology with criteria for evaluating plant equipment for license renewal. The focus of review for such equipment is its ability to perform throughout the license renewal period. Plant equipment dispositioned during the licensing renewal evaluation will continue to be maintained in accordance with established plant practice to assure reliable operation.

The methodology presented is based upon the following precepts:

1. License renewal focuses on ensuring continued safe operation for the license renewal period.
2. License renewal is based upon continuation of the plant's current licensing basis.
3. Some equipment contributes to safety more than other equipment.
4. Existing plant programs contribute to ensuring continued safe operation.
5. Both deterministic and probabilistic approaches exist for evaluating equipment for license renewal, and subsequently for identifying plant equipment requiring further evaluation.
6. A variety of options are available to address equipment requiring further license renewal evaluation.

These precepts form the basis for the following step-by-step methodology for reevaluating plant equipment for license renewal. License renewal evaluation focuses on those systems, structures, and components that are relied upon to operate the plant safely, are subject to potentially

1 significant age-related degradation, and are not subject to established
2 effective replacement, refurbishment, or inspection programs.

3 The methodology begins with a systematic evaluation of all plant systems
4 and structures, followed by a more focused evaluation on the component level.
5 At each step, the evaluation focuses upon a decreasing subset of equipment,
6 and the basis for sufficiency of review is documented and subject to
7 regulatory review. The steps include:

- 8 o Identification of systems and structures which will be relied upon to
9 ensure continued safe plant operation.
- 10 o Within these systems and structures, identification of components
11 important to the system's or structure's safety function.
- 12 o Review of existing replacement, refurbishment, and inspection
13 programs for these components.
- 14 o For the remaining components, assessment of the potential for
15 significant age-related degradation.
- 16 o Application of options for preventing or mitigating such degradation.

17 Although both deterministic and probabilistic approaches are presented
18 in some steps, this document does not suggest development of a Probabilistic
19 Risk Assessment (PRA), if one does not already exist, nor does it require the
20 use of an existing PRA if a utility chooses to base its license renewal review
21 on deterministic criteria only. Rather, it simply provides criteria for using
22 an existing PRA to further focus the review.

23 This report presents a description of the methodology with both
24 deterministic and probabilistic means of applying it. Specific criteria for
25 each step are provided along with accompanying rationale; these criteria may
26 be found in Appendix A. Application of the methodology should result in an
27 effective and efficient review of the plant and should serve as a technical
28 basis for license renewal, a focus for license renewal evaluations, and a
29 foundation for the license renewal process and regulations.

1.0 INTRODUCTION

Currently licensed nuclear power plants represent a substantial capital investment and constitute a significant percentage of the installed electrical generating capacity in the U.S. The present regulatory process provides for a nuclear plant operating license term of 40 years. A nuclear plant license renewal program encompasses those activities that will be required to secure regulatory approval for plant operation beyond the 40-year initial operating license term.

The ability to operate a nuclear power plant beyond its initial license term may require a greater understanding of the impacts of aging mechanisms on plant safety and performance. Many plant components are already subject to a variety of programs to detect and prevent or mitigate potentially significant age-related degradation. The objective is to ensure that the proper activities are in place to manage age-related degradation in such a manner that plant safety is not adversely impacted during the license renewal period.

1.1 Background

Based on industry studies to date, there are three categories of components found in the plant: (1) those components that are routinely inspected, refurbished, or replaced, (2) those that have lifetimes in excess of the range of license renewal, and (3) those that have lifetimes within the range of license renewal. The latter category is the primary focus of license renewal.

Nuclear power plant owners have the ultimate responsibility for safe plant operation. Part of this responsibility is fulfilled through programs which detect and mitigate the effects of age-related degradation. In parallel with these efforts, there are programs under way to enhance the performance of a plant which offsets any adverse effects of age-related degradation. These programs are the principal means of maintaining a plant in a condition that will ensure safe operation.

1 A broader, more systematic assessment of plant systems, structures, and
2 components is necessary to ensure the ability to operate safely during the
3 license renewal period. To accomplish this objective, it is necessary to
4 determine what plant equipment contributes to safe plant operation and is
5 subject to age-related degradation. The methodology described in this report
6 for evaluation of plant equipment will serve as industry's technical basis for
7 license renewal review.

8 1.2 Purpose

9 The purpose of this report is to define a methodology with criteria for
10 evaluating systems, structures, and components for license renewal.

11 1.3 Scope

12 This document contains a methodology to be used by applicants and the
13 Nuclear Regulatory Commission (NRC) for evaluating systems, structures, and
14 components for license renewal.

15 1.4 Approach

16 The methodology provides both deterministic and probabilistic approaches
17 to identifying plant systems and structures which contribute to plant safety
18 and of those, identifying the ones for which degradation is potentially
19 significant to plant safety. These systems and structures are established as
20 the primary focus of further review. From this list of systems and
21 structures, the methodology describes how to: (1) identify the subset of
22 components that are important to the system's or structure's safety function;
23 (2) identify those components which currently are subject to established -
24 effective replacement, refurbishment, or inspection programs; (3) review those
25 remaining components to determine the impacts, if any, of potential
26 age-related degradation. For those components where age-related degradation
27 is a concern, options for resolving such degradation are identified. These
28 options are described but not prescribed. While there may be generic

1 strategies for continued operation of particular components, implementation of
2 these options will be plant-specific.

3 2.0 METHODOLOGY

4 A methodology with criteria for evaluating systems, structures, and
5 components for license renewal is presented in Sections 2.1 and 2.2. This
6 methodology, is based on the following precepts:

- 7 1. License renewal focuses on ensuring continued safe operation for the
8 license renewal period.
- 9 2. License renewal is based upon continuation of the plant's current
10 licensing basis.
- 11 3. Some equipment contributes to safety more than other equipment.
- 12 4. Existing plant programs contribute to ensuring continued safe
13 operation.
- 14 5. Both deterministic and probabilistic approaches exist for evaluating
15 equipment for license renewal, and subsequently for identifying
16 equipment requiring further evaluation.
- 17 6. A variety of options are available to address equipment requiring
18 further license renewal evaluation.

19 These precepts form the foundation for the method consisting of two
20 major steps with a series of substeps that progressively focus the license
21 renewal evaluation. Figure 1 summarizes the method, Appendix A summarizes the
22 criteria.

23 Step 1, "Evaluation of All Plant Systems and Structures," reviews all
24 plant systems and structures to determine those that require component-level

1 license renewal evaluation. First, Substep 1a develops a list of systems and
2 structures potentially requiring further license renewal evaluation based upon
3 the system or structure having a role, whether major or minor, in plant
4 safety. Second, Substep 1b determines if degradation of the systems and
5 structure identified in Substep 1a could potentially affect plant safety.
6 Such systems and structures require component-level evaluation for license
7 renewal. The net result, after Substeps 1a and 1b are completed, is the
8 development of a list of systems and structures requiring further
9 component-level evaluation for license renewal.

10 Step 2, "Evaluation of Components Within Systems and Structures,"
11 addresses plant systems and structures that have been determined by Step 1 to
12 require component-level evaluation for license renewal. Each such system and
13 structure is reviewed: (1) to identify components that are important to
14 performance of the system's or structure's safety function; (2) of these, to
15 identify components that are not routinely replaced, refurbished, or subject
16 to detailed inspection; (3) to determine if these remaining components are
17 susceptible to age-related degradation which may significantly affect plant
18 safety; and (4) to suggest options which can be used to resolve
19 potentially-significant age-related degradation.

20 Application of this methodology will result in a systematic evaluation
21 of all plant systems, structures, and components. The detail of the review
22 increases while progressing through the successive steps. At each step, some
23 equipment not requiring further detailed evaluation is likely to be
24 identified. The bases for such a conclusion would be documented and available
25 for regulatory review.

26 2.1 Step 1: Evaluation of All Plant Systems and Structures

27
28 The methodology begins with a systematic review of all plant systems and
29 structures. The review consists of addressing two major questions:

- 30 o Does the plant system or structure contribute to plant safety?

- 1 o Is degradation of the system or structure potentially significant to
2 plant safety?

3 Each is discussed in more detail below.

4 2.1.1 Substep 1a: Does the Plant System or Structure Contribute to Plant
5 Safety

6 As an initial step, all systems and structures that contribute to
7 plant safety are identified from the list of all plant systems and
8 structures.¹ These will be subject to further license renewal review. The
9 intent of Substep 1a is to be all-inclusive and not exclude any system or
10 structure which may contribute to safety.

11 To implement this step, criteria have been developed and are described
12 below:

- 13 o Systems or structures which contribute to plant safety are those
14 which perform one or more safety functions. These systems and
15 structures are defined as:

16 1a.1 Systems or structures that are identified as being
17 safety-related in a licensing basis document,

18 OR

19 1a.2 Systems relied upon or structures identified in a
20 licensing basis safety analysis or evaluation

21 OR

22 1a.3.a Systems utilized in plant emergency operating procedures,

23 ¹ For the purposes of this document, a "system" is a collection of
24 components working together to perform a given function. Structures are
25 composed of components in a similar manner. A component is a piece of
26 equipment, such as a vessel, pipe, pump, valve, beam, or support, which is
27 combined with other components into a system or structure. For example, the
28 PWR reactor coolant system includes, among its components, the reactor vessel,
29 primary system piping, reactor coolant pumps, steam generators, and associated
30 instrumentation and controls.

or

1a.3.b Systems taken credit for in a risk assessment if a plant unique risk assessment is available and used.

These criteria are shown schematically in Figure 2.

Criteria 1a.1 and 1a.2 above, identify those systems and structures relied upon to fulfill the requirements of the plant's current licensing basis. Among the safety functions performed by this equipment are reactor criticality control; control of reactor coolant system integrity, inventory, and heat removal; and containment integrity control and heat removal. Performance of these functions during design basis events will ensure the integrity of the reactor coolant pressure boundary; the capability to shut down the reactor and maintain safe shutdown; and the capability to prevent or mitigate the consequences of accidents that could result in potential off-site exposures comparable to the guidelines of 10 CFR Part 100. Criterion 1a.3 identifies those systems and structures, not traditionally classified as safety-related, which may be used in responding to plant transients or accidents along with the traditional safety-related systems or structures. Systems or structures identified by these Criteria (1a.1 through 1a.3) contribute to plant safety and require further license renewal evaluation.

Criteria 1a.3.a and 1a.3.b provides the option of either deterministically or probabilistically identifying those systems or structures which may be used in responding to plant transients or accidents. In the deterministic approach (Criterion 1a.3.a), the plant's Emergency Operating Procedures (EOPs) are reviewed to identify systems called upon by the EOPs in responding to the various plant transients and accidents. Some systems so identified will have also been identified by Criteria 1a.1 and 1a.2, while the remainder not so identified represent those additional systems, not traditionally classified safety related, which contribute to plant safety.

In criterion 1a.3.b, a plant unique risk assessment, if available, may be used to augment the list of traditional safety-related systems and

1 structures with those systems and structures, not traditionally classified as
2 safety related, which may be used in responding to plant transients and
3 accidents.

4 The approach used in a PRA consists of a functional analysis of each
5 system to identify its safety function. Those systems which are necessary to
6 prevent or mitigate the consequences of an accident are identified. These
7 systems, generally termed "front-line systems," are those that perform safety
8 functions in response to an initiating event. In addition, support systems
9 are frequently necessary to the successful operation of the front-line systems
10 and are modeled as well. PRA generally include a review of the plant
11 emergency operating procedures. As such, the PRA provides an alternative way
12 of identifying additional systems for license renewal review.

13 All plant systems and structures identified by any of the three criteria
14 in Substep 1a pass to Substep 1b for further consideration. These systems and
15 structures comprise the list of the plant systems and structures which have a
16 role in ensuring safe plant operation. In addition to the traditional set of
17 safety-related systems, these criteria recognize the role of selected non-
18 safety systems in controlling plant response to off-normal events and identify
19 such systems for further consideration. Support systems necessary for system
20 operation are identified as well. Thus, the further license evaluation
21 encompasses a broadly defined set of plant systems and structures.

22 2.1.2 Substep 1b: Is Degradation of the System or Structure Potentially
23 Significant to Plant Safety?

24 All systems and structures are subject to age-related degradation.
25 However, this may or may not be significant to plant safety. Criteria have
26 been developed to ascertain the potential significance of such age-related
27 degradation. These criteria are outlined below:

- 28 o Age-related degradation of a system or structure will be considered
29 potentially significant to plant safety unless failure of the system

1 or structure would not significantly contribute to increased
2 radiological health and safety risk to the public. The degradation
3 of a system or structure is considered potentially significant to
4 plant safety unless:

5 1b.1.a The system's or structure's failure could not directly
6 result in off site releases exceeding FSAR or other
7 plant-specific off-site release limits,

8 and

9 1b.1.b The system's or structure's failure could not result in
10 reactor coolant pressure boundary or primary containment
11 leakage in excess of technical specification limits,

12 and

13 1b.1.c.1 The system or structure is not otherwise required for the
14 performance or control of:

15 (1) reactor criticality

16 (2) reactor coolant system integrity, inventory, or heat
17 removal

18 (3) containment integrity or heat removal

19 or

20 1b.1.c.2 Although the system or structure may be required for
21 these functions, the system's or structure's failure is
22 detectable in a time frame which would allow shutdown
23 prior to requiring a manual or automatic plant trip.

OR

1b.2 A plant-unique risk assessment, if available and used, demonstrates that:

1b.2.a The system's or structure's failure does not occur in a sequence that has a core damage frequency greater than or equal to 1×10^{-6} per year or in a sequence that contributes 5% or more to the total estimated core damage frequency,

and

1b.2.b When the system or structure is assumed to fail due to age-related degradation, the total estimated core damage frequency will not increase by more than a factor of 3 or will not exceed 1×10^{-4} per year.

These criteria are shown schematically in Figure 3.

Age-related degradation may not significantly impact plant safety for the systems and structures identified in Substep 1a. Substep 1b assesses the potential safety significance of age-related degradation and determines those systems and structures which require component-level review. The above criteria set forth deterministic requirements which must be met or, if a PRA is used, probabilistic requirements which must be met to make the determination that potential age-related degradation would not significantly impact plant safety. Rather than assess the potential for age-related degradation of system and structures per se, Substep 1b assumes the case of system or structural failure (the bounding assumption) and assesses the potential impact on plant safety. For the determination to be made that safety would not be significantly impacted, all conditions of either the deterministic or probabilistic criteria must be met. Such a determination constitutes sufficient basis for concluding that these systems or structures need not be further evaluated for license renewal. Those systems or

1 structures for which such a determination cannot be made require
2 component-level review as outlined in Step 2 of the methodology.

3 The deterministic Criteria (1b.1.a, 1b.1.b, and 1b.1.c.1 or 1b.1.c.2)
4 require that system or structural failure could not directly result in
5 releases exceeding specified off-site limits, or result in excess leakage from
6 the reactor coolant pressure boundary or primary containment, or compromise
7 plant safety functions.

8 Criterion 1b.1.a ensures that any single system or structural failure
9 which would lead directly to an off-site release in excess of existing
10 plant-specific limits, will be evaluated further. Various licensing basis
11 documents set forth limits for off-site releases. The FSAR may be used for
12 this purpose or, alternately, other accepted licensing limits (Technical
13 Specifications). Although it is recognized that plant design and safety
14 features ensure with high confidence that off-site dose limits will not be
15 reached, this criterion requires that those systems or structures containing
16 sufficient radionuclide inventory such that off-site limits could be exceeded,
17 if no mitigative actions occur, would require further evaluation.

18 Criterion 1b.1.b ensures that those system or structural failures which
19 could lead to reactor coolant pressure boundary leakage or primary containment
20 leakage in excess of Technical Specification limits require further
21 evaluation.

22 For those systems and structures which cannot directly cause off-site
23 releases, or which cannot cause excess leakage of the reactor coolant pressure
24 boundary or primary containment in excess of Technical Specification limits
25 (i.e., those systems and structures satisfying Criteria 1b.1.a and 1b.1.b), it
26 must be also shown that the system or structure meets one of the two
27 conditions set forth in Criterion 1b.1.c.1 and 1b.1.c.2.

28 The first condition, 1b.1.c.1, requires that the system or structure is
29 not otherwise required to perform or control reactor criticality; reactor
30 coolant system integrity, inventory, or heat removal; or integrity of and heat

1 removal from the containment. All modes of plant operation are considered in
2 applying this criterion. Systems and structures which perform or control
3 these functions require further review. Examples include the major safety
4 systems in the plant, such as the emergency core cooling systems and their
5 actuation logic. Other systems or structures which support the equipment
6 performing these safety functions, for example cooling water and power
7 systems, are also subject to further review.

8 Some systems provide only information on system performance or status,
9 but are not necessary for control of system performance. Failure of such
10 systems, unless they preclude bringing the plant to safe shutdown, would not
11 directly influence system or structural performance. The consequences of
12 age-related failure of such systems would be apparent, and the plant would be
13 brought to a safe shutdown. Because plant safety is not significantly
14 affected by the failure of such systems, no further review for license renewal
15 would be required. Of course, existing plant practices which assure their
16 proper functioning will continue for the license renewal term.

17 Equipment redundancy is not considered a sufficient basis for satisfying
18 Criterion 1b.1.c.1. Two diverse systems performing the same function, such as
19 the Scram System and Standby Liquid Control System, still will require further
20 review.

21 Systems or structures which are not otherwise required to perform or
22 control these functions and which meet the off-site release and leakage
23 criteria do not require further evaluation. Most safety-related systems would
24 not be expected to meet these criteria and, hence, would require further
25 evaluation. Some systems, such as the moveable incore monitoring system, may
26 meet this condition.

27 Criterion 1b.1.c.2 acknowledges that the effects of some failures
28 manifest themselves only over a long period of time, during which the failure
29 can be detected and either the function restored or the plant shut down prior
30 to requiring the plant to trip. In this case, the impact of system or
31 structure failures on safety will be minimal. Systems or structures which

1 meet this condition, as well as the off-site release and leakage criteria do
2 not require further review for license renewal. Generally, standby systems
3 will not meet this criterion because their failure may be detected only when
4 the system is called upon to operate.

5 Criteria 1b.1 represent a deterministic approach in identifying those
6 systems and structures for which age-related degradation is potentially
7 significant to plant safety. Criteria 1b.2 give the utilities which have a
8 plant-unique risk analysis the option to use it to assess the potential safety
9 significance of age-related degradation.

10 Since all risk assessments estimate core damage frequency, the
11 probabilistic criteria have been formulated in those terms. It may be
12 demonstrated that system or structure failure does not significantly impact
13 plant safety, as measured in terms of the system's or structure's contribution
14 to core damage frequency. To make such a determination, two types of criteria
15 must be satisfied. First, in Criteria 1b.2.a, it must be shown that the
16 system or structure does not contribute to accident sequences identified as
17 significant to the estimated core damage frequency. For the purposes of this
18 document, all sequences of estimated core damage frequency greater than or
19 equal to 1×10^{-6} per year or those sequences which contribute 5% or more to
20 total core damage frequency have been considered to be significant. Systems
21 or structures which contribute to sequences higher than these thresholds
22 require further license renewal evaluation. Systems or structures
23 contributing only to the sequences lower than these thresholds must meet the
24 added criterion in Substep 1b.2.b before a disposition is made.

25 Second, because age-related degradation could increase a system's or
26 structure's failure probability, the potential effects on estimated core
27 damage frequency of reduced reliability are examined in Criterion 1b.2.b. In
28 theory, by varying the estimate of reliability, calculation of the change in
29 estimated core damage frequency can be made. In practice, however, it may be
30 difficult to estimate how a system's or structure's reliability changes in
31 response to age-related degradation. Therefore, criterion 1b.2.b examines the
? effect on total core damage frequency if the bounding assumption of failure

1 (probability of failure equals one) is made. For systems or structures
2 satisfying criterion 1b.2.a not to require further review, it must also be
3 shown that, using this conservative assumption, the estimated total core
4 damage frequency does not change significantly. Recognizing that some plants
5 have higher core damage frequency estimates than others, an upper bound of the
6 total core damage frequency must also be met.

7 There are currently no regulatory reference values for "risk increase
8 significance." In criterion 1b.2.b an increase in total core damage frequency
9 of less than a factor of three is deemed not significant. This factor is well
10 within the uncertainty bounds of currently estimated core damage frequency.
11 As an upper bound to the total core damage frequency, 10^{-4} per reactor year
12 was chosen recognizing that the upper bound of core damage frequencies for
13 most currently operating plants is approximately at this level. With the
14 bounding assumption, (i.e., system or structure failure) demonstration that
15 this level is not exceeded ensures that the plant risk would not exceed
16 currently accepted levels.

17 The "risk increase" criterion considers the effects of single system or
18 structural failures to assess the potential significance of age-related
19 degradation. While degradation of multiple systems or structures is possible,
20 differing environments, service conditions, and operating history among
21 different systems make this unlikely. The conservative nature of the
22 assumption made (i.e., system failure probability equals one) and the low
23 likelihood of age-related common mode failures that could simultaneously
24 result in failure of multiple systems or structures provides confidence in the
25 consideration of single system or structural failure to assess the potential
26 significance of age-related degradation.

27 Systems or structures meeting both probabilistic criteria in Substep 1b
28 do not require further license renewal review. Examples of such systems will
29 be plant-specific.

30 Preliminary application of the criteria in Substep 1b have identified
31 plant systems and structures which will require component-level review. These

1 systems and structures are generally those major plant systems and structures
2 containing the core and spent fuel, those which have a direct impact on plant
3 safety (e.g., safety-related systems), and those which indirectly influence
4 safety (e.g., support systems). Those systems and structures for which
5 degradation was not considered potentially significant were generally those
6 which provide non-safety functions (e.g., the Administrative Building), or
7 which provide specialized functions which do not impact public health and
8 safety (e.g. Breathing Air Systems, Inert Gas Systems, Decontamination Rooms).

9 2.2 Step 2: Evaluation of Components Within Systems and Structures

10
11 At this point in the evaluation, systems and structures requiring
12 component level review have been identified. This component-level evaluation
13 involves several steps. For each component in a system or structure requiring
14 component-level evaluation, these steps address:

- 15 o Is the component important to system or structure safety function?
- 16 o Is the component subject to established effective replacement,
17 refurbishment, or inspection programs?
- 18 o Is the component subject to potentially-significant age-related
19 degradation?

20 Components that are important to system or structure safety function and
21 are not subject to established effective replacement, refurbishment, or
22 inspection programs, and are subject to potentially significant age-related
23 degradation, require further evaluation for license renewal. There are
24 various options available to resolve potentially-significant age-related
25 degradation. Implementation of one or more of these options would support the
26 continued safe operation of these components during the license renewal
27 period. The methods in the following substeps address the above questions for
28 each component in each of the systems and structures requiring component-level
29 evaluation. A component list for each system and structure is required for
30 the application of the following steps.

2.2.1 Substep 2a: Is the Component Important to System or Structure Safety Function?

The first step of the component-level evaluation for license renewal is to identify all those components important to the system's or structure's safety function within each system or structure identified in Substep 1b as requiring component-level review. To implement Substep 2a, criteria have been developed and are described below:

- o The component is important to system or structure safety function unless:

2a.1 The component is normally isolated and does not perform an accident mitigating function.

OR

2a.2.a Component failure would not result in either the failure of any individual train within the system or the failure of the entire system to perform its required safety function.

and

2a.2.b Component failure would not reduce the structural support of any other component such that it would not perform its system safety function.

and

2a.2.c Component failure would not physically damage any other component such that it would not perform its system safety function.

OR

1 2a.3 For components within the scope of a plant-unique risk
2 assessment, if available and used, the component is not
3 included in the risk assessment models.

4 These are shown schematically in Figure 4.

5 Systems and structures are comprised of components working together to
6 perform a given function. While the systems and structures identified in
7 Substep 1b perform a safety function, not all components within the system or
8 structure may be important to that safety function. For example, systems
9 often contain components which only provide information on system performance
10 or status or which only facilitate testing or maintenance activities.
11 Similarly, structures may contain components which are extraneous to the
12 structure's safety function. For some systems and structures, only particular
13 aspects of their performance are relevant to safety. For example, for BWRs,
14 only the portion of the feedwater system providing core makeup may contribute
15 to safety. Components not necessary for system or structure safety function,
16 if they were to fail due to age-related degradation, would not adversely
17 impact safety performance. Such components will continue to be addressed by
18 existing plant practices, but require no further license renewal review. The
19 criteria developed for this step provide the basis for identifying those
20 components which are not important to the system's safety function. All
21 others will be subject to further review.

22 Some components are normally isolated and are not important to the
23 system's safety function. Examples include small valves and piping used in
24 leakage tests. Failure of such components will not affect safety and,
25 therefore, require no further review for license renewal. These components
26 are addressed in Criterion 2a.1.

27 Other components are an integral part of the system, but are not
28 important to the system's safety function. For such a determination to be
29 made, all conditions given in Criteria 2a.2.a, 2a.2.b, and 2a.2.c must be
30 satisfied. Because different components perform different roles, the criteria

1 capture a variety of perspectives. These include those components of the
2 system required for functional operation and those which provide structural
3 support. Because it is important to maintain redundancy in multi-train
4 systems, the effect of failure on individual trains is considered.
5 Consideration is also given to the potential for physical damage to other
6 components as a result of failure. If failure of the component or structure
7 would not cause system failure or reduce redundancy, would not compromise
8 necessary structural support, and would not damage other important components
9 such that they could not perform their safety function, further review for
10 license renewal is not required. Components meeting Criteria 2a.1 and 2a.2.a,
11 2a.2.b, and 2a.2.c will be plant and system specific.

12 If a risk assessment is utilized in the license renewal review, the
13 system modeling process for the PRA would have determined the components
14 important to the system's safety function. Criterion 2a.3 addresses the
15 components important from the PRA perspective. All components included in the
16 risk assessment model would pass on to Substep 2b for further consideration
17 unless they would have met one of the deterministic criteria, or the
18 combination of Criteria 2a.1 or 2a.2.a, 2a.2.b, and 2a.2.c. Components
19 within the scope of the risk assessment which were not included in the model
20 do not require further review because the determination would have been made
21 that such components are not necessary for the system safety function.
22 Documentation would be provided to support this determination. Examples of
23 components typically excluded from risk models because of their limited impact
24 on system safety function include selected instrumentation providing parameter
25 information and those components in normally isolated paths, such as test
26 lines. Those passive components or other components which are not normally
27 modeled as part of a risk assessment due to their low failure rates or those
28 considered outside the scope of the PRA are addressed only by the
29 deterministic Criteria, 2a.1, 2a.2.a, 2a.2.b, and 2a.2.c.

30 2.2.2 Substep 2b: Is the Component Subject to Established Effective
31 Replacement, Refurbishment, or Inspection Programs?

1 Effective replacement, refurbishment, and inspection programs are
2 important for managing age-related degradation, during both the initial
3 licensing period and for the license renewal period. Continuation of these
4 programs constitutes a basis for continued operation during the license
5 renewal term. Therefore, the next step is to identify which of the components
6 important to system or structure performance are subject to established
7 effective replacement, refurbishment, or inspection programs.

8 To implement Substep 2b, criteria have been developed and are described
9 below:

- 10 o A component is considered to be subject to an established effective
11 replacement, refurbishment, or inspection program if:

12 2b.1 The program is documented, approved, and routinely
13 implemented in accordance with plant administrative
14 procedures,

15 AND

16 2b.2 The program procedures ensure that all of the component's
17 significant safety functions are properly addressed,

18 AND

19 2b.3 The program establishes specific criteria for determining
20 the need for corrective action and requires such action
21 be taken if these criteria are not met.

22 These criteria are shown schematically on Figure 5.

23 Many plant components are subject to established effective repair,
24 replacement, or inspection programs during the initial operating term.
25 Continuation of these established-effective plant programs constitutes a basis

1 for continued operation during the license renewal term provided that all of
2 the component's significant safety functions (i.e. pressure boundary, valve
3 alignment, proper-flow, etc.) are properly addressed. With this attention,
4 these components will be capable of performing their safety function during
5 the license renewal term. The criteria developed for Substep 2b require that
6 these programs be formally established, approved, and routinely implemented in
7 accordance with plant administrative procedures. To be effective, corrective
8 actions must be required as part of the program if established acceptance
9 criteria are not met. The existence of such programs and the acceptance of
10 established corrective actions constitute the basis by which such programs are
11 recognized as effective for current operation and will continue to be so for
12 operation during the license renewal term as well.

13 It is recognized that many components are subject to a variety of
14 replacement, refurbishment, or inspection programs to address diverse
15 functional requirements and various degradation mechanisms. Therefore,
16 several existing programs may be required to address all of a component's
17 significant safety functions. Through a combination of such programs, as
18 necessary, the basis for operation during the license renewal term is
19 established.

20 Programs which could contribute to meeting the requirements of Substep 2b
21 for a particular component include the following:

- 22 o Programs which subject the component to periodic, routine
23 replacement, or refurbishment.
- 24 o Programs which qualify components for a specified life and require
25 requalification or replacement at the end of the qualified life.
- 26 o Programs which subject the component to routine inspections in
27 accordance with ASME, ASTM, ANSI, IEEE, or similar NRC- or
28 industry-recognized codes or standards.

- o Programs which subject the component to regular and thorough disassembly, inspection, overhaul, and testing and which require corrective action if unacceptable conditions are ascertained.
- o Programs which subject components to a failure trending program in which acceptance criteria for reliability are documented and corrective actions are specified.
- o Instrument calibration programs which require replacement or refurbishment if the component fails to meet specified acceptance criteria.
- o Other plant programs which can be shown to meet the above criteria.

Many components are routinely replaced or refurbished periodically as accepted practice during the initial licensing term. Operating experience, historic performance, component data bases, and component manufacturers' recommendations are used to arrive at a sound replacement and refurbishment strategy. Examples are plant unique, but may include refurbishment of safety relief valves, main steam isolation valves, and control rod drive hydraulic units. Continuation of these practices should be acceptable and suffice for the license renewal term.

Plant-specific programs, such as the Equipment Qualification Program, require periodic and scheduled replacement of items. During the license renewal term, these programs will specify replacement of selected components. Alternately, equipment may be requalified at the end of its qualified lifetime. Although it is important to continue to maintain and routinely replace or requalify these components, they need not be considered further in the license renewal review because the existence and continuation of such programs constitute an adequate basis for operation during the license renewal period.

Other components are subject to periodic inspections in accordance with established codes and standards. These standards provide the basis for

1 detecting and managing degradation. Examples include the requirements of ASME
2 Section XI, Subsections IWB, IWF, IWP, and IWV. Components covered by these
3 subsections would include reactor vessels and piping (IWB), snubbers and pipe
4 supports (IWF), pumps (IWP), and valves (IWV). Continued compliance with such
5 standards for those aspects addressed by the code should be sufficient for the
6 license renewal term. As codes and standards are modified over time, required
7 compliance with the new requirements would be examined as it is currently on a
8 case-specific basis.

9 Similarly, components regularly and thoroughly disassembled, inspected,
10 overhauled, and tested under plant-specific programs do not require further
11 detailed review as long as such programs continue during the license renewal
12 term. Examples are plant specific, but might include an electric motor
13 maintenance program that thoroughly disassembles, inspects, overhauls, and
14 tests electric motors for various pumps, fans, and compressors.

15 Additional examples of effective programs include those associated with
16 instrument calibration and those which explicitly track failure trends.
17 Surveillance required to meet applicable Technical Specifications, when
18 supplemented by other actions such as failure rate and performance trending or
19 disassembly inspections, contributes to the management of age-related
20 degradation.

21 The criteria for Substep 2b set forth requirements for established
22 effective practices for managing age-related degradation. Programs which are
23 effective for current operation have been detailed. Through a combination of
24 these programs and the assurance that the programs address all of a
25 component's significant safety functions the basis for continued operation is
26 established. Components subject to such programs do not require further
27 review for license renewal. Components not subject to such programs or which
28 have functions that are not fully addressed by these programs will require
29 further evaluation for license renewal in Substep 2c below.

30 2.2.3 Substep 2c: Is the Component Subject to Potentially Significant
31 Age-Related Degradation?

At this point in the review process, components that are important to the system's or structure's safety function (i.e., not meeting the criteria of Substep 2a) and that are not routinely replaced, refurbished, or subject to detailed inspection (i.e., not meeting the criteria of Substep 2b) are assessed for potential age-related degradation and the impact such degradation has on system performance. Components that are not subject to age-related degradation or for which degradation does not impact system performance do not require further review for license renewal. Components subject to age-related degradation that is significant to the component's performing its intended function and, accordingly, impacts the system's performance and plant safety, require further evaluation for license renewal.

To implement Substep 2c, criteria have been developed and are described below:

- o The component will be considered subject to potentially significant age-related degradation unless:

2c.1 It is established and documented that potentially significant age-related degradation will not occur during the license renewal period.

OR

2c.2 A plant-unique risk assessment, if available and used, demonstrates that:

- a. When the component is assumed to fail due to age-related degradation, the total estimated core damage frequency will not increase by more than a factor of three or will not exceed 1×10^{-4} per year.

and

1 b. When an age-related common-cause failure mechanism is
2 postulated that may cause multiple components to fail
3 (among those which have satisfied criterion 2c.2.a),
4 those components meet Criterion 2c.2.a when their
5 combined failures are considered as a single event.

6 These criteria are shown schematically in Figure 6.

7 Substep 2c provides both a deterministic and probabilistic option. The
8 deterministic option, given in Criterion 2c.1, requires that the potential for
9 significant component age-related degradation be assessed. The probabilistic
10 option, given in Criterion 2c.2, assesses the potential significance to plant
11 safety of component age-related degradation.

12 Assessments may be used to demonstrate the existence (or non-existence)
13 of potentially significant age-related degradation in addressing Criterion
14 2c.1. Components not subject to age-related degradation do not require
15 further review for license renewal. Components determined to be subject to
16 potentially significant age-related degradation will require further
17 evaluation for license renewal.

18 The intent of this substep is to use existing information rather than to
19 conduct detailed aging-degradation evaluations. Further detailed, plant-
20 specific age-related degradation studies of remaining components may be
21 pursued under substep 2d, if necessary. Industry, DOE, and NRC-sponsored
22 equipment evaluations may establish and document that aging does not
23 contribute to component degradation during the license renewal term for
24 selected components. These evaluations may be used as the basis for exclusion
25 of such components from further consideration for license renewal. Such
26 component-specific documentation should address the degradation mechanisms
27 acting upon the particular type of component and assess their effect during
28 the license renewal term. Should the analysis conclude that age-related
29 degradation has no significant effect on the component's ability to perform
30 its safety function or that age-related degradation occurs at a rate that is

1 of no significant concern to plant safety for the period of license renewal,
2 then it may be concluded that the component is not subject to potentially
3 significant age-related degradation.

4 If a plant-unique risk assessment is available, the probabilistic
5 Criteria, 2c.2.a and 2c.2.b, also provide a basis for concluding that further
6 evaluation for license renewal is not required. These criteria provide a
7 probabilistic basis for evaluating the potential significance of age-related
8 degradation.

9 If adequate data and techniques were available to quantitatively assess
10 the effect of age-related degradation, a modification of the PRA for
11 age-related degradation could be performed. Such data and techniques do not
12 currently exist. Rather, the criteria for this step seek to bound the
13 potential effects of age-related component degradation on plant performance.

14 Age-related degradation can impact component reliability which, in turn,
15 could affect plant safety. Criterion 2c.2.a makes the bounding assumption
16 that the component failure probability is 1.0 and calculates the resultant
17 change in estimated total core damage frequency. Such a calculation bounds
18 the effect of age-related degradation on a given component. For component
19 failure to have a minimal impact on public health and safety, it must be shown
20 that the estimated total core damage frequency does not change significantly.
21 Recognizing that some plants have higher total core damage frequency estimates
22 than others, an upper bound of the total core damage frequency, assuming that
23 the component is failed, must also be met by this conservative bounding
24 calculation.

25 There are currently no regulatory reference values for "risk increase
26 significance." This criterion suggests, consistent with that applied on the
27 system level (Substep 1b), that an increase in core damage frequency of less
28 than a factor of 3 under the bounding assumption would not be significant.
29 This factor is well within the uncertainty bounds of currently calculated
30 estimates of core damage frequency. As an upper bound to the total core
31 damage frequency, 1×10^{-4} per reactor year, was chosen recognizing that the

1 upper bound of core damage frequencies for currently operating plants is
2 approximately at this level.

3 At this point, consideration is given to the potential for age-related
4 common-cause failures. Criterion 2c.2.b recognizes that age-related
5 degradation may be a source of common-cause failures among multiple
6 components. For this reason, components which satisfy criterion 2c.2.a must
7 also meet the same numerical criterion when considered collectively in
8 combination with others for which a potential age-related common-cause failure
9 mechanism exists.

10 For those components meeting criterion 2c.2.a, potential age-related
11 common-cause failure mechanisms should be sought. There is reason to expect
12 that such failures will be infrequent, even for identical components, due to
13 differences in environment, service conditions, and testing and maintenance.
14 This would certainly be true among components in diverse systems. Several
15 potential sources of common mode failure have been addressed in previous
16 steps. Failures arising from shared equipment or dependence upon common
17 supporting systems will have been considered for these particular components
18 and systems in the previous substeps. Consideration should, however, be given
19 to potential age-related common cause failures among components remaining
20 under review, that is, those which are in systems and structures requiring
21 component-level evaluation; those which are important to system or structure
22 safety function; and those not periodically replaced, refurbished, or subject
23 to detailed inspection. Not all components need to be considered in
24 combination with all others for this criterion. Only those components subject
25 to the same age-related degradation mechanism need be examined. Should any
26 such mechanism be found, the potential significance can be evaluated using the
27 bounding assumption of failure, accounting for dependence among the failures,
28 and criterion 2c.2.a. For example, multiple motor-operated valves in a given
29 system may be subject to common age-related degradation and, hence, should be
30 considered under this criterion. However, combinations of electrical relays
31 and manual valves would not be expected to be subject to common age-related
32 degradation; as a result, they need not be considered under this criterion.

1 Components for which the above bounding calculations show that
2 age-related degradation could not significantly impact plant safety would not
3 require further review for license renewal. Components which do not meet
4 these criteria require further evaluation for license renewal.

5 2.2.4 Substep 2d: Options to Resolve Potentially Significant Age-Related
6 Degradation

7 At this point, components have been identified that are important to the
8 safety of the plant, that are not routinely replaced or critically inspected
9 during 40-year operation, and that are subject to potentially significant
10 age-related degradation. A strategy for managing age-related degradation
11 needs to be developed by each utility for each such component or group of
12 components to justify continued operation of these components.

13 A variety of options to resolve potentially significant age-related
14 degradation may be appropriate depending upon the component being addressed.

15
16 Among the options are:

- 17 1. Replace the component on a replacement schedule which precludes
18 component age-related degradation from becoming a problem.
- 19 2. Demonstrate, by detailed investigation, that age-related degradation
20 of the component will not be significant during the license renewal
21 period.
- 22 3. Demonstrate, by a more rigorous analysis, that the potential
23 age-related degradation of the component is not significant to
24 safety.
- 25 4. Institute practices which manage component age-related degradation by
26 diagnosing the age-related degradation processes and preventing or
27 mitigating their effect.

1 Implementation of one or more of these options will complete the license
2 renewal evaluation and provide the basis for continued operation of the
3 remaining components for the license renewal term.

4 The most straight-forward resolution of the potential for age-related
5 degradation may be to replace the aged component with a new one. Age-related
6 degradation would not be of concern with the new component for the immediate
7 future. Periodic replacement may obviate concern for age-related degradation
8 altogether.

9 For other components, it may be desirable to conduct a detailed aging
10 evaluation. This evaluation would supplement that which may have been
11 performed under Substep 2c. The purpose of such an evaluation would be to
12 identify the potential for and the effects of age-related degradation during
13 the license renewal term. The evaluation may demonstrate that age-related
14 degradation is not a concern during the license renewal term. If so, the
15 evaluation would justify continued operation. If not, other options detailed
16 in this step of the process would need to be pursued to justify continued
17 operation.

18 The assessment of potential age-related degradation to this point in the
19 review may well have been conservative. Improvements in the assessment can be
20 made by improving analytical techniques for the evaluation, by more accurately
21 assessing the environmental conditions giving rise to the degradation concern,
22 or by implementing predictive monitoring techniques to better monitor the
23 condition of the equipment. Examples include improved margin analysis,
24 development of time-dependent component reliability data, water chemistry data
25 collection, and performance trending. Updated codes and standards may provide
26 improved criteria for assessing the acceptability of continued component
27 operation. Research and development activities may improve our understanding
28 of age-related degradation and its effects enabling more realistic
29 assessments.

30 In making a decision to pursue license renewal prior to expiration of
3 the initial license, after 20 years of operation, for example, a licensee has

1 the option to implement preventive actions before the component reaches its
2 natural life and thereby enhance life expectancy. Application of protective
3 coatings, improved water chemistry, and cathodic protection are examples of
4 such early actions.

5 The licensee also has options to mitigate the effects of age-related
6 degradation. When degradation has been identified, actions can be taken to
7 reduce the severity of the degradation and thereby enhance the service life.
8 In some cases, corrective actions may be necessary to return degraded
9 components to a condition acceptable for continued operation; this may be
10 accomplished via overhaul, refurbishment, repair, replacement, or
11 modification.

12 Improved maintenance and surveillance activities may also provide a basis
13 for continued operation. Such activities would improve the assessment of the
14 effects of age-related degradation and lead to actions to prevent or mitigate
15 such degradation.

16 Life extension options depend largely on the timing of individual
17 decisions and, most of all, on plant-unique assessments of components with due
18 consideration of operational duty and historic performance. Through a
19 combination of better assessment, prevention, and mitigation for those
20 components with the potential for significant age-related degradation,
21 continued safe, reliable, and economic performance can be assured.

22 3.0 CONCLUSION

23 This document describes a methodology with criteria for systematically
24 evaluating plant equipment for license renewal. The methodology identifies
25 plant systems and structures which require component level review. Among
26 these systems and structures, (1) the subset of components that is important
27 to the system's or structure's safety functions are identified; (2) those
28 components which currently are subject to established effective replacement,

1 refurbishment, or inspection programs are identified; (3) the remaining
2 components are reviewed to determine the impacts, if any, of age-related
3 degradation; and (4) for those components where age-related degradation is a
4 concern, options for resolution are detailed. At each step, the review
5 focuses upon a decreasing subset of equipment, and the basis for sufficiency
6 of review is documented and subject to regulatory review. Application of the
7 methodology should result in effective and efficient review of the plant and
8 should serve as a technical basis for the scope of license renewal, a focus
9 for license renewal evaluations, and a foundation for license renewal process
10 and regulations.

1 Step 1. Evaluation of All Plant Systems and Structures

2 Substep 1a. Does the Plant System or Structure Contribute to Plant Safety?

3 1a.1. Systems or structures that are identified as
4 being safety-related in a licensing basis
5 document.

6 OR

7 1a.2. Systems relied upon or structures identified in a
8 licensing basis safety analysis or
9 evaluation.

10 OR

11 1a.3.a Systems utilized in plant emergency operating
12 procedures.

13 or

14 1a.3.b Systems taken credit for in a risk assessment if
15 a plant unique risk assessment is available and
16 used.

17 Substep 1b. Is Degradation of the System or Structure Potentially
18 Significant to Plant Safety?

19 1b.1.a The system's or structure's failure could not
20 directly result in off-site releases exceeding
21 FSAR or other plant-specific off-site release
22 limits.

23 and

24 1b.1.b The system's or structure's failure could not
25 result in reactor coolant pressure boundary or
26 primary containment leakage in excess of
27 technical specification limits.

28 and

1b.1.c.1 The system or structure is not otherwise required for the performance or control of:

(1) reactor criticality

(2) reactor coolant system integrity, inventory, or heat removal

(3) containment integrity or heat removal or

1b.1.c.2 Although the system or structure may be required for these functions, the system's or structure's failure is detectable in a time frame which would allow shutdown prior to requiring a manual or automatic plant trip.

OR

1b.2. A plant-unique risk assessment, if available and used, demonstrates that:

1b.2.a The system's or structure's failure does not occur in a sequence that has a core damage frequency greater than or equal to 1×10^{-6} per year or in a sequence that contributes 5% or more to the total estimated core damage frequency.

and

1b.2.b When the system or structure is assumed to due to age-related degradation, the total estimated core damage frequency will not increase by more than a factor of 3 or will not exceed 1×10^{-4} per year.

Step 2. Evaluation of Components Within Systems and Structures

1 Substep 2a. Is the Component Important to System or Structure Safety
2 Function?

3 The component is important to system or structure safety
4 function unless:

5 2a.1. The component is normally isolated and does not
6 perform an accident mitigating function.

7 OR

8 2a.2.a Component failure would not result in either the
9 failure of any individual train within the system
10 or the failure of the entire system to perform its
11 required safety function.

12 and

13 2a.2.b Component failure would not reduce the structural
14 support of any other component such that it would
15 not perform its system safety function and

16 and

17 2a.2.c Component failure would not physically damage any
18 other component such that it would not perform its
19 system safety function.

20 OR

21 2a.3. For components within the scope of a plant-unique
22 risk assessment, if available and used, the
23 component is not included in the risk assessment
24 models.

25 Substep 2b. Is the Component Subject to Established Effective Replacement,
26 Refurbishment, or Inspection Programs?

27 A component is considered to be subject to an established
28 effective replacement, refurbishment, or inspection program if:

29 2b.1. The program is documented, approved, and routinely
30 implemented in accordance with plant administrative
31 procedures,

1 AND

2 2b.2. The program procedures ensure that all of the
3 component's significant safety functions are properly
4 addressed,

5 AND

6 2b.3. The program establishes specific criteria for
7 determining the need for corrective action and
8 requires such action be taken if these criteria are
9 not met.

10 Substep 2c. Is the Component Subject to Potentially Significant
11 Age-Related Degradation?

12 The component will be considered subject to potentially
13 significant age-related degradation unless:

14 2c.1 It is established and documented that
15 potentially significant age-related degradation
16 will not occur during the license renewal
17 period.

18 OR

19 2c.2 A plant-unique risk assessment, if available and
20 used, demonstrates that:

21
22 2c.2.a When the component is assumed to fail due to
23 age-related degradation, the total core
24 estimated damage
25 frequency will not increase by more than a
26 factor of three or will not exceed 1×10^{-4} per
27 year.

28 and

29 2c.2.b When an age-related common-cause failure
30 mechanism is postulated that may cause multiple
31 components to fail (among those which have

1 satisfied criterion 2c.2.a), those components
2 meet Criterion 2c.2.a when their combined
3 failures are considered as a single event.

4 Substep 2d. Options to Resolve Potentially Significant Age-Related
5 Degradation.

6 A variety of options to resolve potentially significant age-
7 related degradation may be appropriate depending upon the
8 component being addressed. Among the options are:

- 9 1. Replace the component on a replacement schedule which
10 precludes component age-related degradation from
11 becoming a problem.
- 12 2. Demonstrate, by detailed investigation, that
13 age-related degradation of the component will not be
14 significant during the license renewal period.
- 15 3. Demonstrate, by a more rigorous analysis, that the
16 potential age-related degradation of the component is
17 not significant to safety.
- 18 4. Institute practices which manage component age-related
19 degradation by diagnosing the age-related degradation
20 processes and preventing or mitigating their effect.