



UNITED STATES  
ATOMIC ENERGY COMMISSION  
DIRECTORATE OF REGULATORY OPERATIONS  
REGION III  
799 ROOSEVELT ROAD  
GLEN ELLYN, ILLINOIS 60137

TELEPHONE  
(312) 858-2660

July 21, 1972

J. G. Keppler, Chief, Reactor Testing and Operations Branch  
Directorate of Regulatory Operations, Headquarters

WISCONSIN MICHIGAN POWER COMPANY  
LICENSE NO. DPR-24  
POINT BEACH UNIT 1  
BORIC ACID TANK CONCENTRATION

The attached inquiry report is forwarded for information.

The licensee failed to detect an increase in tank level coupled with a decrease in the boric acid concentration.

The licensee will issue a report within ten days as required by the technical specifications.

This item will be reviewed during a routine, unannounced inspection scheduled for July 19-20, 1972.

*D. M. Hunnicutt*

D. M. Hunnicutt, Chief  
Reactor Testing and Startup Branch

Attachment:

RO Inquiry Rpt No. 050-266/72-02  
(2 cys)

cc: H. D. Thornburg, RO  
J. B. Henderson, RO  
R. B. Minogue, RS (3)  
R. S. Boyd, L (2)  
R. C. DeYoung, L (2)  
D. J. Skovholt, L (3)  
H. R. Denton, L (2)  
P. A. Morris, RO  
R. H. Engelken, RO  
RO Files  
DR Central Files