



10CFR50.55(a)  
ASME XI

**BOSTON EDISON**

Pilgrim Nuclear Power Station  
Rocky Hill Road  
Plymouth, Massachusetts 02360

**George W. Davis**  
Senior Vice President -- Nuclear

April 24, 1991  
BEC0 91-058

U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

License DPR-35  
Docket 50-293

Inservice Inspections Planned for Refueling Outage #8  
Pilgrim Nuclear Power Station (PNPS)

Boston Edison Company hereby submits the inservice inspections planned for Refueling Outage #8 at PNPS. The examinations listed in Enclosure A are scheduled in accordance with the requirements of ASME XI 1980 Edition Winter 1980 addenda and will complete 50% of the required examinations for the second ten year inspection interval. Additional ASME XI second interval examinations are listed in Enclosure B and will be performed, if possible. Certain ISI examinations originally scheduled for RFO #8 were performed during the April 1990 mid-cycle maintenance outage and they are identified with an asterisk in Enclosure A.


The following augmented examinations have also been scheduled for RFO #8:

- Examinations for Intergranular Stress Corrosion Cracking (IGSCC) in accordance with our response to Generic Letter 88-01 are listed in Enclosure C. Some of the examinations originally scheduled for RFO #8 were performed during the April 1990 mid-cycle outage and they are identified with an asterisk. Several alternate welds have been substituted into the IGSCC exam schedule reported in our initial response to Generic Letter 88-01. These welds are identified in Enclosure D.
- The following IGSCC examinations will be conducted in accordance with our response to NRC Bulletin 88-08.

10R-IA-5  
14R-A-13  
14R-B-13

BEC0 committed to inspect 10-HS-18 and 10-HS-19 in the response to the bulletin. These welds will not be examined because the head spray line including these welds will be removed during this outage.

- Seven welds in non-safety related Reactor Water Cleanup piping are listed in Enclosure E and they will be examined for IGSCC in accordance with our most recent response to Generic Letter 88-01 (BECc Letter 90-140).
- Ultrasonic thickness measurements for erosion/corrosion will be performed in accordance with our response to Generic Letter 89-08.
- Ultrasonic examination of four Feedwater nozzles will be conducted in accordance with NUREG 0619.
- Visual examination of the Core Spray spargers in response to Bulletin 80-13.
- Remote visual examination of a portion of the buried Salt Service Water piping will be conducted.
- Ultrasonic thickness measurements of a portion of the accessible Salt Service Water piping will be conducted.

  
G. W. Davis

RAH/clc/5515  
cc: See page 3

- Enclosures:
- (A) ASME XI Second Ten Year Interval Examinations Scheduled for Refuel Outage 8.
  - (B) Additional ASME XI Second Ten Year Interval Examinations to be performed During Refuel Outage 8-if possible.
  - (C) Safety-Related IGSCC-Susceptible Welds Scheduled for Examination During Refuel Outage 8 in Accordance with Generic Letter 88-01.
  - (D) Modified IGSCC Inspection Schedule
  - (E) Non-Safety Related IGSCC-Susceptible Welds Scheduled for Examination During Refuel Outage 8 in Accordance with Generic Letter 88-01 and BECO Letter 2.90.140.

BOSTON EDISON COMPANY

U.S. Nuclear Regulatory Commission

Page 3

---

cc: Mr. R. Eaton, Project Manager  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation  
Mail Stop: 14D1  
U. S. Nuclear Regulatory Commission  
1 White Flint North  
11555 Rockville Pike  
Rockville, MD 20852

U. S. Nuclear Regulatory Commission  
Region I  
475 Allendale Road  
King of Prussia, PA 19406

Senior NRC Resident Inspector  
Pilgrim Nuclear Power Station

Mr. Fred P. Barton  
Supervising District Engineering Inspector  
Division of Inspection  
Department of Public Safety  
1 Ashburton Place  
Room 1301  
Boston, MA 02108

Factory Mutual Engineering  
Mr. Kevin McTague  
ANIIS  
Boston District Office  
1151 Boston-Providence Turnpike  
Norwood, MA 02062

\* Exams performed during 1990 Maintenance Outage.

ENCLOSURE A

PILGRIM NUCLEAR POWER STATION  
ASME XI SECOND TEN YEAR INTERVAL EXAMINATIONS SCHEDULED FOR REFUEL OUTAGE B

SYSTEM ID	COMPONENT ID NO.	COMPONENT DESCRIPTION	ITEM NO.	ISOMETRIC NO.	LOCATION	EXAM. METHOD
CACS	H-45-1-1	RIGID HANGER	F(1-3)	ISI-1-50-1	DW ACCESS	VT-3
CACS	H-45-1-1SG	RIGID HANGER	F(1-3)	ISI-1-50-1	DW ACCESS	VT-3
* CACS	H-45-1-5	SPRING HANGER	F(1-4)	ISI-1-50-1	TIP ROOM	VT-3 VT-4
* CACS	H-45-1-6	SPRING HANGER	F(1-4)	ISI-1-50-1	TIP ROOM	VT-3 VT-4
***						
CRD	3-WSD-11	CAP TO PIPE	C5.11	ISI-1-3-1	WEST CRD	MT
***						
CS	14-A-6	PIPE TO ELBOW	B9.11	ISI-1-14-1	DRYWELL	UT45 UT60 MT
CS	14-B-6	PIPE TO ELBOW	B9.11	ISI-1-14-1	DRYWELL	UT45 UT60 MT
CS	14R-A-16	PENETRATION TO ELBOW	B9.11	ISI-1-14-1	DRYWELL DRYWELL	PT UT45 UT60
CS	14R-B-16	PENETRATION TO ELBOW	B9.11	ISI-1-14-1	DRYWELL	PT UT45 UT60
CS	GB-14-1HL1(4)	SUPPORT LUGS	C3.40	ISI-1-14-2B	WEST CRD	MT
* CS	HL-14-F50	PIPE TO VALVE	C5.11	ISI-1-14-2A	TORUS ROOM	MT
* CS	HLB-14-F48H	PIPE TO ELBOW	C5.11	ISI-1-14-2A	TORUS ROOM	MT
* CS	HL-14-F51	PIPE TO FLANGE	C5.11	ISI-1-14-2B	TORUS ROOM	MT
* CS	HLB-14-F14H	PIPE TO ELBOW	C5.11	ISI-1-14-2B	TORUS ROOM	MT
CS	DR/DC-14-3002-5-1	ELBOW TO PIPE	C5.21	ISI-1-14-2A	RWCU HX RM	PT UT45 UT60
CS	DB/DC-14-3001-4-1	PIPE TO PIPE	C5.21	ISI-1-14-2B	RB 51'	UT45 UT60 PT
CS	H-14-1-2	RIGID HANGER	F(1-3)	ISI-1-14-2A	TORUS ROOM	VT-3
CS	H-14-1-4SH	RIGID HANGER	F(1-3)	ISI-1-14-2A	A RHR VV RM	VT-3
CS	H-14-1-20S	RESTRAINT	F(1-3)	ISI-1-14-2A	A RHR QUAD	VT-3
CS	H-14-1-6	RIGID HANGER	F(1-3)	ISI-1-14-2A	TORUS ROOM	VT-3
CS	H-14-1-10	RIGID HANGER	F(1-3)	ISI-1-14-2B	TORUS ROOM	VT-3
***						
FW	6-A-4HL1(B)	SUPPORT LUG	B10.10	ISI-1-6-1	DRYWELL	MT
* FW	6-A-10	PIPE TO FLUED HEAD	B9.11	ISI-1-6-1	STEAM TUNNEL	MT UT45 UT60
* FW	6-B-8	PIPE TO FLUED HEAD	B9.11	ISI-1-6-1	STEAM TUNNEL	MT UT45

\*Exams performed during 1990 maintenance outage.

ENCLOSURE A

PILGRIM NUCLEAR POWER STATION  
ASME XI SECOND TEN YEAR INTERVAL EXAMINATIONS SCHEDULED FOR REFUEL OUTAGE B

SYSTEM ID	COMPONENT ID NO.	COMPONENT DESCRIPTION	ITEM NO.	ISOMETRIC NO.	LOCATION	EXAM. METHOD
						UT60
* FW	H-6-1-68	RIGID HANGER	F(1-3)	ISI-1-6-1	STEAM TUNNEL	VT-3
* FW	H-6-1-69	RIGID HANGER	F(1-3)	ISI-1-6-1	STEAM TUNNEL	VT-3
FW	H-6-1-112	SPRING HANGER	F(1-4)	ISI-1-6-1	DRYWELL	VT-3 VT-4
FW	H-6-1-SS-10	SNUBBER	F(1-4)	ISI-1-6-1	DRYWELL	VT-3 VT-4
FW	H-6-1-SS-3	SNUBBER	F(1-4)	ISI-1-6-1	DRYWELL	VT-3 VT-4
FW	H-6-1-SS-7	SNUBBER	F(1-4)	ISI-1-6-1	DRYWELL	VT-3 VT-4
FW	H-6-1-SS-9	SNUBBER	F(1-4)	ISI-1-6-1	DRYWELL	VT-3 VT-4
FW	H-6-1-107	SPRING HANGER	F(1-4)	ISI-1-6-1	DRYWELL	VT-3 VT-4
FW	H-6-1-114	SPRING HANGER	F(1-4)	ISI-1-6-1	DRYWELL	VT-3 VT-4
***						
HPCI	23-VB-2301-5	VALVE BOLTING	B7.70	ISI-1-23-1	DRYWELL	VT-1
HPCI	23-VB-2301-B	VALVE BOLTING	B7.70	ISI-1-23-1	TIP ROOM	VT-1
* HPCI	23-0-16	PIPE TO PENETRATION	B9.11	ISI-1-23-1	DRYWELL	MT UT45 UT60
* HPCI	23-0-17	PENETRATION TO PIPE	B9.11	ISI-1-23-1	B RHR VV RM	MY UT45 UT60
* HPCI	23-1-12	PIPE TO PIPE	B9.11	ISI-1-23-1	TIP ROOM	MT UT45 UT60
HPCI	EB-23-37HL1(4)	SUPPORT LUGS	C3.40	ISI-1-23-5	HPCI ROOM	MT
* HPCI	HL-23-1-2A	FLANGE TO PIPE	C5.11	ISI-1-23-4	TORUS ROOM	MT
* HPCI	HL-23-F20	PIPE TO VALVE	C5.11	ISI-1-23-4	HPCI ROOM	MT
HPCI	DB-23-F53	ELBOW TO PIPE	C5.21	ISI-1-23-5	TORUS ROOM	MT UT45 UT60
HPCI	H-23-1-28S	RIGID HANGER	F(1-3)	ISI-1-23-2	HPCI ROOM	VT-3
HPCI	H-23-1-25	RIGID HANGER	F(1-3)	ISI-1-23-4	HPCI ROOM	VT-3
HPCI	H-23-1-1SH	ANCHOR	F(1-3)	ISI-1-23-4	TORUS ROOM	VT-3
HPCI	H-23-1-28	RIGID HANGER	F(1-3)	ISI-1-23-5	HPCI ROOM	VT-3
HPCI	H-23-1-SS13	SNUBBER	F(1-4)	ISI-1-23-1	DRYWELL	VT-3 VT-4
HPCI	H-23-1-SS14	SNUBBER	F(1-4)	ISI-1-23-1	DRYWELL	VT-3 VT-4
HPCI	H-23-1-20	SPRING HANGER	F(1-4)	ISI-1-23-3	HPCI ROOM	VT-3 VT-4

\*\*\*

\*Exams performed during 1990 maintenance outage.

ENCLOSURE A

PILGRIM NUCLEAR POWER STATION  
ASME XI SECOND TEN YEAR INTERVAL EXAMINATIONS SCHEDULED FOR REFUEL OUTAGE B

SYSTEM ID	COMPONENT ID NO.	COMPONENT DESCRIPTION	ITEM NO.	ISOMETRIC NO.	LOCATION	EXAM. METHOD
MS	1-VB-220-1	VALVE BOLTING <2"	B7.70	ISI-1-1-1	DRYWELL	VT-1
MS	1-VB-220-2	VALVE BOLTING <2"	B7.70	ISI-1-1-1	STEAM TUNNEL	VT-1
* MS	1-B-14	VALVE TO PIPE	B9.11	ISI-1-1-1	DRYWELL	MT UT45 UT60
* MS	1-B-15	FLUED HEAD TO PIPE	B9.11	ISI-1-1-1	STEAM TUNNEL	MT UT45 UT60
* MS	1-B-8	ELBOW TO PIPE	B9.11	ISI-1-1-1	DRYWELL	MT UT45 UT60
* MS	1-B-9	PIPE TO ELBOW	B9.11	ISI-1-1-1	DRYWELL	MT UT45 UT60
* MS	1-AR-1	PIPE TO WELDOLET	B9.31	ISI-1-1-1	DRYWELL	MT UT45 UT60
* MS	H-1-1-29	RIGID HANGER	F(1-3)	ISI-1-1-1	STEAM TUNNEL	VT-3
* MS	H-1-1-36	RIGID HANGER	F(1-3)	ISI-1-1-1	STEAM TUNNEL	VT-3
* MS	H-1-1-X7B	ANCHOR	F(1-3)	ISI-1-1-1	STEAM TUNNEL	VT-3
* IS	H-1-1-108	RIGID SUPPORT	F(1-3)	ISI-1-1-1	STEAM TUNNEL	VT-3
* MI	H-1-1-X8	ANCHOR	F(1-3)	ISI-1-1-1	STEAM TUNNEL	VT-3
MS	H-1-1-HA1	SPRING HANGER	F(1-4)	ISI-1-1-1	DRYWELL	VT-3 VT-4
MS	H-1-1-HA4	SPRING HANGER	F(1-4)	ISI-1-1-1	DRYWELL	VT-3 VT-4
MS	H-1-1-HB1	SPRING HANGER	F(1-4)	ISI-1-1-1	DRYWELL	VT-3 VT-4
MS	H-1-1-HC3	SPRING HANGER	F(1-4)	ISI-1-1-1	DRYWELL	VT-3 VT-4
MS	H-1-1-HD2	SPRING HANGER	F(1-4)	ISI-1-1-1	DRYWELL	VT-3 VT-4
MS	H-1-1-HD4	SPRING HANGER	F(1-4)	ISI-1-1-1	DRYWELL	VT-3 VT-4
MS	H-1-1-SA3	SNUBBER	F(1-4)	ISI-1-1-1	DRYWELL	VT-3 VT-4
MS	H-1-1-SB3	SNUBBER	F(1-4)	ISI-1-1-1	DRYWELL	VT-3 VT-4
***						
RBCCW	H-30-1-446G	GUIDE	F(1-3)	ISI-1-30-1	B RHR QUAD	VT-3
* RBCCW	H-30-1-288	GUIDE	F(1-3)	ISI-1-30-1	RB 74'	VT-3
* RBCCW	H-30-1-290	GUIDE	F(1-3)	ISI-1-30-1	FP HX RM	VT-3
* RBCCW	H-30-1-291	GUIDE	F(1-3)	ISI-1-30-1	FP HX RM	VT-3
* RBCCW	H-30-1-292	GUIDE	F(1-3)	ISI-1-30-1	FP HX RM	VT-3
* RBCCW	H-30-1-390	GUIDE	F(1-3)	ISI-1-30-1	FP HX RM	VT-3
* RBCCW	H-30-1-595A	ANCHOR	F(1-3)	ISI-1-30-1	RB 74'	VT-3
* RBCCW	H-30-1-60SR	GUIDE	F(1-3)	ISI-1-30-1	FP HX RM	VT-3
* RBCCW	H-30-1-615A	ANCHOR	F(1-3)	ISI-1-30-1	FP HX RM	VT-3

\*Exams performed during 1990 maintenance outage.

ENCLOSURE A

PILGRIM NUCLEAR POWER STATION  
ASME XI SECOND TEN YEAR INTERVAL EXAMINATIONS SCHEDULED FOR REFUEL OUTAGE B

SYSTEM ID	COMPONENT ID NO.	COMPONENT DESCRIPTION	ITEM NO.	ISOMETRIC NO.	LOCATION	EXAM. METHOD
* RBCCW	H-30-1-62SA	ANCHOR	F(1-3)	ISI-1-30-1	FP HX RM	VT-3
RBCCW	H-30-1-SR10	RIGID HANGER	F(1-3)	ISI-1-30-1	FP HX RM	VT-3
* RBCCW	H-30-1-12SA	ANCHOR	F(1-3)	ISI-1-30-1	B AUX BAY	VT-3
* RBCCW	H-30-1-7SA	ANCHOR	F(1-3)	ISI-1-30-1	A AUX BAY	VT-3
* RBCCW	H-30-1-1325SP	ANCHOR	F(1-3)	ISI-1-30-2	PIPEWAY	VT-3
RBCCW	H-30-1-135	RIGID HANGER	F(1-3)	ISI-1-30-2	A RHR QUAD	VT-3
* RBCCW	H-30-1-1SA	ANCHOR	F(1-3)	ISI-1-30-2	B RHR QUAD	VT-3
* RBCCW	H-30-1-27SA	ANCHOR	F(1-3)	ISI-1-30-2	A AUX BAY	VT-3
* RBCCW	H-30-1-30SA	ANCHOR	F(1-3)	ISI-1-30-2	B AUX BAY	VT-3
RBCCW	H-30-1-52	RIGID HANGER	F(1-3)	ISI-1-30-2	B AUX BAY	VT-3
RBCCW	H-30-1-54	RIGID HANGER	F(1-3)	ISI-1-30-2	B AUX BAY	VT-3
RBCCW	H-30-1-66	RIGID HANGER	F(1-3)	ISI-1-30-2	A AUX BAY	VT-3
RBCCW	H-30-1-67	RIGID HANGER	F(1-3)	ISI-1-30-2	A AUX BAY	VT-3
* RBCCW	H-30-1-346	GUIDE	F(1-3)	ISI-1-30-2	PIPEWAY	VT-3
* RBCCW	H-30-1-29SA	ANCHOR	F(1-3)	ISI-1-30-2	B AUX BAY	VT-3
* RBCCW	H-30-1-74SA	ANCHOR	F(1-3)	ISI-1-30-2	MG ROOM	VT-3
* RBCCW	H-30-1-48	SPRING HANGER	F(1-4)	ISI-1-30-2	B RHR QUAD	VT-3
						VT-4
RBCCW	H-30-1-65SH	SPRING HANGER	F(1-4)	ISI-1-30-2	PIPEWAY	VT-3
						VT-4
***						
RCIC	13-VB-1301-16	VALVE BOLTING	B7.70	ISI-1-13-1	DRYWELL	VT-1
RCIC	13-VB-1301-17	VALVE BOLTING	B7.70	ISI-1-13-1	TIP ROOM	VT-1
RCIC	13-O-17	ELBOW TO PIPE	B9.21	ISI-1-13-1	DRYWELL	MT
RCIC	13-O-18	PIPE TO PIPE	B9.21	ISI-1-13-1	TIP ROOM	MT
RCIC	HB-13-F-HL1(2)	HANGER LUGS	C3.40	ISI-1-13-3	RCIC QUAD	MT
RCIC	HL-13-F661	PIPE TO ELBOW	C5.11	ISI-1-13-3	TORUS ROOM	MT
* RCIC	H-13-1-12SA	ANCHOR	F(1-3)	ISI-1-13-1	TIP ROOM	VT-3
* RCIC	H-13-1-42	ANCHOR	F(1-3)	ISI-1-13-1	TIP ROOM	VT-3
* RCIC	H-13-1-43	RESTRAINT	F(1-3)	ISI-1-13-1	TIP ROOM	VT-3
* RCIC	H-13-1-6SH	RIGID HANGER	F(1-3)	ISI-1-13-1	TIP ROOM	VT-3
* RCIC	H-13-1-25	RIGID SUPPORT	F(1-3)	ISI-1-13-2	RCIC QUAD	VT-3
* RCIC	H-13-1-26	RIGID SUPPORT	F(1-3)	ISI-1-13-2	RCIC QUAD	VT-3
* RCIC	H-13-1-2SR	LATERAL RESTRAINT	F(1-3)	ISI-1-13-2	RCIC QUAD	VT-3
* RCIC	H-13-1-29	RIGID HANGER	F(1-3)	ISI-1-13-3	RCIC QUAD	VT-3
* RCIC	H-13-1-33	SPRING HANGER	F(1-3)	ISI-1-13-3	RCIC QUAD	VT-3
						VT-4
* RCIC	H-13-1-44	SPRING HANGER	F(1-4)	ISI-1-13-1	TIP ROOM	VT-3
						VT-4
***						
RECIRC	2R-FB-BP-1A	FLANGE BOLTING	B7.50	ISI-1-2R-B	DRYWELL	VT-1
RECIRC	2R-FB-N1A-79C-1	FLANGE BOLTING	B7.50	ISI-1-2R-B	DRYWELL	VT-1
RECIRC	2-VB-202-4B	VALVE BOLTING	B7.70	ISI-1-2R-B	DRYWELL	VT-1
RECIRC	2R-N2C-3	CROSS TO PIPE	B9.11	ISI-1-2R-A	DRYWELL	PT
						UT45
						UT60

\* Exams performed during 1990 maintenance outage.

ENCLOSURE A

PILGRIM NUCLEAR POWER STATION  
ASME XI SECOND TEN YEAR INTERVAL EXAMINATIONS SCHEDULED FOR REFUEL OUTAGE B

SYSTEM ID	COMPONENT ID NO.	COMPONENT DESCRIPTION	ITEM NO.	ISOMETRIC NO.	LOCATION	EXAM. METHOD
RECIRC	2R-N1B-4	PIPE TO TEE	B9.11	ISI-1-2R-A	DRYWELL	PT UT45 UT60
* RECIRC	2R-N2H-3	CROSS TO PIPE	B9.11	ISI-1-2R-B	DRYWELL	PT UT45 UT60
RECIRC	2R-N1A-14	TEE TO PIPE	B9.11	ISI-1-2R-B	DRYWELL	PT UT45 UT60
RECIRC	2R-N1B-9BC-3	PIPE TO VALVE	B9.40	ISI-1-2R-A	DRYWELL	PT
* RECIRC	H-2-1-G1	GUIDE	F(1-3)	ISI-1-2R-A	DRYWELL	VT-3
RECIRC	H-2-1-SS23	SNUBBER	F(1-4)	ISI-1-2R-A	DRYWELL	VT-3 VT-4
RECIRC	H-2-1-SS7	SNUBBER	F(1-4)	ISI-1-2R-A	DRYWELL	VT-3 VT-4
RECIRC	H-2-1-SS1	SNUBBER	F(1-4)	ISI-1-2R-B	DRYWELL	VT-3 VT-4
RECIRC	H-2-1-H15	SPRING HANGER	F(1-4)	ISI-1-2R-B	DRYWELL	VT-3 VT-4
RECIRC	H-2-1-SS8	SNUBBER	F(1-4)	ISI-1-2R-B	DRYWELL	VT-3 VT-4
***						
RHR	10-VB-1001-47	VALVE BOLTING	B7.70	ISI-1-10-1A	A RHR VV RM	VT-1
RHR	10-1A-14	PIPE TO FLUED HEAD	B9.11	ISI-1-10-1	A RHR VV RM	PT UT45 UT60
RHR	10R-1A-12	PENETRATION TO ELBOW	B9.11	ISI-1-10-1	DRYWELL	PT UT45 UT60
RHR	10R-1A-5	VALVE TO ELBOW	B9.11	ISI-1-10-1	DRYWELL	PT UT45 UT60
* RHR	10R-0-14	PIPE TO PIPE	B9.11	ISI-1-10-1A	DRYWELL	PT UT45 UT60
RHR	HL-10-200HL1(4)	SUPPORT LUGS	C3.40	ISI-1-10-4A	A RHR QUAD	MT
RHR	HL-10-F147	PIPE TO VALVE	C5.11	ISI-1-10-2B	B RHR QUAD	MT
RHR	GB-10-F163	VALVE TO PIPE	C5.11	ISI-1-10-3B	B RHR QUAD	MT
* RHR	GB-10-16-1C	PIPE TO ELBOW	C5.11	ISI-1-10-4A	A RHR QUAD	MT
* RHR	GB-10-16-2C	TEE TO PIPE	C5.11	ISI-1-10-4A	A RHR QUAD	MT
* RHR	GB-10-F65	ELBOW TO VALVE	C5.11	ISI-1-10-4A	A RHR QUAD	MT
RHR	GB-10-3-3B	PIPE TO ELBOW	C5.11	ISI-1-10-4B	TORUS ROOM	MT
RHR	GB-10-F12	ELBOW TO PIPE	C5.11	ISI-1-10-4B	TORUS ROOM	MT
RHR	HL-10-2-1E	PIPE TO ELBOW	C5.11	ISI-1-10-7B	TORUS ROOM	MT
RHR	DB/DC-10-3002-3-3	PIPE TO PIPE	C5.21	ISI-1-10-4A	A RHR VV RM	PT UT45 UT60
RHR	DB/DC-10-3001-2-1	ELBOW TO PIPE	C5.21	ISI-1-10-4B	B RHR VV RM	PT



\* Exams performed during 1990 maintenance outage.

ENCLOSURE A

PILGRIM NUCLEAR POWER STATION  
ASME XI SECOND TEN YEAR INTERVAL EXAMINATIONS SCHEDULED FOR REFUEL OUTAGE B

SYSTEM ID	COMPONENT ID NO.	COMPONENT DESCRIPTION	ITEM NO.	ISOMETRIC NO.	LOCATION	EXAM. METHOD
						UT45 UT60
RHR	GB-10-13-4C	WELDOLET TO PIPE	C5.31	ISI-1-10-3B	B RHR QUAD	MT
RHR	H-10-1-43SH	RIGID HANGER	F(1-3)	ISI-1-10-1B	TORUS ROOM	VT-3
RHR	H-10-1-51SR	RESTRAINT	F(1-3)	ISI-1-10-1B	TORUS ROOM	VT-3
RHR	H-10-1-52SR	RESTRAINT	F(1-3)	ISI-1-10-1B	TORUS ROOM	VT-3
RHR	H-10-1-53SH	RIGID HANGER	F(1-3)	ISI-1-10-1B	TORUS ROOM	VT-3
RHR	H-10-1-55SR	RESTRAINT	F(1-3)	ISI-1-10-1B	TORUS ROOM	VT-3
RHR	H-10-1-18SR	LATERAL RESTRAINT	F(1-3)	ISI-1-10-2A	TORUS ROOM	VT-3
RHR	H-10-1-SG23	LATERAL RESTRAINT	F(1-3)	ISI-1-10-3A	A RHR QUAD	VT-3
RHR	H-10-1-SG20	LATERAL RESTRAINT	F(1-3)	ISI-1-10-3B	B RHR QUAD	VT-3
RHR	H-10-1-63	RIGID HANGER	F(1-3)	ISI-1-10-4B	TORUS ROOM	VT-3
RHR	H-10-1-63SR	LATERAL RESTRAINT	F(1-3)	ISI-1-10-4B	TORUS ROOM	VT-3
RHR	H-10-1-108S	LATERAL RESTRAINT	F(1-3)	ISI-1-10-4B	TORUS ROOM	VT-3
RHR	H-10-1-110S	RIGID HANGER	F(1-3)	ISI-1-10-4B	TORUS ROOM	VT-3
RHR	H-10-1-111S	RIGID HANGER	F(1-3)	ISI-1-10-4B	TORUS ROOM	VT-3
RHR	H-10-1-37SH	RIGID HANGER	F(1-3)	ISI-1-10-4B	TORUS ROOM	VT-3
RHR	H-10-1-81	RIGID HANGER	F(1-3)	ISI-1-10-4B	TORUS ROOM	VT-3
RHR	H-10-1-101S	RIGID HANGER	F(1-3)	ISI-1-10-5B	TORUS ROOM	VT-3
RHR	H-10-1-102S	LATERAL RESTRAINT	F(1-3)	ISI-1-10-5B	TORUS ROOM	VT-3
RHR	H-10-1-103S	RIGID HANGER	F(1-3)	ISI-1-10-5B	TORUS ROOM	VT-3
RHR	H-10-1-105S	LATERAL RESTRAINT	F(1-3)	ISI-1-10-5B	TORUS ROOM	VT-3
RHR	H-10-1-119	SPRING HANGER	F(1-4)	ISI-1-10-1B	B RHR QUAD	VT-3 VT-4
RHR	H-10-1-25S	SPRING SUPPORT	F(1-4)	ISI-1-10-3A	A RHR QUAD	VT-3 VT-4
RHR	H-10-1-144	SPRING HANGER	F(1-4)	ISI-1-10-3A	A RHR QUAD	VT-3 VT-4
RHR	H-10-1-145	SPRING HANGER	F(1-4)	ISI-1-10-3A	A RHR QUAD	VT-3 VT-4
RHR	H-10-1-55S	SPRING SUPPORT	F(1-4)	ISI-1-10-3A	A RHR QUAD	VT-3 VT-4
RHR	H-10-1-990	SPRING HANGER	F(1-4)	ISI-1-10-3A	A RHR QUAD	VT-3 VT-4
RHR	H-10-1-117	SPRING HANGER	F(1-4)	ISI-1-10-3B	B RHR QUAD	VT-3 VT-4
RHR	H-10-1-96	SPRING HANGER	F(1-4)	ISI-1-10-4A	TORUS ROOM	VT-3 VT-4
RHR	H-10-1-85	SPRING HANGER	F(1-4)	ISI-1-10-4B	TORUS ROOM	VT-3 VT-4
***						
RPV	RPV-C-1-180	CIRC WELD @180	B1.11	ISI-1-54-1	DRYWELL	UT45 UT60
RPV	RPV-L-3	LONG SHELL WELD	B1.12	ISI-1-54-1	DRYWELL	UT45 UT60
RPV	RPV-SF-120-240	SHELL TO FLANGE	B1.30	ISI-1-54-1	DRYWELL	UT45 UT60
RPV	RPV-HF-120-240	HEAD TO FLANGE	B1.40	ISI-1-54-2	DRYWELL	UT45

\* Exams performed during 1990 maintenance outage.

ENCLOSURE A

PILGRIM NUCLEAR POWER STATION  
ASME XI SECOND TEN YEAR INTERVAL EXAMINATIONS SCHEDULED FOR REFUEL OUTAGE 8

SYSTEM ID	COMPONENT ID NO.	COMPONENT DESCRIPTION	ITEM NO.	ISOMETRIC NO.	LOCATION	EXAM. METHOD
						UT60 MT
RPV	RPV INTERIOR	VESSEL INTERIOR	B13.10	N/A	117'	VT-3
RPV	RPV-N10-N1R	NOZZLE INNER RADIUS	B3.100	1S1-1-54-1	DRYWELL	UT
RPV	RPV-N1B-N1R	NOZZLE INNER RADIUS	B3.100	1S1-1-54-1	DRYWELL	UT
RPV	RPV-N2D-N1R	NOZZLE INNER RADIUS	B3.100	1S1-1-54-1	DRYWELL	UT
RPV	RPV-N2E-N1R	NOZZLE INNER RADIUS	B3.100	1S1-1-54-1	DRYWELL	UT
RPV	RPV-N2F-N1R	NOZZLE INNER RADIUS	B3.100	1S1-1-54-1	DRYWELL	UT
RPV	RPV-N2J-N1R	NOZZLE INNER RADIUS	B3.100	1S1-1-54-1	DRYWELL	UT
RPV	RPV-N4A-N1R	NOZZLE INNER RADIUS & BORE	B3.100	1S1-1-54-1	DRYWELL	UT
RPV	RPV-N4B-N1R	NOZZLE INNER RADIUS & BORE	B3.100	1S1-1-54-1	DRYWELL	UT
RPV	RPV-N4C-N1R	NOZZLE INNER RADIUS & BORE	B3.100	1S1-1-54-1	DRYWELL	UT
RPV	RPV-N4D-N1R	NOZZLE INNER RADIUS & BORE	B3.100	1S1-1-54-1	DRYWELL	UT
RPV	RPV-N6B-N1R	NOZZLE INNER RADIUS	B3.100	1S1-1-54-1	DRYWELL	UT
RPV	RPV-N10-NV	NOZZLE TO VESSEL	B3.90	1S1-1-54-1	DRYWELL	UT
RPV	RPV-N1B-NV	NOZZLE TO VESSEL	B3.90	1S1-1-54-1	DRYWELL	UT
RPV	RPV-N2D-NV	NOZZLE TO VESSEL	B3.90	1S1-1-54-1	DRYWELL	UT
RPV	RPV-N2E-NV	NOZZLE TO VESSEL	B3.90	1S1-1-54-1	DRYWELL	UT
RPV	RPV-N2F-NV	NOZZLE TO VESSEL	B3.90	1S1-1-54-1	DRYWELL	UT
RPV	RPV-N2J-NV	NOZZLE TO VESSEL	B3.90	1S1-1-54-1	DRYWELL	UT
RPV	RPV-N6B-NV	NOZZLE TO VESSEL	B3.90	1S1-1-54-1	DRYWELL	UT
RPV	14-B-1	SAFE END TO NOZZLE	B5.10	1S1-1-14-1	DRYWELL	UT45 UT60 PT
RPV	2R-N2C-1	SAFE END TO NOZZLE	B5.10	1S1-1-2R-A	DRYWELL	PT UT45 UT60
RPV	2R-N2D-1	SAFE END TO NOZZLE	B5.10	1S1-1-2R-A	DRYWELL	PT UT45 UT60
RPV	2R-N2E-1	SAFE END TO NOZZLE	B5.10	1S1-1-2R-A	DRYWELL	PT UT45 UT60
RPV	2R-N1B-1	NOZZLE TO SAFE END	B5.10	1S1-1-2R-A	DRYWELL	PT UT45 UT60
RPV	2R-N2F-1	SAFE END TO NOZZLE	B5.10	1S1-1-2R-B	DRYWELL	PT UT45 UT60
RPV	2R-N2J-1	SAFE END TO NOZZLE	B5.10	1S1-1-2R-B	DRYWELL	PT UT45 UT60
RPV	3-1-1	NOZZLE TO CAP	B5.10	1S1-1-3-1	DRYWELL	PT UT45 UT60
RPV	RPV-N9A-1	NOZZLE TO SAFE END	B5.10	1S1-1-54-4	DRYWELL	PT UT60

\* Exams performed during 1990 maintenance outage.

ENCLOSURE A

PILGRIM NUCLEAR POWER STATION

ASME XI SECOND TEN YEAR INTERVAL EXAMINATIONS SCHEDULED FOR REFUEL OUTAGE B

SYSTEM ID	COMPONENT ID NO.	COMPONENT DESCRIPTION	ITEM NO.	ISOMETRIC NO.	LOCATION	EXAM. METHOD
RPV	6-N4A-1	SAFE END TO NOZZLE	B5.10	ISI-1-6-1	DRYWELL	UT45 UT60 MT
RPV	6-N4B-1	SAFE END TO NOZZLE	B5.10	ISI-1-6-1	DRYWELL	UT45 UT60 MT
RPV	6-N4C-1	SAFE END TO NOZZLE	B5.10	ISI-1-6-1	DRYWELL	UT45 UT60 MT
RPV	6-N4D-1	SAFE END TO NOZZLE	B5.10	ISI-1-6-1	DRYWELL	UT45 UT60 MT
RPV	RPV-CHW-19-36	CLOSURE HEAD NUTS	B6.10	ISI-1-54-2	DRYWELL	UT MT
RPV	RPV-CS-19-36	CLOSURE STUDS	B6.20	ISI-1-54-2	DRYWELL	UT
RPV	RPV-F1-19-36	THREADS IN FLANGE	B6.40	ISI-1-54-2	DRYWELL	UT
RPV	RPV-CB-19-36	CLOSURE BUSHINGS	B6.50	ISI-1-54-2	DRYWELL	VT-1
RPV	RPV-CW-19-36	CLOSURE WASHERS	B6.50	ISI-1-54-2	DRYWELL	VT-1
RPV	RPV-SW-120-240	SKIRT WELD	B8.10	ISI-1-54-3	DRYWELL	UT
***						
RWCU	12R-0-1A	SWEEPolet TO ELBOW	B9.11	ISI-1-12-1	DRYWELL	PT UT45 UT60
RWCU	12R-0-23	ELBOW TO PENETRATION	B9.11	ISI-1-12-1	DRYWELL	PT UT45 UT60
RWCU	12-1-18	ELBOW TO PIPE	B9.11	ISI-1-12-2	A RHR VV RM	UT-45 UT-60 PT
RWCU	12-1-19	PIPE TO ELBOW	B9.11	ISI-1-12-2	A RHR VV RM	UT-45 UT-60 PT
* RWCU	H-4-1-1	GUIDE	F(1-3)	ISI-1-12-1	DRYWELL	VT-3
* RWCU	H-12-1-97	GUIDE	F(1-3)	ISI-1-12-1	DRYWELL	VT-3
RWCU	H-12-1-99	GUIDE	F(1-3)	ISI-1-12-1	RWCU HX RM	VT-3
* RWCU	H-12-1-113	GUIDE	F(1-3)	ISI-1-12-2	A RHR VV RM	VT-3
* RWCU	H-12-1-1243	RESTRAINT	F(1-3)	ISI-1-12-2	RWCU HX RM	VT-3
* RWCU	H-12-1-1258	RESTRAINT	F(1-3)	ISI-1-12-2	RWCU HX RM	VT-3
* RWCU	H-12-1-350	GUIDE	F(1-3)	ISI-1-12-2	RWCU HX RM	VT-3
RWCU	H-12-1-14	SPRING HANGER	F(1-4)	ISI-1-12-1	DRYWELL	VT-3 VT-4
***						
SBLC	11-VB-1101-1	VALVE BOLTING	B7.70	ISI-1-11-1	DRYWELL	VT-1
SBLC	11-VB-1101-15	VALVE BOLTING	B7.70	ISI-1-11-1	DRYWELL	VT-1

\* Exams performed during 1990 maintenance outage.

ENCLOSURE A

PILGRIM NUCLEAR POWER STATION  
ASME XI SECOND YEAR INTERVAL EXAMINATIONS SCHEDULED FOR REFUEL OUTAGE B

SYSTEM ID	COMPONENT ID NO.	COMPONENT DESCRIPTION	ITEM NO.	ISOMETRIC NO.	LOCATION	EXAM. METHOD
	SBLC B-11-165	PIPE TO ELBOW	B9.40	ISI-1-11-1	DRYWELL	PT
	SBLC B-11-178	ELBOW TO PIPE	B9.40	ISI-1-11-1	RB 74' BW	PT
*	SBLC H-11-1-21	GUIDE	F(1-3)	ISI-1-11-1	DRYWELL	VT-3
*	SBLC H-11-1-22	GUIDE	F(1-3)	ISI-1-11-1	DRYWELL	VT-3
*	SBLC H-11-1-23	GUIDE	F(1-3)	ISI-1-11-1	DRYWELL	VT-3
*	SBLC H-11-1-24	GUIDE	F(1-3)	ISI-1-11-1	DRYWELL	VT-3
*	SBLC H-11-1-25	GUIDE	F(1-3)	ISI-1-11-1	DRYWELL	VT-3
*	SBLC H-11-1-26	GUIDE	F(1-3)	ISI-1-11-1	DRYWELL	VT-3
*	SBLC H-11-1-31	GUIDE	F(1-3)	ISI-1-11-1	RB 74'	VT-3
*	SBLC H-11-1-36	GUIDE	F(1-3)	ISI-1-11-1	RB 74'	VT-3
*	SBLC H-11-1-37	GUIDE	F(1-3)	ISI-1-11-1	RB 74'	VT-3
*	SBLC H-11-1-40	GUIDE	F(1-3)	ISI-1-11-1	RB 91'	VT-3
***						
	SSW H-29-1-15	RIGID HANGER	F(1-3)	ISI-1-29-1	B AUX BAY	VT-3
	SSW H-29-1-25	RIGID HANGER	F(1-3)	ISI-1-29-1	SCREEN HS	VT-3
	SSW H-29-1-36	RIGID HANGER	F(1-3)	ISI-1-29-1	SCREEN HS	VT-3
	SSW H-29-1-37	RIGID HANGER	F(1-3)	ISI-1-29-1	SCREEN HS	VT-3
	SSW H-29-1-1	RIGID HANGER	F(1-3)	ISI-1-29-1	A AUX BAY	VT-3
	SSW H-29-1-20	RIGID HANGER	F(1-3)	ISI-1-29-1	B AUX BAY	VT-3
	SSW H-29-1-21	RIGID HANGER	F(1-3)	ISI-1-29-1	B AUX BAY	VT-3
	SSW H-29-1-6SR	RIGID HANGER	F(1-3)	ISI-1-29-1	B AUX BAY	VT-3
	SSW H-29-1-26	RIGID HANGER	F(1-3)	ISI-1-29-1	SCREEN HS	VT-3
*	SSW H-29-1-13215A	ANCHOR	F(1-3)	ISI-1-29-1	SCREEN HS	VT-3
***						

ENCLOSURE B

PILGRIM NUCLEAR POWER STATION  
 ADDITIONAL ASME XI SECOND TEN YEAR INTERVAL EXAMINATIONS  
 TO BE PERFORMED DURING REFUEL OUTAGE B - SCHEDULE PERMITTING

SYSTEM ID	COMPONENT ID NO.	COMPONENT DESCRIPTION	ITEM NO.	ISOMETRIC NO.	LOCATION	EXAM. METHOD
CRD	H-3-1-22	RESTRAINT	F(1-3)	ISI-1-3-1	EAST CRD	VT-3
CRD	H-3-1-42	RESTRAINT	F(1-3)	ISI-1-3-1	WEST CRD	VT-3
CRD	H-3-1-14	RIGID SUPPORT	F(1-3)	ISI-1-3-1	EAST CRD	VT-3
CRD	H-3-1-27	ANCHOR	F(1-3)	ISI-1-3-1	EAST CRD	VT-3
CRD	H-3-1-40	RIGID SUPPORT	F(1-3)	ISI-1-3-1	WEST CRD	VT-3
***						
CS	14-A-4	PIPE TO PIPE	B9.11	ISI-1-14-1	DRYWELL	UT45 UT60 MT
CS	14-A-5	ELBOW TO PIPE	B9.11	ISI-1-14-1	DRYWELL	UT45 UT60 MT
CS	14-A-7	ELBOW TO PIPE	B9.11	ISI-1-14-1	DRYWELL	UT45 UT60 MT
CS	14-B-4	PIPE TO PIPE	B9.11	ISI-1-14-1	DRYWELL	UT45 UT60 MT
CS	14-B-5	ELBOW TO PIPE	B9.11	ISI-1-14-1	DRYWELL	UT45 UT60 MT
CS	14-B-7	ELBOW TO PIPE	B9.11	ISI-1-14-1	DRYWELL	UT45 UT60 MT
CS	14-B-8	ELBOW TO ELBOW	B9.11	ISI-1-14-1	DRYWELL	UT45 UT60 MT
CS	14-B-9	PIPE TO ELBOW	B9.11	ISI-1-14-1	DRYWELL	UT45 UT60 MT
CS	GB-14-F31	PIPE TO VALVE	C5.11	ISI-1-14-2A	A RHR QUAD	MT
CS	GB-14-F46	VALVE TO PIPE	C5.11	ISI-1-14-2A	A RHR QUAD	MT
CS	GB-14-F21	ELBOW TO PIPE	C5.11	ISI-1-14-2B	WEST CRD	MT
CS	HL-14-2-4A	FLANGE TO PIPE	C5.11	ISI-1-14-2B	TORUS ROOM	MT
CS	H-14-1-3SA	ANCHOR	F(1-3)	ISI-1-14-2A	A RHR QUAD	VT-3
CS	H-14-1-7SG	GUIDE	F(1-3)	ISI-1-14-2A	RWFU HX RM	VT-3
CS	H-14-1-41	SPRING HANGER	F(1-4)	ISI-1-14-1	DRYWELL	VT-3 VT-4
CS	H-14-1-43	SPRING HANGER	F(1-4)	ISI-1-14-1	DRYWELL	VT-3 VT-4
CS	H-14-1-40	SPRING HANGER	F(1-4)	ISI-1-14-1	DRYWELL	VT-3 VT-4
CS	H-14-1-42	SPRING HANGER	F(1-4)	ISI-1-14-1	DRYWELL	VT-3 VT-4
CS	H-14-1-3	SPRING HANGER	F(1-4)	ISI-1-14-2A	TORUS ROOM	VT-3 VT-4
CS	H-14-1-37	SPRING HANGER	F(1-4)	ISI-1-14-2A	EAST CRD	VT-3 VT-4

ENCLOSURE B

PILGRIM NUCLEAR POWER STATION  
 ADDITIONAL ASME XI SECOND TEN YEAR INTERVAL EXAMINATIONS  
 TO BE PERFORMED DURING REFUEL OUTAGE B - SCHEDULE PERMITTING

SYSTEM ID	COMPONENT ID NO.	COMPONENT DESCRIPTION	ITEM NO.	ISOMETRIC NO.	LOCATION	EXAM. METHOD
						VT-4
***						
FW	H-6-1-X9A	ANCHOR	F(1-3)	ISI-1-6-1	STEAM TUNNEL	VT-3
FW	H-6-1-109	SPRING HANGER	F(1-4)	ISI-1-6-1	DRYWELL	VT-3 VT-4
FW	H-6-1-111	SPRING HANGER	F(1-4)	ISI-1-6-1	DRYWELL	VT-3 VT-4
***						
HPCI	EB-23-59HL1(4)	SUPPORT LUGS	C3.40	ISI-1-23-2	HPCI ROOM	MT
HPCI	HE-26-175HL1(1)	SUPPORT LUGS	C3.40	ISI-1-23-4	AUX BAY	MT
HPCI	HB-23-F73	VALVE TO PIPE	C5.11	ISI-1-23-3	HPCI ROOM	MT
HPCI	HB-23-F74	PIPE TO VALVE	C5.11	ISI-1-23-3	HPCI ROOM	MT
HPCI	EB-23-F13	VALVE TO PIPE	C5.21	ISI-1-23-2	B RHR VV RM	MT UT45 UT60
HPCI	H-23-1-2SR	LATERAL RESTRAINT	F(1-3)	ISI-1-23-4	HPCI ROOM	VT-3
HPCI	H-23-1-3SR	LATERAL RESTRAINT	F(1-3)	ISI-1-23-4	HPCI ROOM	VT-3
HPCI	H-23-1-4SR	RIGID HANGER	F(1-3)	ISI-1-23-4	HPCI ROOM	VT-3
HPCI	H-23-1-21	RIGID HANGER	F(1-3)	ISI-1-23-4	TORUS ROOM	VT-3
HPCI	H-23-1-80	SPRING HANGER	F(1-4)	ISI-1-23-1	DRYWELL	VT-3 VT-4
HPCI	H-23-1-81	SPRING HANGER	F(1-4)	ISI-1-23-1	DRYWELL	VT-3 VT-4
HPCI	H-23-1-82	SPRING HANGER	F(1-4)	ISI-1-23-1	DRYWELL	VT-3 VT-4
HPCI	H-23-1-73	SPRING HANGER	F(1-4)	ISI-1-23-1	TIP ROOM	VT-3 VT-4
HPCI	H-23-1-77	SPRING HANGER	F(1-4)	ISI-1-23-1	STEAM TUNNEL	VT-3 VT-4
HPCI	H-23-1-15	SPRING HANGER	F(1-4)	ISI-1-23-3	HPCI ROOM	VT-3 VT-4
HPCI	H-23-1-2	SPRING HANGER	F(1-4)	ISI-1-23-5	TORUS ROOM	VT-3 VT-4
HPCI	H-23-1-4	SPRING HANGER	F(1-4)	ISI-1-23-5	TORUS ROOM	VT-3 VT-4
***						
MS	1-A-10HL1(4)	HANGER LUGS	B10.10	ISI-1-1-1	DRYWELL	MT
MS	1-C-10HL1(4)	SUPPORT LUG	B10.10	ISI-1-1-1	DRYWELL	MT
MS	1-D-10HL1(4)	SUPPORT LUG	B10.10	ISI-1-1-1	DRYWELL	MT
MS	1-AR-2	WELD TO PIPE	B9.11	ISI-1-1-1	DRYWELL	MT UT-5 UT60
MS	1-AR-3	PIPE TO FLANGE	B9.11	ISI-1-1-1	DRYWELL	MT

ENCLOSURE B

PILGRIM NUCLEAR POWER STATION  
 ADDITIONAL ASME XI SECOND TEN YEAR INTERVAL EXAMINATIONS  
 TO BE PERFORMED DURING REFUEL OUTAGE B - SCHEDULE PERMITTING

SYSTEM ID	COMPONENT ID NO.	COMPONENT DESCRIPTION	ITEM NO.	ISOMETRIC NO.	LOCATION	EXAM. METHOD
						UT45 UT60
MS	1-DR1-2	WELDOLET TO PIPE	B9.11	ISI-1-1-1	DRYWELL	MT UT45 UT60
MS	1-DR1-3	PIPE TO FLANGE	B9.11	ISI-1-1-1	DRYWELL	MT UT45 UT60
MS	1-SD-9	FLUED HEAD TO PIPE	B9.21	ISI-1-1-1	STEAM TUNNEL	MT
MS	H-1-1-HA3	SPRING HANGER	F(1-4)	ISI-1-1-1	DRYWELL	VT-3 VT-4
MS	H-1-1-HB2	SPRING HANGER	F(1-4)	ISI-1-1-1	DRYWELL	VT-3 VT-4
MS	H-1-1-SC2	SNUBBER	F(1-4)	ISI-1-1-1	DRYWELL	VT-3 VT-4
***						
RBCCW	H-30-1-32	RIGID SUPPORT	F(1-3)	ISI-1-30-1	TORUS ROOM	VT-3
RBCCW	H-30-1-64SA	ANCHOR	F(1-3)	ISI-1-30-2	PIPEWAY	VT-3
***						
RCIC	HL-13-F665	FLANGE TO PIPE	C5.11	ISI-1-13-3	TORUS ROOM	MT
RCIC	HL-13-F667	ELBOW TO NOZZLE	C5.11	ISI-1-13-3	TORUS ROOM	MT
RCIC	H-13-1-49	SPRING HANGER	F(1-4)	ISI-1-13-1	DRYWELL	VT-3 VT-4
RCIC	H-13-1-50	SPRING HANGER	F(1-4)	ISI-1-13-1	DRYWELL	VT-3 VT-4
***						
RECIRC	H-2-1-H2	SPRING HANGER	F(1-4)	ISI-1-2R-B	DRYWELL	VT-3 VT-4
RECIRC	H-2-1-H19	SPRING HANGER	F(1-4)	ISI-1-2R-B	DRYWELL	VT-3 VT-4
***						
R/R	HL-10-152HL1(2)	SUPPORT LUGS	C3.40	ISI-1-10-5B	B R/R QUAD	MT
R/R	GB-10-F164	ELBOW TO VALVE	C5.11	ISI-1-10-3B	B R/R QUAD	MT
R/R	GB-10-F46A	PIPE TO PIPE	C5.11	ISI-1-10-4A	A R/R VV RM	MT
R/R	GB-10-16-20	TEE TO REDUCER	C5.11	ISI-1-10-4A	A R/R QUAD	MT
R/R	HL-10-F105	ELBOW TO PIPE	C5.11	ISI-1-10-4A	A R/R QUAD	MT
R/R	GB-10-F62A	PIPE TO VALVE	C5.11	ISI-1-10-4A	A R/R VV RM	MT
R/R	GB-10-F67	REDUCER TO VALVE	C5.11	ISI-1-10-4A	A R/R QUAD	MT
R/R	GB-10-3-5C	PIPE TO ELBOW	C5.11	ISI-1-10-4B	TORUS ROOM	MT
R/R	GB-10-3-5E	ELBOW TO PIPE	C5.11	ISI-1-10-4B	TORUS ROOM	MT
R/R	GB-10-15-1E	TEE TO TEE	C5.11	ISI-1-10-4B	CRD QUAD	MT

ENCLOSURE B

PILGRIM NUCLEAR POWER STATION  
 ADDITIONAL ASME XI SECOND TEN YEAR INTERVAL EXAMINATIONS  
 TO BE PERFORMED DURING REFUEL OUTAGE B - SCHEDULE PERMITTING

SYSTEM ID	COMPONENT ID NO.	COMPONENT DESCRIPTION	ITEM NO.	ISOMETRIC NO.	LOCATION	EXAM. METHOD
RHR	GB-10-F13	PIPE TO ELBOW	C5.11	ISI-1-10-4B	TORUS ROOM	MT
RHR	GL-10-F102	VALVE TO PENETRATION	C5.11	ISI-1-10-5B	TIP ROOM	MT
RHR	HL-10-F76	ELBOW TO NOZZLE	C5.11	ISI-1-10-5B	TORUS ROOM	MT
RHR	HL-10-F73	PIPE TO NOZZLE	C5.11	ISI-1-10-5B	TORUS ROOM	MT
RHR	H-10-1-44SA	ANCHOR	F(1-3)	ISI-1-10-1B	TORUS ROOM	VT-3
RHR	H-10-1-45SR	GUIDE	F(1-3)	ISI-1-10-1B	TORUS ROOM	VT-3
RHR	H-10-1-49SG	GUIDE	F(1-3)	ISI-1-10-1B	A RHR VV RM	VT-3
RHR	H-10-1-19	RIGID HANGER	F(1-3)	ISI-1-10-2A	TORUS ROOM	VT-3
RHR	H-10-1-20	RIGID SUPPORT	F(1-3)	ISI-1-10-2A	TORUS ROOM	VT-3
RHR	H-10-1-21	RIGID HANGER	F(1-3)	ISI-1-10-2A	TORUS ROOM	VT-3
RHR	H-10-1-22	RIGID SUPPORT	F(1-3)	ISI-1-10-2A	TORUS ROOM	VT-3
RHR	H-10-1-23	RIGID HANGER	F(1-3)	ISI-1-10-2A	TORUS ROOM	VT-3
RHR	H-10-1-27SR	LATERAL RESTRAINT	F(1-3)	ISI-1-10-2B	B RHR QUAD	VT-3
RHR	H-10-1-121	RIGID HANGER	F(1-3)	ISI-1-10-2B	B RHR QUAD	VT-3
RHR	H-10-1-142	RIGID HANGER	F(1-3)	ISI-1-10-3A	A RHR QUAD	VT-3
RHR	H-10-1-99S	LATERAL RESTRAINT	F(1-3)	ISI-1-10-3B	B RHR QUAD	VT-3
RHR	H-10-1-89SA	ANCHOR	F(1-3)	ISI-1-10-4A	A RHR QUAD	VT-3
RHR	H-10-1-52	RIGID HANGER	F(1-3)	ISI-1-10-4A	TORUS ROOM	VT-3
RHR	H-10-1-87SA	ANCHOR	F(1-3)	ISI-1-10-4A	A RHR QUAD	VT-3
RHR	H-10-1-61SA	ANCHOR	F(1-3)	ISI-1-10-4B	TORUS ROOM	VT-3
RHR	H-10-1-62	RIGID HANGER	F(1-3)	ISI-1-10-4B	TORUS ROOM	VT-3
RHR	H-10-1-41SG	GUIDE	F(1-3)	ISI-1-10-5B	B RHR QUAD	VT-3
RHR	H-10-1-111	GUIDE	F(1-3)	ISI-1-10-5B	B RHR QUAD	VT-3
RHR	H-26-1-35A	ANCHOR	F(1-3)	ISI-1-10-5B	B RHR QUAD	VT-3
RHR	H-10-1-134	SPRING HANGER	F(1-4)	ISI-1-10-1B	A RHR QUAD	VT-3 VT-4
RHR	H-10-1-35S	SPRING HANGER	F(1-4)	ISI-1-10-3A	A RHR QUAD	VT-3 VT-4
RHR	H-10-1-199	SPRING HANGER	F(1-4)	ISI-1-10-4A	RWCU HX RM	VT-3 VT-4
RHR	H-10-1-82	SPRING HANGER	F(1-4)	ISI-1-10-4B	TORUS ROOM	VT-3 VT-4
***						
RWCU	H-12-1-1463	GUIDE	F(1-3)	ISI-1-12-1	DRYWELL	VT-3
RWCU	H-12-1-115	RIGID HANGER	F(1-3)	ISI-1-12-1	RWCU HX RM	VT-3
RWCU	H-12-1-111	GUIDE	F(1-3)	ISI-1-12-2	A RHR VV RM	
RWCU	H-12-1-112	GUIDE	F(1-3)	ISI-1-12-2	A RHR VV RM	VT-3
RWCU	H-12-1-8	SPRING HANGER	F(1-4)	ISI-1-12-2	A RHR VV RM	VT-3 VT-4
***						
SBLC	B-11-181A	SOCKET TO PIPE	B9.40	ISI-1-11-1	RB 74'	PT
SBLC	B-11-181B	PIPE TO SOCKET	B9.40	ISI-1-11-1	RB 74'	PT
***						



ENCLOSURE B

PILGRIM NUCLEAR POWER STATION  
 ADDITIONAL ASME XI SECOND TEN YEAR INTERVAL EXAMINATIONS  
 TO BE PERFORMED DURING REFUEL OUTAGE B - SCHEDULE PERMITTING

SYSTEM ID	COMPONENT ID NO.	COMPONENT DESCRIPTION	ITEM NO.	ISOMETRIC NO.	LOCATION	EXAM. METHOD
SSW	H-29-1-1062	GUIDE	F(1-3)	ISI-1-29-1	SCREEN HS	VT-3
SSW	H-29-1-1065	GUIDE	F(1-3)	ISI-1-29-1	SCREEN HS	VT-3
SSW	H-29-1-13	RIGID HANGER	F(1-3)	ISI-1-29-1	B AUX BAY	VT-3
SSW	H-29-1-22	RIGID HANGER	F(1-3)	ISI-1-29-1	SCREEN HS	VT-3
SSW	H-29-1-5SR	RIGID HANGER	F(1-3)	ISI-1-29-1	B AUX BAY	VT-3
SSW	H-29-1-2	RIGID HANGER	F(1-3)	ISI-1-29-1	A AUX BAY	VT-3

\*\*\*

\* Exams performed during 1990 maintenance outage.

ENCLOSURE C

PILGRIM NUCLEAR POWER STATION

SAFETY-RELATED IGSCC-SUSCEPTIBLE WELDS SCHEDULED FOR EXAMINATION DURING REFUEL OUTAGE 8  
IN ACCORDANCE WITH GENERIC LETTER 88-01

IGSCC... CATEGORY	COMPONENT ID NO..	COMPONENT..... DESCRIPTION	SYSTEM ID	ITEM NO.	ISOMETRIC NO.	LOCATION....	
IGSCC A	14R-A-13	VALVE TO ELBOW	CS	B9.11	ISI-1-14-1	DRYWELL	
IGSCC A	14R-B-13	VALVE TO ELBOW	CS	B9.11	ISI-1-14-1	DRYWELL	
IGSCC A	2R-N1B-4	PIPE TO TEE	RECIRC	B9.11	ISI-1-2R-A	DRYWELL	
IGSCC A	2R-N2C-3	CROSS TO PIPE	RECIRC	B9.11	ISI-1-2R-A	DRYWELL	
IGSCC A	2R-N1A-14	TEE TO PIPE	RECIRC	B9.11	ISI-1-2R-B	DRYWELL	
*	IGSCC A	2R-N2H-3	CROSS TO PIPE	RECIRC	B9.11	ISI-1-2R-B	DRYWELL
IGSCC A	10R-1A-5	VALVE TO ELBOW	RHR	B9.11	ISI-1-10-1	DRYWELL	
*	IGSCC A	10R-O-14	PIPE TO PIPE	RHR	B9.11	ISI-1-10-1A	DRYWELL
IGSCC A	14-B-1	SAFE END TO NOZZLE	RPV	B5.10	ISI-1-14-1	DRYWELL	
IGSCC A	12R-O-1A	SWEEPOLET TO ELBOW	RWCU	B9.11	ISI-1-12-1	DRYWELL	
***							
IGSCC D	14-A-19	VALVE TO PIPE	CS	B9.11	ISI-1-14-1	RWCU HX RM	
IGSCC D	14R-A-16	PENETRATION TO ELBOW	CS	B9.11	ISI-1-14-1	DRYWELL DRYWELL	
IGSCC D	14R-B-16	PENETRATION TO ELBOW	CS	B9.11	ISI-1-14-1	DRYWELL	
IGSCC D	14R-B-21A	PIPE TO PIPE	CS	B9.11	ISI-1-14-1	RB 51'	
IGSCC D	10-1A-14	PIPE TO FLUED HEAD	RHR	B9.11	ISI-1-10-1	A RHR VV RM	
IGSCC D	10-1A-15	VALVE TO PIPE	RHR	B9.11	ISI-1-10-1	A RHR VV RM	
IGSCC D	10R-1A-12	PENETRATION TO ELBOW	RHR	B9.11	ISI-1-10-1	DRYWELL	
IGSCC D	2R-N1B-1	NOZZLE TO SAFE END	RPV	B5.10	ISI-1-2R-A	DRYWELL	
IGSCC D	2R-N2C-1	SAFE END TO NOZZLE	RPV	B5.10	ISI-1-2R-A	DRYWELL	
IGSCC D	2R-N2D-1	SAFE END TO NOZZLE	RPV	B5.10	ISI-1-2R-A	DRYWELL	
IGSCC D	2R-N2E-1	SAFE END TO NOZZLE	RPV	B5.10	ISI-1-2R-A	DRYWELL	
IGSCC D	2R-N2F-1	SAFE END TO NOZZLE	RPV	B5.10	ISI-1-2R-B	DRYWELL	
IGSCC D	2R-N2J-1	SAFE END TO NOZZLE	RPV	B5.10	ISI-1-2R-B	DRYWELL	
IGSCC D	12-O-28	PIPE TO ELBOW	RWCU	B9.11	ISI-1-12-1	RWCU HX RM	
IGSCC D	12R-O-23	ELBOW TO PENETRATION	RWCU	B9.11	ISI-1-12-1	DRYWELL	
IGSCC D	12R-O-32	PIPE TO VALVE	RWCU	B9.11	ISI-1-12-1	RWCU HX RM	
IGSCC D	12-1-17	PIPE TO REDUCER	RWCU	B9.11	ISI-1-12-2	A RHR VV RM	
IGSCC D	12-1-18	ELBOW TO PIPE	RWCU	B9.11	ISI-1-12-2	A RHR VV RM	
IGSCC D	12-1-19	PIPE TO ELBOW	RWCU	B9.11	ISI-1-12-2	A RHR VV RM	
IGSCC D	12-1-21	PIPE TO ELBOW	RWCU	B9.11	ISI-1-12-2	A RHR VV RM	
IGSCC D	12-1-23	PIPE TO ELBOW	RWCU	B9.11	ISI-1-12-2	A RHR VV RM	
IGSCC D	12-1-23A	PIPE TO PIPE	RWCU	B9.11	ISI-1-12-2	EAST CRD	
IGSCC D	12-1-24	ELBOW TO PIPE	RWCU	B9.11	ISI-1-12-2	EAST CRD	
IGSCC D	12-1-25	PIPE TO ELBOW	RWCU	B9.11	ISI-1-12-2	EAST CRD	
IGSCC D	12-1-25A	PIPE TO PIPE	RWCU	B9.11	ISI-1-12-2	EAST CRD	
IGSCC D	12-1-26	ELBOW TO PIPE	RWCU	B9.11	ISI-1-12-2	EAST CRD	
IGSCC D	12-1-27	PIPE TO ELBOW	RWCU	B9.11	ISI-1-12-2	EAST CRD	
IGSCC D	12-1-28	ELBOW TO PIPE	RWCU	B9.11	ISI-1-12-2	RWCU HX RM	
IGSCC D	12-1-29	PIPE TO ELBOW	RWCU	B9.11	ISI-1-12-2	RWCU HX RM	
IGSCC D	12-1-32	ELBOW TO PIPE	RWCU	B9.11	ISI-1-12-2	RWCU HX RM	
IGSCC D	12-1-33	PIPE TO ELBOW	RWCU	B9.11	ISI-1-12-2	RWCU HX RM	
***							
IGSCC E	RPV-N9A-1	NOZZLE TO SAFE END	RPV	B5.10	ISI-1-54-4	DRYWELL	

\*Exams performed  
during 1990  
maintenance outage.

ENCLOSURE C

PILGRIM NUCLEAR POWER STATION  
SAFETY-RELATED IGSCC-SUSCEPTIBLE WELDS SCHEDULED FOR EXAMINATION DURING REFUEL OUTAGE 8  
IN ACCORDANCE WITH GENERIC LETTER 88-01

..... IGSCC... COMPONENT ID NO., COMPONENT..... SYSTEM ID ITEM NO. ISOMETRIC NO. LOCATION....  
CATEGORY DESCRIPTION

\*\*\*

IGSCC G	DB/DC-14-3002-5-1	ELBOW TO PIPE	CS	C5.21	ISI-1-14-2A	RWCU HX RM
IGSCC G	DC-14-F31	PIPE TO VALVE	CS	C5.21	ISI-1-14-2A	RWCU HX RM
IGSCC G	DB/DC-14-3001-4-1	PIPE TO PIPE	CS	C5.21	ISI-1-14-2B	RB 51'
IGSCC G	DC-14-F1	PIPE TO VALVE	CS	C5.21	ISI-1-14-2B/1	RB 51'
IGSCC G	DB/DC-10-3002-3-3	PIPE TO PIPE	RHR	C5.21	ISI-1-10-4A	A RHR VV RM
IGSCC G	DC-10-F9	PIPE TO VALVE	RHR	C5.21	ISI-1-10-4A	A RHR VV RM
IGSCC G	DB/DC-10-3001-2-1	ELBOW TO PIPE	RHR	C5.21	ISI-1-10-4B	B RHR VV RM
IGSCC G	DC-10-F10R	PIPE TO VALVE	RHR	C5.21	ISI-1-10-4B	B RHR VV RM
IGSCC G	3-1-1	NOZZLE TO CAP	RPV	B5.10	ISI-1-3-1	DRYWELL

\*\*\*

ENCLOSURE D  
 PILGRIM NUCLEAR POWER STATION  
 MODIFIED IGSCC INSPECTION SCHEDULE  
 (REFERENCE BECo LETTER 89.084)

<u>CATEGORY</u>	<u>DELETED FROM RFO 8</u>	<u>ADDED TO RFO 8</u>
A	14R-A-11A	
A		14R-A-13
A		14R-B-13
A		2R-N2C-3
A		2R-N1A-14
D	14-A-17	
D	14-A-18	
D	12-0-29	
D	12-0-30	
D	12-0-31	
D		12-I-23A
D		12-I-24
D		12-I-25A
D		12-I-25
D		12-I-26
D		12-I-27
D		12-I-33
D	12-I-30	
D	12-I-31	

## ENCLOSURE E

## PILGRIM NUCLEAR POWER STATION

NON-SAFETY RELATED IGSCC SUSCEPTIBLE WELDS SCHEDULED FOR EXAMINATION

IN ACCORDANCE WITH GENERIC LETTER 88-01 AND BECO LETTER 2.90.140

DURING REFUEL OUTAGE 8

<u>IGSCC CATEGORY</u>	<u>WELD NO.</u>	<u>DESCRIPTION</u>	<u>SYSTEM</u>	<u>ISOMETRIC</u>	<u>LOCATION</u>
IGSCC D	SW-12-6	Pipe to valve	RWCU	ISI-I-12-3	RWCU HX RM
IGSCC D	EA12-1	Pipe to elbow	RWCU	ISI-I-12-3	RWCU HX RM
IGSCC D	EA12-2	Elbow to pipe	RWCU	ISI-I-12-3	RWCU HX RM
IGSCC D	EA12-3	Pipe to elbow	RWCU	ISI-I-12-3	RWCU HX RM
IGSCC D	EA12-4	Elbow to pipe	RWCU	ISI-I-12-3	RWCU HX RM
IGSCC D	SW-12-129	Pipe to elbow	RWCU	ISI-I-12-3	RWCU HX RM
IGSCC D	EA12-12	Elbow to pipe	RWCU	ISI-I-12-3	RWCU HX RM