

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

1 | I | L | D | R | S | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | _____ | 5

REPORT SOURCE: L | 0 | 5 | 10 | 0 | 0 | 2 | 3 | 7 | 1 | 1 | 0 | 8 | 7 | 8 | 1 | 2 | 0 | 8 | 7 | 8

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

2 | During normal unit operation, AO-2-1601-24 failed to close when its control switch

3 | was placed in the "close" position following containment venting. Upstream valves

4 | AO-2-1601-60, -61, -62 & -23 were operable and were closed to maintain containment

5 | integrity. AO-2-1601-24 was closed 25 min later by disconnecting an air line. This

6 | is the first occurrence of this type.

SYSTEM CODE: S | D | CAUSE CODE: E | CAUSE SUBCODE: B | COMPONENT CODE: V | E | A | L | V | E | X | COMP SUBCODE: X | VALVE SUBCODE: F

EVENT YEAR: 7 | 8 | SEQUENTIAL REPORT NO.: 0 | 6 | 1 | OCCURRENCE CODE: 0 | 3 | REPORT TYPE: L | REVISION NO.: 0

ACTION TAKEN: C | FUTURE ACTION: Z | EFFECT ON PLANT: Z | SHUTDOWN METHOD: Z | HOURS: 0 | 0 | 0 | 0 | ATTACHMENT SUBMITTED: N | NPD-4 FORM SUB: Y | PRIME COMP. SUPPLIER: N | COMPONENT MANUFACTURER: V | 0 | 9 | 5

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

0 | Valve AO-2-1601-24's air operator solenoid valve stuck in the "open" position due to

1 | an accumulation of dirt in the valve internals. The solenoid valve was replaced

2 | and AO-2-1601-24 tested for proper operation prior to returning to service. Due to

3 | the singular nature of this event, no additional action is planned.

FACILITY STATUS: E | % POWER: 0 | 9 | 6 | OTHER STATUS: NA | METHOD OF DISCOVERY: A | DISCOVERY DESCRIPTION: Attempted Valve Operation

ACTIVITY CONTENT RELEASED OF RELEASE: Z | AMOUNT OF ACTIVITY: NA | LOCATION OF RELEASE: NA

PERSONNEL EXPOSURES NUMBER: 0 | 0 | 0 | TYPE: Z | DESCRIPTION: NA

PERSONNEL INJURIES NUMBER: 0 | 0 | 0 | DESCRIPTION: NA

LOSS OF OR DAMAGE TO FACILITY TYPE: Z | DESCRIPTION: NA

PUBLICITY ISSUED DESCRIPTION: N

7812150272