(1-11)	LICENSEE EVENT REPORT
	CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1	N C B E P 1 2 0 0 - 0 0 0 0 0 0 0 0 4 1 1 1 1 1 4 5 5 B LICENSE CODE 14 2 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58
O 1 8	SOURCE L 6 0 5 0 - 0 3 2 5 7 0 8 1 2 8 2 8 0 9 0 9 8 2 9 SOURCE 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80
0 2	While performing a review of surveillance procedures to assure technical adequacy, it
0 3	was determined that plant procedures did not provide for a required once per 18 month
0 4	poperability and functional test of AOG Building miscellaneous fire doors, hatches and
0 5	seals. This event did not affect the health and safety of the public.
0 [6]	Technical Specifications 4.7.8, 6.9.1.9c
[0]8]	
7 8	9 SYSTEM CAUSE CAUSE COMPONENT CODE SUBCODE CODE CODE SUBCODE COMPONENT CODE SUBCODE
0 9 8	A B 11 D 12 Z 13 Z Z Z Z Z Z 16 20 16
	LER/RO REPORT NO. LER/RO NO. NO. NO. 17 21 22 23 24 26 27 28 29 30 31 32
	ACTION FUTURE ACTION ON PLANT SHUTDOWN METHOD HOURS 22 ATTACHMENT SUBMITTED FORM SUB. PRIME COMP. COMPONENT MANUFACTURER X 18 G 19 Z 20 Z 21 0 0 0 0 N 23 N 24 Z 25 25 27 40 47 CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
10	This procedural inadequacy occurred due to personnel oversight during development of
1 1	the applicable surveillance procedure, PT-35.18.3. A temporary revision was made to
112	the PT and the required components were satisfactorily tested on 8-13-82. Prior to
1 3	start-up of both units, a permanent revision to the PT will be made to reflect the
1 4	subject surveillance.
7 8	G QB O O Q9 OTHER STATUS OTHER STATUS
	9 10 12 13 44 45 46 80 ACTIVITY CONTENT ELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)
1 6	Z (33) Z (34) NA
1 7	PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (S) IC 10 10 1(37) Z 1(38) NA
7 8	9 PERSONNEL INJURIES (41)
18	0 0 0 40 DESCRIPTION (41) NA
7 8	9 11 12 8209160313 820909 80 LOSS OF OR DAMAGE TO FACILITY (43) S ADOCK 05000325
7 8	2 (42) 9 10 80
2 0	ISSUED DESCRIPTION (45) NA NA
7 8	9 10 68 69 80 5 NAME OF PREPARER M. J. PASTVA, JR. PHONE 919-457-9521 0