

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

September 23, 1982

TELEPHONE
(704) 373-4531

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Ms. E. G. Adensam
Licensing Branch No. 4

Subject: McGuire Nuclear Station
Docket Nos. 50-369 and 50-370

Dear Mr. Denton:

This letter provides documentation for statements concerning the Standby Shutdown System (SSS) which were made to NRC Staff by telephone:

In a telephone conversation on January 18, 1982, reference was made to "fire area" when identifying a space enclosed within three-hour rated fire barriers. The term "fire zone" had been used in the design description of the SSS for identifying a similar area. As used in the description of the SSS, "fire zone" is equivalent to fire area, a space enclosed within three-hour rated fire barriers. Each fire area (except the Reactor Containment Buildings) has either a normal or a standby shutdown system train outside the area.

In a telephone conversation on January 29, 1982 a description was provided of the separation between the "A" switchgear room, the "B" division disconnect cubicle, and each of these areas from other plant areas. The "A" switchgear room and the "B" division disconnect cubicle are separated from other plant areas and from each other by three-hour rated fire barriers. Access to the "B" division disconnect cubicle is from the "A" switchgear room.

Very truly yours,

H.B. Tucker

Hal B. Tucker

HBT:REH:jfw

cc: James P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

P. R. Bemis
Sr. Resident Inspector
McGuire Nuclear Station

8209300305 820923
PDR ADOCK 05000369
F PDR

13021