

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CONT

0	1
---	---

REPORT SOURCE

L	6	0	5	0	0	0	3	1	6	7	0	9	0	7	8	2	3	1	0	0	5	8	2	9
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

DOCKET NUMBER

EVENT DATE

REPORT DATE

ON A SHIFT TOUR DURING NORMAL OPERATION, THE EQUALIZING VALVE ON THE INNER DOOR OF

THE UPPER CONTAINMENT PERSONNEL AIRLOCK WAS FOUND TO BE LEAKING SLIGHTLY DURING A

CONTAINMENT ENTRY. THIS CONSTITUTED AN INOPERABLE CONTAINMENT AIRLOCK, CONTRARY

TO T.S. 3.6.1.3. THE ACTION REQUIREMENT WAS MET AND PUBLIC HEALTH AND SAFETY WERE

NOT AFFECTED.

0 7

0 8

7 8 9

SYSTEM CODE S A 11		CAUSE CODE X 12		CAUSE SUBCODE Z 13		COMPONENT CODE P E N E T R 14				COMP SUBCODE A 15		VALVE SUBCODE Z 16	
LER/RO REPORT NUMBER 17		EVENT YEAR 8 2 21 22		SEQUENTIAL REPORT NO. 0 7 7 24 26		OCCURRENCE CODE 0 3 28 29		REPORT TYPE L 30		REVISION NO. 0 32			
ACTION TAKEN E 18		FUTURE ACTION Z 19		EFFECT ON PLANT Z 20		SHUTDOWN METHOD Z 21		HOURS 0 0 0 0 22 40		ATTACHMENT SUBMITTED N 23		NPRD-4 FORM SUB. N 24	
PRIME COMP. SUPPLIER A 25		COMPONENT MANUFACTURER W 3 0 2 26											

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

THE CAUSE OF THE CONDITION COULD NOT BE DETERMINED. THE VALVE ACTUATING MECHANISM

WAS ADJUSTED AND THE DOOR RETURNED TO SERVICE IN 2 HOURS AND 28 MINUTES. NO FURTHER

ACTION IS PLANNED AT THIS TIME.

1 3

1 4

7 8 9

80

FACILITY STATUS (E) (28) 1 POWER (1) (0) (0) (29) OTHER STATUS (NA) (30) METHOD OF DISCOVERY (B) (31) DISCOVERY DESCRIPTION (32) OPERATOR OBSERVATION (32)

30

ACTIVITY CONTENT RELEASED OF RELEASE (Z) (33) (Z) (34) AMOUNT OF ACTIVITY (NA) (35) LOCATION OF RELEASE (NA) (36)

PERSONNEL EXPOSURES NUMBER (0) (0) (0) (37) TYPE (Z) (38) DESCRIPTION (NA) (39)

PERSONNEL INJURIES NUMBER (0) (0) (0) (40) DESCRIPTION (NA) (41)

LOSS OF OR DAMAGE TO FACILITY TYPE (Z) (42) DESCRIPTION (NA) (43)

PUBLICITY ISSUED (N) (44) DESCRIPTION (45) 8210180123 821005 PDR ADDCK 05000316 S PDR

80

NRC USE ONLY

NAME OF PREPARER R. H. PIEHL

PHONE 516-465-5901