

DCD-716

OCT 07 1982

Docket No. 50-346

Mr. Richard P. Crouse  
Vice President, Nuclear  
Toledo Edison Company  
Edison Plaza - Stop 712  
300 Madison Avenue  
Toledo, Ohio 43652

Dear Mr. Crouse:

By letter dated July 21, 1982 we sent you a request for additional information concerning NUREG-0737 Item II.B.3 Post Accident Sampling System. There has been confusion concerning our request and the purpose of this letter is to provide some clarification. First, the requirements of this item are as described in NUREG-0737. The clarification section of our previous letter provides staff guidelines not requirements on how to meet the NUREG-0737 criteria.

Additional guidance concerning our initial letter is as follows:

1. NUREG-0737 states that the licensee should be able to perform sampling and analysis within 3 hours of deciding to take the sample. Our clarification section asks how the 3 hour limit is to be met during a loss of offsite power. It was not meant to imply that the sampling system had to be operational during a loss of offsite power. Rather the intent was if there is a loss of offsite power, can you meet the three hour limit.
2. Clarification 2(d) of our original request asked for a discussion of the reliability and maintenance information to demonstrate that the selected on-line instrument is appropriate for this application. A detailed reliability analysis is not required to satisfy the staff concerns in this area. The staff needs enough data to provide reasonable assurance that the on-line instrument will function when needed.
3. Clarification 3 of our original request discussed environmental qualification of certain valves. These valves should already be on the list of equipment that must be environmentally qualified by previous Commission Order. Therefore a statement that the valves are in the previously submitted environmental qualification program will satisfy staff concerns for this review.

8211030102 821007  
PDR ADOCK 05000346  
P PDR

OFFICE ▶	.....	.....	.....	.....	.....	.....	.....
SURNAME ▶	.....	.....	.....	.....	.....	.....	.....
DATE ▶	.....	.....	.....	.....	.....	.....	.....

- 4. Clarification 6 requested information on the predicted man-rem exposures based on person-motion sampling, transport and analysis of all parameters. This information is necessary to confirm that the licensee has made adequate provisions to meet GDC 19 requirements.
- 5. Finally, several portions of the clarification section refer to Regulatory Guide 1.97 Revision 2. For purposes of this information request, Regulatory Guide 1.97 is recognized as a recommendation and not a requirement.

The above should resolve the present concerns in this area. If you have further questions please contact your assigned NRC Project Manager.

Sincerely,

\*ORIGINAL SIGNED BY

JOHN F. STOLZ

John F. Stolz, Chief  
Operating Reactors Branch #4  
Division of Licensing

cc: See next page

<p>DISTRIBUTION: Docket File NRC PDR L PDR ORB#4 Rdg Gray File</p>	<p>DEisenhut AEOD ACRS-10 RIngram EBlackwood</p>	<p>OELD IE ORB#4 PM Hornstein</p>
--	--	---

OFFICE	ORB#4:DL	ORB#4:DL	C-ORB#4:DL			
SURNAME	RIngram/cb	ADe Agazio	JStolz			
DATE	9/1/82	9/1/82	9/1/82			

Toledo Edison Company

Mr. Donald H. Hauser, Esq.  
The Cleveland Electric  
Illuminating Company  
P. O. Box 5000  
Cleveland, Ohio 44101

Gerald Charnoff, Esq.  
Shaw, Pittman, Potts  
and Trowbridge  
1800 M Street, N.W.  
Washington, D. C. 20036

Paul M. Smart, Esq.  
Fuller & Henry  
300 Madison Avenue  
P. O. Box 2088  
Toledo, Ohio 43603

Mr. Robert B. Borsum  
Babcock & Wilcox  
Nuclear Power Generation Division  
7910 Woodmont Avenue, Suite 220  
Bethesda, Maryland 20814

President, Board of County  
Commissioners of Ottawa County  
Port Clinton, Ohio 43452

Attorney General  
Department of Attorney General  
30 East Broad Street  
Columbus, Ohio 43215

Harold Kahn, Staff Scientist  
Power Siting Commission  
361 East Broad Street  
Columbus, Ohio 43216

Mr. James G. Keppler, Regional Administrator  
U. S. Nuclear Regulatory Commission, Region III  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Mr. Ted Myers  
Manager, Nuclear Licensing  
Toledo Edison Company  
Edison Plaza  
300 Madison Avenue  
Toledo, Ohio 43652

U.S. Nuclear Regulatory Commission  
Resident Inspector's Office  
5503 N. State Route 2  
Oak Harbor, Ohio 43449

Regional Radiation Representative  
EPA Region V  
230 South Dearborn Street  
Chicago, Illinois 60604

Ohio Department of Health  
ATTN: Radiological Health  
Program Director  
P. O. Box 118  
Columbus, Ohio 43216