

OPERATING DATA REPORT

DOCKET NO. 50-344
 DATE 1-5-82
 COMPLETED BY W. O. Nicholson
 TELEPHONE 503-556-3713
 Ext. 409

OPERATING STATUS

1. Unit Name: Trojan Nuclear Plant
2. Reporting Period: December 1981
3. Licensed Thermal Power (MWt): 3411
4. Nameplate Rating (Gross MWe): 1216
5. Design Electrical Rating (Net MWe): 1130
6. Maximum Dependable Capacity (Gross MWe): 1122
7. Maximum Dependable Capacity (Net MWe): 1080
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:
None

Notes

9. Power Level To Which Restricted, If Any (Net MWe): None
10. Reasons For Restrictions, If Any: N/A

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	<u>744</u>	<u>8760</u>	<u>46752</u>
12. Number Of Hours Reactor Was Critical	<u>744</u>	<u>6701.9</u>	<u>29463.2</u>
13. Reactor Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>2171.8</u>
14. Hours Generator On-Line	<u>744</u>	<u>6494.6</u>	<u>28488.1</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>1508.7</u>
16. Gross Thermal Energy Generated (MWH)	<u>2536819</u>	<u>20952094</u>	<u>89518776</u>
17. Gross Electrical Energy Generated (MWH)	<u>816850</u>	<u>6793985</u>	<u>29169371</u>
18. Net Electrical Energy Generated (MWH)	<u>776081</u>	<u>6423930</u>	<u>27530689</u>
19. Unit Service Factor	<u>100.0</u>	<u>74.1</u>	<u>60.9</u>
20. Unit Availability Factor	<u>100.0</u>	<u>74.1</u>	<u>64.2</u>
21. Unit Capacity Factor (Using MDC Net)	<u>96.6</u>	<u>67.9</u>	<u>54.5</u>
22. Unit Capacity Factor (Using DER Net)	<u>92.3</u>	<u>64.9</u>	<u>52.1</u>
23. Unit Forced Outage Rate	<u>0.0</u>	<u>4.9</u>	<u>21.8</u>
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each): <u>Refueling, May 1982, 55 days</u>			

25. If Shut Down At End Of Report Period, Estimated Date of Startup: NA
26. Units In Test Status (Prior to Commercial Operation):

INITIAL CRITICALITY
 INITIAL ELECTRICITY
 COMMERCIAL OPERATION

Forecast

Achieved

NA
NA
NA

NA
NA
NA

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-344

UNIT Trojan

DATE 1-5-82

COMPLETED BY W. O. Nicholson

TELEPHONE 503-556-3713

Ext. 409

MONTH December 1981

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>1041</u>
2	<u>1043</u>
3	<u>1046</u>
4	<u>1041</u>
5	<u>1034</u>
6	<u>1038</u>
7	<u>1040</u>
8	<u>1042</u>
9	<u>1040</u>
10	<u>1041</u>
11	<u>1040</u>
12	<u>1046</u>
13	<u>1045</u>
14	<u>1043</u>
15	<u>1038</u>
16	<u>1043</u>

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
17	<u>1044</u>
18	<u>1043</u>
19	<u>1043</u>
20	<u>1049</u>
21	<u>1047</u>
22	<u>1046</u>
23	<u>1048</u>
24	<u>1044</u>
25	<u>1045</u>
26	<u>1047</u>
27	<u>1048</u>
28	<u>1044</u>
29	<u>1044</u>
30	<u>1039</u>
31	<u>1043</u>

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH December 1981

DOCKET NO. 50-344
 UNIT NAME Trojan
 DATE 1-5-82
 COMPLETED BY W. O. Nicholson
 TELEPHONE 503-556-3713
 Ext. 409

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
	None								

1 F: Forced
S: Scheduled

2 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance of Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

3 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

4 Exhibit G - Instructions
 for Preparation of Data
 Entry Sheets for Licensee
 Event Report (LER) File (NUREG-
 0161)

5 Exhibit I - Same Source

(9/77)

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO: 50-344
DATE: 1-5-82
COMPLETED BY: W. O. Nicholson
TELEPHONE: 503-556-3713
Ext. 409

OPERATION

The plant operated at or near 100% throughout the month of December.

On December 1, 1981, preferred instrument bus Y 24 failed due to the loss of its associated static inverter Y 28. Power to Y 24 was switched from the inverter to instrument bus Y 02 with no effect on plant operation. The inverter has been reenergized on a test load bank to determine the cause of the failure.

The Steam Generator primary-to-secondary leak rate increased over the month from 0.2 gallons per day to about 13 gallons per day. Most of the leakage appears to be from "B" Steam Generator.

The Reactor Coolant System gross gamma activity increased slightly during the month from about 25 $\mu\text{Ci/ml}$ to about 29 $\mu\text{Ci/ml}$.

MAJOR SAFETY RELATED MAINTENANCE

Completed semi-annual maintenance on the west emergency diesel generator.

Replaced mechanical seal on the north boron injection tank recirc pump.

Completed modification adding additional valves to the Containment post-accident Hydrogen Analysis System.

MISCELLANEOUS MAINTENANCE

Worked throughout the month attempting to repair failed static inverter Y 28.

Replaced mechanical seal on the south boric acid transfer pump.

Completed semi-annual maintenance on the Joy Air compressors.

Completed annual maintenance on the startup boiler.

LICENSE CHANGES (Effective November 24, 1981)

Amendment 68 - reduces the trip setpoint for high containment pressure as specified in NUREG-0737 "Clarification of TMI Action Plan Requirements".

Amendment 69 - revises requirements for the Fire Protection System.