


50-298



Nebraska Public Power District

GENERAL OFFICE
P.O. BOX 499, COLUMBUS, NEBRASKA 68601-0499
TELEPHONE (402) 564-8561

October 29, 1982

U.S. Nuclear Regulatory Commission
Attention: Mr. Domenic B. Vassallo, Chief
Operating Reactors Branch No. 2
Division of Licensing
Washington, DC 20555

Reference: Letter from D. B. Vassallo to J. M. Pilant dated
July 13, 1982, Same Subject

Dear Mr. Vassallo:

Subject: NUREG-0737 Item II.D.1, Relief and Safety Valve Test
Requirements; Request for Additional Information

Reference 1 requested the District to respond to six plant
specific concerns arising from your review of NEDE-24988-P,
"Analysis of Generic BWR Safety/Relief Valve Operability Test
Results." Enclosed are the plant specific responses for Cooper
Nuclear Station.

If additional clarification is necessary regarding the enclosed
information, please do not hesitate to contact me.

Sincerely,

Jay M. Pilant
Division Manager of Licensing
and Quality Assurance

JMP/kcw:bkn21/2
Enclosure

A046

8211080159 821029
PDR ADOCK 05000298
P PDR

NRC QUESTION 1

The test program utilized a "rams head" discharge pipe configuration. Cooper Station utilizes a "tee" quencher configuration at the end of the discharge line. Describe the discharge pipe configuration used at Cooper Station and compare the anticipated loads on valve internals in the Cooper Station configuration to the measured loads in the test program. Discuss the impact of any differences in loads on valve operability.

RESPONSE TO NRC QUESTION 1

The safety/relief valve discharge piping configuration at Cooper Station utilizes a "tee" quencher at the discharge pipe exit. The average length of the eight (8) SRV discharge lines (SRVDL) is 140 feet and the submergence length in the suppression pool is approximately 12 feet. The SRV test program utilized a rams head at the discharge pipe exit, a pipe length of 112 feet and a submergence length of approximately 13 feet. Loads on valve internals during the test program are larger than loads on valve internals in the Cooper Station configuration for the following reasons:

1. No dynamic mechanical load originating at the "tee" quencher is transmitted to the valve in the Cooper Station configuration because there is at least one anchor point between the valve and the tee quencher.
2. The first length of the segment of piping downstream of the SRV in the test facility was longer than the Cooper Station piping, thereby resulting in a bounding dynamic mechanical load on the valve in the test program. The first segment length in the test facility is 12 ft whereas this length is 6 ft in the plant configuration.
3. Dynamic hydraulic loads (backpressure) are experienced by the valve internals in the Cooper Station configuration. The backpressure loads may be either (i) transient backpressures occurring during valve actuation, or (ii) steady-state backpressures occurring during steady-state flow following valve actuation.
 - (a) The key parameters affecting the transient backpressures are the fluid pressure upstream of the valve, the valve opening time, the fluid inertia in the submerged SRVDL and the SRVDL air volume. Transient backpressures increase with higher upstream pressure, shorter valve opening times, greater line submergence, and smaller SRVDL air volume. The transient backpressure in the test program was maximized by utilizing a submergence of 13', which is greater than Cooper Station and a pipe length of 112' which is less than Cooper Station. The maximum transient backpressure occurs with high pressure steam flow conditions. The transient backpressure for the alternate shutdown cooling mode of operation is always less than the design for steam flow conditions because of the lower upstream pressure and the longer valve opening time.

- (b) The steady-state backpressure in the test program was maximized by utilizing an orifice plate in the SRVDL above the water level and before the rams head. The orifice was sized to produce a backpressure greater than that calculated for any of the Cooper Station SRVDL's.

The differences in the line configuration between Cooper Station and the test program as discussed above result in the loads on the valve internals for the test facility which bound the actual Cooper Station loads. An additional consideration in the selection of the rams head for the test facility was to allow more direct measurement of the thrust load in the final pipe segment. Utilization of a "tee" quencher in the test program would have required quencher supports that would unnecessarily obscure accurate measurement of the pipe thrust loads. For the reasons stated above, differences between the SRVDL configurations at Cooper Station and the test facility will not have any adverse effect on SRV operability at Cooper Station relative to the test facility.

NRC QUESTION 2

The test configuration utilized no spring hangers as pipe supports. Plant specific configurations do use spring hangers in conjunction with snubber and rigid supports. Describe the safety relief valve pipe supports used at Cooper Station and compare the anticipated loads on valve internals for the Cooper Station pipe supports to the measured loads in the test program. Describe the impact of any differences in loads on valve operability.

RESPONSE TO NRC QUESTION 2

The Cooper Station safety-relief valve discharge lines (SRVDL's) are supported by a combination of snubbers, rigid supports, and spring hangers. The locations of snubbers and rigid supports at Cooper Station are such that the location of such supports in the BWR generic test facility is prototypical, i.e., in each case (Cooper Station and the test facility) there are supports near each change of direction in the pipe routing. Additionally, SRVDL's at Cooper Station have between 1 and 5 spring hangers, all of which are located in the drywell. The spring hangers, snubbers, and rigid supports were designed to accommodate combinations of loads resulting from piping dead weight, thermal conditions, seismic and suppression pool hydrodynamic events, and a high pressure steam discharge transient.

The dynamic load effects on the piping and supports of the test facility due to the water discharge event (the alternate shutdown cooling mode) were found to be significantly lower than corresponding loads resulting from the high pressure steam discharge event. As stated in NEDE-24988-P, this finding is considered generic to all BWR's since the test facility was designed to be prototypical of the features pertinent to this issue.

During the water discharge transient there will be significantly lower dynamic loads acting on the snubbers and rigid supports than during the steam discharge transient. This will more than offset the small increase in the dead load on these supports due to the weight of the water during the alternate shutdown cooling mode of operation. Therefore, design adequacy of

the snubbers and rigid supports is assured as they are designed for the larger steam discharge transient loads.

This question addresses the design adequacy of the spring hangers with respect to the increased dead load due to the weight of the water during the liquid discharge transient. As was discussed with respect to snubbers and rigid supports, the dynamic loads resulting from liquid discharge during the alternate shutdown cooling mode of operation are significantly lower than those from the high pressure steam discharge. Therefore, it is believed that sufficient margin exists in the Cooper Station piping system design to adequately offset the increased dead load on the spring hangers in an unpinned condition due to a water filled condition. Furthermore, the effect of the water dead weight load does not affect the ability of SRV's to open to establish the alternate shutdown cooling path since the loads occur in the SRVDL only after valve opening.

NRC QUESTION 3

Report NEDE-24988-P did not identify any valve functional deficiencies or anomalies during the test program. Describe the impact on valve safety function of any valve functional deficiencies or anomalies encountered during the program.

RESPONSE TO NRC QUESTION 3

No functional deficiencies or anomalies of the safety relief or relief valves, were experienced during the testing at Wyle Laboratories for compliance with the alternate shutdown cooling mode requirement. All the valves subjected to test runs, valid and invalid, opened and closed without loss of pressure integrity or damage. Anomalies encountered during the test program were all due to failures of test facility instrumentation, equipment, data acquisition equipment, or deviation from the approved test procedure.

The test specification for each valve required six runs. Under the test procedure, any anomaly caused the test run to be judged invalid. All anomalies were reported in the test report. The Wyle Laboratories test log sheet for the two-stage target rock valve tests is attached. This valve is used at Cooper Nuclear Station.

Each Wyle test report for the respective valves identifies each test run performed and documents whether or not the test run is valid or invalid and states the reason for considering the run invalid. No anomaly encountered during the required test program affects any valve safety or operability function.

All valid test runs are identified in Table 2.2-1 of NEDE-24988-P. The data presented in Table 4.2-1 for each valve were obtained from the Table 2.2-1 test runs and were based upon the selection criteria of:

- (a) Presenting the maximum representative loading information obtained from the steam run data,
- (b) Presenting the maximum representative water loading information obtained from the 15°F subcooled water test data,

- (c) Presenting the data on the only test run performed for the 50°F subcooled water test condition.

NRC QUESTION 4

The purpose of the test program was to determine valve performance under conditions anticipated to be encountered in the plants. Describe the events and anticipated conditions at Cooper Station for which the valves are required to operate and compare these plant conditions to the conditions in the test program. Describe the plant features assumed in the event evaluations used to scope the test program and compare them to plant features at Cooper Station. For example, describe high level trips to prevent water from entering the steam lines under high pressure operating conditions as assumed in the test event and compare them to trips used at Cooper Station.

RESPONSE TO NRC QUESTION 4

The purpose of the S/RV test program was to demonstrate that the Safety Relief Valve (S/RV) will open and reclose under all expected flow conditions. The expected valve operating conditions were determined through the use of analyses of accidents and anticipated operational occurrences referenced in Regulatory Guide 1.70, Revision 2. Single failures were applied to these analyses so that the dynamic forces on the safety and relief valves would be maximized. Test pressures were the highest predicted by conventional safety analysis procedures. The BWR Owners Group, in their enclosure to the September 17, 1980, letter from D. B. Waters to R. H. Vollmer, identified 13 events which may result in liquid or two-phase S/RV inlet flow that would maximize the dynamic forces on the safety and relief valve. These events were identified by evaluating the initial events described in Regulatory Guide 1.70, Revision 2, with and without the additional conservatism of a single active component failure or operator error postulated in the event sequence. It was concluded from this evaluation that the alternate shutdown cooling mode is the only expected event which will result in liquid at the valve inlet. Consequently, this was the event simulated in the S/RV test program. This conclusion and the test results applicable to Cooper Station are discussed below. The alternate shutdown cooling mode of operation has been described in the response to NRC Question 5.

The S/RV inlet fluid conditions tested in the BWR Owners Group S/RV test program, as documented in NEDE-24988-P, are 15°F to 50°F subcooled liquid at 20 psig to 250 psig. These fluid conditions envelope the conditions expected to occur at Cooper Station in the alternate shutdown cooling mode of operation.

The BWR Owners Group identified 13 events by evaluating the initiating events described in Regulatory Guide 1.70, Revision 2, with the additional conservatism of a single active component failure or operator error postulated in the events sequence. These events and the plant-specific features that

mitigate these events, are summarized in Table 1. Of these 13 events, only ten (10) are applicable to Cooper because of its design and specific plant configuration. Three events, namely 5, 6, and 10 are not applicable to Cooper Station for the reasons listed below:

- a. Event Number 5 - Transient High Pressure Core Spray

This system is not installed at Cooper.

- b. Event Number 6 - Transient RCIC Head Spray

This system is not installed at Cooper.

- c. Event Number 10 - Small Break Accident, High Pressure Core Spray

This system is not installed at Cooper.

Of these ten (10) remaining events, the Cooper Station specific features, such as trip logic, power supplies, instrument line configuration, alarms and operator actions, have been compared to the base case analysis presented in the BWR Owners Group submittal of September 17, 1980. The comparison has demonstrated that in each case, the base case analysis is applicable to Cooper Station because the base case analysis does not include any plant features which are not already present in the BWR Owners Group submittal of September 17, 1980. It is seen from Table 1, that all plant features assumed in the event evaluation are also existing features in the Cooper Station plant. All features included in this base case analysis are similar to plant features in the Cooper Station design. Furthermore, the time available for operator action, is expected to be longer in the Cooper Station plant than in the base case analysis for each case where operator action is required.

Event 7, the alternate shutdown cooling mode of operation, is the only expected event which will result in liquid or two-phase fluid at the S/RV inlet. Consequently, this event was simulated in the BWR S/RV test program. At Cooper Station, this event involves flow of subcooled water (approximately 44°F subcooled) at a pressure of approximately 75 psig. The test conditions clearly envelope these plant conditions.

As discussed above, the BWR Owners Group evaluated transients including single active failures that would maximize the dynamic forces on the safety relief valves. As a result of this evaluation, the alternate shutdown cooling mode is the only expected event involving liquid or two-phase flow. Consequently, this event was tested in the BWR S/RV test program. The fluid conditions and flow conditions tested in the BWR Owners Group test program conservatively envelope the Cooper Station plant-specific fluid conditions expected for the alternate shutdown cooling mode of operation.

NRC QUESTION 5

The valves are likely to be extensively cycled in a controlled depressurization mode in a plant-specific application. Was this mode simulated in the test program? What is the effect of this valve cycling on valve performance and probability of the valve to fail open or to fail closed?

RESPONSE TO NRC QUESTION 5

The BWR safety/relief valve (SRV) operability test program was designed to simulate the alternate shutdown cooling mode, which is the only expected liquid discharge event for Cooper Station. The sequence of events leading to the alternate shutdown cooling mode is given below.

Following normal reactor shutdown, the reactor operator depressurizes the reactor vessel by opening the turbine bypass valves and removing heat through the main condenser. If the main condenser is unavailable, the operator could depressurize the reactor vessel by using the SRV's to discharge steam to the suppression pool. If SRV operation is required, the operator cycles the valves in order to assure that the cooldown rate is maintained within the technical specification limit of 100°F per hour. When the vessel is depressurized, the operator initiates normal shutdown cooling by use of the RHR system. If that system is unavailable because the valve on the RHR shutdown cooling suction line fails to open, the operator initiates the alternate shutdown cooling mode.

For alternate shutdown cooling, the operator opens one SRV and initiates either an RHR or core spray pump utilizing the suppression pool as the suction source. The reactor vessel is filled such that water is allowed to flow into the main stream lines and out of the SRV and back to the suppression pool. Cooling of the system is provided by use of an RHR heat exchanger. As a result, an alternate cooling mode is maintained.

In order to assure continuous long-term heat removal, the SRV is kept open and no cycling of the valve is performed. In order to control the reactor vessel cooldown rate, the operator would control the flow rate into the vessel. Consequently, no cycling of the SRV is required for the alternate shutdown cooling mode, and no cycling of the SRV was performed for the generic BWR SRV operability test program.

The ability of the Cooper Station SRV to be extensively cycled for steam discharge conditions has been confirmed during steam discharge qualification testing of the valve by the valve vendor. Based on the qualification testing of the SRV's, the cycling of the valves in a controlled depressurization mode for steam discharge conditions will not adversely affect valve performance and the probability of the valve to fail open or closed is extremely low.

NRC QUESTION 6

Describe how the values of Valve C_v's in report NEDE-24988-P will be used at Cooper Station. Show that the methodology used in the test program to determine the valve C_v will be consistent with the application at Cooper Station.

RESPONSE TO NRC QUESTION 6

The flow coefficient, C_v , for the Target Rock safety relief valve (SRV) (2 stage) utilized at Cooper Station was determined in the generic SRV test program (NEDE-24988-P). The average flow coefficient calculated from the test results for the Target Rocks, is reported in Table 5.2-1 of NEDE-24988-P. This test value has been used by BWR plants to confirm that the liquid discharge flow capacity of the SRV's will be sufficient to remove core decay heat when injecting into the reactor pressure vessel (RPV) in the alternate shutdown cooling mode. CNS does not rely upon the alternate shutdown cooling mode as the licensing basis in the FSAR. The C_v value determined in the SRV test indicates that the Cooper Station SRV's are capable of returning the flow injected by the RHR or CS pump to the suppression pool.

If it were necessary for the operator to place Cooper Station in the alternate shutdown cooling mode, he would assure that adequate core cooling was being provided by monitoring the following parameters: RHR or CS flow rate, reactor vessel pressure and reactor vessel temperature.

The flow coefficient for the Target Rock valve reported in NEDE-24988-P was determined from the SRV flow rate when the valve inlet was pressurized to approximately 250 psig. The valve flow rate was measured with the supply line flow venturi upstream of the steam chest. The C_v for the valve was calculated using the nominal measured pressure differential between the valve inlet (steam chest) and 3' downstream of the valve and the corresponding measured flowrate. Furthermore, the test conditions and test configuration were judged representative of Cooper Station plant conditions for the alternate shutdown cooling mode, e.g., pressure upstream of the valve, fluid temperature, friction losses and liquid flowrate, although the alternate shutdown cooling mode is not required to be fully analyzed for CNS. Therefore, the reported C_v values are appropriate for application to Cooper Station.

TABLE 1 - EVENTS EVALUATED

PLANT FEATURES	EVENTS EVALUATED												
	# 1	# 2	# 3	# 4	# 5	# 6	# 7	# 8	# 9	# 10	# 11	# 12	# 13
High Water Level 7 Alarm	X	S	X	S	X	NA			X	X	X	X	X
High Drywell Pressure Alarm													
FW Level 8 Trip	X	S											
RCIC Level 8 Trip			X	S	X	NA			X	X	X	X	X
HPCS Level 8 Trip					X	NA			X	X			X
HPCI Level 8 Trip			X	S					X		X		X
HPCI/S and RCIC Initiation on Low Water Level	X	S	X	S	X	NA		X	X				X
HPCI/S Initiation on High Drywell Pressure			X	S					X	X	X	X	X
RCIC Initiation on High Drywell Pressure													X

TABLE 1 - EVENTS EVALUATED (Continued)

Page 2 of 3		EVENTS EVALUATED												
PLANT FEATURES		# 1	# 2	# 3	# 4	# 5	# 6	# 7	# 8	# 9	#10	#11	#12	#13
Low Pressure ECCS Initiation on High Drywell Pressure													X	S
Low Pressure Initiation on Low Water Level														X
FW Pumps Trip on Low Section Pressure	X	S												
HPCI Trip on High Backpressure				X								X		S
RCIC Trip on High Backpressure					X		S			X				S
Turbine Trip on Vessel High Level	X	S	X											
MSIVs Closure on Low Turbine Inlet Pressure	X	NA	X						X					
MSIVs Closure on High Steam Flow		X							X					
MSIVs Closure on High Steam Tunnel Temperature			S						X					S

TABLE 1 - EVENTS EVALUATED (Continued)

PLANT FEATURES	EVENTS EVALUATED												
	# 1	# 2	# 3	# 4	# 5	# 6	# 7	# 8	# 9	#10	#11	#12	#13
MSIV Closure on High Radiation								X	S				
Reactor Scram on Turbine Trip	X	S	X	S									
Reactor Scram on Neutron Flux Monitor		X	S										
Reactor Scram on MSIVs Closure		X	S										
Reactor Scram on High Radiation							X	S					
Reactor Scram on High Drywell Pressure									X	S		X	S
Reactor Scram on Low Water Level												X	S
Reactor Isolation on Low Water Level												X	S


KEY: X - Feature Considered in Base Case Analysis
 S - Feature in Plant Specific Design
 NA - Not Applicable

TURN DOCUMENT

DOCUMENT (SET)
START

WYLE LABORATORIES
SCIENTIFIC SERVICES AND SYSTEMS GROUP

OPERABILITY TEST REPORT
FOR
TARGET ROCK 6X10 SRV
FOR
LOW PRESSURE WATER TESTS
FOR
GENERAL ELECTRIC COMPANY



test **REPORT**

TABLE I
TEST LOG FOR SRV TR-1

Test No.	Test Media	Load Line Configuration	Test Date	Remarks
301	Steam	I	3/17/81	Acceptable
302	Water	I	3/17/81	GN ₂ Regulator failed. Data not acceptable.
303	Water	I	3/17/81	Acceptable
304	Steam	I	3/17/81	Acceptable
305	Water	I	3/18/81	Acceptable
306	Steam	I	3/18/81	Acceptable
307	Water	I	3/18/81	Acceptable
308	Water	I	3/18/81	Special test at elevated temperature and low pressure requested by G.E.

17601 1029