NOV 2 1982

DISTRIBUTION
Docket Nos.: 50-413/414
NRC PDR
L PDR
PRC Sys
NSIC
LB#4 Reading
EAdensam
MDuncan
KJabbour
DEisenhut/RPurple
Attorney, OELD
ELJordan, DEQA:IE
ACRS (16)
JMTaylor, DRP:IE
DShum
JPersensky
TNovak

Docket Nos.: 50-413/414

Mr. H. B. Tucker, Vice President
Nuclear Production Department
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242

Dear Mr. Tucker:

Subject: Request for Additional Information - Catawba Nuclear Station

In the performance of the Catawba Station licensing review, the NRC staff has identified the need for additional information in the operator training area (Enclosure). We request that you provide the information herein requested no later than November 19, 1982. If you require any clarification of this matter, please contact the project manager, Kahtan Jabbour, at (301) 492-7821.

The reporting and/or recordkeeping requirements contained in this letter affect fewer than ten respondents; therefore, OMB clearance is not required under P.L. 96-511.

Sincerely,

Elinor G. Adensam, Chief
Licensing Branch No. 4
Division of Licensing

Enclosure:
As stated

cc: See next page

8211160076 821102
PDR ADOCK 05000413
A PDR

OFFICE	DL:LB#4 KNJ	LA:DL:LB#4	DL:LB#4	LQB	LQB		
SURNAME	KJabbour:eb	MDuncan	EAdensam	DShum	JPersensky		
DATE	11/ /82	11/ /82	11/ /82	11/ /82	11/ /82		

CATAWBA

Mr. H. B. Tucker, Vice President
Nuclear Production Dept.
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242

cc: William L. Porter, Esq.
Duke Power Company
P.O. Box 33189
Charlotte, North Carolina 28242

J. Michael McGarry, III, Esq.
Debevoise & Liberman
1200 Seventeenth Street, N.W.
Washington, D. C. 20036

North Carolina MPA-1
P.O. Box 95162
Raleigh, North Carolina 27625

Mr. F. J. Twogood
Power Systems Division
Westinghouse Electric Corp.
P.O. Box 355
Pittsburgh, Pennsylvania 15230

Mr. J. C. Plunkett, Jr.
NUS Corporation
2536 Countryside Boulevard
Clearwater, Florida 33515

Mr. Jesse L. Riley, President
Carolina Environmental Study Group
854 Henley Place
Charlotte, North Carolina 28208

Richard P. Wilson, Esq.
Assistant Attorney General
S.C. Attorney General's Office
P.O. Box 11549
Columbia, South Carolina 29211

Mr. Henry Presler, Chairman
Charlotte - Mecklenburg Environmental Coalition
943 Henly Place
Charlotte, North Carolina 28207

North Carolina Electric Membership Corp.
3333 North Boulevard
P.O. Box 27306
Raleigh, North Carolina 27611

Saluda River Electric Cooperative, Inc.
207 Sherwood Drive
Laurens, South Carolina 29360

Mr. Peter K. VanDoorn
Route 2, Box 179N
York, South Carolina 29745

James P. O'Reilly, Regional Administrator
U.S. Nuclear Regulatory Commission, Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Robert Guild, Esq.
314 Pall Mall
Columbia, South Carolina 29201

Palmetto Alliance
2135 1/2 Devine Street
Columbia, South Carolina 29205

ENCLOSURE

REQUEST FOR ADDITIONAL INFORMATION

630.5 Provide a training program for mitigating core damage as described in Item II.B.4 of NUREG-0737, in accordance with the guidance specified in Enclosure 3 of H. R. Denton's letter dated March 28, 1980. Provide a listing of those individuals, and their qualifications, who must participate in the training program. Provide a schedule for the training as it relates to the presently - scheduled fuel load date.

630.6 FSAR page 13.2-11 lists only nine specific reactivity changes. Ten is required.

630.7 FSAR Figure 13.2.2-1 should be revised to include SRO.