OPERATI. G DATA REPORT

DOCKET NO. 50-269

DATE 11-15-82

COMPLETED BY J. A. Reavis
TELEPHONE 704-373-8552

OPERATING STATUS						
1. Unit Name: Oconee #1		Notes				
2. Reporting Period: October 1, 1982-	October 31, 1982	Year-to-date and cummulative capacity factors are calcu-				
3. Licensed Thermal Power (MWt): 2568						
4. Nameplate Rating (Gross MWe):	934	lated using a weighted				
5. Design Electrical Rating (Net MWe):	886	average for maximum dependable capacity.				
6. Maximum Dependable Capacity (Gross MV	Ve): 899	dependable cap	eacity.			
7. Maximum Dependable Capacity (Net MWe	242					
8. If Changes Occur in Capacity Ratings (Item None		ince Last Report, Give R	easons:			
9. Power Level To Which Restricted, If Any (10. Reasons For Restrictions, If Any:						
	This Month	Yrto-Date	Cumulative			
1. Hours In Reporting Period	745.0	7 296.0	81 481.0			
2. Number Of Hours Reactor Was Critical	532.9	5 147.7	56 203.0			
3. Reactor Reserve Shutdown Hours						
4. Hours Generator On-Line	507.4	4 875.8	53 119.0			
5. Unit Reserve Shutdown Hours						
6. Gross Thermal Energy Generated (MWH)	1 266 299	11 910 466	125 368 238			
7. Gross Electrical Energy Generated (MWH)	434 720	4 128 740	43 605 090			
8. Net Electrical Energy Generated (MWH)	410 495	3 897 339	41 241 515			
9. Unit Service Factor	68.1	66.8	65.2			
0. Unit Availability Factor	68.1	66.8	65.2			
1. Unit Capacity Factor (Using MDC Net)	64.1	62.1	58.7			
2. Unit Capacity Factor (Using DER Net)	62.2	60.3	57.1			
3. Unit Forced Outage Rate	6.3	31.3	19.6			
Shutdowns Scheduled Over Next 6 Months None	(Type, Date, and Duration	of Each):				
5. If Shut Down At En.i Of Report Period, Es 6. Units In Test Status (Prior to Commercial (Forecast	Achieved			
			Aciliered			
INITIAL CRITICALITY						
INITIAL ELECTRICITY						
COMMERCIAL OPERAL						

DOCKET NO. 50-269

UNIT 0conee 1

DATE 11-15-82

AVERAGE DAILY UNIT POWER LEVEL

MONTH Oc	tober, 1982		
DAY	AGE DAILY POWER LEVEL (MWe-net)	DAY	(MWe-net)
1 .	851	17	842
2	852	18	842
3	852	19	841
4	851	20	841
5	852	21	847
6	853	22	683
7	660	23	
8		24	
9	327	25	
10	.819	26	
11	845	27	
12	850	28	
13	851	29	
14	848	30	
15	844	31	349
15	844		

DAILY UNIT POWER LEVEL FORM INSTRUCTIONS

On this form, list the average daily unit power level in MWe-net for each day in the reporting month. Compute to the nearest whole megawatt.

These figures will be used to plot a graph for each reporting month. Note that by using maximum dependable capacity for the net electrical rating of the unit there may be occasions when the daily average power level exceeds the 100% line for the restricted power level line). In such cases, the average daily unit power output sheet should be footnoted to explain the apparent anomaly.

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH October, 1982

DOCKET NO. UNIT NAME DATE COMPLETED BY TELEPHONE

50-269 Oconee #1 11715782 J. A. Reavis

704-373-7433

No.	Date	Type1	Duration (Hours)	Reason,	Method of Shutting Down Reactor3	Licensee Event Report #	System Code4	Component Code5	Cause & Corrective Action to Prevent Recurrence
11-P	82-10-07	F		Н			СВ	PUMPXX	Reduced load to isolate 'IA1' RCP due to low oil level alarm.
21	82-10-07	F	34.07	Н	1		СВ	PUMPXX	Reactor shutdown to add oil to 'IA1' RCP.
22	82-10-22	S	203.55	В	1		СВ	VALVEX	Unit shutdown to adjust internal ring settings of pressurizer code relief valves.

F Forced

S. Scheduled

Reason:

A-Equipment Failure (Explain)

B-Maintenance of Test

C-Refucing

D-Regulatory Restriction E-Operator Training & License Examination

F-Administrative

G-Operational Error (Explain)

H-Other (Explain)

Method:

1-Manual

2-Manual Scrain.

A-Automatic Scram.

4-Other (Explain)

Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NURLG-0161)

Exhibit 1 - Same Source

(9/77)

MONTHLY REFUELING INFORMATION REQUEST

Facility name: Oconee Unit 1
Scheduled next refueling shutdown: September 1983
Scheduled restart following refueling: November 1983
Will refueling or resumption of operation thereafter require a technical specification change or other license amendment? Yes. If yes, what will these be? Technical Specification Revision
If no, has reload design and core configuration been reviewed by Safety
Review Committee regarding unreviewed safety questions? N/A.
Scheduled date(s) for submitting proposed licensing action and supporting information: N/A
Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes is design or new operating procedures).
Number of fuel assemblies (a) in the core: 177 .
(b) in the spent fuel pool: 785.
(b) in the spent fuel pool: Present licensed fuel pool capacity:1312*
(b) in the spent fuel pool:

^{*}Represents the total for the combined Units 1 and 2.

DOCKET NO: 50-269

UNIT: Oconee Unit 1

DATE: 11-15-82

NARRATIVE SUMMARY

Month: October, 1982

Oconee Unit 1 operated near full power until October 7 when power was reduced to 68% to isolate the 1Al RCP following a low oil level alarm. The unit was shutdown that night to add oil to the pump and was back on line in about 34 hours.

The unit operated at near full load until October 22 when the unit was shutdown to adjust the internal ring settings of the pressurizer code relief valves. The unit returned to service on October 31, 1982.

OPERATING DATA REPORT

DOCKET NO. 50 270
DATE 11-15-82
COMPLETED BY J. A. Reavis
TELEPHONE 704-373-8552

OPE	RA	TIN	GS	TAT	US

1. Unit Name: Oconee #2 2. Reporting Period: October 1. 1982- 3. Licensed Thermal Power (MWt): 2568 4. Nameplate Rating (Gross MWe): 5. Design Electrical Rating (Net MWe): 6. Maximum Dependable Capacity (Gross MW 7. Maximum Dependable Capacity (Net MWe) 8. If Changes Occur in Capacity Ratings (Item None)	934 886 (e): 899): 860	Notes Year-to-date and cummulative capacity factors are calculated using a weighted average for maximum dependable capacity. ince Last Report, Give Reasons:			
9. Power Level To Which Restricted, If Any () 0. Reasons For Restrictions, If Any:					
	This Month	Yrto-Date	Cumulative		
1. Hours In Reporting Period	745.0	7 296.0	71 401.0		
2. Number Of Hours Reactor Was Critical	598.3	3 254.4	49 462.8		
3. Reactor Reserve Shutdown Hours					
4. Hours Generator On-Line	593.5	3 155.0	48 383.4		
5. Unit Reserve Shutdown Hours					
6. Gross Thermal Energy Generated (MWH)	1 510 358	6 990 307	113 025 119		
7 Gross Electrical Energy Generated (MWH)	513 920	2 386 670	38 463 456		
8. Net Electrical Energy Generated (MWH)	489 286	2 243 109	36 475 957		
9. Unit Service Factor	79.7	43.2	67.8		
0. Unit Availability Factor	79.7	43.2	67.8		
1. Unit Capacity Factor (Using MDC Net)	76.4	35 8	59.2		
2. Unit Capacity Factor (Using DER Net)	74.1	34.7	57.7		
3. Unit Forced Outage Rate	20.3	23.8	18.1		
4. Shutdowns Scheduled Over Next 6 Months None	(Type, Date, and Duration	of Each):			
5. If Shut Down At End Of Report Period, Es	timated Date of Startum				
6. Units In Test Status (Prior to Commercial C		Forecast	Achieved		
INITIAL CRITICALITY					
INITIAL ELECTRICITY					
COMMERCIAL OPERAT	TON				

DOCKET NO. 50-270

UNIT 0conee 2

DATE 11-15-82

AVERAGE DAILY UNIT POWER LEVEL

MONTH_	October, 1982		
	RAGE DAILY POWER LEVEL (MWe-net)	DAY	VERAGE DAILY POWER LEVEL (MWe-net)
1	831	17	
2	32	18	
3	833	19	
4	834	20	
5	834	21	732
6	833	22	841
	833	23	839
7	830	24	839
8	829	25	841
9	833		842
10		26	042
11	834	27	843
12	834	28	840
13	836	29	839
14	483	30	839
15		31	840
15			

DAILY UNIT POWER LEVEL FORM INSTRUCTIONS.

On this form, list the average daily unit power level in Mile-net for each day in the reporting month. Compute to the nearest whole megawatt.

These figures will be used to plot a graph for each reporting month. Note that by using maximum dependable capacity for the net electrical rating of the unit there may be occasions when the daily average power level exceeds the 100% line for the restricted power level line). In such cases, the average daily unit power output sheet should be footnoted to explain the apparent anomaly.

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH October, 1982

DOCKET NO. UNIT NAME DATE

50-270 Oconee 2 11-15-82

COMPLETED BY TELEPHONE J. A. Reavis 704-373-7433

No.	Date	Type1	Duration (Hours)	Reason -	Method of Shutting Down Reactor3	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
9	82-10-14	F	151.48	В	1		СВ	VALVEX	Unit shutdown to adjust internal ring settings of pressurizer code relief valves.

F. Forced

S. Scheduled

Reasont

A-Equipment Failure (Explain)

B-Maintenance or Test

C-Refueling

D-Regulatory Restriction

1-Operator Training & License Examination

F-Administrative

G-Operational Error (Explain)

H-Other (Explain)

Method:

1-Manual

2-Manual Scram. 3-Automatic Seram.

4-Other (Explain)

Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NURLG-01611

Exhibit 1 - Same Source

(9/77)

MONTHLY REFUELING INFORMATION REQUEST

F	acility name:	Oconee Unit 2		
S	cheduled next	refueling shutdown:	December, 1983	
S	cheduled resta	rt following refuelin	g: February, 1984	
s	pecification c	hange or other licens	ration thereafter require a technic se amendment? Yes . cal Specification Revision	ca
			enfiguration been reviewed by Safe	ĽУ
	cheduled date(s) for submitting pro	posed licensing action and suppor	i
				-
I	mportant licen		new or different design or supplicallysis methods, significant changes	
I	mportant licen	gn or performance ana	lysis methods, significant changes	
I u d	mportant licen nreviewed desi esign or new o	gn or performance and perating procedures).	lysis methods, significant changes	
I ud	mportant licens nreviewed design or new or umber of fuel a	gn or performance and perating procedures).	core: 177 spent fuel pool: 785	
I u d N P S P	umber of fuel a	assemblies (a) in the (b) in the d fuel pool capacity: ed or planned increas	core: 177 spent fuel pool: 785	
I u d	umber of fuel a	assemblies (a) in the (b) in the d fuel pool capacity: ed or planned increas of last refueling whity:	core: 177 spent fuel pool:785 1312*	3

^{*}Represents the total for the combined Units 1 and 2.

DOCKET NO: 50-270

UNIT: 0conee 2

DATE: 11-15-82

NARRATIVE SUMMARY

Month: October, 1982

Oconee Unit 2 operated near full power until October 14 when the unit shutdown to adjust the internal ring settings of the pressurizer code relief valves. The unit returned to service late October 20.

The unit operated the remainder of the month at near full power.

OPERATING DATA REPORT

DOCKET NO. 50-287 DATE 11-15-82 COMPLETED BY J. A. Reavis TELEPHONE 704-373-8552

OPERATING STATUS	OPE	RA	TIN	G	STA	TUS
------------------	-----	----	-----	---	-----	-----

1. Unit Name: Oconee #3 2. Reporting Period: October 1, 1982- 3. Licensed Thermal Power (MWt): 2569 4. Nameplate Rating (Gross MWe): 5. Design Electrical Rating (Net MWe): 6. Maximum Dependable Capacity (Gross MW7. Maximum Dependable Capacity (Net MWe) 8. If Changes Occur in Capacity Ratings (Item None)	Notes Year-to-date and cummulative capacity factors are calculated using a weighted average for maximum dependable capacity. ince Last Report, Give Reasons:			
9. Power Level To Which Restricted, If Any (0. Reasons For Restrictions, If Any:	(Net MWe): None			
	This Month	Ytto-Date	Cumulative	
1. Hours In Reporting Period	745.0	7 296.0	69 048.0	
2. Number Of Hours Reactor Was Critical	469.8	2 179.4	47 493.3	
3. Reactor Reserve Shutdown Hours				
4. Hours Generator On-Line	409.5	2 111.8	46 427.9	
5. Unit Reserve Shutdown Hours				
6. Gross Thermal Energy Generated (MWH)	818 783	5 141 430	112 660 169	
7. Gross Electrical Energy Generated (MWH)	278 580	1 772 690	38 919 504	
8. Net Electrical Energy Generated (MWH)	259 211	1 671 121	37 022 597	
9. Unit Service Factor	55.0	28.9	67.2	
0. Unit Availability Factor	55.0	28.9	67.2	
1. Unit Capacity Factor (Using MDC Net)	40.5	26.6	62.1	
2. Unit Capacity Factor (Using DER Net)	39.3	25.9	60.5	
3. Unit Forced Outage Rate	39.5	37.7	16.4	
4. Shutdowns Scheduled Over Next 6 Months None	s (Type, Date, and Direction	of Each):		
5. If Shut Down At End Of Report Period, E.	stimated Date of Carrier			
6. Units In Test Status (Prior to Commercial		Forecast	Achieved	
INITIAL CRITICALITY INITIAL ELECTRICITY COMMERCIAL OPERA				

DOCKET NO. _ 50-287 UNIT Oconee #3 DATE 11-15-82

AVERAGE DAILY UNIT POWER LEVEL

AVE	RAGE DAILY POWER LEVEL		RAGE DAILY POWER LEV
AY	(MWe-net)	DAY	(MWe-net)
1		17	
2		18	
3		19	
4	293	20	
5	304	21	
5	495	22	429
7	621	23	712
8	774	24	779
9	848	25	769
0	685	26	770
11		27	771
		28	771
12		29	823
13		30	666
14		31	439
15 16			

DAILY UNIT POWER LEVEL FORM INSTRUCTIONS

On this form, list the average daily unit power level in M'Ne-net for each day in the reporting month. Compute to the nearest whole megawatt.

These figures will be used to plot a graph for each reporting month. Note that by using maximum dependable capacity for the net electrical rating of the unit, there may be occasions when the daily average power level exceeds the 100% line (or the restricted power level line). In such cases, the average daily unit power output sheet should be footnoted to explain the apparent anomaly.

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH October, 1982

DOCKET NO. UNIT NAME DATE COMPLETED BY TELEPHONE

50-287 Oconee 3 11/15/82 J. A. Reavis 704-373-7433

No.	Date	Type	Duration (Hours)	Reason?	Method of Shutting Down Reactor3	Licensee Event Report #	System Code ⁴	Conponent Code5	Cause & Corrective Action to Prevent Recurrence
2	82-10-01	S	68.42	В			ZZ	7.7.7.7.7.7	End of cycle outage and auxiliary feedwater header work completed.
2-P	82-10-03	S		В			ZZ	ZZZZZZ	Power escalation testing.
3	82-10-10	F	267.08	А	7		СВ	нтехсн	Unit shutdown to attempt to locate steam generator tube leak. Work also completed on pressurizer code relief.
3-P	82-10-22	F		А			СВ	нтехсн	Holding at various power levels to monitor steam generator tube leak.
4-P	82-10-25	F		А			нн	PUMPXX	3D2 heater drain pump out of service.
5-P	82-10-25	F		A			нн	PUMPXX	Condensate booster pump out of service for repair of discharge valve.

F: Forced

S. Scheduled

Reason:

A-Equipment Failure (Explain) B-Maintenance of Test

C-Refueling

D-Regulatory Restriction

E-Operator Training & License Examination

F-Administrative

G-Operational Error (Explain)

H-Other (Explain)

3 Method:

1-Manual

2-Manual Scram.

3-Automatic Scrain.

4-Other (Explain)

Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-

0161)

Exhibit 1 - Same Source

(9/77)

MONTHLY REFUELING INFORMATION REQUEST

Facility name: Oconee Unit 3
Scheduled next refueling shutdown: May, 1984
Scheduled restart following refueling: July, 1984
Will refueling or resumption of operation thereafter require a technical specification change or other license amendment? Yes If yes, what will these be? Technical Specification Revision
If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions? N/A Scheduled date(s) for submitting proposed licensing action and supports
Important licensing considerations (new or different design or supplier unreviewed design or performance analysis methods, significant changes design or new operating procedures).
 Number of fuel assemblies (a) in the core:
Number of fuel assemblies (a) in the core: (b) in the spent fuel pool:
(b) in the spent fuel pool: 205. Present licensed fuel pool capacity: 474
(b) in the spent fuel pool: 205. Present licensed fuel pool capacity: 474 Size of requested or planned increase: Projected date of last refueling which can be accommodated by present
(b) in the spent fuel pool: 205.

DOCKET NO:_	50-287
UNIT:	Oconee 3
DATE:	11-15-82

NARRATIVE SUMMARY

Month	:	October,		1982	
		A STATE OF THE PARTY OF THE PAR	-		and the same of th

Oconee Unit 3 began the month with heat-up in progress following an outage for steam generator modifications and refuel. The unit was critical the first and on-line the third. Power escalation testing continued through October 8.

October 10 the unit shutdown to try and locate a steam generator tube leak. While the unit was down the pressurizer code relief valves were adjusted. The unit returned to service October 22 without identifying the leak. The increase in power was held up at several points to evaulate any changes in the tube leak rate.

The unit was limited to 85% power in October 25 due to the 3D2 heater drain pump being out of service. When the drain pump was put back into service, the unit remained limited to 90% until a condensate booster pump discharge valve was repaired. These repairs were complete October 29.

October 30 power was reduced to 50% to further evaluate the steam generator tube leak rate.

The unit ended the month at 75% power and holding for system dispatch requirements.

OCONEE NUCLEAR STATION

Operating Status Report

1. Personnel Exposure:

For the month of September, 5 individual(s) exceeded 10 percent of their allowable annual radiation dose limit with the highest dose being 1.700 rem, which represents approximately 14.2% of that person's allowable annual limit.

2. The total station liquid release for September has been compared with the Technical Specifications annual value of 15 curies; the total release for September was less than 10 percent of this limit.

The total station gaseous release for September has been compared with the derived Technical Specifications annual value of 51,000 curies; the total release for September was less than 10 percent of this limit.