

CONTROL BLOCK: [] [] [] [] [] [] [] [] [] [] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

[01] [S][C][V][C][S][I] (2) [0][0] - [0][0][0][0][0] - [0][0] (3) [4][1][0][0][0] (4) [] [] (5)
7 8 9 LICENSEE CODE 16 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CONT

[01] REPORT SOURCE [I] (6) [0][5][0][0][0][3][9][5] (7) [1][0][1][2][8][2] (8) [1][1][1][1][8][2] (9)
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

[02] With the Plant in Mode 3, NRC Resident Inspector discovered that the circuit
[03] breaker for Reactor Building Cooling Unit Fan XFN-62B was open and in the
[04] discharged position. The fan would not have started on an auto start signal.
[05] There were no adverse consequences as the remaining selected fan was OPERABLE
[06] and both trains of Reactor Building Spray were OPERABLE. Also, the Plant was in
[07] Mode 3 prior to initial criticality.
[08]

[09] SYSTEM CODE [S][B] (11) CAUSE CODE [X] (12) CAUSE SUBCODE [X] (13) COMPONENT CODE [C][K][T][B][K][R] (14) COMP. SUBCODE [F] (15) VALVE SUBCODE [Z] (16)
7 8 9 10 11 12 13 14 15 16 17 18 19 20
17 LER/RO REPORT NUMBER [8][2] (17) SEQUENTIAL REPORT NO. [0][2][2] (18) OCCURRENCE CODE [0][3] (19) REPORT TYPE [L] (20) REVISION NO. [0] (21)
ACTION TAKEN [X] (18) FUTURE ACTION [G] (19) EFFECT ON PLANT [Z] (20) SHUTDOWN METHOD [Z] (21) HOURS [0][0][0][0] (22) ATTACHMENT SUBMITTED [Y] (23) NPRO-4 FORM SUB. [N] (24) PRIME COMP. SUPPLIER [N] (25) COMPONENT MANUFACTURER [I][2][0][2] (26)
13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

[10] Event appears to be an isolated case for which cause has not been determined.
[11] Fan functioned properly on October 7, 1982, during surveillance test with no
[12] subsequent maintenance on fan or breaker. Corrective action was taken to check
[13] all 480V safeguard switchgear. No problems were discovered. Also, procedures
[14] are being revised and developed to require signoff verification of position.

[15] FACILITY STATUS [B] (28) % POWER [0][0][0] (29) OTHER STATUS [N/A] (30) METHOD OF DISCOVERY [D] (31) DISCOVERY DESCRIPTION [NRC Inspection] (32)
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

[16] ACTIVITY RELEASED [Z] (33) CONTENT OF RELEASE [Z] (34) AMOUNT OF ACTIVITY [N/A] (35) LOCATION OF RELEASE [N/A] (36)
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

[17] PERSONNEL EXPOSURES NUMBER [0][0][0] (37) TYPE [Z] (38) DESCRIPTION [N/A] (39)
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

[18] PERSONNEL INJURIES NUMBER [0][0][0] (40) DESCRIPTION [N/A] (41)
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

[19] LOSS OF OR DAMAGE TO FACILITY TYPE [Z] (42) DESCRIPTION [N/A] (43)
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

[20] PUBLICITY ISSUED [N] (44) DESCRIPTION [N/A] (45) NRC USE ONLY [] [] [] [] [] [] [] [] [] []
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

NAME OF PREPARER

AR Koon, Jr.
A. R. Koon, Jr.

PHONE: (803) 345-5209