

LICENSEE EVENT REPORT

Unit 2

CONTROL BLOCK: [ ][ ][ ][ ][ ][ ] 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 [ T | N | S | N | P | ] 2 [ 2 ] [ 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 ] 3 [ 4 | 1 | 1 | 1 | 1 ] 4 [ ] [ ] [ ] [ ] 5

CONT [ 0 | 1 ] REPORT SOURCE [ L ] 6 [ 0 | 5 | 1 | 0 | 0 | 0 | 3 | 2 | 8 ] 7 [ 1 | 0 | 2 | 0 | 8 | 2 ] 8 [ 1 | 1 | 1 | 8 | 8 | 2 ] 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

0 2 At 1000 on 10/20/82, unit 2 in mode 1, cooling jacket circulating water pump on
0 3 diesel generator (D/G) 2B-B was found inoperable during the performance of SI-7,
0 4 "Electrical Power System: Diesel Generators." This required entry into the
0 5 action statement of LCO 3.8.1.1. There was no effect on public health or safety.
0 6 Previous occurrences - none.
0 7
0 8

0 9 SYSTEM CODE [ E | E ] 11 CAUSE CODE [ E ] 12 CAUSE SUBCODE [ B ] 13 COMPONENT CODE [ E | N | G | I | N | E ] 14 COMP. SUBCODE [ Z ] 15 VALVE SUBCODE [ Z ] 16

17 LER/RO REPORT NUMBER [ 8 | 2 ] 21-22 SEQUENTIAL REPORT NO. [ 1 | 2 | 7 ] 24-26 OCCURRENCE CODE [ 0 | 3 ] 28-29 REPORT TYPE [ L ] 30 REVISION NO. [ 0 ] 32
ACTION TAKEN [ A ] 18 FUTURE ACTION [ Z ] 19 EFFECT ON PLANT [ Z ] 20 SHUTDOWN METHOD [ Z ] 21 HOURS [ 0 | 0 | 0 | 0 ] 22 ATTACHMENT SUBMITTED [ N ] 23 NPD-4 FORM SUB. [ N ] 24 PRIME COMP. SUPPLIER [ N ] 25 COMPONENT MANUFACTURER [ B | 4 | 8 | 5 ] 44-47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

1 0 The pump failure was caused by ball bearing failure. The pump was replaced and the
1 1 diesel generator was returned to service at 0100 on 10/21/82. The failure of the
1 2 ball bearing is attributed to normal wear. No additional corrective action is
1 3 planned.
1 4

1 5 FACILITY STATUS [ E ] 28 % POWER [ 0 | 9 | 5 ] 29 OTHER STATUS [ NA ] 30 METHOD OF DISCOVERY [ B ] 31 DISCOVERY DESCRIPTION [ Surveillance testing ] 32

1 6 ACTIVITY CONTENT RELEASED OF RELEASE [ Z ] 33 AMOUNT OF ACTIVITY [ NA ] 35 LOCATION OF RELEASE [ NA ] 36

1 7 PERSONNEL EXPOSURES NUMBER [ 0 | 0 | 0 ] 37 TYPE [ Z ] 38 DESCRIPTION [ NA ] 39

1 8 PERSONNEL INJURIES NUMBER [ 0 | 0 | 0 ] 40 DESCRIPTION [ NA ] 41

1 9 LOSS OF OR DAMAGE TO FACILITY TYPE [ Z ] 42 DESCRIPTION [ NA ] 43

2 0 PUBLICITY ISSUED DESCRIPTION [ N ] 44 [ NA ] 45