


Virginia Electric and Power Company

# Emergency Exercise

Surry Power Station  
1982 Exercise Manual



8211290405 821019  
PDR ADOCK 05000280  
F PDR

Virginia Electric and Power Company

EMERGENCY EXERCISE

SURRY POWER STATION

1982 EXERCISE MANUAL

MANUAL NO.

008

## INDEX

- 1.0 Scope
- 2.0 Objectives of the Exercise
- 3.0 Logistics and Participants
- 4.0 Summary of Events
- 5.0 Exercise Scenario
- 6.0 Narrative Summary
- 7.0 Evaluators and Controllers
- 8.0 Exercise Freeplay
- 9.0 Critique/Evaluations
- 10.0 Notes
  
- Appendix A Plant Parameters
- Appendix B Onsite In-Plant Doses Inside Buildings
- Appendix B-1 Onsite Plant Dose Outside Buildings
- Appendix C Onsite Out-of-Plant Doses
- Appendix D Offsite Doses
- Appendix E Controller Messages
- Appendix F Controller and Observer Duties and Responsibilities
- Appendix G Useful Information
- Appendix H Diagrams of Facilities
- Appendix I VOPEX 2-82

REFERENCES

1. Corporate Emergency Response Plan
2. Corporate Plan Implementing Procedures
3. Surry Power Station Emergency Plan
4. Surry Power Station Emergency Plan Implementing Procedures
5. Commonwealth of Virginia Radiological Emergency Response Plan
6. Radiological Emergency Response Plan for the counties of Surry, Isle of Wight, James City and York.
7. Radiological Emergency Response Plan for the cities of Newport News and Williamsburg.
8. NUREG-0654
9. NUREG-0696
9. Virginia Operations Plan Exercise 2-82 (VOPEX 2-82)

The Virginia Electric and Power Company intends to exercise the Emergency Plan and the Emergency Preparedness of the Surry Power Station (SPS) on November 10, 1982. The details of the exercise are summarized below.

#### 1.0 Scope

The scope of this exercise includes the initiation of emergency responses for three of the four categories of emergencies as outlined in NUREG 0654 (up to Site Emergency).

To the greatest extent possible, freeplay will be encouraged during the exercise. It should be recognized that control of the exercise may be re-initiated from time to time to ensure that the prime objectives are accomplished. Control will be provided by controllers and the issuance of exercise messages.

The Technical Support Center (TSC), Emergency Operations Facility (EOF), Operations Support Center (OSC) and Corporate Emergency Response Center (CERC) will be activated.

Pre-selected emergency response organizations (e.g., INPO, NRC, Westinghouse, etc.) will be called from the CERC, located in the VEPCO Corporate Office in Richmond, Virginia, to verify communications capability.

## 2.0 Objectives

The objectives of this exercise are to test and evaluate the emergency response capability of Vepco and coordination with offsite emergency response agencies as outlined below:

### 2.1 Notification and Communications

- 2.1.1 To test and evaluate the adequacy of the Surry Power Station notification procedures.
- 2.1.2 To test and evaluate the ability of key Surry Power Station response personnel to implement notification procedures including initial and follow-up communications, and coordination and updating of information.
- 2.1.3 To test and evaluate the ability of Surry Power Station emergency response personnel to accurately and efficiently assess an abnormal or accident situation and disseminate vital information to appropriate offsite agencies.
- 2.1.4 To test and evaluate the Vepco Emergency Communication Systems between Vepco emergency response facilities (Control Room, OSC, TSC, EOF, CERC); and between these facilities and outside agencies.
- 2.1.5 To test and evaluate communication capabilities between the Surry Power Station offsite and onsite radiation monitoring teams and the TSC.

### 2.2 Direction and Control

- 2.2.1 To test and evaluate the Surry Power Station response staff in their ability to determine the cause of an accident, terminate or limit radioactive releases, and bring the unit to a safe shutdown condition.
- 2.2.2 To test and evaluate the adequacy of the Surry Power Station Emergency Plan Implementing Procedures in terms of management control of an emergency situation, dose assessment, health physics monitoring onsite and offsite.

- 2.2.3 To test and evaluate the adequacy of procedures for personnel accountability, site evacuation, and damage control.
- 2.2.4 To test and evaluate the adequacy of emergency medical response and transportation of a contaminated injured personnel.

3.0 Logistics

3.1 Date: November 10, 1982 - Wednesday

3.2 Time: 0930 to 1630 Exercise  
1700 to 2000 Critique

3.3 Location: Virginia Electric and Power Company  
Surry Power Station  
Route 650 Off of Route 10  
Surry County  
Surry, VA 23883  
See Map-Figure 3-1

3.4 Facilities: SPS Control Room (CR)  
Technical Support Center (TSC)  
Emergency Operations Facility (EOF)  
Operational Support Center (OSC)  
Corporate Emergency Response Center (CERC)  
Public News Center (PNC)

3.5 Participating Organizations: (see Attachment for Telephone Numbers)

3.5.1 Virginia Electric and Power Company

3.5.2 Commonwealth of Virginia

3.5.3 Local Agencies:

A. Surry County, Virginia

B. James City County, Virginia

C. Isle of Wight County, Virginia

D. City of Newport News, Virginia

E. York County, Virginia

F. City of Williamsburg, Virginia

3.5.4 Medical Support:

A. Medical College of Virginia (MCV)  
Richmond, Virginia

3.5.5 Federal Government Agencies

A. Federal Emergency Management Agency (FEMA)

B. Nuclear Regulatory Commission (NRC)



ATTACHMENT

LIST OF PARTICIPANTS

Telephone Numbers

The following organizations, agencies, and political subdivisions will participate in the Surry Power Station Emergency Exercise:

A. Virginia Electric and Power Company (VEPCO)

1. Corporate Headquarters (804) 771-3000
2. Surry Power Station (SPS) (804) 357-3184
3. Surry Power Station News Media Center (804) 294-5140

B. State Agencies, Commonwealth of Virginia

1. Agriculture and Consumer Services, Department of (804) 786-3544
2. Air Pollution Control Board, State (804) 786-7913
3. Consolidated and Laboratory Services, Division of (804) 786-5485
4. Conservation and Economic Development, Department of (Parks Division) (804) 786-2121
5. Corrections, Department of (804) 257-0167/1989
6. Emergency and Energy Services, Office of (804) 323-2300
7. Game and Inland Fisheries, Commission of (804) 257-1381
8. Health, Department of (804) 323-2300 (State EOC)
9. Highways and Transportation, Department of (804) 786-2817
10. Mental Health and Mental Retardation, Department of (804) 786-4005
11. Military Affairs, Department of (804) 786-2504/2416
12. State Police, Department of (804) 323-2014
13. Water Control Board, State (804) 257-0080
14. Welfare, Department of (804) 281-9209
15. Marine Resources Commission (804) 245-2811


C. Local Governments

1. Surry County (804) 294-3156 or 3182
2. Isle of Wight (804) 357-3191 x217
3. York County (804) 898-0180
4. James City County (804) 220-0242
5. City of Newport News (804) 247-8606
6. City of Williamsburg (804) 229-4821
7. City of Hampton (804) 727-6414
8. City of Poquoson (804) 868-7151
9. New Kent County (804) 730-9550
10. Charles City County (804) 829-2401 or 2466

D. Institutions - within ten miles of the Surry Power Station

E. Nuclear Regulatory Commission (NRC)

F. Federal Emergency Management Agency (FEMA)



**JOHN F. KENNEDY MEM. HT.**

**MARYLAND**  
 Total District 40 Miles  
 Passenger Car Ton 1500  
 1. Baltimore-Baltimore Mt. 10  
 2. Washington-Baltimore Mt. 10  
 3. Annapolis-Baltimore Mt. 10  
 4. Frederick-Baltimore Mt. 10  
 5. Baltimore-Washington 10  
 6. Baltimore-Annapolis 10  
 7. Baltimore-Frederick 10  
 8. Baltimore-Farmersville 10  
 9. Baltimore-Crofton 10  
 10. Baltimore-Elkton 10

**DELAWARE**  
 Total District 11 Miles  
 Passenger Car Ton 500  
 1. Newark-Del. Mt. 10  
 2. Newark-Del. Mt. 10  
 3. Newark-Del. Mt. 10  
 4. Newark-Del. Mt. 10  
 5. Newark-Del. Mt. 10

North Mile Type Size  
 Fredericksburg Indicate Where  
 New Martinsville 0000000000

**WEST CHESTER**  
**PETERSBURG**  
**ALEXANDRIA**  
**ARLINGTON**

**RICHMOND-PETERSBURG TURNPIKE**  
 Total District 11 Miles-Passenger Car Ton 500

1. U.S. 301	14. Delaware Express
2. U.S. 301 & U.S. 301 East	15. U.S. 301
3. U.S. 301 & U.S. 301 West	16. U.S. 301
4. U.S. 301	17. U.S. 301
5. U.S. 301	18. U.S. 301
6. U.S. 301	19. U.S. 301
7. U.S. 301	20. U.S. 301
8. U.S. 301	21. U.S. 301
9. U.S. 301	22. U.S. 301
10. U.S. 301	23. U.S. 301
11. U.S. 301	24. U.S. 301
12. U.S. 301	25. U.S. 301
13. U.S. 301	26. U.S. 301

#### 4.0 Summary of Events

All major events listed below will be executed unless otherwise noted.

- 4.1 Declaration of Emergency or Emergencies
- 4.2 Notification of Offsite Agencies
- 4.3 Emergency Announcements
- 4.4 Activation of Emergency Response Facilities
  - A. TSC - Technical Support Center
  - B. EOF - Emergency Operations Facility
  - C. OSC - Operational Support Center
  - D. CERC - Corporate Emergency Response Center
  - E. PNC - Public News Center
- 4.5 Activation of Health Physics Onsite and Offsite Monitoring Teams.
- 4.6 Site Evacuation and Accountability of Personnel (limited number of personnel).
- 4.7 Emergency Medical Assistance of Simulated Contaminated Injured Person.
  - A. First Aid and Decontamination
  - B. Transport to Medical care facility
  - C. Treatment at Medical care facility
- 4.8 Activation of the Damage Control Team.

## 5.0 Exercise Scenario

### 5.1 Initial Conditions

Unit 2 is operating at 100% power (MOL; Boron Concentration: 500 ppm). All safety systems are operable. Pressurizer PORV's and main steam PORV's are isolated. Unit 1 is in the last day of a 7 day outage for overhauling of the charging pumps and snubber inspection. SW Transformer 1 (15G1) is out for maintenance. S/G "A & B" are aligned to BD Monitor "A". S/G "C" is aligned to BD Monitor "B".

The sky is overcast. Stability class is D. Winds are 15 mph from East-Northeast (60° to 65°). The 32 ft temperature is 80°F. A tropical storm off the coast of North and South Carolina has developed into a hurricane overnight and is headed in the North - Northeast direction.

### 5.2 Time Vs Events

<u>Time</u>	<u>Event</u>
9:30 A.M.	Exercise commences
9:40 A.M.	System Operator notifies Surry Power Station that a Hurricane Watch as been declared for Eastern and Southeastern Virginia, including Surry County.  <u>An Unusual Event is declared</u>
10:00 A.M.	Increased levels of air ejector and S/G blowdown activities are detected.
10:05 A.M.	Operations determines that increased blowdown activity is from S/G "C".  RCS Leak Rate Periodic Test is initiated. RCS and S/G samples and analyses are requested.

10:15 A.M. Chemistry Technician returning from the sample room trips and falls. His left forearm and hand are cut. He is doused with radioactive samples and his wounds are contaminated. The accident also causes a heart attack. The victim remains conscious but is incapacitated by the chest pain.

10:20 A.M. The Auxiliary Building Operator walks by and notices the victim on the floor. The Shift Supervisor and the First-Aid Team are notified.

10:30 A.M. Shift Supervisor is notified of the need to transport contaminated victim to MCV.

10:40 A.M. The on-site ambulance departs Surry Power Station.

A second Unusual Event is reported

11:00 A.M. The RCS Leak Rate Test indicated an unidentified RCS leakage of 0.2 gpm. Chemical analyses of RCS and S/G samples confirm a primary to secondary leakage of 0.1 gpm for S/G "C" and negligible leakage from "A & B" S/G's.

11:10 A.M. High winds are being experienced as a result of the close proximity of the hurricane. Met Tower data indicate wind gusts are up to 60 mph.

11:15 A.M. Air ejector and blowdown monitor "B" are maintaining a high but steady level due to S/G "C" leakage.

11:30 A.M. Instrument power fuse for NI-41 power range monitor is blown causing a negative rate-of-change signal to initiate turbine runback, resulting in a load rejection of 30%.

Reactor does not trip as the Rod Control System and Steam Dump to Condenser operate properly to gradually restore RCS pressure and temperature to normal levels.

11:40 A.M. Vibration monitors on RCP C alarm and indicate very high vibrations. RCP C trips on motor overcurrent. Reactor trips, followed by the turbine and generator.

11:41 A.M. Letdown radiation monitors alarm and reach a high reading of  $2 \times 10^4$  cpm before readings decay to a steady  $5 \times 10^3$  cpm.

11:45 A.M. Plant stabilizes as control systems act to restore RCS pressure and temperature, pressurizer and S/G levels at their no-load (zero power) levels.

11:50 A.M. 34.5KV Bus 5 experiences a faulted condition when high winds blow the sheet metal top off Fire Hose Station Building #18 onto the bus disconnect. Power to 4160 Station Service Buses A, B, 2H Emergency and 2G bus is lost. #2 Diesel Generator starts. All emergency buses are energized. Auxiliary FW system starts and operates properly.

12:00 P.M. AP-39, Natural Circulation of Primary Coolant is implemented due to the loss of all RCP's. Steam dump is switched to the MS PORV's due to the loss of condenser vacuum as a result of the loss of circulating water pumps.

12:10 P.M. Core exit Thermocouples (T/C's) indicate the existence of hot spots near core locations K5 and L6. Subcooling monitors show a 25°F superheat condition for the hot spot region.

Let down monitors read 10<sup>4</sup> Cpm. RCS sample and analysis are requested.

12:20 P.M. Letdown radiation monitor reading steadily increasing. High level alarms are sounded at 10<sup>5</sup> cpm.

12:25 P.M. T/C readings for core locations K5 and L6 indicate 1000°F. Remaining T/C readings average about 585°.

12:30 P.M. RCS sample and analysis indicate fuel cladding damage. RCS specific activity is 260 Micro Ci/gm I-131 dose equivalent.

An Alert is declared.

12:35 P.M. PORV on MS Line C and FW to S/G "C" are isolated to reduce the radiological release. PORV's for MS Lines A & B continue to operate to remove decay heat.

12:45 P.M. RCS wide range T-Hot and core exit T/C readings indicate adequate natural circulation for all outer core regions. Only fuel assemblies at core locations K5 and L6 are experiencing inadequate cooling. Natural circulation cooling is estimated at about 15°F per hour.



1:30 P.M. Motor drive Aux. Feedwater Pump  
3A stops as motor bearing seizes.

2:45 P.M. A primary to secondary tube leak  
occurs in S/G "B".

Winds are now 7 mph, from ENE  
(68°).  $\Delta T$  is  $-1.05^\circ$  (Class C).

2:50 P.M. MS line B Hi Range Radiation  
Monitor indicates  $2 \times 10^{-1}$   
MR/hr. Attempts to close PORV  
on Line B fail as PORV will not  
close on controller demand  
signal.

A Site Emergency is declared

3:00 P.M. Handwheel on PORV isolation  
valve is broken off the valve  
stem when attempt is made to  
close the manual isolation  
valve. Steam continues to  
"weep" from the valve. Venting  
instrument air at PORV actuator  
does not close the PORV.

3:15 P.M. Maintenance crew reports that  
the spring on the PORV actuator  
is broken, causing the valve to  
stay partially open.

3:50 P.M. Isolation valve to PORV is shut  
by applying wrench to valve stem.

Release is Terminated

3:55 P.M. Decay heat is being removed only  
through the PORV for MS Line A.  
Core exit T/C's continue to show  
inadequate cooling for fuel  
assemblies near core locations  
K5 and L6.

4:00 P.M. Suffolk repair crew has repaired  
Bus 5. Station Service Buses A,  
B and Bus 2G are restored.

4:05 P.M. RCP A is started to initiate  
forced circulation cooling.

4:15 P.M. Core locations K5 and L6 are being cooled by forced circulation cooling as evidenced by decreasing T/C readings.

4:25 P.M. All T/C and RCS temperature indications show adequate core cooling. (T-Hot = 465°F, Avg T/C = 475°)

4:45 P.M. (Time compression) It is now 7:00 P.M. All reporting onsite and offsite radiological monitoring data are indicating background readings.

5:00 P.M. Exercise Terminated

5.2 Plant Parameters vs. Time: See Appendix A.

5.3 Radiation Levels vs Time

5.3.1 In-plant radiation levels vs. time: See Appendix B.

5.3.2 On-site (out of plant) radiation levels vs. time: See Appendix C.

5.3.3 Offsite radiation levels vs. time: See Appendix D

5.4 Controller messages: See Appendix E.

## 6.0 NARRATIVE SUMMARY

The scenario begins with a hurricane watch being declared for Southeastern Virginia, including Surry County. An Unusual Event is declared. A chemistry technician is injured and contaminated in an accident when returning from the sample room. The transport of the contaminated, injured victim to the Medical College of Virginia causes the declaration of a second Unusual Event.

A loose part in the RCS causes a part of RCP C impeller to break off. Intense vibration of RCP C causes the pump to trip, resulting in reactor, turbine, and generator trips. Post-trip cooldown proceeds normally until 34.5 KV Bus 5 is lost. This results in the loss of RCP's A & B as well as condenser vacuum. RCS cooldown continues by natural circulation and the operation of the main steam atmospheric PORV's.

Loose parts and debris in RCS cause the partial blockage of flow channels for core locations K5 and L6. Natural circulation is insufficient to cool the affected assemblies and fuel cladding failure occurs. An Alert is declared when RCS activity attains 260 Micro Ci/gm I-131 dose equivalent.

A 10 gpm primary to secondary leakage develops for S/G "B", thus providing a release path to the environs. A Site Emergency is declared when Hi Rang Radiation Monitor on MS Line B exceeds  $7.5 \times 10^{-2}$  MR/hr. MS Line B cannot be isolated due to failure of the PORV and the manual isolation valve. Offsite radiation monitoring teams are dispatched because of the release to the environment. A site evacuation is also ordered based on a projected release period of 1-1/2 hours. The PORV is isolated one hour later, thus terminating the release. Upon restoration of Bus 5, forced circulation is initiated and provides adequate cooling to the affected assemblies.

7.0 EVALUATORS/CONTROLLERS

7.1 Controllers

Medical Emergency (1)  
Remote Assembly Area (1)  
Control Room (1)  
TSC and Dose Assessment (2)  
OSC (1)  
EOF and Dose Assessment (2)  
Offsite Monitoring Areas (2)  
HP/Chemistry/floater (1)  
Security/floater (1)

7.2 Evaluators

Control Room (1)  
Medical Emergency (1 + Corp.)  
HP/Count Room (1)  
HP/Chemistry (1)  
TSC (1)  
OSC (1)  
EOF (1)  
Offsite Monitoring Area (1)  
Security (1)  
Remote Assembly Area (1)  
Public News Center (1 + Corp.)

(Designation of Controllers/Evaluators will be made at a later date)

## 8.0 EXERCISE FREEPLAY ITEMS AND SIMULATIONS

The following list of freeplay items and simulations represent a conclusive listing of all nonscheduled events that may be inserted during the course of the exercise. All or none of the items may be utilized, depending on exercise progress and timing. An item may be inserted by the controller associated with the activity effected only with the express direction or concurrence of the Lead Controller.

### 8.1 Freeplay Items

<u>Item</u>	<u>Approximate Time</u>
One manager not present (accident/auto failure/vacation)	9:30 a.m. - 1:00 p.m.
One telephone or radio line disabled	9:30 a.m. or 1:00 p.m.
Automobile accident blocking plant access route	10:30 a.m. or 3:00 p.m.
Loss of plant parameter indicator	9:30 a.m. - 4:50 p.m.
Personnel overexposure/contamination	12:30 p.m. - 4:00 p.m.
Personnel injury onsite	1:30 p.m. - 4:00 p.m.
Unaccounted personnel	2:50 p.m.
Spontaneous evacuation of general population near the site	1:00 p.m. - 3:30 p.m.

### 8.2 Simulations

Simulate evacuating personnel, taking their personal dosimetry with them to their Remote Assembly Area.

Simulate partial monitoring of the personnel and vehicles at the Remote Assembly Area. (e.g., Survey as normal the first 10 to 20 vehicles and personnel at the Remote Assembly Area, but not all the vehicles and personnel).

Simulate a request for additional field monitoring personnel and vehicles from North Anna Power Station.

Simulate recall of as many employees on vacation as possible.

Simulate a request for food and bedding supplies for station personnel.

Simulate the following calls for technical assistance if necessary:

- Westinghouse
- INPO
- Stone and Webster

Simulate after a discussion, the relief of Key Emergency Personnel.

Simulate Suffolk repair crew working in the Switch Yard.

## 9.0 CRITIQUE/EVALUATIONS

A series of critiques will take place after the completion of the Surry Emergency Exercise, Wednesday, November 10, 1982. The initial critiques will be held immediately following the exercise. Vepco participants will assemble in the TRAINING COMPLEX AUDITORIUM, Surry Power Station, upon completion of the Recovery Phase of the exercise. Concurrently with this critique it is normal practice for the NRC to hold a separate critique of their observers. At a mutually agreeable time NRC Representatives and Vepco Representatives will conduct a joint meeting to present the findings of the preceding critiques.

The internal Vepco critique that follows the termination of the exercise should last approximately 30 to 60 minutes. Controllers and observers should present their comments. Key participants in the exercise shall attend this critique. The start of the critique will be delayed until representatives from the Corporate Emergency Response Center arrive. These representatives may leave the CERC before the completion of the Recovery Phase to avoid delaying the start of the station critique.

The initial station critique is intended to highlight exercise problem areas and/or identify those aspects of emergency planning that could be improved or changed to facilitate smoother operations. It is intended that this critique be an open discussion among Vepco participants in the exercise. It is possible that misunderstandings or erroneous observations can be resolved at this time.

In the joint meeting with the NRC and Vepco that follows the initial critiques it is normal practice for the utility to appoint a principal spokesman to present the findings of the critique. The utility normally makes its presentation first. The NRC Representatives will then present their findings. At this time it is also possible to resolve misunderstandings or misconceptions.

A tentative critique schedule of the Emergency Exercise to be held on November 10, 1982, is as follows:

- 1530 - CERC Representatives depart for Surry
- 1700 - Exercise Terminated
- 1730 - Vepco Critique
- 1800 - NRC Critique
- 1830 - Vepco List of Critique Findings Resolved
- 1900 - Joint NRC/Vepco Meeting and NRC Exit Interview

There is no planned formal Commonwealth of Virginia/FEMA Critique scheduled.

## 10. Notes

### 10.1 Controllers

Controllers, as designated in Section 7.1 are the only personnel who are authorized to provide input to the exercise response personnel. Controllers shall wear red arm bands and shall be responsible for all inputs (i.e. data, initiate scenario events, etc.) in their assigned area. Controllers are responsible for the successful conduct of this exercise scenario as scheduled. Any simulation required to assure the objectives of this exercise are met shall be the responsibility of the affected controller. The Controller shall not, however prompt an exercise participant unless required to meet the scenario schedule, in which case the participant shall be considered to have unsatisfactorily responded. Use of "Freeplay" additional simulations shall be conducted only after agreement on the item is reached between the lead controller and the controller(s) of the affected areas.

### 10.2 Evaluators

Evaluators, as designated in Section 7.2, shall wear orange armbands and shall not participate in any way in the exercise. Their function is limited to evaluating the exercise as objective critics, and documenting any deficiencies noted for evaluation and correction following the exercise. Evaluators may ask questions of participants to clarify actions taken, but should not interfere with the flow of events.

### 10.3 Participants

Exercise response personnel shall not wear any armbands and shall respond to exercise input data as provided by the controllers.

### 10.4 Exempts

Any station personnel whose position at the time of the exercise requires their attention to actual plant conditions to assure safe operation shall wear green armbands and shall be exempted from response to the simulated conditions of the exercise.

### 10.5 Observers

Observers are personnel who serve no evaluation, control or participatory function in the exercise. Visitors from NRC, offsite agencies, other utilities, etc. shall not interfere with Evaluators or Participants. Questions from observers should be directed to a controller.



APPENDIX A

Plant Parameters

MS Hi Range RMS Readings (MR/hr)

<u>Time</u>	<u>Line C</u>	<u>Line B</u>
10:00-10:29	Not on Scale	Not on Scale
10:30-10:59		
11:00-11:29		
11:30-11:59		
12:00-12:29		
12:30-12:59		
1:00- 1:29		
1:30- 1:59		
2:00- 2:29		
2:30- 2:59		
3:00- 3:29		
3:30- 3:50		
3:50- 5:44		

Not on Scale

Not on Scale

$2.0 \times 10^{-1}$


$2.0 \times 10^{-1}$

$2.0 \times 10^{-1}$


BKND

after initiation of natural  
 circ cooling, graph applies  
 only to 1st loop(s), i.e. S/4(B)  
 used for cooling


Natural circ cooling  
 established with  
 $\Delta T = 32^\circ$ , RCS flow = 3%  
 ~1.8% being heat




REV	BY	DATE	CHECKED	DATE	eds nuclear	JOB NO	PAGE
						CALC NO	OF




HEV	BY	DATE	CHECKED	DATE	eds nuclear	JOB NO	PAGE
						CALC NO	



REV	BY	DATE	CHECKED	DATE	eds nuclear	JOB NO	PAGE
						CALC NO	OF



					eds nuclear		JOB NO	PAGE
							CALC NO	OF
REV	BY	DATE	CHECKED	DATE				




REF	BY	DATE	CHECKED	DATE	eds nuclear	JOB NO	PAGE
						CALC NO	OF

REV	BY	DATE	CHECKED	DATE


eds nuclear

JOB NO  
CALC NO


PAGE  
OF








					eds nuclear		JOB NO	PAGE
							CALC NO	OF
REV	BY	DATE	CHECKED	DATE				



					JOB NO		PAGE
					CALC NO		OF
REV	BY	DATE	CHECKED	DATE	eds nuclear		

Based on fixed flow rate and  
assuming no make up



JCN  
-TR-1A  
CST  
Level  
(%)


REV	BY	DATE	CHECKED	DATE	eds nuclear	JOB NO	PAGE
						CALC NO	OF

CONDENSER AIR EJECTOR SAMPLING RESULTS

H.P. MONITORING:

@ 12:45: DOSE RATE OF GAS SAMPLE @ 1ft = 0.06 mR/hr

ALL TIMES: DOSE RATE FOR IODINE CARTRIDGE = 0.02 mR/hr



10<sup>-2</sup>

BLOWDOWN SAMPLING: S/G B ~ uCi/cc

H.P. MONITORING

ALL TIMES: JOSE RATE OF  
COLLECTED SAMPLE @ 1 FT IS  
< 0.01 uR/hr

10<sup>-3</sup>

uCi/cc

10<sup>-4</sup>

10<sup>-5</sup>

10<sup>-6</sup>

10<sup>-7</sup>


I-131

G-137

Co-60

Co-57


9:00 10:00 11:00 12:00 1:00 2:00 3:00 4:00 5:00  
TIME



BLOWDOWN SAMPLING: S/G C. ~  $\mu\text{Ci/cc}$

HP MONITORING:

ALL TIMES: DOSE RATE OF COLLECTED SAMPLE @ 1 FT.  
IS  $< 0.01 \text{ MR/hr}$



NUCLEAR INSTRUMENTATION

WIND

SPEED 15 MPH  
 DIRECT. 4.0 65°  
 TEMP. 80 °F  
 Δ T -0.5 °F  
 0 θ 10 °

PLANT DATA SHEET

Date 1/10/82 Time 3:30 a

POWER RANGE 100 % 100 % 100 % 100 %  
 INTR. RANGE 10 AMPS 10 AMPS  
 SOURCE RANGE NA CPS NA CPS

*Int. C Conditions*

PRIMARY SYSTEM | RCS Pressure 2210 psig RCP's Oper. (A/B/C)  
 | RCS Flow loop A 100 % B 100 % C 100 %  
 T-Hot/T-Cold Loop A 604/550 °F B 604/550 °F C 604/550 °F  
 Pressurizer (Liq/Gas) 653/453 °F Level 58 % Press. 2200 psig  
 PRT Temp. 80 °F Level 10 % Press 3 psig  
 Safety Valves Open/Closed  
 PROV's Open/Closed  
 Other \_\_\_\_\_

Containment |  
 Pressure 8.9 psia CS Pump  
 Temperature 100 °F Pres.  
 Sump Level 5 % A 0  
 Sump Temp 98 °F B 0

SECONDARY COOLANT SYSTEM | S/G Levels A 44 % B 43 % C 44 %  
 S/G Pressure A 820 psig B 820 psig C 820 psig  
 S/G Flow A 2546 lb/hr B 2546 lb/hr C 2546 lb/hr  
 S/G Feed A 2546 lb/hr B 2546 lb/hr C 2546 lb/hr  
 Aux. Feed Pump 3A AVL 3B AVL 2 AVL  
 APW Flow S/G A 0 GPM B 0 GPM C 0 GPM

Core Cooling |  
 Core Thermocouples  
 Avg 609 °F  
 Peak 615 °F Location H8

Subcooling Monitors (with selector switch in 7/c)  
 A 485 psi to Sat / - °F Superheat  
 B 485 psi to Sat / - °F Superheat

ENGINEERED SAFEGUARDS

COLD/HOT LEG SI A 0 GPM B 0 GPM C 0 GPM  
 LHSI Flow A 0 GPM B 0 GPM  
 Accumulator Level A 57 % B 57 % C 57 %  
 IRS A AVL B AVL  
 ORS A AVL B AVL

RMS |  
 S/G BD Monitor A/B 100/100 cpm  
 Condenser Air Ejector 50 cpm  
 Process Vent (gas) 100 cpm  
 Process Vent (part) 10 cpm  
 Vent Vent (gas) 70 cpm  
 Vent Vent (part) 70 cpm  
 Letdown (high/low) 10<sup>3</sup>/10<sup>3</sup> cpm

Emergency Diesel Generators (EDG) 1 OP AVL  OOC ---  
 2 OP AVL  OOC ---  
 3 OP AVL  OOC ---

Cont/Manipulator 10/50 mr/hr  
 Aux Bldg-Control Area 1 mr/hr  
 Aux Bldg-Drumming 1 mr/hr  
 Sample Room 1 mr/hr  
 New Fuel 1 mr/hr  
 Spent Fuel Pit 2 mr/hr  
 Control Room 41 mr/hr

AUXILIARY SYSTEMS

RWST Level 100 %  
 CST Level 100 %  
 Charging Flow 56 GPM  
 Letdown Flow 110 GPM  
 VCT Level 55 %  
 BAST A 50 %  
 BAST B 70 %  
 BAST C 75 %  
 CCW: Supply HDR (A/B) 6000 GPM  
 Return HDR (A/B) 70 °F

Other:

NUCLEAR INSTRUMENTATION

POWER RANGE 10V % AVL % 10V % 10V %  
INTR. RANGE 10 % AMPS 10 % AMPS  
SOURCE RANGE NA CPS NA CPS

WIND |  
SPEED 20 MPH  
DIRECT. from 68 °F  
TEMP. 79 °F  
Δ T -0.5 °F  
0 0 10 °

PLANT DATA SHEET SURRY UNIT 2  
Date 11/10/87 Time 10:57 a

PRIMARY SYSTEM | RCS Pressure 2212 psig RCP's Oper. (A/B/C)  
RCS Flow loop A 10V % B 10V % C 10V %

T-Hot/T-Cold Loop A 604/350 °F B 604/350 °F C 604/350 °F  
Pressurizer (Liq/Gas) 633/653 °F Level 58 % Press. 2200 psig  
PRT Temp. 80 °F Level 10 % Press 3 psig  
Safety Valves Open/Closed  
PROV's Open/Closed  
Other \_\_\_\_\_

Containment |  
Pressure 8.9 psia CS Pump  
Temperature 105 °F Pres.  
Sump Level 5 % A 0  
Sump Temp 98 °F B 0

Core Cooling |  
Core Thermocouples  
Avg 609 °F  
Peak 615 °F Location H8

SECONDARY COOLANT SYSTEM | S/G Levels A 44 % B 44 % C 43 %  
S/G Pressure A 920 psig B 920 psig C 920 psig  
S/G Flow A 3566 lb/hr B 3566 lb/hr C 3566 lb/hr  
S/G Feed A 3566 lb/hr B 3566 lb/hr C 3566 lb/hr  
Aux. Feed Pump 3A AVL 3B AVL 2 AVL  
AFW Flow S/G A 0 GPM B 0 GPM C 0 GPM

Subcooling Monitors (with switch on T/C)  
A 45 psi to Sat/ - °F Superheat  
B 45 psi to Sat/ - °F Superheat

RMS

S/G BD Monitor A/B 100/1000 cpm  
Condenser Air Ejector 500 cpm  
Process Vent (gas) 100 cpm  
Process Vent (part) 10 cpm  
Vent Vent (gas) 10 cpm  
Vent Vent (part) 10 cpm  
Letdown (high/low) 10/100 cpm

Cont/Manipulator 10/50 mr/hr  
Aux Bldg-Control Area 1 mr/hr  
Aux Bldg-Drumming 1 mr/hr  
Sample Room 1 mr/hr  
New Fuel 1 mr/hr  
Spent Fuel Pit 2 mr/hr  
Control Room 21 mr/hr

Other:

ENGINEERED SAFEGUARDS

COLD/HOT LEG SI A 0 GPM B 0 GPM C 0 GPM  
LHSI Flow A 0 GPM B 0 GPM  
Accumulator Level A 57 % B 57 % C 57 %  
IRS A AVL B AVL  
ORS A AVL B AVL

Emergency Diesel Generators (EDG) 1 OP AVL  OOC ---  
2 OP AVL  OOC ---  
3 OP AVL  OOC ---

AUXILIARY SYSTEMS

RWST Level 10V %  
CST Level AVL %  
Charging Flow 36 GPM  
Letdown Flow 111 GPM  
VCT Level 35 %

BAST A 20 %  
BAST B 20 %  
BAST C 15 %  
CCW: Supply HDR (A/B) 6000 GPM  
Return HDR (A/B) 11 °F



NUCLEAR INSTRUMENTATION

POWER RANGE 100 % 100 % 100 % 100 %  
 INTR. RANGE 10 AMPS 10 AMPS  
 SOURCE RANGE NA CPS NA CPS

WIND

SPEED 30 MPH  
 DIRECT 75 °  
 TEMP. 77 °F  
 Δ T -1.0 °F  
 θ 13 °

PLANT DATA SHEET

SURRY UNIT 2

Date 11/10/92

Time 10:30 a

PRIMARY SYSTEM

RCS Pressure 2210 psig RCP's Oper. A/B/C/D  
 RCS Flow loop A 150 % B 100 % C 100 %

T-Hot/T-Cold Loop A 604/550 °F B 604/550 °F C 604/550 °F  
 Pressurizer (Liq/Gas) 653/653 °F Level 58 % Press. 2200 psig  
 PRT Temp. 80 °F Level 10 % Press 3 psig  
 Safety Valves Open/Closed  
 PROV's Open/Closed  
 Other \_\_\_\_\_

Containment

Pressure 2.9 psia CS Pump  
 Temperature 100 °F Pres.  
 Sump Level 5 % A 0  
 Sump Temp 93 °F B 0

SECONDARY COOLANT SYSTEM

S/G Levels A 94 % B 94 % C 94 %  
 S/G Pressure A 920 psig B 920 psig C 920 psig  
 S/G Flow A 3556 lb/hr B 3556 lb/hr C 3556 lb/hr  
 S/G Feed A 3556 lb/hr B 3556 lb/hr C 3556 lb/hr  
 Aux. Feed Pump 3A AVL 3B AVL 2 AVL  
 AFW Flow S/G A 0 GPM B 0 GPM C 0 GPM

Core Cooling

Core Thermocouples  
 Avg 69 °F  
 Peak 65 °F Location H8

Subcooling Monitors

A 1 psi to Sat / - °F Superheat  
 B 1 psi to Sat / - °F Superheat

ENGINEERED SAFEGUARDS

COLD/HOT LEG SI A 0 GPM B 0 GPM C 0 GPM  
 LHSI Flow A 0 GPM B 0 GPM  
 Accumulator Level A 57 % B 57 % C 57 %  
 IRS A AVL B AVL  
 ORS A AVL B AVL

Emergency Diesel Generators (EDG) 1 OP AVL ✓ OOC -  
 2 OP AVL ✓ OOC -  
 3 OP AVL ✓ OOC -

AUXILIARY SYSTEMS

RWST Level 100 %  
 CST Level 100 %  
 Charging Flow 35 GPM  
 Letdown Flow 110 GPM  
 VCT Level 39 %

BAST A 96 %  
 BAST B 100 %  
 BAST C 100 %  
 CCW: Supply HDR A/B 6000 GPM  
 Return HDR (A/B) 11 °F  
 Discharge

RMS

S/G BD Monitor A/B 100/120 cpm  
 Condenser Air Ejector 50 cpm  
 Process Vent (gas) 100 cpm  
 Process Vent (part) 90 cpm  
 Vent Vent (gas) 70 cpm  
 Vent Vent (part) 70 cpm  
 Letdown (high/low) 10/10 cpm

Cont/Manipulator 10/30 mr/hr  
 Aux Bldg-Control Area 1 mr/hr  
 Aux Bldg-Drumming 1 mr/hr  
 Sample Room 1 mr/hr  
 New Fuel 1 mr/hr  
 Spent Fuel Pit 2 mr/hr  
 Control Room <1 mr/hr

Other:

NUCLEAR INSTRUMENTATION

POWER RANGE Low % Low % Low % Low %  
INTR. RANGE 10 AMPS 10 AMPS  
SOURCE RANGE NA CPS NA CPS

WIND SPEED 38 MPH  
DIRECT. 77 °  
TEMP. 76 °F  
Δ T -1.1 °F  
θ 13 °

PLANT DATA SHEET SURRY UNIT 2  
Date 11/10/92 Time 11:01a

PRIMARY SYSTEM RCS Pressure 2210 psig RCP's Oper. AVBXO  
RCS Flow loop A AV % B AV % C AV %  
T-Hot/T-Cold Loop A 604/550 °F B 604/550 °F C 604/550 °F  
Pressurizer (Liq/Gas) 653/653 °F Level 58 % Press. 2200 psig  
Pri Temp. 80 °F Level 10 % Press 3 psig  
Safety Valves Open/Closed  
PROV's Open/Closed  
Other

Containment Pressure 8.9 psia CS Pump  
Temperature 100 °F Pres.  
Sump Level 5 % A 0  
Sump Temp 98 °F B 0

SECONDARY COOLANT SYSTEM S/G Levels A 04 % B 04 % C 04 %  
S/G Pressure A 820 psig B 820 psig C 820 psig  
S/G Flow A 3556 lb/hr B 3556 lb/hr C 3556 lb/hr  
S/G Feed A 3556 lb/hr B 3556 lb/hr C 3556 lb/hr  
Aux. Feed Pump 3A AVL 3B AVL 2 AVL  
APW Flow S/G A 0 GPM B 0 GPM C 0 GPM

Core Cooling Core Thermocouples  
Avg 609 °F  
Peak 615 °F Location A18

Subcooling Monitors  
A 70 psi to Sat / — °F Superheat  
B 70 psi to Sat / — °F Superheat

ENGINEERED SAFEGUARDS

COLD/HOT LEG SI A 0 GPM B 0 GPM C 0 GPM  
LHSI Flow A 0 GPM B 0 GPM  
Accumulator Level A 57 % B 57 % C 57 %  
IRS A AVL B AVL  
ORS A AVL B AVL

Emergency Diesel Generators (EDG) 1 OP — AVL  OOC —  
2 OP — AVL  OOC —  
3 OP — AVL  OOC —

S/G BD Monitor A/B 100/120 cpm  
Condenser Air Ejector 650 cpm  
Process Vent (gas) 100 cpm  
Process Vent (part) 20 cpm  
Vent Vent (gas) 20 cpm  
Vent Vent (part) 20 cpm  
Letdown (high/low) 10<sup>3</sup>/10<sup>3</sup> cpm

Cont/Manipulator 10/50 mr/hr  
Aux Bldg-Control Area 1 mr/hr  
Aux Bldg-Drumming 1 mr/hr  
Sample Room 1 mr/hr  
New Fuel 1 mr/hr  
Spent Fuel Pit 2 mr/hr  
Control Room 41 mr/hr

Other:

AUXILIARY SYSTEMS

RWST Level AV % Charging Flow 96 GPM  
CST Level AV % Letdown Flow 110 GPM  
VCT Level 39 %  
BAST A 80 % CCW: Supply HDR A/B 6000 GPM  
BAST B 2 % Return HDR A/B 11 °F  
BAST C 15 % Drainage

NUCLEAR INSTRUMENTATION

POWER RANGE 0 % 80 % 82 % 83 %  
 INTR. RANGE 10 AMPS 10 AMPS  
 SOURCE RANGE NA CPS NA CPS

WIND

SPEED 39 MPH  
 DIRECT. 15 °  
 TEMP. 76 °F  
 Δ T 1.1 °F  
 σ θ 13 °

PLANT DATA SHEET

SURRY UNIT 2

Date 4/10/02

Time 11:30:10

*113-41 back to turbine number  
 @ control room to 704 pit*

PRIMARY SYSTEM | RCS Pressure 2275 psig RCP's Oper. A/B/C  
 | RCS Flow loop A 100 % B 100 % C 100 %

T-Hot/T-Cold Loop A 613/555 °F B 614/558 °F C 651/560 °F  
 Pressurizer (Liq/Gas) 645/645 °F Level 63 % Press. 2265 psig  
 PRT Temp. 80 °F Level 10 % Press 3 psig  
 Safety Valves Open/Closed  
 PROV's Open/Closed  
 Other \_\_\_\_\_

Containment

Pressure 9 psia CS Pump  
 Temperature 101 °F Pres.  
 Sump Level 6 % A 0  
 Sump Temp 99 °F B 0

Core Cooling

Core Thermocouples  
 Avg 620 °F  
 Peak 625 °F Location H8

SECONDARY COOLANT SYSTEM | S/G Levels A 34 % B 35 % C 34 %

S/G Pressure A 935 psig B 935 psig C 935 psig  
 S/G Flow A 3066 lb/hr B 3066 lb/hr C 3066 lb/hr  
 S/G Feed A 3566 lb/hr B 3656 lb/hr C 3656 lb/hr  
 Aux. Feed Pump 3A AVL 3B AVL 2 AVL  
 AFW Flow S/G A 0 GPM B 0 GPM C 0 GPM

Subcooling Monitors

A 125 psi to Sat / — °F Superheat  
 B 125 psi to Sat / — °F Superheat

ENGINEERED SAFEGUARDS

COLD/HOT LEG SI A 0 GPM B 0 GPM C 0 GPM  
 LHSI Flow A 0 GPM B 0 GPM  
 Accumulator Level A 57 % B 57 % C 57 %  
 IRS A AVL B AVL  
 ORS A AVL B AVL

Emergency Diesel Generators (EDG) 1 OP — AVL ✓ OOC —  
 2 OP — AVL ✓ OOC —  
 3 OP — AVL ✓ OOC —

S/G BD Monitor A/B 100/120 cpm  
 Condenser Air Ejector 650 cpm  
 Process Vent (gas) 145 cpm  
 Process Vent (part) 20 cpm  
 Vent Vent (gas) 20 cpm  
 Vent Vent (part) 20 cpm  
 Letdown (high/low) 107/122 cpm

Cont/Manipulator 10/50 mr/hr  
 Aux Bldg-Control Area 1 mr/hr  
 Aux Bldg-Drumming 1 mr/hr  
 Sample Room 1 mr/hr  
 New Fuel 1 mr/hr  
 Spent Fuel Pit 2 mr/hr  
 Control Room <1 mr/hr

AUXILIARY SYSTEMS

RWST Level 100 % Charging Flow 25 GPM  
 CST Level 100 % Letdown Flow 110 GPM  
 VCT Level 40 %

BAST A — % CCW: Supply HDR A/B 6000 GPM  
 BAST B 20 % Return HDR A/B 70 °F  
 BAST C 75 % *Deluge*

Other:

NUCLEAR INSTRUMENTATION

POWER RANGE 0 % 70 % 70 % 70 %  
INTR. RANGE 10<sup>3</sup> AMPS 10<sup>3</sup> AMPS  
SOURCE RANGE 24 CPS 211 CPS

WIND SPEED 40 MPH  
DIRECT. 210-69°  
TEMP. 76 °F  
Δ T -11 °F  
o θ 13 °

PLANT DATA SHEET SURRY UNIT 2  
Date 11/23/02 Time 11:31a

PRIMARY SYSTEM RCS Pressure 2.60 psig RCP's Oper. A/B/C  
RCS Flow loop A 100 % B 100 % C 100 %  
T-Hot/T-Cold Loop A 610/555 °F B 610/555 °F C 611/555 °F  
Pressurizer (Liq/Gas) 697/647 °F Level 61 % Press. 2250 psig  
PRT Temp. 90 °F Level 10 % Press 3 psig  
Safety Valves Open/Closed  
PROV's Open/Closed  
Other

Containment Pressure 9 psia CS Pump  
Temperature 101 °F Pres.  
Sump Level 6 % A 0  
Sump Temp 99 °F B 0

SECONDARY COOLANT SYSTEM S/G Levels A 38 % B 39 % C 38 %  
S/G Pressure A 990 psig B 990 psig C 990 psig  
S/G Flow A 2866 lb/hr B 2866 lb/hr C 2866 lb/hr  
S/G Feed A 2566 lb/hr B 2566 lb/hr C 2566 lb/hr  
Aux. Feed Pump 3A Avl 3B Avl 2 Avl  
AFW Flow S/G A 0 GPM B 0 GPM C 0 GPM

Core Cooling Core Thermocouples  
Avg 615 °F  
Peak 620 °F Location H8

Subcooling Monitors  
A 473 psi to Sat/ °F Superheat  
B 473 psi to Sat/ °F Superheat

ENGINEERED SAFEGUARDS

COLD/HOT LEG SI A 0 GPM B 0 GPM C 0 GPM  
LHSI Flow A 0 GPM B 0 GPM  
Accumulator Level A 57 % B 57 % C 57 %  
IRS A Avl B Avl  
ORS A Avl B Avl

RMS

S/G BD Monitor A/B 100/150 cpm  
Condenser Air Ejector 750 cpm  
Process Vent (gas) 150 cpm  
Process Vent (part) 70 cpm  
Vent Vent (gas) 70 cpm  
Vent Vent (part) 70 cpm  
Letdown (high/low) 150/150 cpm

Emergency Diesel Generators (EDG) 1 OP \_\_\_ AVL  OOC \_\_\_  
2 OP \_\_\_ AVL  OOC \_\_\_  
3 OP \_\_\_ AVL  OOC \_\_\_

Cont/Manipulator 10/50 mr/hr  
Aux Bldg-Control Area 1 mr/hr  
Aux Bldg-Drumming 1 mr/hr  
Sample Room 1 mr/hr  
New Fuel 1 mr/hr  
Spent Fuel Pit 2 mr/hr  
Control Room 51 mr/hr

AUXILIARY SYSTEMS

RWST Level 100 % Charging Flow 25 GPM  
CST Level 100 % Letdown Flow 110 GPM  
VCT Level 90 %  
BAST A 80 % CCW: Supply HDR (A/B) 6000 GPM  
BAST B 10 % Return HDR (A/B) 70 °F  
BAST C 15 %  
purity

Other:

NUCLEAR INSTRUMENTATION

POWER RANGE 0 % 70 % 70 % 70 %  
 INTR. RANGE 10 AMPS 10 AMPS  
 SOURCE RANGE 111 CPS 111 CPS

WIND SPEED 40 MPH  
 DIRECT. 20 °F  
 TEMP. 75 °F  
 Δ T 13 °F  
 θ 30 °

PLANT DATA SHEET SURRY UNIT 2  
 Date 11/10/82 Time 11:35 a

PRIMARY SYSTEM RCS Pressure 2210 psig RCP's Oper. A/B/C  
 RCS Flow loop A 100 % B 100 % C 100 %  
 T-Hot/T-Cold Loop A 595/553 °F B 594/554 °F C 594/553 °F  
 Pressurizer (Liq/Gas) 450/450 °F Level 59 % Press. 2200 psig  
 PRT Temp. 80 °F Level 10 % Press 3 psig  
 Safety Valves Open/Closed  
 PROV's Open/Closed  
 Other \_\_\_\_\_

Containment Pressure 9 psia CS Pump  
 Temperature 101 °F Pres.  
 Sump Level 6 % A 0  
 Sump Temp 79 °F B 0

Core Cooling Core Thermocouples  
 Avg 602 °F  
 Peak 605 °F Location H8

SECONDARY COOLANT SYSTEM S/G Levels A 42 % B 42 % C 42 %  
 S/G Pressure A 880 psig B 880 psig C 880 psig  
 S/G Flow A 2566 lb/hr B 2566 lb/hr C 2566 lb/hr  
 S/G Feed A 24 lb/hr B 486 lb/hr C 2486 lb/hr  
 Aux. Feed Pump 3A AVL 3B AVL2 AVL  
 AFW Flow S/G A 0 GPM B 0 GPM C 0 GPM

Subcooling Monitors  
 A 509 psi to Sat/ - °F Superheat  
 B 409 psi to Sat/ - °F Superheat

ENGINEERED SAFEGUARDS

COLD/HOT LEG SI A 0 GPM B 0 GPM C 0 GPM  
 LHSI Flow A 0 GPM B 0 GPM  
 Accumulator Level A 57 % B 57 % C 57 %  
 IRS A AVL B AVL  
 ORS A AVL B AVL

IRMS

S/G BD Monitor A/B 100/100 cpm  
 Condenser Air Ejector 750 cpm  
 Process Vent (gas) 100 cpm  
 Process Vent (part) 70 cpm  
 Vent Vent (gas) 70 cpm  
 Vent Vent (part) 70 cpm  
 Letdown (high/low) 1300/1300 cpm

Emergency Diesel Generators (EDG) 1 OP AVL  OOC ---  
 2 OP AVL  OOC ---  
 3 OP AVL  OOC ---

Cont/Manipulator 1/50 mr/hr  
 Aux Bldg-Control Area 1 mr/hr  
 Aux Bldg-Drumming 1 mr/hr  
 Sample Room 1 mr/hr  
 New Fuel 1 mr/hr  
 Spent Fuel Pit 2 mr/hr  
 Control Room <1 mr/hr

AUXILIARY SYSTEMS

RWST Level 100 % Charging Flow 40 GPM  
 CST Level 100 % Letdown Flow 100 GPM  
 VCT Level 51 %  
 BAST A 20 % CCW: Supply HDR A/B 6000 GPM  
 BAST B 10 % Return HDR A/B 70 °F  
 BAST C 10 % incl. by

Other:

NUCLEAR INSTRUMENTATION

POWER RANGE 0 % 70 % 70 % 70 %  
 INTR. RANGE 0 AMPS 10 AMPS  
 SOURCE RANGE NA CPS NA CPS

WIND |  
 SPEED 38 MPH  
 DIRECT. 20 °  
 TEMP. 75 °F  
 Δ T -1.3 °F  
 0 0 30 °

PLANT DATA SHEET SURRY UNIT 2  
 Date 11/10/82 Time 11:38 a

PRIMARY SYSTEM | RCS Pressure 2210 psig RCP's Oper. (A/B/C)  
 | RCS Flow loop A 100 % B 100 % C 100 %  
 T-Hot/T-Cold Loop A 588/550 °F B 587/550 °F C 588/550 °F  
 Pressurizer (Liq/Gas) 6.4/654 °F Level 59 % Press. 2200 psig  
 PRT Temp. 80 °F Level 10 % Press 3 psig  
 Safety Valves Open/Closed  
 PROV's Open/Closed  
 Other \_\_\_\_\_

Containment |  
 Pressure 9 psia CS Pump  
 Temperature 101 °F Pres.  
 Sump Level 6 % A 0  
 Sump Temp 99 °F B 0

SECONDARY COOLANT SYSTEM | S/G Levels A 45 % B 45 % C 45 %  
 S/G Pressure A 830 psig B 900 psig C 850 psig  
 S/G Flow A 2566 lb/hr B 2566 lb/hr C 2566 lb/hr  
 S/G Feed A 2566 lb/hr B 2566 lb/hr C 2566 lb/hr  
 Aux. Feed Pump 3A AVL 3B AVL 2 AVL  
 AFW Flow S/G A 0 GPM B 0 GPM C 0 GPM

Core Cooling |  
 Core Thermocouples  
 Avg 594 °F  
 Peak 578 °F Location H8

Subcooling Monitors  
 A 690 psi to Sat / - °F Superheat  
 B 690 psi to Sat / - °F Superheat

ENGINEERED SAFEGUARDS

COLD/HOT LEG SI A 0 GPM B 0 GPM C 0 GPM  
 LHSI Flow A 0 GPM B 0 GPM  
 Accumulator Level A 57 % B 57 % C 57 %  
 IRS A AVL B AVL  
 ORS A AVL B AVL

RMS

S/G BD Monitor A/B 100/150 cpm  
 Condenser Air Ejector 15 cpm  
 Process Vent (gas) AVL cpm  
 Process Vent (part) 20 cpm  
 Vent Vent (gas) 20 cpm  
 Vent Vent (part) 20 cpm  
 Letdown (high/low) 1200/1200 cpm

Emergency Diesel Generators (EDG) 1 OP AVL ✓ OOC ---  
 2 OP AVL ✓ OOC ---  
 3 OP AVL ✓ OOC ---

Cont/Manipulator 10/50 mr/hr  
 Aux Bldg-Control Area 1 mr/hr  
 Aux Bldg-Drumming 1 mr/hr  
 Sample Room 1 mr/hr  
 New Fuel 1 mr/hr  
 Spent Fuel Pit 2 mr/hr  
 Control Room 21 mr/hr

AUXILIARY SYSTEMS

RWST Level 100 % Charging Flow 85 GPM  
 CST Level 100 % Letdown Flow 110 GPM  
 VCT Level 40 %  
 BAST A 100 % CCW: Supply HDR (A/B) 6000 GPM  
 BAST B 100 % Return HDR (A/B) 70 °F  
 BAST C 100 % charging

Other:



NUCLEAR INSTRUMENTATION

POWER RANGE 0% 0% 0% 0%
INTR. RANGE 7409 AMPS 7409 AMPS
SOURCE RANGE 111 CPS 111 CPS

WIND SPEED 40 MPH
DIRECT. 70° 69°
TEMP. 75 °F
Δ T -1.5 °F
σ θ 35 °

PLANT DATA SHEET SURRY UNIT 2
Date 11/10/82 Time 11:41 a

PRIMARY SYSTEM RCS Pressure 2075 psig
RCS Flow loop A 100% B 100% C 10%
T-Hot/T-Cold Loop A 553/550 °F B 553/550 °F C 555/550 °F
Pressurizer (Liq/Gas) 640/640 °F Level 22% Press. 2050 psig
PRT Temp. 40 °F Level 0% Press 3 psig
Safety Valves Open/Closed
PROV's Open/Closed
Other

Containment Pressure 9 psia CS Pump Pres.
Temperature 101 °F
Sump Level 6% A 0
Sump Temp 77 °F B 0

Core Cooling Core Thermocouples
Avg 559 °F
Peak 562 °F Location H9

SECONDARY COOLANT SYSTEM S/G Levels A 8% B 8% C 8%
S/G Pressure A 1030 psig B 1030 psig C 1030 psig
S/G Flow A 245 lb/hr B 245 lb/hr C 245 lb/hr
S/G Feed A 855 lb/hr B 855 lb/hr C 855 lb/hr
Aux. Feed Pump 3A 1AVL 3B 1AVL 2 AVL
AFW Flow S/G A 0 GPM B 0 GPM C 0 GPM

Subcooling Monitors
A 125 psi to Sat / - °F Superheat
B 125 psi to Sat / - °F Superheat

ENGINEERED SAFEGUARDS

COLD/HOT LEG SI A 0 GPM B 0 GPM C 0 GPM
LHSI Flow A 0 GPM B 0 GPM
Accumulator Level A 57% B 57% C 57%
IRS A 1AVL B 1AVL
ORS A 1AVL B 1AVL

Emergency Diesel Generators (EDG) 1 OP AVL OOC
2 OP AVL OOC
3 OP AVL OOC

IRMS

S/G BD Monitor A/B 102/1600 cpm
Condenser Air Ejector 1500 cpm
Process Vent (gas) 105 cpm
Process Vent (part) 105 cpm
Vent Vent (gas) 20 cpm
Vent Vent (part) 70 cpm
Letdown (high/low) 240/2510 cpm

Cont/Manipulator 10/50 mr/hr
Aux Bldg-Control Area 1 mr/hr
Aux Bldg-Drumming 1 mr/hr
Sample Room 1 mr/hr
New Fuel 1 mr/hr
Spent Fuel Pit 2 mr/hr
Control Room <1 mr/hr

AUXILIARY SYSTEMS

RWST Level 100%
CST Level 100%

Charging Flow 120 GPM
Letdown Flow GPM
VCT Level 35%

BAST A 80%
BAST B 70%
BAST C 70%

CCW: Supply HDR (A/B) 600 GPM
Return HDR (A/B) 10 °F

Other:



**NUCLEAR INSTRUMENTATION**

POWER RANGE 0 % 0 % 0 % 0 %  
 INTR. RANGE 5.0 AMPs 5.0 AMPs  
 SOURCE RANGE 0.1 CPS 0.1 CPS

WIND SPEED 40 MPH  
 DIRECT. 7 75 °F  
 TEMP. 75 °F  
 Δ T -15 °F  
 θ 35 °

PLANT DATA SHEET SURRY UNIT 2  
 Date 11/10/82 Time 1145 CE

PRIMARY SYSTEM | RCS Pressure 2110 psig RCP's Oper. A/B/C  
 | RCS Flow loop A 100 % B 100 % C 10 %  
 T-Hot/T-Cold Loop A 550/598 °F B 550/598 °F C 554/550 °F  
 Pressurizer (Liq/Gas) 650/650 °F Level 21 % Press. 2100 psig  
 PRT Temp. 90 °F Level 0 % Press 3 psig  
 Safety Valves Open/Closed  
 PROV's Open/Closed  
 Other \_\_\_\_\_

Containment |  
 Pressure 9 psia CS Pump  
 Temperature 101 °F Pres.  
 Sump Level 7 % A 0  
 Sump Temp 99 °F B 0

SECONDARY COOLANT SYSTEM | S/G Levels A 15 % B 15 % C 15 %  
 S/G Pressure A 1010 psig B 1010 psig C 1010 psig  
 S/G Flow A 1565 lb/hr B 1565 lb/hr C 1565 lb/hr  
 S/G Feed A 8.5 lb/hr B 8.5 lb/hr C 8.5 lb/hr  
 Aux. Feed Pump 3A AVL 3B AVL 2 AVL  
 AFW Flow S/G A 0 GPM B 0 GPM C 0 GPM

Core Cooling |  
 Core Thermocouples  
 Avg 357 °F  
 Peak 560 °F Location A9

Subcooling Monitors  
 A 7 psi to Sat/ - °F Superheat  
 B 117 psi to Sat/ - °F Superheat

**ENGINEERED SAFEGUARDS**

COLD/HOT LEG SI A 0 GPM B 0 GPM C 0 GPM  
 LHSI Flow A 0 GPM B 0 GPM  
 Accumulator Level A 57 % B 57 % C 57 %  
 IRS A AVL B AVL  
 ORS A AVL B AVL

S/G BD Monitor A/B 104/12000 cpm  
 Condenser Air Ejector 100 cpm  
 Process Vent (gas) 100 cpm  
 Process Vent (part) 100 cpm  
 Vent Vent (gas) 20 cpm  
 Vent Vent (part) 20 cpm  
 Letdown (high/low) 5000/5000 cpm

Emergency Diesel Generators (EDG) 1 OP AVL  OOC ---  
 2 OP AVL  OOC ---  
 3 OP AVL  OOC ---

Cont/Manipulator 1/50 mr/hr  
 Aux Bldg-Control Area 1 mr/hr  
 Aux Bldg-Drumming 1 mr/hr  
 Sample Room 1 mr/hr  
 New Fuel 1 mr/hr  
 Spent Fuel Pit 2 mr/hr  
 Control Room 1 mr/hr

**AUXILIARY SYSTEMS**

RWST Level 100 %  
 CST Level 100 %  
 Charging Flow 100 GPM  
 Letdown Flow 120 GPM  
 VCT Level 50 %

Other:

BAST A 100 %  
 BAST B 100 %  
 BAST C 100 %  
 CCW: Supply HDR A/B 6000 GPM  
 Return HDR A/B 11 °F

NUCLEAR INSTRUMENTATION

POWER RANGE 0 % 0 % 0 % 0 %  
 INTR. RANGE 5.0 AMPS 5.0 AMPS  
 SOURCE RANGE 35 CPS 250 CPS

WIND SPEED 27 MPH  
 DIRECT. from 70 °F  
 TEMP. 76 °F  
 Δ T -1.3 °F  
 θ 33 °

PLANT DATA SHEET SURRY UNIT 2  
 Date 11/10/82 Time 11:49 a

PRIMARY SYSTEM | RCS Pressure 2165 psig RCP's Oper. (A/B/C)  
 | RCS Flow loop A 1.4 % B 1.0 % C 1.0 %  
 T-Hot/T-Cold Loop A 549/549 °F B 547/549 °F C 554/550 °F  
 Pressurizer (Liq/Gas) 657/652 °F Level 21 % Press. 2150 psig  
 PRT Temp. 30 °F Level 0 % Press 3 psig  
 Safety Valves Open/Closed  
 PROV's Open/Closed  
 Other \_\_\_\_\_

Containment |  
 Pressure 9 psia CS Pump  
 Temperature 400 °F Pres.  
 Sump Level 7 % A 0  
 Sump Temp 97 °F B 0

SECONDARY COOLANT SYSTEM | S/G Levels A 25 % B 25 % C 25 %  
 | S/G Pressure A 1030 psig B 1030 psig C 1030 psig  
 | S/G Flow A 1045 lb/hr B 1045 lb/hr C 1045 lb/hr  
 | S/G Feed A 7045 lb/hr B 7045 lb/hr C 7045 lb/hr  
 | Aux. Feed Pump 3A AVL 3B AVL 2 AVL  
 | APW Flow S/G A 0 GPM B 0 GPM C 0 GPM

Core Cooling |  
 Core Thermocouples  
 Avg 553 °F  
 Peak 558 °F Location H9

Subcooling Monitors  
 A 250 psi to Sat/ --- °F Superheat  
 B 250 psi to Sat/ --- °F Superheat

RMS

S/G BD Monitor A/B 106/2350 cpm  
 Condenser Air Ejector 1505 cpm  
 Process Vent (gas) 1830 cpm  
 Process Vent (part) 100 cpm  
 Vent Vent (gas) 70 cpm  
 Vent Vent (part) 70 cpm  
 Letdown (high/low) 5000/5000 cpm

Cont/Manipulator 10/30 mr/hr  
 Aux Bldg-Control Area 1 mr/hr  
 Aux Bldg-Drumming 1 mr/hr  
 Sample Room 1 mr/hr  
 New Fuel 1 mr/hr  
 Spent Fuel Pit 2 mr/hr  
 Control Room <1 mr/hr

Other:

ENGINEERED SAFEGUARDS

COLD/HOT LEG SI A 0 GPM B 0 GPM C 0 GPM  
 LHSI Flow A 0 GPM B 0 GPM  
 Accumulator Level A 57 % B 57 % C 57 %  
 IRS A AVL B AVL  
 ORS A AVL B AVL  
 Emergency Diesel Generators (EDG) 1 OP --- AVL  OOC ---  
 2 OP --- AVL  OOC ---  
 3 OP --- AVL  OOC ---

AUXILIARY SYSTEMS

RWST Level 100 % Charging Flow 100 GPM  
 CST Level 100 % Letdown Flow 120 GPM  
 VCT Level 27 %  
 BAST A 50 % CCW: Supply HDR A/B 6000 GPM  
 BAST B 70 % Return HDR A/B 71 °F  
 BAST C 70 %

**NUCLEAR INSTRUMENTATION**

POWER RANGE 0 % 0 % 0 % 0 %  
 INTR. RANGE 10-11 AMPS 11-17 AMPS  
 SOURCE RANGE 7500 CPS 7500 CPS

WIND SPEED 45 MPH  
 DIRECT. 71-72 °F  
 TEMP. 76 °F  
 Δ T -1.3 °F  
 0 0 39 °

PLANT DATA SHEET SURRY UNIT 2  
 Date 11/10/82 Time 11:51 a

RSS A & B anal 26 hrs rec lost  
 on RFR 1712 1982 lost to fault  
 at Bus 5

PRIMARY SYSTEM | RCS Pressure 2210 psig RCP's Oper. A/B/C  
 | RCS Flow loop A 75 % B 95 % C 10 %

T-Hot/T-Cold Loop A 549/548 °F B 547/546 °F C 554/553 °F  
 Pressurizer (Liq/Gas) 654/654 °F Level 21 % Press. 2200 psig  
 PRT Temp. 92 °F Level 0 % Press 3 psig  
 Safety Valves Open/Closed  
 PROV's Open/Closed  
 Other \_\_\_\_\_

Containment |  
 Pressure 9 psia CS Pump  
 Temperature 100 °F Pres.  
 Sump Level 7 % A 0  
 Sump Temp 97 °F B 0

Core Cooling |  
 Core Thermocouples  
 Avg 553 °F  
 Peak 557 °F Location H9

**SECONDARY COOLANT SYSTEM** | S/G Levels A 28 % B 28 % C 28 %

S/G Pressure A 1020 psig B 1020 psig C 1020 psig  
 S/G Flow A 6464 lb/hr B 6464 lb/hr C 6464 lb/hr  
 S/G Feed A 5065 lb/hr B 5065 lb/hr C 5065 lb/hr  
 Aux. Feed Pump 3A op 3B op 2 op  
 AFW Flow S/G A 200 GPM B 200 GPM C 200 GPM *over feed auto started*

Subcooling Monitors  
 A 1104 psi to Sat/ — °F Superheat  
 B 1104 psi to Sat/ — °F Superheat

**ENGINEERED SAFEGUARDS**

COLD/HOT LEG SI A 0 GPM B 0 GPM C 0 GPM  
 LHSI Flow A 0 GPM B 0 GPM  
 Accumulator Level A 57 % B 57 % C 57 %  
 IRS A Avl B Avl  
 ORS A Avl B Avl

IRMS |  
 S/G BD Monitor A/B 110/250 cpm  
 Condenser Air Ejector 1500 cpm  
 Process Vent (gas) 100 cpm  
 Process Vent (part) 100 cpm  
 Vent Vent (gas) 70 cpm  
 Vent Vent (part) 70 cpm  
 Letdown (high/low) 9500/9500 cpm

Emergency Diesel Generators (EDG) 1 OP — AVL ✓ OOC —  
 2 OP ✓ AVL — OOC —  
 3 OP — AVL ✓ OOC —

Cont/Manipulator 10/50 mr/hr  
 Aux Bldg-Control Area 1 mr/hr  
 Aux Bldg-Drumming 1 mr/hr  
 Sample Room 1 mr/hr  
 New Fuel 1 mr/hr  
 Spent Fuel Pit 2 mr/hr  
 Control Room <1 mr/hr

**AUXILIARY SYSTEMS**

RWST Level Avl %  
 CST Level Avl %  
 Charging Flow 1000 GPM  
 Letdown Flow 120 GPM  
 VCT Level 17 %

Other:

BAST A 0 %  
 BAST B 0 %  
 BAST C 1/2 %  
 CCW: Supply HDR (A/B) 6000 GPM  
 Return HDR (A/B) 10 °F  
*Discharge*

NUCLEAR INSTRUMENTATION

POWER RANGE 0 % 0 % 0 % 0 %  
INTR. RANGE 10 AMPS 20 AMPS  
SOURCE RANGE 200 CPS 200 CPS

WIND SPEED 43 MPH  
DIRECT. 200°  
TEMP. 77 °F  
Δ T -12 °F  
0 0 30

PLANT DATA SHEET SUPRY UNIT 2  
Date 11/17/82 Time 11:55 a

*6 psi un-rotated steam from relief valves  
in anticipation of loss of condenser vacuum*

PRIMARY SYSTEM | RCS Pressure 2210 psig RCP's Oper. A/B/C  
RCS Flow loop A 3 % B 3 % C 3 %  
T-Hot/T-Cold Loop A 595/555 °F B 599/556 °F C 595/555 °F  
Pressurizer (Liq/Gas) 650/250 °F Level 38 % Press. 2200 psig  
PRT Temp. 90 °F Level 0 % Press 3 psig  
Safety Valves Open/Closed  
PROV's Open/Closed  
Other

Containment |  
Pressure 9 psia CS Pump  
Temperature 100 °F Pres.  
Sump Level 7 % A 0  
Sump Temp 77 °F B 0

Core Cooling |  
Core Thermocouples  
Avg 592 °F  
Peak 615 °F Location K5

SECONDARY COOLANT SYSTEM | S/G Levels A 30 % B 30 % C 30 %  
S/G Pressure A 1035 psig B 1055 psig C 1055 psig  
S/G Flow A 5524 lb/hr B 5524 lb/hr C 5524 lb/hr  
S/G Feed A 225 lb/hr B 225 lb/hr C 225 lb/hr  
Aux. Feed Pump 3A Op 3B Op 2 AVL - secured  
AFW Flow S/G A 200 GPM B 200 GPM C 200 GPM

Subcooling Monitors  
A 1.8 psi to Sat / - °F Superheat  
B 1.8 psi to Sat / - °F Superheat

ENGINEERED SAFEGUARDS

COLD/HOT LEG SI A 0 GPM B 0 GPM C 0 GPM  
LHSI Flow A 0 GPM B 0 GPM  
Accumulator Level A 57 % B 57 % C 57 %  
IRS A AVL B AVL  
ORS A AVL B AVL

RMS |  
S/G BD Monitor A/B 110/2500 cpm  
Condenser Air Ejector 1500 cpm  
Process Vent (gas) 100 cpm  
Process Vent (part) 100 cpm  
Vent Vent (gas) 70 cpm  
Vent Vent (part) 10 cpm  
Letdown (high/low) 4500/4500 cpm

Emergency Diesel Generators (EDG) 1 OP \_\_\_ AVL ✓ OOC \_\_\_  
2 OP ✓ AVL \_\_\_ OOC \_\_\_  
3 OP \_\_\_ AVL ✓ OOC \_\_\_

Cont/Manipulator 1/10 mr/hr  
Aux Bldg-Control Area 1 mr/hr  
Aux Bldg-Drumming 1 mr/hr  
Sample Room 1 mr/hr  
New Fuel 1 mr/hr  
Spent Fuel Pit 2 mr/hr  
Control Room 51 mr/hr

AUXILIARY SYSTEMS

RWST Level 10 %  
CST Level 78 %  
Charging Flow 120 GPM  
Letdown Flow 60 GPM  
VCT Level 35 %  
BAST A 70 %  
BAST B 70 %  
BAST C 75 %  
CCW: Supply HDR (A/B) 6000 GPM  
Return HDR (A/B) 11 °F

Other:

NUCLEAR INSTRUMENTATION

POWER RANGE 0 % 0 % 0 % 0 %  
 INTR. RANGE 10-11 AMPS 10-11 AMPS  
 SOURCE RANGE 2000 CPS 2000 CPS

WIND SPEED 30 MPH  
 DIRECT. 200 69°  
 TEMP. 72 °F  
 Δ T -12 °F  
 0 θ 30 °

PLANT DATA SHEET SURRY UNIT 2  
 Date 11/10/72 Time 12:05 N

PRIMARY SYSTEM | RCS Pressure 2210 psig RCP's Oper. A/B/C  
 | RCS Flow loop A 3 % B 3 % C 3 %  
 T-Hot/T-Cold Loop A 534/555 °F B 534/555 °F C 534/555 °F  
 Pressurizer (Liq/Gas) 644/555 °F Level 52 % Press. 2200 psig  
 PRT Temp. 30 °F Level 0 % Press 3 psig  
 Safety Valves Open/Closed  
 PROV's Open/Closed  
 Other \_\_\_\_\_

Containment |  
 Pressure 9 psia CS Pump  
 Temperature 100 °F Pres.  
 Sump Level 7 % A 0  
 Sump Temp 99 °F B 0

SECONDARY COOLANT SYSTEM | S/G Levels A 30 % B 30 % C 30 %  
 S/G Pressure A 1035 psig B 1035 psig C 1035 psig  
 S/G Flow A 5224 lb/hr B 5224 lb/hr C 5224 lb/hr  
 S/G Feed A 225 lb/hr B 225 lb/hr C 225 lb/hr  
 Aux. Feed Pump 3A op 3B op 2 AVL  
 AFW Flow S/G A 200 GPM B 200 GPM C 200 GPM

Core Cooling |  
 Core Thermocouples  
 Avg 593 °F  
 Peak 625 °F Location KS

Subcooling Monitors  
 A 358 psi to Sat / --- °F Superheat  
 B 358 psi to Sat / --- °F Superheat

ENGINEERED SAFEGUARDS

COLD/HOT LEG SI A 0 GPM B 0 GPM C 0 GPM  
 LHSI Flow A 0 GPM B 0 GPM  
 Accumulator Level A 57 % B 57 % C 57 %  
 IRS A AVL B AVL  
 ORS A AVL B AVL

RMS |  
 S/G BD Monitor A/B 110/2400 cpm  
 Condenser Air Ejector 1500 cpm  
 Process Vent (gas) 100 cpm  
 Process Vent (part) 100 cpm  
 Vent Vent (gas) 70 cpm  
 Vent Vent (part) 70 cpm  
 Letdown (high/low) 4000/4000 cpm

Emergency Diesel Generators (EDG) 1 OP AVL  OOC ---  
 2 OP  AVL --- OOC ---  
 3 OP --- AVL  OOC ---

Cont/Manipulator 10/50 mr/hr  
 Aux Bldg-Control Area 1 mr/hr  
 Aux Bldg-Drumming 1 mr/hr  
 Sample Room 1 mr/hr  
 New Fuel 1 mr/hr  
 Spent Fuel Pit 2 mr/hr  
 Control Room <1 mr/hr

AUXILIARY SYSTEMS

RWST Level 100 %  
 CST Level 76 %  
 Charging Flow 120 GPM  
 Letdown Flow 60 GPM  
 VCT Level 53 %

BAST A 4 %  
 BAST B 4 %  
 BAST C 15 %  
 CCW: Supply HDR (A/B) 6000 GPM  
 Return HDR (A/B) 71 °F  
 D. Inj.

Other:

NUCLEAR INSTRUMENTATION

POWER RANGE 0 % 0 % 0 % 0 %  
INTR. RANGE 10-11 AMPS 10-11 AMPS  
SOURCE RANGE 150 CPS 150 CPS

WIND SPEED 35 MPH  
DIRECT. from 70°  
TEMP. 77 °F  
Δ T -12 °F  
0 θ 31 °

PLANT DATA SHEET SURRY UNIT 2  
Date 11/13/32 Time 12.05 P

Condenser vacuum is lost. Ops  
operation changeover possible to removal  
dry heat

PRIMARY SYSTEM | RCS Pressure 2210 psig RCP's Oper. A/B/C  
RCS Flow loop A 3 % B 3 % C 3 %

T-Hot/T-Cold Loop A 587/555 °F B 587/555 °F C 587/555 °F  
Pressurizer (Liq/Gas) 655/655 °F Level 52 % Press. 2200 psig  
PRT Temp. 50 °F Level 0 % Press 3 psig  
Safety Valves Open/Closed  
PROV's Open/Closed  
Other

Containment | Pressure 9 psia CS Pump Pres.  
Temperature 100 °F  
Sump Level 7 % A 0  
Sump Temp 99 °F B 0

Core Cooling | Core Thermocouples  
Avg 574 °F  
Peak 640 °F Location K5, L6

SECONDARY COOLANT SYSTEM | S/G Levels A 30 % B 30 % C 30 %  
S/G Pressure A 1000 psig B 1000 psig C 1000 psig  
S/G Flow A 5000 lb/hr B 5000 lb/hr C 5000 lb/hr  
S/G Feed A 0 lb/hr B 0 lb/hr C 0 lb/hr  
Aux. Feed Pump 3A 100 3B 100 2 AVL  
AFW Flow S/G A 200 GPM B 200 GPM C 200 GPM

FW secured. Ops decides  
to use aux feed  
given the loss  
of condenser

Subcooling Monitors  
A 150 psi to Sat / - °F Superheat  
B 150 psi to Sat / - °F Superheat

RMS

S/G BD Monitor A/B 110/250 cpm  
Condenser Air Ejector 1500 cpm  
Process Vent (gas) 1000 cpm  
Process Vent (part) 1000 cpm  
Vent Vent (gas) 70 cpm  
Vent Vent (part) 70 cpm  
Letdown (high/low) 4500/4500 cpm

Cont/Manipulator 10/50 mr/hr  
Aux Bldg-Control Area 1 mr/hr  
Aux Bldg-Drumming 1 mr/hr  
Sample Room 1 mr/hr  
New Fuel 1 mr/hr  
Spent Fuel Pit 2 mr/hr  
Control Room <1 mr/hr

Other:

ENGINEERED SAFEGUARDS

COLD/HOT LEG SI A 0 GPM B 0 GPM C 0 GPM  
LHSI Flow A 0 GPM B 0 GPM  
Accumulator Level A 57 % B 57 % C 57 %  
IRS A AVL B AVL  
ORS A AVL B AVL

Emergency Diesel Generators (EDG) 1 OP \_\_\_ AVL ✓ OOC \_\_\_  
2 OP ✓ AVL \_\_\_ OOC \_\_\_  
3 OP \_\_\_ AVL ✓ OOC \_\_\_

AUXILIARY SYSTEMS

RWST Level 100 %  
CST Level 95 %  
Charging Flow 60 GPM  
Letdown Flow 60 GPM  
VCT Level 30 %

BAST A 60 %  
BAST B 60 %  
BAST C 60 %  
CCW: Supply HDR (A/B) 6000 GPM  
Return HDR (A/B) 71 °F

NUCLEAR INSTRUMENTATION

WIND

PLANT DATA SHEET

SURRY UNIT 2

POWER RANGE 0 % 0 % 0 % 0 %  
INTR. RANGE 10" AMPS 10" AMPS  
SOURCE RANGE 190 CPS 190 CPS

SPEED 35 MPH  
DIRECT. 140 75°  
TEMP. 77 °F  
Δ T -1.2 °F  
0 0 32 °

Date 11/10/82

Time 12:10 P

PRIMARY SYSTEM

RCS Pressure 2210 psig RCP's Oper. A/B/C  
RCS Flow loop A 3 % B 3 % C 3 %

T-Hot/T-Cold Loop A 583/553 °F B 583/553 °F C 583/553 °F  
Pressurizer (Liq/Gas) 655/655 °F Level 52 % Press. 2210 psig  
PRT Temp. 80 °F Level 0 % Press 3 psig  
Safety Valves Open/Closed  
PROV's Open/Closed  
Other

Containment

Pressure 9 psia CS Pump  
Temperature 100 °F Pres.  
Sump Level 7 % A 0  
Sump Temp 99 °F B 0

SECONDARY COOLANT SYSTEM

S/G Levels A 30 % B 30 % C 30 %

S/G Pressure A 1000 psig B 1000 psig C 1000 psig  
S/G Flow A 4800 lb/hr B 4800 lb/hr C 4800 lb/hr  
S/G Feed A 0 lb/hr B 0 lb/hr C 0 lb/hr  
Aux. Feed Pump 3A 4 3B 2 3C 2  
AFW Flow S/G A 175 GPM B 175 GPM C 175 GPM

Core Cooling

Core Thermocouples  
Avg 525 °F  
Peak 675 °F Location KS. 46

Subcooling Monitors

A \_\_\_ psi to Sat/\_\_\_ °F Superheat  
B \_\_\_ psi to Sat/\_\_\_ °F Superheat

ENGINEERED SAFEGUARDS

COLD/HOT LEG SI A 0 GPM B 0 GPM C 0 GPM  
LHSI Flow A 0 GPM B 0 GPM  
Accumulator Level A 57 % B 57 % C 57 %  
IRS A AVL B AVL  
ORS A AVL B AVL

Emergency Diesel Generators (EDG) 1 OP \_\_\_ AVL ✓ OOC \_\_\_  
2 OP ✓ AVL \_\_\_ OOC \_\_\_  
3 OP \_\_\_ AVL ✓ OOC \_\_\_

AUXILIARY SYSTEMS

RWST Level 100 %  
CST Level 80 %  
Charging Flow 60 GPM  
Letdown Flow 60 GPM  
VCT Level 30 %

BAST A 80 %  
BAST B 100 %  
BAST C 100 %  
CCW: Supply HDR (A/B) 6000 GPM  
Return HDR (A/B) 71 °F  
w. large

RMS

S/G BD Monitor A/B 110/2500 cpm  
Condenser Air Ejector 1500 cpm  
Process Vent (gas) 100 cpm  
Process Vent (part) 100 cpm  
Vent Vent (gas) 70 cpm  
Vent Vent (part) 70 cpm  
Letdown (high/low) 10,000/15,000 cpm

Cont/Manipulator 10/50 mr/hr  
Aux Bldg-Control Area 1 mr/hr  
Aux Bldg-Drumming 1 mr/hr  
Sample Room 1 mr/hr  
New Fuel 1 mr/hr  
Spent Fuel Pit 2 mr/hr  
Control Room <1 mr/hr

Other:

NUCLEAR INSTRUMENTATION

POWER RANGE 0 % 0 % 0 % 0 %  
 INTR. RANGE 10 AMPS 10 AMPS  
 SOURCE RANGE 175 CPS 175 CPS

WIND SPEED 32 MPH  
 DIRECT. 24 MPH 65 °  
 TEMP. 77 °F  
 Δ T -1.2 °F  
 θ 32 °

PLANT DATA SHEET SURRY UNIT 2  
 Date 11/10/82 Time 12:15 P

PRIMARY SYSTEM | RCS Pressure 2210 psig RCP's Oper. A/B/C  
 | RCS Flow loop A 3 % B 3 % C 3 %  
 T-Hot/T-Cold Loop A 580/551 °F B 581/551 °F C 590/551 °F  
 Pressurizer (Liq/Gas) 655/655 °F Level 52 % Press. 2200 psig  
 PRT Temp. 30 °F Level 0 % Press 3 psig  
 Safety Valves Open/Closed  
 PROV's Open/Closed  
 Other \_\_\_\_\_

Containment |  
 Pressure 9 psia CS Pump  
 Temperature 141 °F Pres.  
 Sump Level 7 % A 0  
 Sump Temp 99 °F B 0

SECONDARY COOLANT SYSTEM | S/G Levels A 30 % B 30 % C 30 %  
 S/G Pressure A 175 psig B 175 psig C 175 psig  
 S/G Flow A 4664 lb/hr B 4664 lb/hr C 4664 lb/hr  
 S/G Feed A 0 lb/hr B 0 lb/hr C 0 lb/hr  
 Aux. Feed Pump 3A OP 3B OP 2 AVL  
 AFW Flow S/G A 175 GPM B 175 GPM C 175 GPM

Core Cooling |  
 Core Thermocouples  
 Avg 590 °F  
 Peak 725 °F Location KS, LL

Subcooling Monitors  
 A — psi to Sat / 5 °F Superheat  
 B — psi to Sat / 75 °F Superheat

ENGINEERED SAFEGUARDS

COLD/HOT LEG SI A 0 GPM B 0 GPM C 0 GPM  
 LHSI Flow A 0 GPM B 0 GPM  
 Accumulator Level A 57 % B 57 % C 57 %  
 IRS A AVL B AVL  
 ORS A AVL B AVL

Emergency Diesel Generators (EDG) 1 OP — AVL ✓ OOC —  
 2 OP ✓ AVL — OOC —  
 3 OP — AVL ✓ OOC —

S/G BD Monitor A/B 110/2600 cpm  
 Condenser Air Ejector 15 cpm  
 Process Vent (gas) 100 cpm  
 Process Vent (part) 15 cpm  
 Vent Vent (gas) 10 cpm  
 Vent Vent (part) 70 cpm  
 Letdown (high/low) 1250/1750 cpm

Cont/Manipulator 10/50 mr/hr  
 Aux Bldg-Control Area 1 mr/hr  
 Aux Bldg-Drumming 1 mr/hr  
 Sample Room 1 mr/hr  
 New Fuel 1 mr/hr  
 Spent Fuel Pit 2 mr/hr  
 Control Room <1 mr/hr

AUXILIARY SYSTEMS

RWST Level 100 %  
 CST Level 57 %  
 Charging Flow 60 GPM  
 Letdown Flow 60 GPM  
 VCT Level 30 %

BAST A 80 %  
 BAST B 100 %  
 BAST C 75 %  
 CCW: Supply HDR (A/B) 6000 GPM  
 Return HDR (A/B) 11 °F  
*Do not log*

Other:



NUCLEAR INSTRUMENTATION

POWER RANGE 0 % 0 % 0 % 0 %  
INTR. RANGE 10" AMPS 10-11 AMPS  
SOURCE RANGE 175 CPS 175 CPS

WIND SPEED 32 MPH  
DIRECT. 209 62°  
TEMP. 77 °F  
Δ T -1.1 °F  
0 0 25 °

PLANT DATA SHEET SURRY UNIT 2  
Date 11/10/82 Time 12:20 P

PRIMARY SYSTEM | RCS Pressure 2210 psig RCP's Oper. A/B/C  
RCS Flow loop A 3 % B 3 % C 3 %  
T-Hot/T-Cold Loop A 579/549 °F B 579/549 °F C 579/549 °F  
Pressurizer (Liq/Gas) 655/655 °F Level 52 % Press. 2200 psig  
PRT Temp. 90 °F Level 0 % Press 3 psig  
Safety Valves Open/Closed  
PROV's Open/Closed  
Other

Containment |  
Pressure 9 psia CS Pump  
Temperature 100 °F Pres.  
Sump Level 2 % A 0  
Sump Temp 99 °F B 0

SECONDARY COOLANT SYSTEM | S/G Levels A 30 % B 30 % C 30 %  
S/G Pressure A 730 psig B 730 psig C 730 psig  
S/G Flow A 4424 lb/hr B 4424 lb/hr C 4424 lb/hr  
S/G Feed A 0 lb/hr B 0 lb/hr C 0 lb/hr  
Aux. Feed Pump 3A op 3B op 2 AVL  
AFW Flow S/G A 170 GPM B 170 GPM C 170 GPM

Core Cooling |  
Core Thermocouples  
Avg 528 °F  
Peak 750 °F Location K5.46  
Subcooling Monitors  
A psi to Sat/100 °F Superheat  
B psi to Sat/100 °F Superheat

ENGINEERED SAFEGUARDS

COLD/HOT LEG SI A 0 GPM B 0 GPM C 0 GPM  
LHSI Flow A 0 GPM B 0 GPM  
Accumulator Level A 57 % B 57 % C 57 %  
IRS A AVL B AVL  
ORS A AVL B AVL

(RMS)  
S/G BD Monitor A/B 115/2550 cpm  
Condenser Air Ejector 1400 cpm  
Process Vent (gas) 100 cpm  
Process Vent (part) 100 cpm  
Vent Vent (gas) 20 cpm  
Vent Vent (part) 20 cpm  
Letdown (high/low) 105/105 cpm

Emergency Diesel Generators (EDG) 1 OP AVL ✓ OOC ---  
2 OP ✓ AVL ✓ OOC ---  
3 OP --- AVL ✓ OOC ---

Cont/Manipulator 1/50 mr/hr  
Aux Bldg-Control Area 1 mr/hr  
Aux Bldg-Drumming 1 mr/hr  
Sample Room 1 mr/hr  
New Fuel 1 mr/hr  
Spent Fuel Pit 2 mr/hr  
Control Room 21 mr/hr

AUXILIARY SYSTEMS

RWST Level 100 %  
CST Level 24 %  
Charging Flow 60 GPM  
Letdown Flow 60 GPM  
VCT Level 20 %  
CCW: Supply HDR (A/B) 60 °F GPM  
Return HDR (A/B) 71 °F

Other:

NUCLEAR INSTRUMENTATION

POWER RANGE 0 % 0 % 0 % 0 %  
 INTR. RANGE 10 AMPS 10 AMPS  
 SOURCE RANGE 175 CPS 175 CPS

WIND SPEED 30 MPH  
 DIRECT. 65 °F  
 TEMP. 77 °F  
 Δ T -1.1 °F  
 θ 23 °

PLANT DATA SHEET SURRY UNIT 2  
 Date 11/10/82 Time 17:25 P

PRIMARY SYSTEM RCS Pressure 2710 psig RCP's Oper. A/B/C  
 RCS Flow loop A 3 % B 3 % C 3 %  
 T-Hot/T-Cold Loop A 577/546 °F B 577/546 °F C 577/543 °F  
 Pressurizer (Liq/Gas) 655/654 °F Level 52 % Press. 2700 psig  
 PRT Temp. 80 °F Level 0 % Press 3 psig  
 Safety Valves Open/Closed  
 PROV's Open/Closed  
 Other \_\_\_\_\_

Containment Pressure 9 psia CS Pump  
 Temperature 100 °F Pres.  
 Sump Level 7 % A 0  
 Sump Temp 99 °F B 0

SECONDARY COOLANT SYSTEM S/G Levels A 20 % B 20 % C 20 %  
 S/G Pressure A 770 psig B 770 psig C 770 psig  
 S/G Flow A 4224 lb/hr B 4224 lb/hr C 4224 lb/hr  
 S/G Feed A 0 lb/hr B 0 lb/hr C 0 lb/hr  
 Aux. Feed Pump 3A OP 3B OP 2 AVL  
 AFW Flow S/G A 165 GPM B 165 GPM C 165 GPM

Core Cooling Core Thermocouples  
 Avg 585 °F  
 Peak 1000 °F Location AS-66  
 Subcooling Monitors  
 A — psi to Sat/— °F Superheat  
 B — psi to Sat/— °F Superheat

ENGINEERED SAFEGUARDS  
 COLD/HOT LEG SI A 0 GPM B 0 GPM C 0 GPM  
 LHSI Flow A 0 GPM B 0 GPM  
 Accumulator Level A 57 % B 57 % C 57 %  
 IRS A AVL B AVL  
 ORS A AVL B AVL  
 Emergency Diesel Generators (EDG) 1 OP — AVL ✓ OOC —  
 2 OP ✓ AVL — OOC —  
 3 OP — AVL ✓ OOC —

RMS  
 S/G BD Monitor A/B 100/2500 cpm  
 Condenser Air Ejector 1400 cpm  
 Process Vent (gas) — cpm  
 Process Vent (part) 1000 cpm  
 Vent Vent (gas) 10 cpm  
 Vent Vent (part) 20 cpm  
 Letdown (high/low) 1800/1500 cpm  
 Cont/Manipulator 10/50 mr/hr  
 Aux Bldg-Control Area 1 mr/hr  
 Aux Bldg-Drumming 1 mr/hr  
 Sample Room 1 mr/hr  
 New Fuel 1 mr/hr  
 Spent Fuel Pit 2 mr/hr  
 Control Room 21 mr/hr

AUXILIARY SYSTEMS  
 RWST Level 100 %  
 CST Level 81 %  
 Charging Flow 60 GPM  
 Letdown Flow 60 GPM  
 VCT Level 70 %  
 BAST A 90 %  
 BAST B — %  
 BAST C 15 %  
 CCW: Supply HDR (A/B) 6 GPM  
 Return HDR (A/B) 11 °F

Other:

NUCLEAR INSTRUMENTATION

POWER RANGE 0 % 0 % 0 % 0 %  
INTR. RANGE 100 AMPS 100 AMPS  
SOURCE RANGE 175 CPS 175 CPS

WIND SPEED 25 MPH  
DIRECT. 110 deg  
TEMP. 77 deg F  
Δ T -1.1 deg F  
θ 22 deg

PLANT DATA SHEET SURRY UNIT 2  
Date 11/10/82 Time 0359

*46°C and accounted for that control  
to some of heater in 1/4 C and  
from relieving to atmosphere*

PRIMARY SYSTEM | RCS Pressure 2210 psig RCP's Oper. A/B/C  
RCS Flow loop A 3 % B 3 % C 3 %

T-Hot/T-Cold Loop A 576/597 deg F B 576/597 deg F C 576/597 deg F  
Pressurizer (Liq/Gas) 655/655 deg F Level 52 % Press. 2200 psig  
PRT Temp. 90 deg F Level 0 % Press 3 psig  
Safety Valves Open/Closed  
PROV's Open/Closed  
Other

Containment |  
Pressure 9 psia CS Pump  
Temperature 200 deg F Pres.  
Sump Level 7 % A 0  
Sump Temp 99 deg F B 0

Core Cooling |  
Core Thermocouples  
Avg 585 deg F  
Peak 1150 deg F Location K5, L6

SECONDARY COOLANT SYSTEM | S/G Levels A 30 % B 30 % C 30 %  
S/G Pressure A 775 psig B 775 psig C 780 psig  
S/G Flow A 5.76 lb/hr B 5.76 lb/hr C 0 lb/hr  
S/G Feed A 0 lb/hr B 0 lb/hr C 0 lb/hr  
Aux. Feed Pump 3A up 3B up 2 AVL  
APW Flow S/G A 225 GPM B 225 GPM C 0 GPM

Subcooling Monitors  
A \_\_\_ psi to Sat/500 deg F Superheat  
B \_\_\_ psi to Sat/500 deg F Superheat

IRMS |  
S/G BD Monitor A/B 110/2550 cpm  
Condenser Air Ejector 1500 cpm  
Process Vent (gas) 100 cpm  
Process Vent (part) 100 cpm  
Vent Vent (gas) 70 cpm  
Vent Vent (part) 70 cpm  
Letdown (high/low) 2405/1240 cpm

Cont/Manipulator 10/50 mr/hr  
Aux Bldg-Control Area 1 mr/hr  
Aux Bldg-Drumming 1 mr/hr  
Sample Room 1 mr/hr  
New Fuel 1 mr/hr  
Spent Fuel Pit 2 mr/hr  
Control Room <1 mr/hr

Other:

ENGINEERED SAFEGUARDS

COLD/HOT LEG SI A 0 GPM B 0 GPM C 0 GPM  
LHSI Flow A 0 GPM B 0 GPM  
Accumulator Level A 57 % B 57 % C 57 %  
IRS A AVL B AVL  
ORS A AVL B AVL

Emergency Diesel Generators (EDG) 1 OP \_\_\_ AVL  OOC \_\_\_  
2 OP  AVL \_\_\_ OOC \_\_\_  
3 OP \_\_\_ AVL  OOC \_\_\_

AUXILIARY SYSTEMS

RWST Level 45 %  
CST Level 15 %  
Charging Flow 60 GPM  
Letdown Flow 60 GPM  
VCT Level 40 %

BAST A 90 %  
BAST B 70 %  
BAST C 15 %  
CCW: Supply HDR (A/B) 6000 GPM  
Return HDR (A/B) 11 deg F  
*Drinking*

NUCLEAR INSTRUMENTATION

POWER RANGE 0% 0% 0% 0%
INTR. RANGE 10 AMPS 10 AMPS
SOURCE RANGE 75 CPS 175 CPS

WIND SPEED 20 MPH
DIRECT. 70
TEMP. 77
delta T -11
theta 22

PLANT DATA SHEET SURRY UNIT 2
Date 11/10/82 Time 1245 P

PRIMARY SYSTEM RCS Pressure 2210 psig RCP's Oper. A/B/C
RCS Flow loop A 3% B 3% C 0%

T-Hot/T-Cold Loop A 570/541 F B 570/541 F C 575/546 F
Pressurizer (Liq/Gas) 655/655 F Level 52% Press. 2200 psig
PRT Temp. 93 F Level 0% Press 3 psig
Safety Valves Open/Closed
PROV's Open/Closed
Other

Containment Pressure 9 psia CS Pump
Temperature 111 F Pres.
Sump Level 7% A 0
Sump Temp 99 F B 0

Core Cooling Core Thermocouples
Avg 584 F
Peak 1205 F Location K5, L6

Subcooling Monitors
A psi to Sat/500 F Superheat
B psi to Sat/500 F Superheat

SECONDARY COOLANT SYSTEM S/G Levels A 50% B 50% C 50%
S/G Pressure A 775 psig B 775 psig C 780 psig
S/G Flow A 5.654 lb/hr B 5.654 lb/hr C 0 lb/hr
S/G Feed A 0 lb/hr B 0 lb/hr C 0 lb/hr
Aux. Feed Pump 3A 2 3B 2
AFW Flow S/G A 172 GPM B 172 GPM C 0 GPM

IRMS

S/G BD Monitor A/B 120/2550 cpm
Condenser Air Ejector 1205 cpm
Process Vent (gas) 105 cpm
Process Vent (part) 205 cpm
Vent Vent (gas) 20 cpm
Vent Vent (part) 20 cpm
Letdown (high/low) 305/105 cpm

Cont/Manipulator 10/50 mr/hr
Aux Bldg-Control Area 1 mr/hr
Aux Bldg-Drumming 1 mr/hr
Sample Room 1 mr/hr
New Fuel 1 mr/hr
Spent Fuel Pit 2 mr/hr
Control Room <1 mr/hr

Other:

ENGINEERED SAFEGUARDS

COLD/HOT LEG SI A 0 GPM B 0 GPM C 0 GPM
LHSI Flow A 0 GPM B 0 GPM
Accumulator Level A 57% B 57% C 57%
IRS A AVL B AVL
ORS A AVL B AVL

Emergency Diesel Generators (EDG) 1 OP AVL [check] OOC
2 OP [check] AVL [check] OOC
3 OP AVL [check] OOC

AUXILIARY SYSTEMS

RWST Level 100%
CST Level 73%
Charging Flow 60 GPM
Letdown Flow 60 GPM
VCT Level 40%

BAST A 20%
BAST B 10%
BAST C 10%
CCW: Supply HDR A/B 61 GPM
Return HDR A/B 71 F

NUCLEAR INSTRUMENTATION

POWER RANGE 0 % 0 % 0 % 0 %  
INTR. RANGE 12 AMPS 12 AMPS  
SOURCE RANGE 175 CPS 175 CPS

WIND SPEED 17 MPH  
DIRECT. mmHg  
TEMP. 77 °F  
Δ T -1.1 °F  
σ θ 21 °

PLANT DATA SHEET SURRY UNIT 2  
Date 11/01/02 Time 11:00

PRIMARY SYSTEM RCS Pressure 2210 psig RCP's Oper. A/B/C  
RCS Flow loop A 2 % B 3 % C 0 %

T-Hot/T-Cold Loop A 564/539 °F B 564/539 °F C 575/506 °F  
Pressurizer (Liq/Gas) 655/655 °F Level 52 % Press. 2200 psig  
PRT Temp. 80 °F Level 0 % Press 3 psig  
Safety Valves Open/Closed  
PROV's Open/Closed  
Other

Containment Pressure 9 psia CS Pump Pres.  
Temperature 115 °F  
Sump Level 7 % A 0  
Sump Temp 99 °F B 0

Core Cooling Core Thermocouples  
Avg 578 °F  
Peak 1250 °F Location K5, L6

SECONDARY COOLANT SYSTEM S/G Levels A 20 % B 30 % C 30 %  
S/G Pressure A 875 psig B 875 psig C 985 psig  
S/G Flow A 5584 lb/hr B 5584 lb/hr C 0 lb/hr  
S/G Feed A 0 lb/hr B 0 lb/hr C 0 lb/hr  
Aux. Feed Pump 3A OP 3B up 2 AVL  
APW Flow S/G A 135 GPM B 135 GPM C 0 GPM

Subcooling Monitors  
A — psi to Sat/500 °F Superheat  
B — psi to Sat/500 °F Superheat

ENGINEERED SAFEGUARDS

COLD/HOT LEG SI A 0 GPM B 0 GPM C 0 GPM  
LHSI Flow A 0 GPM B 0 GPM  
Accumulator Level A 57 % B 57 % C 57 %  
IRS A AVL B AVL  
ORS A AVL B AVL

RMS

S/G BD Monitor A/B 110/2550 cpm  
Condenser Air Ejector 1400 cpm  
Process Vent (gas) 1400 cpm  
Process Vent (part) 1400 cpm  
Vent Vent (gas) 70 cpm  
Vent Vent (part) 70 cpm  
Letdown (high/low) 5x10<sup>5</sup>/5x10<sup>5</sup> cpm

Emergency Diesel Generators (EDG) 1 OP \_\_\_ AVL ✓ OOC \_\_\_  
2 OP ✓ AVL \_\_\_ OOC \_\_\_  
3 OP \_\_\_ AVL ✓ OOC \_\_\_

Cont/Manipulator 12/50 mr/hr  
Aux Bldg-Control Area 1 mr/hr  
Aux Bldg-Drumming 1 mr/hr  
Sample Room 1 mr/hr  
New Fuel 1 mr/hr  
Spent Fuel Pit 2 mr/hr  
Control Room 1 mr/hr

AUXILIARY SYSTEMS

RWST Level 10 %  
CST Level 10 %  
Charging Flow 60 GPM  
Letdown Flow 10 GPM  
VCT Level 40 %

Other:

BAST A 30 %  
BAST B 10 %  
BAST C 15 %  
CCW: Supply HDR (A/B) 600 GPM  
Return HDR (A/B) 71 °F  
Package

NUCLEAR INSTRUMENTATION

POWER RANGE 0% 0% 0% 0%
INTR. RANGE 10-11 AMPS 10-11 AMPS
SOURCE RANGE 175 CPS 175 CPS

WIND SPEED 12 MPH
DIRECT. 71mm 72°
TEMP. 13 °F
Δ T -1.07 °F
σ θ 19 °

PLANT DATA SHEET SURRY UNIT 2
Date 11/10/92 Time 1:15

PRIMARY SYSTEM RCS Pressure 2210 psig RCP's Oper. A/B/C
RCS Flow loop A 3% B 5% C 0%
T-Hot/T-Cold Loop A 560/533 °F B 560/533 °F C 575/546 °F
Pressurizer (Liq/Gas) 655/655 °F Level 52% Press. 2200 psig
PRT Temp. 80 °F Level 0% Press 2 psig
Safety Valves Open/Closed
PROV's Open/Closed

Containment Pressure 9 psia CS Pump
Temperature 105 °F Pres.
Sump Level 7% A 0
Sump Temp 79 °F B 0

SECONDARY COOLANT SYSTEM S/G Levels A 30% B 30% C 30%
S/G Pressure A 870 psig B 870 psig C 960 psig
S/G Flow A 5.424 lb/hr B 5.424 lb/hr C 0 lb/hr
S/G Feed A 0 lb/hr B 0 lb/hr C 0 lb/hr
Aux. Feed Pump 3A OP 3B OP 2 AVL
AFW Flow S/G A 120 GPM B 120 GPM C 0 GPM

Core Cooling Core Thermocouples
Avg 575 °F
Peak 1250 °F Location K5, C6

Subcooling Monitors
A - psi to Sat/600 °F Superheat
B - psi to Sat/600 °F Superheat

ENGINEERED SAFEGUARDS

COLD/HOT LEG SI A 0 GPM B 0 GPM C 0 GPM
LHSI Flow A 0 GPM B 0 GPM
Accumulator Level A 57% B 57% C 57%
IRS A AVL B AVL
ORS A AVL B AVL

RMS S/G BD Monitor A/B 110/250 cpm
Condenser Air Ejector 1000 cpm
Process Vent (gas) 100 cpm
Process Vent (part) 200 cpm
Vent Vent (gas) 70 cpm
Vent Vent (part) 70 cpm
Letdown (high/low) 6405/6410 cpm

Emergency Diesel Generators (EDG) 1 OP AVL [check] OOC
2 OP [check] AVL OOC
3 OP AVL [check] OOC

Cont/Manipulator 10/50 mr/hr
Aux Bldg-Control Area 1 mr/hr
Aux Bldg-Drumming 1 mr/hr
Sample Room 1 mr/hr
New Fuel 1 mr/hr
Spent Fuel Pit 2 mr/hr
Control Room <1 mr/hr

AUXILIARY SYSTEMS

RWST Level 10%
CST Level 17%
Charging Flow 60 GPM
Letdown Flow 60 GPM
VCT Level 40%
BAST A 80%
BAST B 70%
BAST C 70%
CCW: Supply HDR A/B 6000 GPM
Return HDR A/B 21 °F

Other:

NUCLEAR INSTRUMENTATION

POWER RANGE 0% 0% 0% 0%
INTR. RANGE 12" AMPS 12" AMPS
SOURCE RANGE 175 CPS 175 CPS

WIND SPEED 10 MPH
DIRECT. 70°
TEMP. 78°F
Δ T -1.07°F
σ θ 18°

PLANT DATA SHEET SURRY UNIT 2
Date 11/10/02 Time 1:30 P

Handwritten note: N/ or imp 3A tag 22 off

PRIMARY SYSTEM RCS Pressure 2210 psig RCP's Oper. A/B/C
RCS Flow loop A 3% B 3% C 0%
T-Hot/T-Cold Loop A 555/520°F B 555/530°F C 575/546°F
Pressurizer (Liq/Gas) 655/655°F Level 52% Press. 2200 psig
PRT Temp. 80°F Level 0% Press 3 psig
Safety Valves Open/Closed
PROV's Open/Closed

Containment Pressure 9 psia CS Pump
Temperature 100°F Pres.
Sump Level 7% A 0
Sump Temp 77°F B 0

Core Cooling Core Thermocouples
Avg 570°F
Peak 1250°F Location K5, C6

Subcooling Monitors
A psi to Sat/500°F Superheat
B psi to Sat/500°F Superheat

SECONDARY COOLANT SYSTEM S/G Levels A 30% B 30% C 30%
S/G Pressure A 440 psig B 440 psig C 440 psig
S/G Flow A 5144 lb/hr B 5144 lb/hr C 0 lb/hr
S/G Feed A 0 lb/hr B 0 lb/hr C 0 lb/hr
Aux. Feed Pump 3A 00C 3B 0P2 AVL
APW Flow S/G A 110 GPM B 110 GPM C 0 GPM

ENGINEERED SAFEGUARDS

COLD/HOT LEG SI A 0 GPM B 0 GPM C 0 GPM
LHSI Flow A 0 GPM B 0 GPM
Accumulator Level A 57% B 57% C 57%
IRS A AVL B AVL
ORS A AVL B AVL

Emergency Diesel Generators (EDG) 1 OP AVL [checked] OOC
2 OP [checked] AVL OOC
3 OP AVL [checked] OOC

RMS S/G BD Monitor A/B 110/2550 cpm
Condenser Air Ejector 1000 cpm
Process Vent (gas) 100 cpm
Process Vent (part) 100 cpm
Vent Vent (gas) 70 cpm
Vent Vent (part) 70 cpm
Letdown (high/low) 600/600 cpm

Cont/Manipulator 10/50 mr/hr
Aux Bldg-Control Area 1 mr/hr
Aux Bldg-Drumming 1 mr/hr
Sample Room 1 mr/hr
New Fuel 1 mr/hr
Spent Fuel Pit 2 mr/hr
Control Room <1 mr/hr

Other:

AUXILIARY SYSTEMS

RWST Level 100%
CST Level 100%
Charging Flow 60 GPM
Letdown Flow 60 GPM
VCT Level 90%

BAST A 0%
BAST B 10%
BAST C 10%
CCW: Supply HDR A/B 6000 GPM
Return HDR A/B 70°F

NUCLEAR INSTRUMENTATION

POWER RANGE 0 % 0 % 0 % 0 %  
 INTR. RANGE 10 AMPS 10 AMPS  
 SOURCE RANGE 175 CPS 175 CPS

WIND SPEED 7 MPH  
 DIRECT. 180 °  
 TEMP. 78 °F  
 Δ T -1.05 °F  
 θ 15 °

PLANT DATA SHEET SURRY UNIT 2  
 Date 11/10/82 Time 7:50

PRIMARY SYSTEM | RCS Pressure 2210 psig RCP's Oper. A/B/C  
 | RCS Flow loop A 2.5 % B 2.5 % C 0 %  
 T-Hot/T-Cold Loop A 507/521 °F B 595/512 °F C 576/545 °F  
 Pressurizer (Liq/Gas) 655/655 °F Level 52 % Press. 2200 psig  
 PRT Temp. 60 °F Level 0 % Press 3 psig  
 Safety Valves Open/Closed  
 PROV's Open/Closed  
 Other \_\_\_\_\_

Containment |  
 Pressure 9 psia CS Pump  
 Temperature 145 °F Pres.  
 Sump Level 7 % A 0  
 Sump Temp 97 °F B 0

Core Cooling |  
 Core Thermocouples  
 Avg 560 °F  
 Peak 1250 °F Location K5 L6

Subcooling Monitors  
 A — psi to Sat/600 °F Superheat  
 B — psi to Sat/620 °F Superheat

SECONDARY COOLANT SYSTEM | S/G Levels A 20 % B 20 % C 20 %  
 S/G Pressure A 790 psig B 790 psig C 930 psig  
 S/G Flow A 434 lb/hr B 434 lb/hr C 0 lb/hr  
 S/G Feed A 0 lb/hr B 0 lb/hr C 0 lb/hr  
 Aux. Feed Pump 3A 00C 3B up 2 AVL  
 AFW Flow S/G A 110 GPM B 110 GPM C 0 GPM

RMS

S/G BD Monitor A/B 110/1250 cpm  
 Condenser Air Ejector 505 cpm  
 Process Vent (gas) 115 cpm  
 Process Vent (part) 175 cpm  
 Vent Vent (gas) 70 cpm  
 Vent Vent (part) 70 cpm  
 Letdown (high/low) 6410/6420 cpm

Cont/Manipulator 10/30 mr/hr  
 Aux Bldg-Control Area 1 mr/hr  
 Aux Bldg-Drumming 1 mr/hr  
 Sample Room 1 mr/hr  
 New Fuel 1 mr/hr  
 Spent Fuel Pit 2 mr/hr  
 Control Room <1 mr/hr

Other:

ENGINEERED SAFEGUARDS

COLD/HOT LEG SI A 0 GPM B 0 GPM C 0 GPM  
 LHSI Flow A 0 GPM B 0 GPM  
 Accumulator Level A 57 % B 57 % C 57 %  
 IRS A AVL B AVL  
 ORS A AVL B AVL

Emergency Diesel Generators (EDG) 1 OP — AVL ✓ OOC —  
 2 OP ✓ AVL — OOC —  
 3 OP — AVL ✓ OOC —

AUXILIARY SYSTEMS

RWST Level 100 % Charging Flow 60 GPM  
 CST Level 60 % Letdown Flow 30 GPM  
 VCT Level 20 %  
 CCW: Supply HDR (A/B) 6000 GPM  
 Return HDR (A/B) 10 °F

BAST A 0 %  
 BAST B 0 %  
 BAST C 0 %



NUCLEAR INSTRUMENTATION

POWER RANGE 0 % 0 % 0 %  
INTR. RANGE 0 AMPS 0 AMPS  
SOURCE RANGE 125 CPS 125 CPS

WIND SPEED 8 MPH  
DIRECT. 45°  
TEMP. 78°  
Δ T -1.03°  
0 0 15

PLANT DATA SHEET  
Date 1/15/72  
SURREY UNIT 2  
Time 2:10 p.m.

PRIMARY SYSTEM  
RCS Pressure 2270 psig  
RCS Flow loop A 2.5 % B 2.5 % C 0 %  
T-Hot/T-Cold Loop A 538/516° F B 533/516° F C 526/505° F  
Pressurizer (Liq/Gas) 655/615° F Level 52 % Press. 2700 psig  
PRT Temp. 40° F  
Safety Valves Open/Closed  
PROV's Open/Closed  
Other

Containment  
Pressure 9 psia CS Pump  
Temperature 74°F  
Sump Level 7 % A 0  
Sump Temp 27°F B 0

Core Cooling  
Core Thermocouples  
Avg 550° F  
Peak 750° F Location KS LL

SECONDARY COOLANT SYSTEM  
S/G Pressure A 735 psig B 735 psig C 725 psig  
S/G Flow A 264 lb/hr B 244 lb/hr C 0 lb/hr  
S/G Feed A 0 lb/hr B 0 lb/hr C 0 lb/hr  
Aux. Feed Pump 3A 600 3B 0 2 745  
AFW Flow S/G A 735 GPM B 745 GPM C GPM

Subcooling Monitors  
A psi to Sat/60° F Superheat  
B psi to Sat/50° F Superheat

ENGINEERED SAFEGUARDS

COLD/HOT LEG SI A 0 GPM B 0 GPM C 0 GPM  
LHSI Flow A 0 GPM B 0 GPM  
Accumulator Level A 57 % B 57 % C 57 %  
IRS A 745 B 745  
ORS A 745 B 745

Emergency Diesel Generators (EDG)  
1 OP AVL ✓ OOC  
2 OP ✓ AVL OOC  
3 OP ✓ AVL OOC

S/G BD Monitor A/B 110/255 cpm  
Condenser Air Ejector 20 cpm  
Process Vent (gas) 20 cpm  
Process Vent (part) 20 cpm  
Vent Vent (gas) 20 cpm  
Vent Vent (part) 20 cpm  
Letdown (high/low) 605/605 cpm

AUXILIARY SYSTEMS

RWST Level 70 %  
CST Level 50 %  
Charging Flow 70 GPM  
Letdown Flow 70 GPM  
VCT Level 50 %

Cont/Manipulator 10/50 m/hr  
Aux Bldg-Control Area 1 m/hr  
Aux Bldg-Drumming 1 m/hr  
Sample Room 1 m/hr  
New Fuel 1 m/hr  
Spent Fuel Pit 1 m/hr  
Control Room 1 m/hr

BAST A 70 %  
BAST B 50 %  
CCW: Supply HDR A/B 60 %  
Return HDR A/B 70 %  
Other:

NUCLEAR INSTRUMENTATION

PLANT DATA SHEET SURRY UNIT 2  
Date 4/10/82 Time 2:30 PM

POWER RANGE 0% 0% 0% 0%  
INTR. RANGE 1000 AMPS 1000 AMPS  
SOURCE RANGE 175 CPS 175 CPS

WIND SPEED 7 MPH  
DIRECT. 74.00 63°  
TEMP. 72°  
Δ T 103°  
0 0 15°

PRIMARY SYSTEM | RCS Pressure 2200 psig RCP's Oper. A/B/C  
| RCS Flow loop A 75% B 75% C 0%

T-Hot/T-Cold Loop A 532/570°F B 532/570°F C 570/565°F  
Pressurizer (Liq/Gas) 655/655°F Level 52% Press. 2700 psig  
PRT Temp. 70°F Level 0% Press 3%  
Safety Valves Open/Closed  
PROV's Open/Closed  
Other

Containment  
Pressure 9 psia CS Pump Pres.  
Temperature 74°F  
Sump Level 7% A  
Sump Temp 77°F B

Core Cooling  
Core Thermocouples  
AVG 547°F  
Peak 1250°F Location K5, L6

SECONDARY COOLANT SYSTEM | S/G Levels A 37% B 30% C 50%  
S/G Pressure A 730 psig B 730 psig C 970 psig  
S/G Flow A 444 lb/hr B 444 lb/hr C 0 lb/hr  
S/G Feed A 0 lb/hr B 0 lb/hr C 0 lb/hr  
Aux. Feed Pump 3A 0.03B of 2 Air  
AFW Flow S/G A 100 GPM B 100 GPM C 0 GPM

Subcooling Monitors  
A psi to Sat/600°F Superheat  
B psi to Sat/600°F Superheat

ENGINEERED SAFEGUARDS

COLD/HOT LEG SI A 0 GPM B 0 GPM C 0 GPM  
LMSI Flow A 0 GPM B 0 GPM  
Accumulator Level A 57% B 52% C 57%  
IRS A 0% B 0%  
ORS A 0% B 0%

S/G BD Monitor A/B 10/2000 cpm  
Condenser Air Ejector 400 cpm  
Process Vent (gas) 200 cpm  
Process Vent (part) 200 cpm  
Vent Vent (gas) 200 cpm  
Vent Vent (part) 200 cpm  
Letdown (high/low) 65.8/1000 cpm

Emergency Diesel Generators (EDG) 1 OP AVL ✓ OOC  
2 OP AVL ✓ OOC  
3 OP AVL ✓ OOC

AUXILIARY SYSTEMS

RWST Level 56%  
CST Level 56%  
Charging Flow 0 GPM  
Letdown Flow 0 GPM  
VCT Level 25%

Cont/Manipulator 40/50 MI/hr  
Aux Bldg-Control Area 1 MI/hr  
Aux Bldg-Drumming 1 MI/hr  
Sample Room 1 MI/hr  
New Fuel 1 MI/hr  
Spent Fuel Pit 2 MI/hr  
Control Room 2 MI/hr

BAST A 0%  
BAST B 0%  
CCW: Supply HDR A/B 60 GPM  
Return HDR A/B 70 GPM  
°F

Other:

NUCLEAR INSTRUMENTATION

POWER RANGE 0 % 0 % 0 % 0 %  
 INTR. RANGE 15 AMPS 15 AMPS  
 SOURCE RANGE 75 CPS 175 CPS

WIND SPEED 0 MPH  
 DIRECT 7.0 °F  
 TEMP. 77 °F  
 Δ T -1.02 °F  
 0 0 15 °

PLANT DATA SHEET SURRY UNIT 2  
 Date 11/10/72 Time 2:05

PRIMARY SYSTEM | RCS Pressure 2210 psig RCP's Oper. A/B/C  
 | RCS Flow loop A 2.5 % B 2.5 % C 0 %  
 T-Hot/T-Cold Loop A 527/505 °F B 527/505 °F C 576/505 °F  
 Pressurizer (Liq/Gas) 655/655 °F Level 52 % Press. 2200 psig  
 PRT Temp. 80 °F Level 0 % Press 3 psig  
 Safety Valves Open/Closed  
 PROV's Open/Closed  
 Other \_\_\_\_\_

Containment |  
 Pressure 9 psia CS Pump  
 Temperature 100 °F Pres.  
 Sump Level 7 % A 0  
 Sump Temp 97 °F B 0

SECONDARY COOLANT SYSTEM | S/G Levels A 33 % B 33 % C 30 %  
 S/G Pressure A 720 psig B 750 psig C 915 psig  
 S/G Flow A 451 lb/hr B 458 lb/hr C 0 lb/hr  
 S/G Feed A 0 lb/hr B 0 lb/hr C 0 lb/hr  
 Aux. Feed Pump 3A 20 C 3B 0 2 AVL  
 AFW Flow S/G A 75 GPM B 75 GPM C 0 GPM

Core Cooling |  
 Core Thermocouples  
 Avg 590 °F  
 Peak 750 °F Location KS, 66

Subcooling Monitors  
 A     psi to Sat/600 °F Superheat  
 B     psi to Sat/600 °F Superheat

ENGINEERED SAFEGUARDS

COLD/HOT LEG SI A 0 GPM B 0 GPM C 0 GPM  
 LHSI Flow A 0 GPM B 0 GPM  
 Accumulator Level A 57 % B 57 % C 57 %  
 IRS A AVL B AVL  
 ORS A AVL B AVL

S/G BD Monitor A/B 110/2600 cpm  
 Condenser Air Ejector 200 cpm  
 Process Vent (gas) 100 cpm  
 Process Vent (part) 100 cpm  
 Vent Vent (gas) 70 cpm  
 Vent Vent (part) 70 cpm  
 Letdown (high/low) 7.10/7.10 cpm

Emergency Diesel Generators (EDG) 1 OP     AVL  OOC      
 2 OP  AVL     OOC      
 3 OP     AVL  OOC    

Cont/Manipulator 10/50 mr/hr  
 Aux Bldg-Control Area 1 mr/hr  
 Aux Bldg-Drumming 1 mr/hr  
 Sample Room 1 mr/hr  
 New Fuel 1 mr/hr  
 Spent Fuel Pit 2 mr/hr  
 Control Room 21 mr/hr

AUXILIARY SYSTEMS

RWST Level 40 %  
 CST Level 50 %  
 Charging Flow 70 GPM  
 Letdown Flow 50 GPM  
 VCT Level     %  
 BAST A 30 %  
 BAST B     %  
 BAST C     %  
 CCW: Supply HDR A/B 6000 GPM  
 Return HDR A/B 20 °F

Other:

NUCLEAR INSTRUMENTATION

POWER RANGE 0 % 0 % 0 % 0 %  
INTR. RANGE 10 AMPS 10 AMPS  
SOURCE RANGE 175 CPS 175 CPS

WIND SPEED 7 MPH  
DIRECT. 120°  
TEMP. 77 °F  
Δ T 102 °F  
0 0 15 °

PLANT DATA SHEET SURRY UNIT 2  
Date 11/10/72 Time 5:05 PM

PRIMARY SYSTEM RCS Pressure 2210 psig RCP's Oper. A/B/C  
RCS Flow loop A 25 % B 25 % C 0 %  
T-Hot/T-Cold Loop A 520/499 °F B 520/499 °F C 515/504 °F  
Pressurizer (Liq/Gas) 655/655 °F Level 52 % Press. 2700 psig  
PRT Temp. 80 °F Level 0 % Press 3 psig  
Safety Valves Open/Closed  
PROV's Open/Closed  
Other

Containment Pressure 9 psia CS Pump Pres.  
Temperature 100 °F  
Sump Level 7 % A 0  
Sump Temp 97 °F B 0

Core Cooling Core Thermocouples  
Avg 530 °F  
Peak 1250 °F Location K5 L6

SECONDARY COOLANT SYSTEM S/G Levels A 34 % B 34 % C 30 %  
S/G Pressure A 705 psig B 755 psig C 710 psig  
S/G Flow A 900 lb/hr B 880 lb/hr C 0 lb/hr  
S/G Feed A 0 lb/hr B 0 lb/hr C 0 lb/hr  
Aux. Feed Pump 3A 00 C 3B 0p 2 AVL  
AFW Flow S/G A 100 GPM B 0 GPM C 0 GPM

Subcooling Monitors  
A - psi to Sat/600 °F Superheat  
B - psi to Sat/600 °F Superheat

RMS

S/G BD Monitor A/B 110/260 cpm  
Condenser Air Ejector 200 cpm  
Process Vent (gas) 100 cpm  
Process Vent (part) 100 cpm  
Vent Vent (gas) 20 cpm  
Vent Vent (part) 10 cpm  
Letdown (high/low) 20/200 cpm

Cont/Manipulator 10/50 mr/hr  
Aux Bldg-Control Area 1 mr/hr  
Aux Bldg-Drumming 1 mr/hr  
Sample Room 1 mr/hr  
New Fuel 1 mr/hr  
Spent Fuel Pit 0 mr/hr  
Control Room 1 mr/hr

Other:

ENGINEERED SAFEGUARDS

COLD/HOT LEG SI A 0 GPM B 0 GPM C 0 GPM  
LH SI Flow A 0 GPM B 0 GPM  
Accumulator Level A 57 % B 57 % C 57 %  
IRS A AVL B AVL  
ORS A AVL B AVL

Emergency Diesel Generators (EDG) 1 OP AVL OOC  
2 OP AVL OOC  
3 OP AVL OOC

AUXILIARY SYSTEMS

RWST Level 100 %  
CST Level 52 %  
Charging Flow 70 GPM  
Letdown Flow 0 GPM  
VCT Level 0 %

BAST A 0 %  
BAST B 0 %  
BAST C 0 %  
CCW: Supply HDR (A/B) 0 GPM  
Return HDR (A/B) 70 °F

NUCLEAR INSTRUMENTATION

POWER RANGE 0 % 0 AMPS 0 % 0 AMPS  
INTR. RANGE 10 AMPS 0 % 0 AMPS  
SOURCE RANGE 175 CPS 175 CPS

WIND SPEED 7 MPH  
DIRECT. 100 ft/hr  
TEMP. 79 °F  
A T -102 °F  
0 0 15 °

PLANT DATA SHEET SURRY UNIT 2  
Date 4/10/68 Time 3:15 PM

PRIMARY SYSTEM RCS Pressure 2210 psig RCP's Oper. A/B/C  
RCS Flow Loop A 25 % B 25 % C 0 %

T-Hot/T-Cold Loop A 514/473 °F B 594/472 °F C 570/442 °F  
Pressurizer (L/G) 655/655 °F Level 52 % Press. 2200 psig  
F Level 0 % Press 3 psig  
Safety Valves Open/Closed  
PROV'S Open/Closed  
Other

SECONDARY COOLANT SYSTEM S/G Levels A 54 % B 32 % C 30 %  
S/G Pressure A 700 psig B 805 psig C 707 psig  
S/G Flow A 324 lb/hr B 544 lb/hr C 0 lb/hr  
S/G Feed A 0 lb/hr B 0 lb/hr C 0 lb/hr  
Aux. Feed Pump 3A 0 GPM 3B 0 GPM 2 0 GPM  
APW Flow S/G A 10 GPM B 0 GPM C 0 GPM

ENGINEERED SAFEGUARDS

COLD/HOT LEG SI A 0 GPM B 0 GPM C 0 GPM  
LHSI Flow A 0 GPM B 0 GPM  
Accumulator Level A 57 % B 57 % C 57 %  
IRS A 0 B 0  
ORS A 0 B 0

Emergency Diesel Generators (EDG) 1 OP AVL ✓ OOC  
2 OP AVL OOC  
3 OP AVL ✓ OOC

AUXILIARY SYSTEMS

RWT Level 0 %  
CST Level 0 %  
Charging Flow 70 GPM  
Letdown Flow 60 GPM  
VCT Level 30 %

BAST A 0 %  
BAST B 0 %  
BAST C 0 %  
CCW: Supply HDR A/B 6.7 L GPM  
Return HDR A/B 70 GPM

Containment Pressure 9 psia CS Pump  
Temperature 70 °F Pres. A 0  
Sump Level 7 % B 0  
Sump Temp 67 °F

Core Cooling Core Thermocouples  
AVG 525 °F  
Peak 1750 °F Location K5, L1

Subcooling Monitors  
A psi to Sat/600 °F Superheat  
B psi to Sat/600 °F Superheat

RMS

S/G BD Monitor A/B 11/2450 cpm  
Condenser Air Ejector 100 cpm  
Process Vent (gas) 100 cpm  
Process Vent (part) 100 cpm  
Vent Vent (gas) 70 cpm  
Vent Vent (part) 70 cpm  
Letdown (high/low) 245/140 cpm

Cont/Manipulator 20/50 mt/hr  
Aux Bldg-Control Area 1 mt/hr  
Aux Bldg-Drumming 1 mt/hr  
Sample Room 1 mt/hr  
New Fuel 2 mt/hr  
Spent Fuel Pit 21 mt/hr  
Control Room 21 mt/hr

Other:

NUCLEAR INSTRUMENTATION

POWER RANGE 0 % 0 8 0 8 0 %  
INTR. RANGE 15 AMPS 15 AMPS  
SOURCE RANGE 175 CPS 175 CPS

WIND SPEED 7 MPH  
DIRECT. 4.0 67°  
TEMP. 80 °F  
Δ T -1.02 °F  
0 θ 15 °

PLANT DATA SHEET SURRY UNIT 2  
Date 11/10/82 Time 3:55 PM

PRIMARY SYSTEM RCS Pressure 2210 psig RCP's Oper. A/B/C  
RCS Flow loop A 2.5 % B 2.5 % C 0 %  
T-Hot/T-Cold Loop A 505/489 °F B 505/489 °F C 567/540 °F  
Pressurizer (Liq/Gas) 655/655 °F Level 52 % Press. 2200 psig  
PRT Temp. 80 °F Level 0 % Press 8 psig  
Safety Valves Open/Closed  
PROV's Open/Closed  
Other

Containment Pressure 9 psia CS Pump Pres.  
Temperature 100 °F  
Sump Level 7 % A 0  
Sump Temp 77 °F B 0

Core Cooling Core Thermocouples  
Avg 515 °F  
Peak 1250 °F Location KS 66

SECONDARY COOLANT SYSTEM S/G Levels A 32 % B 32 % C 30 %  
S/G Pressure A 850 psig B 805 psig C 900 psig  
S/G Flow A 354 lb/hr B 554 lb/hr C 0 lb/hr  
S/G Feed A 0 lb/hr B 0 lb/hr C 0 lb/hr  
Aux. Feed Pump 3A 200 3B 0 2 AVL  
AFW Flow S/G A 120 GPM B 0 GPM C 0 GPM

Subcooling Monitors  
A \_\_\_ psi to Sat/600 °F Superheat  
B \_\_\_ psi to Sat/500 °F Superheat

ENGINEERED SAFEGUARDS

COLD/HOT LEG SI A 0 GPM B 0 GPM C 0 GPM  
LHSI Flow A 0 GPM B 0 GPM  
Accumulator Level A 57 % B 57 % C 57 %  
IRS A AVL B AVL  
ORS A AVL B AVL

RMS S/G BD Monitor A/B 110/2600 cpm  
Condenser Air Ejector 150 cpm  
Process Vent (gas) 105 cpm  
Process Vent (part) 100 cpm  
Vent Vent (gas) 20 cpm  
Vent Vent (part) 20 cpm  
Letdown (high/low) 700/2400 cpm

Emergency Diesel Generators (EDG) 1 OP \_\_\_ AVL  OOC \_\_\_  
2 OP  AVL \_\_\_ OOC \_\_\_  
3 OP \_\_\_ AVL  OOC \_\_\_

Cont/Manipulator 10/50 mr/hr  
Aux Bldg-Control Area 1 mr/hr  
Aux Bldg-Drumming 1 mr/hr  
Sample Room 1 mr/hr  
New Fuel 1 mr/hr  
Spent Fuel Pit 2 mr/hr  
Control Room <1 mr/hr

AUXILIARY SYSTEMS

RWST Level 71 %  
CST Level 97 %  
Charging Flow 60 GPM  
Letdown Flow 70 GPM  
VCT Level 32 %  
BAST A 0 %  
BAST B 0 %  
BAST C 15 %  
CCW: Supply HDR A/B 6000 GPM  
Return HDR A/B 200 °F

Other:

POWER RANGE 0 % 0 % 0 % 0 %  
 INTR. RANGE 0 AMPS 0 AMPS  
 SOURCE RANGE 175 CPS 175 CPS

SPEED 3 MPH  
 DIRECT. 100 °F  
 TEMP. 30 °F  
 Δ T -1.02 °F  
 0 0 15 °

PLANT DATA SHEET SURVEY UNIT 2  
 Date 11/10/92 Time 3:50 PM  
 MS Acc. & Pres. as indicated

PRIMARY SYSTEM | RCS Pressure 2210 psig RCP's Oper. A B/C  
 | RCS Flow loop A 25 % B 25 % C 0 %  
 T-Hot/T-Cold Loop A 478 / 482 °F B 478 / 482 °F C 564 / 578 °F  
 Pressurizer (Liq/Gas) 655 / 555 °F Level 52 % Press. 2200 psig  
 PRT Temp. 90 °F Level 0 % Press 3 psig  
 Safety Valves Open/Closed  
 PROV's Open/Closed  
 Other \_\_\_\_\_

Containment |  
 Pressure 9 psia CS Pump  
 Temperature 100 °F Pres.  
 Sump Level 7 % A 0  
 Sump Temp 97 °F B 0

SECONDARY COOLANT SYSTEM | S/G Levels A 30 % B 33 % C 20 %  
 S/G Pressure A 625 psig B 650 psig C 590 psig  
 S/G Flow A 290 lb/hr B 0 lb/hr C 0 lb/hr  
 S/G Feed A 0 lb/hr B 0 lb/hr C 0 lb/hr  
 Aux. Feed Pump 3A 00C 3B 0P 2 AVL  
 AFW Flow S/G A 120 GPM B 0 GPM C 0 GPM

Core Cooling |  
 Core Thermocouples  
 Avg 505 °F  
 Peak 1250 °F Location K5 66

Subcooling Monitors  
 A — psi to Sat/600 °F Superheat  
 B — psi to Sat/600 °F Superheat

ENGINEERED SAFEGUARDS |  
 COLD/HOT LEG SI A 0 GPM B 0 GPM C 0 GPM  
 LHSI Flow A 0 GPM B 0 GPM  
 Accumulator Level A 57 % B 57 % C 57 %  
 IRS A AVL B AVL  
 ORS A AVL B AVL  
 Emergency Diesel Generators (EDG) 1 OP — AVL ✓ OOC —  
 2 OP ✓ AVL — OOC —  
 3 OP — AVL ✓ OOC —

RMS |  
 S/G BD Monitor A/B 115/2650 cpm  
 Condenser Air Ejector 157 cpm  
 Process Vent (gas) 157 cpm  
 Process Vent (part) 157 cpm  
 Vent Vent (gas) 70 cpm  
 Vent Vent (part) 70 cpm  
 Letdown (high/low) 70/2650 cpm

Cont/Manipulator 10/50 mr/hr  
 Aux Bldg-Control Area 1 mr/hr  
 Aux Bldg-Drumming 1 mr/hr  
 Sample Room 1 mr/hr  
 New Fuel 1 mr/hr  
 Spent Fuel Pit 2 mr/hr  
 Control Room 21 mr/hr

AUXILIARY SYSTEMS |  
 RWST Level 40 % Charging Flow 70 GPM  
 CST Level 47 % Letdown Flow 25 GPM  
 VCT Level 33 %  
 BAST A 70 % CCW: Supply HDR (A/B) 6000 GPM  
 BAST B 70 % Return HDR (A/B) 70 °F  
 BAST C 75 %  
 BAST C 75 %

Other:

NUCLEAR INSTRUMENTATION

PLANT DATA SHEET  
Date 11/10/73  
SURREY UNIT 4  
Time 9:25 PM

POWER RANGE 0 % AMPS 0 % 0 %  
INTR. RANGE 10 AMPS 10 AMPS  
SOURCE RANGE 10 CPS 120 CPS  
WIND SPEED 9 MPH  
DIRECT. TEMP. 67 °F  
Δ T -1.3 °F  
0 0

PRIMARY SYSTEM  
RCS Pressure 2210 psig RCP's Oper. AVB/C  
RCS Flow loop A AV % B 10 % C 10 %

T-Hot/T-Cold Loop A 485/465 °F B 465/465 °F C 465/465 °F  
Pressurizer (Liq/Gas) 653/653 °F Level 25 % Press. 2200 psig  
PRT Temp. 80 °F Level 0 % Press 3 psig  
Safety Valves Open/Closed  
PROV's Open/Closed  
Other

SECONDARY COOLANT SYSTEM  
S/G Levels A 34 % B 34 % C 34 %  
S/G Pressure A 500 psig B 880 psig C 820 psig  
S/G Flow A 724 lb/hr B 0 lb/hr C 0 lb/hr  
S/G Feed A 0 lb/hr B 0 lb/hr C 0 lb/hr  
Aux. Feed Pump 3A 000 3B 0 2 AVL  
APW Flow S/G A 100 GPM B 0 GPM C 0 GPM

ENGINEERED SAFEGUARDS

COLD/HOT LEG SI A 0 GPM B 0 GPM C 0 GPM  
LHSI Flow A 0 GPM B 0 GPM  
Accumulator Level A 57 % B 57 % C 57 %  
IRS A AVL B AVL  
ORS A AVL B AVL

Emergency Diesel Generators (EDG)  
1 OP  AVL  OOC  
2 OP  AVL  OOC  
3 OP  AVL  OOC

AUXILIARY SYSTEMS

RWST Level 100 %  
CST Level 91 %  
Charging Flow 50 GPM  
Letdown Flow 120 GPM  
VCT Level 10 %  
CCW: Supply HDR AVB GPM  
Return HDR AVB GPM

BAST A 100 %  
BAST B 100 %  
BAST C 100 %

Containment  
Pressure 9 psia CS Pump Pres.  
Temperature AV °F  
Sump Level 1 % A 0  
Sump Temp 89 °F B 0

Core Cooling  
Core Thermocouples  
Avg 425 °F  
Peak 490 °F Location K5

Subcooling Monitors  
A 159 psi to Sat / AV °F Superheat  
B 159 psi to Sat / AV °F Superheat

IRMS

S/G BD Monitor A/B 110/2550 cpm  
Condenser Air Ejector 250 cpm  
Process Vent (gas) 45 cpm  
Process Vent (part) 20 cpm  
Vent Vent (gas) 20 cpm  
Vent Vent (part) 20 cpm  
Letdown (high/low) 245/2505 cpm

Cont/Manipulator 0/50 ml/hr  
Aux Bldg-Control Area 1 ml/hr  
Aux Bldg-Drumming 1 ml/hr  
Sample Room 1 ml/hr  
New Fuel 1 ml/hr  
Spent Fuel Pit 2 ml/hr  
Control Room 21 ml/hr

Other:



NUCLEAR INSTRUMENTATION

POWER RANGE 0% 0% 0% 0%  
INTR. RANGE 10-11 AMPS 10-11 AMPS  
SOURCE RANGE 100 CPS 100 CPS

WIND SPEED 11 MPH  
DIRECT 1.05°  
TEMP. 75°  
Δ T -1.2°  
0 0 19°

PLANT DATA SHEET  
Date 11/20/72  
SURREY UNIT 2  
Time 9:45

7:10 run 7:00 PM  
RCS is in RHR

PRIMARY SYSTEM | RCS Pressure 315 psig RCP's Oper.  B/C  
RCS Flow loop A 10% B 10% C 10%

T-Hot/T-Cold Loop A 310/310°F B 30/30°F C 30/30°F  
Pressurizer (Liq/Gas) 30/30°F Level 100% Press. 310 psig  
PRT Temp. 60°F Level 0% Press 3 psig  
Safety Valves Open/Closed  
PROV's Open/Closed  
Other

SECONDARY COOLANT SYSTEM | S/G Levels A 30% B 35% C 30%  
S/G Pressure A 100 psig B 100 psig C 100 psig  
S/G Flow A 0 lb/hr B 0 lb/hr C 0 lb/hr  
S/G Feed A 0 lb/hr B 0 lb/hr C 0 lb/hr  
Aux. Feed Pump 3A 0 GPM B 0 GPM C 0 GPM  
AFW Flow S/G A 0 GPM B 0 GPM C 0 GPM

ENGINEERED SAFEGUARDS

COLD/HOT LEG SI A 0 GPM B 0 GPM C 0 GPM  
LMSI Flow A 0 GPM B 0 GPM  
Accumulator Level A 57% B 52% C 52%  
IRS A 100% B 100%  
ORS A 100% B 100%

Emergency Diesel Generators (EDG) 1 OP  AVL  OOC  
2 OP  AVL  OOC  
3 OP  AVL  OOC

AUXILIARY SYSTEMS

RWST Level 100%  
CST Level 40%  
Charging Flow 30 GPM  
Letdown Flow 0 GPM  
VCT Level 30%  
CCW: Supply HDR A/B 100% GPM  
Return HDR A/B 100% GPM  
BAST A 100%  
BAST B 100%  
BAST C 100%

Containment | Pressure 9 psia CS Pump  
Temperature 100°F Pres. A 0  
Sump Level 7% B 0  
Sump Temp 95°F C 0

Core Cooling | Core Thermocouples  
AV9 375°F  
Peak 319°F Location K5

Subcooling Monitors  
A 227 psi to Sat/°F Superheat  
B 227 psi to Sat/°F Superheat

(RMS)

S/G BD Monitor A/B 110/2600 cpm  
Condenser Air Ejector 10 cpm  
Process Vent (gas) 10 cpm  
Process Vent (part) 10 cpm  
Vent Vent (gas) 10 cpm  
Vent Vent (part) 10 cpm  
Letdown (high/low) 10/10 cpm

Cont/Manipulator 10/30 ml/hr  
Aux Bldg-Control Area 1 ml/hr  
Aux Bldg-Drumming 1 ml/hr  
Sample Room 1 ml/hr  
New Fuel 1 ml/hr  
Spent Fuel Pit 1 ml/hr  
Control Room 1 ml/hr


Other:

APPENDIX B

Onsite In-Plant Doses

Inside Buildings

ONSITE PROTECTED AREA MAP



Time: 9:30 to 2:49

Onsite In-Plant Doses - Inside Buildings

<u>Location</u> (Zone)	<u>Whole Body Dose</u> (MR/HR)		<u>Thyroid Dose</u> (cpm $\mu$ Ci/cc)		
A		<1		0	0
B		<1		0	0
C		<1		0	0
D		<1		0	0
E		<1		0	0

Note: Above values do not  
apply to control room  
or counting/analysis rooms

Time: 2:50 to 3:14

Onsite In-Plant Doses - Inside Buildings

<u>Location</u> (Zone)	<u>Whole Body Dose</u> (MR/HR)		<u>Thyroid Dose</u> (cpm $\mu\text{Ci/cc}$ )	
	A		5	
B		20		$5 \times 10^3$ $1.6 \times 10^{-7}$
C		31		$9.5 \times 10^4$ $3.02 \times 10^{-6}$
D		6		$5 \times 10^3$ $1.6 \times 10^{-7}$
E		2		$4 \times 10^2$ $1.2 \times 10^{-8}$

Note: Above values do not  
apply to control room  
or counting/analysis rooms

Time: 3:15 to 3:44

Onsite In-Plant Doses - Inside Buildings

<u>Location</u> (Zone)	<u>Whole Body Dose</u>		<u>Thyroid Dose</u>		
		(MR/HR)	(cpm)	$\mu\text{Ci/cc}$	
A		7		$1.8 \times 10^3$	$5.7 \times 10^{-8}$
B		18		$2.9 \times 10^4$	$9.2 \times 10^{-7}$
C		32		$2.93 \times 10^5$	$9.3 \times 10^{-6}$
D		8		$2.9 \times 10^4$	$9.2 \times 10^{-7}$
E		1		$1.8 \times 10^3$	$5.7 \times 10^{-8}$

Note: Above values do not  
apply to control room  
or counting/analysis rooms

Time: 3:45 to 4:14

Onsite In-Plant Doses - Inside Buildings

<u>Location</u> (Zone)	<u>Whole Body Dose</u>		<u>Thyroid Dose</u>	
		(MR/HR)	(cpm)	μCi/cc)
A		< 1		0
B		2		$1.5 \times 10^2$
C		3		$4.6 \times 10^{-9}$
D		2		$2.9 \times 10^3$
E		< 1		$1.5 \times 10^2$
				$4.6 \times 10^{-9}$
				0

Note: Above values do not  
apply to control room  
or counting/analysis rooms

Time: 4:15 to 4:44

Onsite In-Plant Doses - Inside Buildings

<u>Location</u> (Zone)	<u>Whole Body Dose</u> (MR/HR)		<u>Thyroid Dose</u>	
			(cpm)	$\mu\text{Ci/cc}$
A		<1		0
B		<1		195
C		<1		230
D		<1		195
E		<1		0

Note: Above values do not  
apply to control room  
or counting/analysis rooms



Time: 4:45 to 4:54

Onsite In-Plant Doses - Inside Buildings

<u>Location</u> (Zone)	<u>Whole Body Dose</u>		<u>Thyroid Dose</u>	
		(MR/HR)	(cpm)	μCi/cc)
A		<1		0
B		<1		0
C		<1		0
D		<1		0
E		<1		0

Note: Above values do not  
apply to control room  
or counting/analysis rooms

Time: 7:00

Onsite In-Plant Doses

<u>Location</u> (Zone)	<u>Whole Body Dose</u> (MR/HR)	<u>Thyroid Dose</u>	
		(cpm)	$\mu$ Ci/cc)
A	<1	0	0
B	<1	0	0
C	<1	0	0
D	<1	0	0
E	<1	0	0


Note: Above values do not  
apply to control room  
or counting/analysis rooms

APPENDIX B1

Onsite Plant Dose

Outside Buildings

ONSITE PROTECTED AREA MAP



Time: 9:30 to 2:49

Onsite Plant Doses - Outside Buildings

<u>Location</u> (Zone)	<u>Whole Body Dose</u> (MR/HR)		<u>Thyroid Dose</u>		
			(cpm)	$\mu$ Ci/cc)	
A		< 1		0	0
B		< 1		0	0
C		< 1		0	0
D		< 1		0	0
E		< 1		0	0

Time: 2:50 to 3:54

Onsite Plant Doses - Outside Buildings

<u>Location</u> (Zone)		<u>Whole Body Dose</u>		<u>Thyroid Dose</u>	
		(MR/HR)		(cpm)	$\mu\text{Ci/cc}$ )
A		10		$1 \times 10^5$	$3.2 \times 10^{-6}$
B		23		$1.4 \times 10^5$	$4.4 \times 10^{-6}$
C		80		$5 \times 10^5$	$1.6 \times 10^{-5}$
D		17		$1 \times 10^5$	$3.2 \times 10^{-6}$
E		7		$5 \times 10^4$	$1.6 \times 10^{-6}$

Time: 3:55 to 4:14

Onsite Plant Doses - Outside Buildings

<u>Location</u> (Zone)	<u>Whole Body Dose</u> (MR/HR)	<u>Thyroid Dose</u>	
		(cpm)	$\mu\text{Ci/cc}$
A	1	60	$1.9 \times 10^{-9}$
B	3	78	$2.5 \times 10^{-9}$
C	15	260	$8.3 \times 10^{-9}$
D	5	62	$2 \times 10^{-9}$
E	2	48	$1.5 \times 10^{-9}$

Time: 4:15 to 4:44

Onsite Plant Doses - Outside Buildings

<u>Location</u> (Zone)	<u>Whole Body Dose</u>		<u>Thyroid Dose</u>	
	(MR/HR)		(cpm)	( $\mu\text{Ci/cc}$ )
A	< 1		48	$1.5 \times 10^{-9}$
B	1.5		79	$2.4 \times 10^{-9}$
C	4.5		215	$6.8 \times 10^{-9}$
D	< 1		77	$2.4 \times 10^{-9}$
E	< 1		50	$1.6 \times 10^{-9}$



Time: 4:45 to 4:54

Onsite Plant Doses - Outside Buildings

<u>Location</u> (Zone)	<u>Whole Body Dose</u> (MR/HR)		<u>Thyroid Dose</u>	
			(cpm)	( $\mu\text{Ci/cc}$ )
A		< 1		0
B		< 1		45
C		2.5		85
D		1		50
E		< 1		0

$1.4 \times 10^{-9}$   
 $2.7 \times 10^{-9}$   
 $1.6 \times 10^{-9}$

Time: 7:00


Onsite Plant Doses - Outside Buildings

<u>Location</u> (Zone)	<u>Whole Body Dose</u>		<u>Thyroid Dose</u>		
	(MR/HR)		(cpm)	( $\mu$ Ci/cc)	
A		< 1		0	0
B		< 1		0	0
C		< 1		0	0
D		< 1		0	0
E		< 1		0	0

APPENDIX C

Onsite Out-Of-Plant Doses

SITE BOUNDARY MAP



Time: 9:30 to 2:49

Onsite Out-Of-Plant Doses

<u>Location</u> (Zone)	<u>Whole Body Dose</u>		<u>Thyroid Dose</u>	
		(MR/HR)	(cpm)	( $\mu$ ci/cc)
A		< 1		0
B		< 1		0
C		< 1		0

Time: 2:50 to 3:55

Onsite Out-Of-Plant Doses

<u>Location</u> (Zone)		<u>Whole Body Dose</u> (MR/HR)		<u>Thyroid Dose</u>	
				(cpm)	( $\mu$ ci/cc)
A		21		$1.29 \times 10^5$	$4 \times 10^{-6}$
B		73		$4.5 \times 10^5$	$1.4 \times 10^{-5}$
C		15		$9.19 \times 10^4$	$2.9 \times 10^{-6}$

Time: 3:55 to 4:14

Onsite Out-Of-Plant Doses

<u>Location</u> (Zone)	<u>Whole Body Dose</u> (MR/HR)	<u>Thyroid Dose</u>	
		(cpm)	( $\mu$ ci/cc)
A	2	71	$2.22 \times 10^{-9}$
B	10	235	$7.4 \times 10^{-9}$
C	3	56	$1.8 \times 10^{-9}$

Time: 4:15 to 4:44

Onsite Out-Of-Plant Doses

<u>Location</u> (Zone)	<u>Whole Body Dose</u> (MR/HR)	<u>Thyroid Dose</u>	
		(cpm)	( $\mu\text{Ci/cc}$ )
A	1	72	$2.2 \times 10^{-9}$
B	4	195	$6.2 \times 10^{-9}$
C	1	70	$2.1 \times 10^{-9}$



Time: 4:45 to 4:54

Onsite Out-Of-Plant Doses

<u>Location</u> (Zone)		<u>Whole Body Dose</u> (MR/HR)			<u>Thyroid Dose</u> (cpm $\mu\text{Ci/cc}$ )	
		<				
A		<	1		0	0
B			2		78	$2.4 \times 10^{-9}$
C			1		0	0

Time: 7:00

Onsite Out-Of-Plant Doses

<u>Location</u> (Zone)	<u>Whole Body Dose</u> (MR/HR)		<u>Thyroid Dose</u>		
			(cpm)	µci/cc)	
A		< 1		0	0
B		< 1		0	0
C		< 1		0	0

APPENDIX D

Offsite Doses

Time: 2:50 to 3:14

Offsite Doses

SITE	Location		Whole Body Dose (MR/HR)	Thyroid Dose	
	(Distance	Sector)		(cpm	$\mu$ ci/cc)
BOUND - 0.99		L	5	$3.5 \times 10^4$	$1.1 \times 10^{-6}$
		M	11	$6.9 \times 10^4$	$2.2 \times 10^{-6}$
		N	5	$3.2 \times 10^4$	$1.0 \times 10^{-6}$
1.0 - 1.99		L	1	5,100	$1.6 \times 10^{-7}$
		M	2	9,800	$3.1 \times 10^{-7}$
		N	1	4,600	$1.5 \times 10^{-7}$
2.0 - 2.99		L	< 1	1,200	$3.8 \times 10^{-8}$
		M	< 1	2,940	$9.3 \times 10^{-8}$
		N	< 1	1,100	$3.5 \times 10^{-8}$
3.0 - 3.99		L	< 1	750	$2.4 \times 10^{-8}$
		M	< 1	1,470	$4.7 \times 10^{-8}$
		N	< 1	570	$1.8 \times 10^{-8}$
4.0 - 4.99		L	< 1	0	0
		M	< 1	0	0
		N	< 1	0	0
5.0 - 5.99		L	< 1	0	0
		M	< 1	0	0
		N	< 1	0	0
6.0 - 6.99		L	< 1	0	0
		M	< 1	0	0
		N	< 1	0	0

Time: 2:50 to 3:14

Offsite Doses

(Distance	Location		Whole Body Dose (MR/HR)	Thyroid Dose	
	(Distance	Sector)		(cpm	μ ci/cc)
7.0 - 7.99	L		< 1	0	0
	M		< 1	0	0
	N		< 1	0	0
8.0 - 8.99	L		< 1	0	0
	M		< 1	0	0
	N		< 1	0	0
9.0 - 9.99	L		< 1	0	0
	M		< 1	0	0
	N		< 1	0	0
10.0 - 10.99	L		< 1	0	0
	M		< 1	0	0
	N		< 1	0	0

Time: 3:15 to 3:44

<u>Location</u>		<u>Offsite Doses</u>			
<u>(Distance</u>	<u>Sector)</u>	<u>Whole Body Dose</u>	<u>Thyroid Dose</u>		
		<u>(MR/HR)</u>	<u>(cpm</u>	<u>µci/cc)</u>	
Site Bound-0.99	L	5	$3.0 \times 10^4$	$9.5 \times 10^{-7}$	
	M	11	$6.9 \times 10^4$	$2.2 \times 10^{-6}$	
	N	5	$3.8 \times 10^4$	$1.2 \times 10^{-6}$	
1.0-1.99	L	1	5,000	$1.6 \times 10^{-7}$	
	M	2	9,800	$3.1 \times 10^{-7}$	
	N	1	4,500	$1.4 \times 10^{-7}$	
2.0-2.99	L	< 1	1,100	$3.5 \times 10^{-8}$	
	M	< 1	2,940	$9.3 \times 10^{-8}$	
	N	< 1	900	$2.9 \times 10^{-8}$	
3.0-3.99	L	< 1	700	$2.2 \times 10^{-8}$	
	M	< 1	1,470	$4.7 \times 10^{-8}$	
	N	< 1	550	$1.7 \times 10^{-8}$	
4.0-4.99	L	< 1	300	$9.5 \times 10^{-9}$	
	M	< 1	850	$2.7 \times 10^{-8}$	
	N	< 1	350	$1.1 \times 10^{-8}$	
5.0-5.99	L	< 1	250	$8.0 \times 10^{-9}$	
	M	< 1	620	$2.0 \times 10^{-8}$	
	N	< 1	220	$7.0 \times 10^{-9}$	
6.0-6.99	L	< 1	200	$6.4 \times 10^{-9}$	
	M	< 1	440	$1.4 \times 10^{-8}$	
	N	< 1	150	$4.8 \times 10^{-9}$	

Time: 3:15 to 3:44

<u>Location</u>		<u>Offsite Doses</u>	
<u>(Distance</u>	<u>Sector)</u>	<u>Whole Body Dose</u>	<u>Thyroid Dose</u>
		<u>(MR/HR)</u>	<u>(cpm      <math>\mu</math> ci/cc)</u>
7.0-7.99	L	< 1	120 $3.8 \times 10^{-9}$
	M	< 1	370 $1.2 \times 10^{-8}$
	N	< 1	100 $3.2 \times 10^{-9}$
8.0-8.99	L	< 1	0      0
	M	< 1	0      0
	N	< 1	0      0
9.0-9.99	L	< 1	0      0
	M	< 1	0      0
	N	< 1	0      0
10.0-10.99	L	< 1	0      0
	M	< 1	0      0
	N	< 1	0      0

Time: 3:45 to 4:14Offsite Doses

(Distance	<u>Location</u>		<u>Whole Body Dose</u> (MR/HR)	<u>Thyroid Dose</u>	
	(Sector)			(cpm	$\mu$ ci/cc)
Site Bound 0.99	L		5	$3.2 \times 10^4$	$1.0 \times 10^{-6}$
	M		11	$6.9 \times 10^4$	$2.2 \times 10^{-6}$
	N		5	$3.5 \times 10^4$	$1.1 \times 10^{-6}$
1.0-1.99	L		1	4,500	$1.4 \times 10^{-7}$
	M		2	9,800	$3.1 \times 10^{-7}$
	N		1	5,000	$1.6 \times 10^{-7}$
2.0-2.99	L		<1	900	$2.9 \times 10^{-8}$
	M		<1	2,940	$9.3 \times 10^{-8}$
	N		<1	1,100	$3.5 \times 10^{-8}$
3.0-3.99	L		<1	580	$1.8 \times 10^{-8}$
	M		<1	1,470	$4.7 \times 10^{-8}$
	N		<1	670	$2.1 \times 10^{-8}$
4.0-4.99	L		<1	320	$1.0 \times 10^{-8}$
	M		<1	850	$2.7 \times 10^{-8}$
	N		<1	290	$9.2 \times 10^{-9}$
5.0-5.99	L		<1	210	$6.7 \times 10^{-9}$
	M		<1	620	$2.0 \times 10^{-8}$
	N		<1	250	$8.0 \times 10^{-9}$
6.0-6.99	L		<1	150	$4.8 \times 10^{-9}$
	M		<1	440	$1.4 \times 10^{-8}$
	N		<1	200	$6.4 \times 10^{-9}$
7.0-7.99	L		<1	100	$3.18 \times 10^{-9}$



Time: 3:45 to 4:14

Offsite Doses (cont'd)

(Distance	Location		Whole Body Dose (MR/HR)	Thyroid Dose	
	(Distance	Sector)		(cpm	μci/cc)
		M	<1	370	$1.2 \times 10^{-8}$
		N	<1	120	$3.8 \times 10^{-9}$
8.0-8.99		L	<1	100	$3.2 \times 10^{-9}$
		M	<1	275	$8.8 \times 10^{-9}$
		N	<1	95	$3.0 \times 10^{-9}$
9.0-9.99		L	<1	90	$2.9 \times 10^{-9}$
		M	<1	230	$7.3 \times 10^{-9}$
		N	<1	100	$3.2 \times 10^{-9}$
10.0-10.99		L	<1	65	$2.1 \times 10^{-9}$
		M	<1	195	$6.2 \times 10^{-9}$
		N	<1	50	$1.6 \times 10^{-9}$

Time: 4:15 to 4:44

Offsite Doses

Location (Distance	Sector)	<u>Whole Body Dose</u>		<u>Thyroid Dose</u>	
		(MR/HR)	(cpm)	$\mu$ ci/cc	
SITE BOUND - 0.99	L	< 1	0	0	
	M	< 1	0	0	
	N	< 1	0	0	
1.0 - 1.99	L	< 1	0	0	
	M	< 1	0	0	
	N	< 1	0	0	
2.0 - 2.99	L	< 1	0	0	
	M	< 1	0	0	
	N	< 1	0	0	
3.0 - 3.99	L	< 1	0	0	
	M	< 1	0	0	
	N	< 1	0	0	
4.0 - 4.99	L	< 1	310	$9.9 \times 10^{-9}$	
	M	< 1	850	$2.7 \times 10^{-8}$	
	N	< 1	280	$8.9 \times 10^{-9}$	
5.0 - 5.99	L	< 1	240	$7.6 \times 10^{-9}$	
	M	< 1	620	$2.0 \times 10^{-8}$	
	N	< 1	210	$6.7 \times 10^{-9}$	
6.0 - 6.99	L	< 1	170	$5.4 \times 10^{-9}$	
	M	< 1	440	$1.4 \times 10^{-8}$	

Time: 4:15 to 4:44

Offsite Doses

(Distance	Location		Whole Body Dose (MR/HR)	Thyroid Dose	
	(Sector)			(cpm	$\mu$ ci/cc)
7.0 - 7.99	N		< 1	190	$6.0 \times 10^{-9}$
	L		< 1	110	$3.5 \times 10^{-9}$
	M		< 1	370	$1.2 \times 10^{-8}$
8.0 - 8.99	N		< 1	120	$3.8 \times 10^{-9}$
	L		< 1	95	$3.0 \times 10^{-9}$
	M		< 1	275	$8.8 \times 10^{-9}$
9.0 - 9.99	N		< 1	100	$3.2 \times 10^{-9}$
	L		< 1	90	$2.8 \times 10^{-9}$
	M		< 1	230	$7.3 \times 10^{-9}$
10.0 - 10.99	N		< 1	80	$2.5 \times 10^{-9}$
	L		< 1	62	$2.0 \times 10^{-9}$
	M		< 1	195	$6.2 \times 10^{-9}$
	N		< 1	45	$1.4 \times 10^{-9}$

Time: 4:45 to 4:54

Offsite Doses

(Distance	Location		Whole Body Dose		Thyroid Dose	
	Sector)		(MR/HR)		(cpm	$\mu$ ci/cc)
Site Bound -0.99	L		<1		0	0
	M		<1		0	0
	N		<1		0	0
1.0-1.99	L		<1		0	0
	M		<1		0	0
	N		<1		0	0
2.0-2.99	L		<1		0	0
	M		<1		0	0
	N		<1		0	0
3.0-3.99	L		<1		0	0
	M		<1		0	0
	N		<1		0	0
4.0-4.99	L		<1		0	0
	M		<1		0	0
	N		<1		0	0
5.0-5.99	L		<1		0	0
	M		<1		0	0
	N		<1		0	0
6.0-6.99	L		<1		0	0
	M		<1		0	0
	N		<1		0	0

Time: 4:45 to 4:54

Offsite Doses

<u>Location</u>		<u>Whole Body Dose</u>		<u>Thyroid Dose</u>	
(Distance	Sector)	(MR/HR)		(cpm	$\mu$ ci/cc)
7.0-7.99	L	< 1	0	0	
	M	< 1	0	0	
	N	< 1	0	0	
8.0-8.99	L	< 1	90		$2.9 \times 10^{-9}$
	M	< 1	275		$8.8 \times 10^{-9}$
	N	< 1	80		$2.5 \times 10^{-9}$
9.0-9.99	L	< 1	78		$2.5 \times 10^{-9}$
	M	< 1	230		$7.3 \times 10^{-9}$
	N	< 1	75		$2.4 \times 10^{-9}$
10.0-10.99	L	< 1	43		$1.4 \times 10^{-9}$
	M	< 1	195		$6.2 \times 10^{-9}$
	N	< 1	61		$1.9 \times 10^{-9}$

Time: 7:00

Offsite Doses

(Distance	<u>Location</u>	Whole Body Dose	<u>Thyroid Dose</u>	
	Sector)		(MR/HR)	(cpm
Site Bound-0.99	L	<1	0	0
	M	<1	0	0
	N	<1	0	0
1.0-1.99	L	<1	0	0
	M	<1	0	0
	N	<1	0	0
2.0-2.99	L	<1	0	0
	M	<1	0	0
	N	<1	0	0
3.0-3.99	L	<1	0	0
	M	<1	0	0
	N	<1	0	0
4.0-4.99	L	<1	0	0
	M	<1	0	0
	N	<1	0	0
5.0-5.99	L	<1	0	0
	M	<1	0	0
	N	<1	0	0
6.0-6.99	L	<1	0	0
	M	<1	0	0
	N	<1	0	0

Time: 7:00

Offsite Doses

(Distance	Location	Whole Body Dose	Thyroid Dose	
	Sector)		(MR/HR)	(cpm
Site Bound-0.99	L	<1	0	0
	M	<1	0	0
	N	<1	0	0
1.0-1.99	L	<1	0	0
	M	<1	0	0
	N	<1	0	0
2.0-2.99	L	<1	0	0
	M	<1	0	0
	N	<1	0	0
3.0-3.99	L	<1	0	0
	M	<1	0	0
	N	<1	0	0
4.0-4.99	L	<1	0	0
	M	<1	0	0
	N	<1	0	0
5.0-5.99	L	<1	0	0
	M	<1	0	0
	N	<1	0	0
6.0-6.99	L	<1	0	0
	M	<1	0	0
	N	<1	0	0

Time: 7:00

<u>Location</u>		<u>Offsite Doses</u>	
(Distance	Sector)	<u>Whole Body Dose</u>	<u>Thyroid Dose</u>
		(MR/HR)	(cpm $\mu$ ci/cc)
7.0-7.99	L	<1	0      0
	M	<1	0      0
	N	<1	0      0
8.0-8.99	L	<1	0      0
	M	<1	0      0
	N	<1	0      0
9.0-9.99	L	<1	0      0
	M	<1	0      0
	N	<1	0      0
10.0-10.99	L	<1	0      0
	M	<1	0      0
	N	<1	0      0



APPENDIX E

Controller Messages

Message No. 1

SEE-82  
CONTROLLER INSTRUCTION/EVALUATION

TO: CR OPERATORS  
SHIFT SUPV.

Date: 11/10 Time: 9:30 AM

MESSAGE | :

This is a Drill

Unit 2 is operating at 100% power (MOL; Boron Concentration: 500 ppm). All safety systems are operable. Pressurizer PORV's and main steam PORV's are isolated. Unit 1 is in the last day of a 7 day outage for overhauling of the charging pumps and snubber inspection. SW Transformer 1 (15G1) is out for maintenance. S/G "A & B" are aligned to BD Monitor "A". S/G "C" is aligned to BD Monitor "B".

The sky is overcast. Stability class is D. Winds are 15 mph from East-Northeast (60° to 65°). The 32 ft temperature is 80°F. A tropical storm off the coast of North and South Carolina has developed into a hurricane overnight and is headed in the North - Northeast direction.

This is a Drill

FROM: Lead Controller

Expected Actions:

None - initial conditions

Controllers Evaluation/Comments:

Deliver to: \_\_\_\_\_

Message No. 2

SEE-82  
CONTROLLER INSTRUCTION/EVALUATION

TO: CR OPERATOR

Date: 11/10 Time: 9:40 AM

MESSAGE | :

This is a Drill

Eastern and Southeastern Virginia are under a Hurricane Watch. The area under the Watch includes Surry County.

This is a Drill

FROM: System Operator (Lead controller)

Expected Actions:

Declare Unusual Event

Controllers Evaluation/Comments:

Deliver to: \_\_\_\_\_

Message No. 3

SEE-82  
CONTROLLER INSTRUCTION/EVALUATION

TO: CR OPERATOR |

Date: 11/10 Time: 10:00 AM

MESSAGE | :

This is a Drill

Activities on S/G Blowdown and Condenser Air Ejectors are increasing.

Air Ejector	500 cpm
S/G Bldn A	100 cpm
S/G Bldn B	1000 cpm

This is a Drill

FROM: Lead Controller

Expected Actions:

Start investigation to determine cause.

Determine RCS Leakage rate and request RCS & S/G Blowdown samples.  
See Message 3C

Controllers Evaluation/Comments:

Deliver to: \_\_\_\_\_

Message No. 3C

SEE-82  
CONTROLLER INSTRUCTION/EVALUATION

TO: SHIFT SUPV.

Date: 11/10 Time: 10:05 AM

MESSAGE | :

This is a Drill

Initiate RCS Lead Rate Periodic Test. Request RCS and S/G sample analysis.

---

In the event an air ejector radiation sample is requested the results are:

Time of Collection: 10:20 AM

Kr-85 Equivalent  $2.5 \times 10^{-2}$   $\mu\text{Ci/cc}$   
Xe-133 Equivalent  $4.9 \times 10^{-3}$   $\mu\text{Ci/cc}$   
I-131 Equivalent  $<1 \times 10^{-11}$   $\mu\text{Ci/cc}$

Dose Rates at 1 foot from collected samples:

Gas Sample - 0.06 mR/hr  
Iodine Cartridge - <0.02 mR/hr

This is a Drill

FROM: Lead Controller

---

Expected Actions:

None - contingency

Controllers Evaluation/Comments:

Deliver to: \_\_\_\_\_

Message No. 4

SEE-82  
CONTROLLER INSTRUCTION/EVALUATION

TO: CR OPERATOR

Date: 11/10 Time: 10:15 AM

MESSAGE | :

This is a Drill

S/G "C" Blowdown - sample results are:

Co60 -  $1.6 \times 10^{-6}$   $\mu\text{Ci/cc}$   
Co57 -  $4.1 \times 10^{-7}$   $\mu\text{Ci/cc}$   
Cs137-  $1.6 \times 10^{-7}$   $\mu\text{Ci/cc}$   
I 131-  $1.2 \times 10^{-7}$   $\mu\text{Ci/cc}$

Dose rate at 1 foot from collected sample:  $< 0.01$  mR/hr

This is a Drill

FROM: Lead Controller

---

Expected Actions:

Controllers Evaluation/Comments:

Deliver to: \_\_\_\_\_

Message No. 5

SEE-82  
CONTROLLER INSTRUCTION/EVALUATION

TO: SHIFT SUPV.

Date: 11/10 Time: 10/20 AM

MESSAGE | :

This is a Drill

A Chem Tech is seriously injured at (location). His left arm and hand are cut from broken sample containers - possibly contaminated. He is conscious, but appears to be having severe chest pains. I think the guy may have had a heart attack.

This is a Drill

FROM: Auxiliary Building Operator

Expected Actions:

Dispatch First-Aid Team

Controllers Evaluation/Comments:

Deliver to: \_\_\_\_\_

Message No. 6

SEE-82  
CONTROLLER INSTRUCTION/EVALUATION

TO: SHIFT SUPV.

Date: 11/10 Time: 10:40 AM

MESSAGE | :

This is a Drill

The ambulance has departed from the site with the injured Chem Tech.

This is a Drill

FROM: First Aid Team Leader

---

Expected Actions:

Declare a second  
UNUSUAL EVENT.

Controllers Evaluation/Comments:

Deliver to: \_\_\_\_\_



Message No. 7

SEE-82  
CONTROLLER INSTRUCTION/EVALUATION

TO: SHIFT SUPV.

Date: 11/10 Time: 11:00 AM

MESSAGE | :

This is a Drill

Results of the RCS Leak Rate Test indicate 0.2 gpm unidentified leakage. Chem analysis of RCS and S/G's indicate 0.1 gpm primary to secondary leak on S/G "C"; negligible for S/G "A and B".

This is a Drill

FROM: Chem Tech and Lead Controller

---

Expected Actions:

Controllers Evaluation/Comments:

Deliver to: \_\_\_\_\_

Message No. 8

SEE-82  
CONTROLLER INSTRUCTION/EVALUATION

TO: CR OPERATOR |

Date: 11/10 Time: 11:30 AM

MESSAGE | :

This is a Drill

NI - 41 fuse is blown, initiating turbine runback to 70%.  
Reactor did not trip. Steam Dump to condenser operated okay.

This is a Drill

FROM: Lead Controller

---

Expected Actions:

Controllers Evaluation/Comments:

Deliver to: \_\_\_\_\_

Message No. 9

SEE-82  
CONTROLLER INSTRUCTION/EVALUATION

TO: CR OPERATOR

Date: 11/10 Time: 11:40 AM

MESSAGE | :

This is a Drill

RCP C Vibration Alarm initiates.  
Vibration recorder indicates very high vibration.

RCP C Trip Alarm initiated (O/C).

Reactor and turbine/generator trip.

This is a Drill

FROM: Lead Controller

---

Expected Actions:

Controllers Evaluation/Comments:

Deliver to: \_\_\_\_\_

Message No. 10

SEE-82  
CONTROLLER INSTRUCTION/EVALUATION

TO: CR OPERATOR

Date: 11/10 Time: 11/41 AM

MESSAGE | :

This is a Drill

Letdown Radiation Monitors alarm. They peak at  $2 \times 10^4$  cpm,  
then steady out at  $5 \times 10^3$  cpm.

This is a Drill

FROM: Lead Controller

Expected Actions:

Controllers Evaluation/Comments:

Deliver to: \_\_\_\_\_

Message No. 11

SEE-82  
CONTROLLER INSTRUCTION/EVALUATION

TO: CR OPERATOR

Date: 11/10 Time: 11:50 AM

MESSAGE | :

This is a Drill

34.5 KV Bkr LT12 Trip Alarm initiates.  
4160 v Bus A, B, 2G, 2H Emergency U/V alarms.  
No. 2 DG starts and satisfactorily re-energizes Bus 2H.  
Aux. FW starts and operates satisfactorily. S/G Blowdown isolates all loads from A & B Bus de-energized.

This is a Drill

FROM: Lead Controller

Expected Actions:

Shift Supr. should dispatch operator to unisolate MS PORV's. See Message l/c. Direct operator to investigate cause of power loss.

Controllers Evaluation/Comments:

Deliver to: \_\_\_\_\_

Message No. 11C

SEE-82  
CONTROLLER INSTRUCTION/EVALUATION

TO: SHIFT SUPV.

Date: 11/10 Time: 11:55 AM

MESSAGE | :

This is a Drill

Direct an Equipment Operator to open MS PORV isolation valves.

This is a Drill

FROM: Lead Controller

Expected Actions:

None - contingency

Controllers Evaluation/Comments:

Deliver to: \_\_\_\_\_

Message No. 12

SEE-82  
CONTROLLER INSTRUCTION/EVALUATION

TO: CR OPERATOR

Date: 11/10 Time: 12:00 Noon

MESSAGE | :

This is a Drill

Isolation valves to MS PORV's are open.

This is a Drill

FROM: Equipment Operator

Expected Actions:

Switch Steam dump to MS  
PORV's due to loss of  
condenser vacuum - circ  
pumps de-energized.

Controllers Evaluation/Comments:

Deliver to: \_\_\_\_\_

Message No. 13

SEE-82  
CONTROLLER INSTRUCTION/EVALUATION

TO: CR OPERATOR

Date: 11/10 Time: 12:10 PM

MESSAGE | :

This is a Drill

Subcooled margin alarm comes in.

Letdown monitors read  $10^4$  cpm.

Suffolk repair crew on its way to repair 34.5 KV Bus. Fire  
Hose Station #18 roof blew off and caused fault on the bus.

This is a Drill

FROM: Lead Controller

Expected Actions:

Shift Supv. request RCS  
sample analysis.  
See Message 13C

Controllers Evaluation/Comments:

Deliver to: \_\_\_\_\_



Message No. 13C

SEE-82  
CONTROLLER INSTRUCTION/EVALUATION

TO: SHIFT SUPV.

Date: 11/10 Time: 12:10 PM

MESSAGE | :

This is a Drill

Request RCS sample analysis.

This is a Drill

FROM: Lead Controller

Expected Actions:

None - contingency

Controllers Evaluation/Comments:

Deliver to: \_\_\_\_\_

Message No. 14

SEE-82  
CONTROLLER INSTRUCTION/EVALUATION

TO: CR OPERATOR

Date: 11/10 Time: 12:20 PM

MESSAGE | :

This is a Drill

Letdown RM's in alarm and reading  $10^5$  cpm.

Suffolk repair crew estimates 4 - 5 hours to get 34.5 KV Bus 5 back in service.

This is a Drill

FROM: Lead Controller

Expected Actions:

Controllers Evaluation/Comments:

Deliver to: \_\_\_\_\_

SEE-82  
CONTROLLER INSTRUCTION/EVALUATION

TO: SHIFT SUPV.

Date: 11/10 Time: 12:30 PM

MESSAGE | :

This is a Drill

RCS activity is 260  $\mu\text{Ci/gm}$  I-131 dose equivalent.

Other data: I-131 137  $\mu\text{Ci/gm}$   
I-132 201  $\mu\text{Ci/gm}$   
I-133 315  $\mu\text{Ci/gm}$   
I-134 367  $\mu\text{Ci/gm}$   
I-135 291  $\mu\text{Ci/gm}$   
Cs-134 320  $\mu\text{Ci/gm}$   
Cs-137 411  $\mu\text{Ci/gm}$

RMS-156 reading before entry into sample room: 36 mR/hr  
Dose rate at 1 foot from unshielded sample = 1.32 R/hr  
Dose rate at 1 foot from unshielded sample diluted 1:1,000: 1.3mR/hr  
Dose rate at 1 foot from unshielded sample diluted 1:10<sup>6</sup>: 0.01mR/hr  
Dose rate at 1 foot from original sample shielded in "Pig": 27 mR/hr

This is a Drill

FROM: Chem Tech

Expected Actions:

Shift Supv. should declare  
ALERT.  
Isolate MS line C  
PORV - See Message 15C

Controllers Evaluation/Comments:

Deliver to: \_\_\_\_\_

Message No. 15C

SEE-82  
CONTROLLER INSTRUCTION/EVALUATION

TO: SHIFT SUPV.

Date: 11/10 Time: 12:30 PM

MESSAGE | :

This is a Drill

Dispatch an Equipment Operator to isolate MS line C PORV.

This is a Drill

FROM: Lead Controller

---

Expected Actions:

None - contingency

Controllers Evaluation/Comments:

Deliver to: \_\_\_\_\_

Message No. 16

SEE-82  
CONTROLLER INSTRUCTION/EVALUATION

TO: CR OPERATOR

Date: 11/10 Time: 12:35 PM

MESSAGE |:

This is a Drill

MS line C PORV is isolated.

This is a Drill

FROM: Equipment Operator.

---

Expected Actions:

Controllers Evaluation/Comments:

Deliver to: \_\_\_\_\_

Message No. 17

SEE-82  
CONTROLLER INSTRUCTION/EVALUATION

TO: CR OPERATOR

Date: 11/10 Time: 1:30 PM

MESSAGE | :

This is a Drill

MDAFWPump 3A trip alarm comes in.

This is a Drill

FROM: Lead Controller

---

Expected Actions:

Controllers Evaluation/Comments:

Deliver to: \_\_\_\_\_

Message No. 18

SEE-82  
CONTROLLER INSTRUCTION/EVALUATION

TO: DC Team Leader

Date: 11/10 Time: 1:40 PM

MESSAGE | :

This is a Drill

MDAFWP 3A Motor is slightly smoking at the pump end bearing and has loosened its motor mounts. The pump shaft is not free to move.

This is a Drill

FROM: Controller

Expected Actions:

Controllers Evaluation/Comments:

Deliver to: \_\_\_\_\_

Message No. 19

SEE-82  
CONTROLLER INSTRUCTION/EVALUATION

TO: CR OPERATOR

Date: 11/10 Time: 2:45 PM

MESSAGE | :

This is a Drill

S/G "B" level has promptly increased in level from 30% to 33%  
and pressure from 730# to 750#.

This is a Drill

FROM: Lead Controller

---

Expected Actions:

Dispatch operator to check  
reading on MS line B Hi -  
Range RM. - See Message 19C

Controllers Evaluation/Comments:

Deliver to: \_\_\_\_\_



Message No. 19C

SEE-82  
CONTROLLER INSTRUCTION/EVALUATION

TO: SHIFT SUPV.

Date: 11/10 Time: 2:45 PM

MESSAGE | :

This is a Drill

Dispatch operator to check reading on MS line B Hi-Range RM.

This is a Drill

FROM: Lead Controller

Expected Actions:

None - contingency

Controllers Evaluation/Comments:

Deliver to: \_\_\_\_\_

Message No. 20

SEE-82  
CONTROLLER INSTRUCTION/EVALUATION

TO: CR OPERATOR

Date: 11/10 Time: 2:50 PM

MESSAGE | :

This is a Drill

Attempts to close MS line B PORV fail.

MS line B Hi-Range RM indicates  $2 \times 10^{-1}$  mR/hr.

This is a Drill

FROM: Operator/Lead Controller

Expected Actions:

Shift Supervisor should  
declare SITE EMERGENCY,

Dispatch operator to isolate  
MS line B PORV - See Message  
20C  
Dispatch maintenance to PORV.

Controllers Evaluation/Comments:

Deliver to: \_\_\_\_\_

Message No. 20C

SEE-82  
CONTROLLER INSTRUCTION/EVALUATION

TO: SHIFT SUPV.

Date: 11/10 Time: 2:50 PM

MESSAGE :

This is a Drill

Dispatch an operator to isolate MS line B PORV.

Dispatch maintenance to fix PORV.

If a post accident RCS sample is requested.

Results are: I-131 2340  $\mu\text{Ci/gm}$   
I-132 3410  $\mu\text{Ci/gm}$   
I-133 5360  $\mu\text{Ci/gm}$   
I-134 6240  $\mu\text{Ci/gm}$   
I-135 4950  $\mu\text{Ci/gm}$   
Cs-134 900  $\mu\text{Ci/gm}$   
Cs-137 4960  $\mu\text{Ci/gm}$

RMS-156 reading before entry into sample room :550mR/hr

Dose rate at 1 foot from unshielded sample = 20 R/hr

Dose rate at 1 foot from unshielded sample diluted 1:1,000: 20mR/hr

Dose rate at 1 foot from unshielded sample diluted 1:10<sup>6</sup>: 0.02mR/hr

Dose rate at 1 foot from original sample shielded in "Pig": 0.6 R/hr

This is a Drill

FROM: Lead Controller

Expected Actions:

None - contingency

Controllers Evaluation/Comments:

Deliver to: \_\_\_\_\_

Message No. 21

SEE-82  
CONTROLLER INSTRUCTION/EVALUATION

TO: CR OPERATOR

Date: 11/10 Time: 3:00 PM

MESSAGE | :

This is a Drill

As the MS line B PORV isolation valve nears the closed seat, the handwheel on MS line B PORV isolation valve is broken off the valve stem. Steam continues to "weep" from the valve. Venting air at the PORV will not close the PORV.

This is a Drill

FROM: Operator (@ PORV)

---

Expected Actions:

Controllers Evaluation/Comments:

Deliver to: \_\_\_\_\_

Message No. 22

SEE-82  
CONTROLLER INSTRUCTION/EVALUATION

TO: CR OPERATOR

Date: 11/10 Time: 3:15 PM

MESSAGE | :

This is a Drill

The spring on the MS line B PORV is broken, causing the valve to remain open.

This is a Drill

FROM: Maintenance (@ PORV)

Expected Actions:

Controllers Evaluation/Comments:

Deliver to: \_\_\_\_\_

Message No. 23

SEE-82  
CONTROLLER INSTRUCTION/EVALUATION

TO: CR OPERATOR

Date: 11/10 Time: 3:50 PM

MESSAGE | :

This is a Drill

The isolation valve to MS line B PORV is closed. Maintenance closed it with a wrench.

This is a Drill

FROM: Operator (@ PORV)

Expected Actions:

Controllers Evaluation/Comments:

Deliver to: \_\_\_\_\_

Message No. 24

SEE-82  
CONTROLLER INSTRUCTION/EVALUATION

TO: SHIFT SUPV.

Date: 11/10 Time: 4:00 PM

MESSAGE | :

This is a Drill

The Suffolk repair crew has repaired 34.5 KV Bus 5. LT12 is closed and 4.16 KV Buses A, B, and 2G are restored to service.

This is a Drill

FROM: Operator (at repair location)

Expected Actions:

Start forced circulation cooling of RCS.

Controllers Evaluation/Comments:

Deliver to: \_\_\_\_\_

Message No. 24C

SEE-82  
CONTROLLER INSTRUCTION/EVALUATION

TO: SHIFT SUPV.

Date: 11/10 Time: 4:05 PM

MESSAGE | :

This is a Drill

RCP A is restarted.

This is a Drill

FROM: Lead Controller

Expected Actions:

None - contingency

Controllers Evaluation/Comments:

Deliver to: \_\_\_\_\_



Message No. 25

SEE-82  
CONTROLLER INSTRUCTION/EVALUATION

TO: CR OPERATOR

Date: 11/10 Time: 4:55 PM

MESSAGE |:

This is a Drill

It is now 7:00 PM.

Offsite and onsite monitoring teams now reporting background.

This is a Drill

FROM: All controllers

---

Expected Actions:

Controllers Evaluation/Comments:

Deliver to: \_\_\_\_\_

Message No. 26

SEE-82  
CONTROLLER INSTRUCTION/EVALUATION

TO: ALL PARTICIPANTS

Date: 11/10 Time: 5:00 PM

MESSAGE | :

This is a Drill

Exercise terminated.

This is a Drill

FROM: All controllers

---

Expected Actions:

Controllers Evaluation/Comments:

Deliver to: \_\_\_\_\_

APPENDIX F

CONTROLLER AND OBSERVER  
DUTIES AND RESPONSIBILITIES

VIRGINIA ELECTRIC AND POWER COMPANY  
SURRY EMERGENCY EXERCISE

CONTROLLER DUTIES AND RESPONSIBILITIES

1. The Controller will:
  - a. Initiate the exercise by providing the emergency conditions either by cue cards, written direction, or verbal communication.
  - b. Closely follow the progress of the exercise within his assigned area and keep abreast of the overall progress of the exercise.
  - c. If the Controller observes the player going off on a tangent, because of either receiving misleading information or misinterpreting the emergency condition given by the Controller, the Controller can request reevaluation of the data or give minor guidance, but at no time may he lead the player in the resolution of the problem.
  - d. The Controller will continue to distribute key emergency information as directed by the Lead Controller.
2. One Controller will be stationed at the following area(s) during the exercise unless otherwise indicated:
  - a. Medical Emergency
  - b. Remote Assembly Area
  - c. Control Room
  - d. TSC and Dose Assessment (2)
  - e. OSC
  - f. EOF and Dose Assessment (2)
  - g. Offsite Monitoring Area(s) (2)
  - h. HP/Chemistry Office (floater as required)
  - i. Security (floater as required)

VIRGINIA ELECTRIC AND POWER COMPANY  
SURRY EMERGENCY EXERCISE

OBSERVER DUTIES AND RESPONSIBILITIES

1. The Observer will become knowledgeable of what actions are expected in his assigned area.
2. The Observer will closely monitor the players actions, responses and use of emergency procedures.
3. Observers will note key data on check sheets and make specific remarks of any irregularities observed.
4. The observer will summarize his/her findings and present, or have them presented, at the critique.
5. One observer will be assigned to cover the following areas:
  - a. Control Room
  - b. Medical Emergency
  - c. Health Physics Office/Count Room
  - d. HP/Chemistry Office(s)
  - e. TSC
  - f. OSC
  - g. EOF
  - h. Offsite Monitoring Area(s)
  - i. Security
  - j. Public News Center
  - k. Remote Assembly Area
  - l. Floater as Required

OBSERVER CRITIQUE SHEETS

VIRGINIA ELECTRIC AND POWER COMPANY  
SURRY EMERGENCY EXERCISE

CRITIQUE SHEET

Q.C. OBSERVER \_\_\_\_\_

DATE \_\_\_\_\_

CONTROL ROOM

1. What time/date did the exercise commence?

Time: \_\_\_\_\_ Date: \_\_\_\_\_

2. What time were the following emergency conditions declared and which EAL caused escalation:

Unusual Event \_\_\_\_\_ EAL# \_\_\_\_\_

Alert \_\_\_\_\_ EAL# \_\_\_\_\_

Site Emergency \_\_\_\_\_ EAL# \_\_\_\_\_

General Emergency \_\_\_\_\_ EAL# \_\_\_\_\_

3. Were procedures (AP's, EP's, EPIP's) properly utilized? \_\_\_\_\_

4. Was the Control Room properly staffed? \_\_\_\_\_

5. What time was security called to initiate the call-out process? \_\_\_\_\_

6. Were Control Room access requirements maintained? \_\_\_\_\_

7. Were the following EPIP's initiated? If so, what time?

EPIP-1.01 - 1.04 Yes \_\_\_ No \_\_\_ Time \_\_\_\_\_

EPIP-2.01 - 2.03 Yes \_\_\_ No \_\_\_ Time \_\_\_\_\_

EPIP-3.01 - 3.04 Yes \_\_\_ No \_\_\_ Time \_\_\_\_\_

EPIP-4.01 Yes \_\_\_ No \_\_\_ Time \_\_\_\_\_

EPIP-5.05 Yes \_\_\_ No \_\_\_ Time \_\_\_\_\_

8. Other major items on attached exercise covered: \_\_\_\_\_

REMARKS: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

VIRGINIA ELECTRIC AND POWER COMPANY  
SURRY EMERGENCY EXERCISE

CRITIQUE SHEET

Q. C. OBSERVER \_\_\_\_\_

DATE \_\_\_\_\_

MEDICAL EMERGENCY

1. What time was the first aid team called? \_\_\_\_\_
2. What time did the team arrive at the scene? \_\_\_\_\_
3. What time was outside help requested? \_\_\_\_\_
4. What time did offsite rescue squad arrive? \_\_\_\_\_
5. Was communications established/maintained with the Control Room? \_\_\_\_\_
6. What time did the victim depart the site for the medical facility? \_\_\_\_\_
7. Were appropriate procedures followed? \_\_\_\_\_
8. What time did ambulance arrive at Medical College of Virginia? \_\_\_\_\_

REMARKS: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

VIRGINIA ELECTRIC AND POWER COMPANY  
SURRY EMERGENCY EXERCISE

CRITIQUE SHEET

Q. C. OBSERVER \_\_\_\_\_

DATE \_\_\_\_\_

HEALTH PHYSICS

1. What time was HP notified of emergency? \_\_\_\_\_
2. What time was EPIP-4.01 initiated? \_\_\_\_\_
3. Did HP perform required monitoring? \_\_\_\_\_
4. Was EPIP-4.08 initiated? \_\_\_\_\_
5. Were calculations performed properly? \_\_\_\_\_
6. What time(s) were the following EPIP's completed?  
EPIP-4.03 \_\_\_\_\_  
EPIP-4.15 \_\_\_\_\_  
EPIP-4.16 \_\_\_\_\_  
EPIP-4.21 \_\_\_\_\_
7. What time did HP begin to survey and monitor the Auxiliary Bldg.? \_\_\_\_\_
8. What other HP oriented EPIP's were initiated? \_\_\_\_\_
9. Did HP accompany the chemist to obtain the high activity samples? \_\_\_\_\_

REMARKS: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



VIRGINIA ELECTRIC AND POWER COMPANY  
SURRY EMERGENCY EXERCISE

CRITIQUE SHEET

Q. C. OBSERVER \_\_\_\_\_

DATE \_\_\_\_\_

CHEMISTRY

1. When was the chemistry technician notified to draw a primary water sample? \_\_\_\_\_
2. What time(s) were the following EPIP's initiated?  
EPIP-4.23 \_\_\_\_\_  
EPIP-4.25 \_\_\_\_\_  
EPIP-4.26 \_\_\_\_\_
3. Were all requirements of the above listed EPIP's adhered to? \_\_\_\_\_
4. Did the chemistry technician use the post accident sampling system properly? \_\_\_\_\_
5. What condition alerted the chemistry technician to use this system? \_\_\_\_\_  
\_\_\_\_\_
6. What were the highest radiation readings obtained from the sample? \_\_\_\_\_  
\_\_\_\_\_
7. Was dilution achieved before the sample was taken to HP for analysis? \_\_\_\_\_  
\_\_\_\_\_

REMARKS: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

VIRGINIA ELECTRIC AND POWER COMPANY  
SURRY EMERGENCY EXERCISE

CRITIQUE SHEET

Q. C. OBSERVER \_\_\_\_\_

DATE \_\_\_\_\_

ONSITE TECHNICAL SUPPORT CENTER (TSC)

1. What time was the TSC manned? \_\_\_\_\_
2. Was all needed equipment in the TSC operable? \_\_\_\_\_
3. Was the initiation of data transmitted from the Control Room to the TSC performed in a timely and effective manner? \_\_\_\_\_
4. What time were monitoring teams alerted? \_\_\_\_\_
5. Were the following Attachments to EPIP-3.02 initiated? Time?  
Attachment 1 \_\_\_\_\_ Time: \_\_\_\_\_ Attachment 6 \_\_\_\_\_ Time: \_\_\_\_\_  
Attachment 2 \_\_\_\_\_ Time: \_\_\_\_\_ Attachment 7 \_\_\_\_\_ Time: \_\_\_\_\_  
Attachment 3 \_\_\_\_\_ Time: \_\_\_\_\_ Attachment 8 \_\_\_\_\_ Time: \_\_\_\_\_  
Attachment 4 \_\_\_\_\_ Time: \_\_\_\_\_ Attachment 9 \_\_\_\_\_ Time: \_\_\_\_\_  
Attachment 5 \_\_\_\_\_ Time: \_\_\_\_\_ Attachment 10 \_\_\_\_\_ Time: \_\_\_\_\_
6. Were all aspects of EPIP-3.02 complied with? \_\_\_\_\_
7. What time did the Station Emergency Manager transfer Management responsibility to the EOF? \_\_\_\_\_
8. What time was the Dose Assessment Team Leader directed to report to the Radiological Assessment Coordinator at the EOF? \_\_\_\_\_
9. What time was accountability ordered? \_\_\_\_\_
10. What time was site evacuation ordered? \_\_\_\_\_
11. What time did the Recovery Phase start? \_\_\_\_\_

REMARKS: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

VIRGINIA ELECTRIC AND POWER COMPANY  
SURRY EMERGENCY EXERCISE

CRITIQUE SHEET

Q. C. OBSERVER \_\_\_\_\_

DATE \_\_\_\_\_

OPERATIONS SUPPORT CENTER (OSC)

1. What time was the OSC manned? \_\_\_\_\_
2. Who assumed the position of OSC Director? \_\_\_\_\_
3. Was EPIP-3.03, Attachment 1, completed and reported to Security? \_\_\_\_\_
4. Was a personnel check-in/check-out system initiated? \_\_\_\_\_
5. What time was the Station Emergency Manager advised that the OSC was activated? \_\_\_\_\_

REMARKS: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

VIRGINIA ELECTRIC AND POWER COMPANY  
SURRY EMERGENCY EXERCISE

CRITIQUE SHEET

Q. C. OBSERVER \_\_\_\_\_

DATE \_\_\_\_\_

EMERGENCY OPERATIONS FACILITY (EOF)

1. What time was the EOF manned by the following individuals?

Recovery Manager:            Name: \_\_\_\_\_            Time: \_\_\_\_\_

Director-Chemistry & HP:   Name: \_\_\_\_\_            Time: \_\_\_\_\_

EOF Coordinator:            Name: \_\_\_\_\_            Time: \_\_\_\_\_

2. What time was communications established with the following:

Onsite Technical Support Center            Time: \_\_\_\_\_

Corporate Emergency Response Center      Time: \_\_\_\_\_

Public News Center                          Time: \_\_\_\_\_

3. What time did the Station Emergency Manager transfer management responsibility to the EOF? \_\_\_\_\_

4. Were facsimile messages transmitted?    Yes \_\_\_\_\_    No \_\_\_\_\_

Itemize: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

REMARKS: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

VIRGINIA ELECTRIC AND POWER COMPANY  
SURRY EMERGENCY EXERCISE

CRITIQUE SHEET

Q. C. OBSERVER \_\_\_\_\_

DATE \_\_\_\_\_

HEALTH PHYSICS MONITORING TEAM

1. Was the HP instrumentation verified operable before departing the station? \_\_\_\_\_
2. Was the vehicle checked (gas, oil, etc.) before departing station? \_\_\_\_\_
3. What time did team leave the station? \_\_\_\_\_
4. Was EPIP-4.16 available and complied with? \_\_\_\_\_
5. Was EPIP-4.19 available and complied with? \_\_\_\_\_
6. Were radiation levels properly transmitted? \_\_\_\_\_
7. What were the readings and their locations? \_\_\_\_\_

Reading: _____	Location: _____
Reading: _____	Location: _____
Reading: _____	Location: _____
Reading: _____	Location: _____

REMARKS: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

VIRGINIA ELECTRIC AND POWER COMPANY  
SURRY EMERGENCY EXERCISE

CRITIQUE SHEET

Q. C. OBSERVER \_\_\_\_\_

DATE \_\_\_\_\_

SECURITY

1. What time was Security notified to implement notification of emergency response personnel? \_\_\_\_\_
2. Were applicable departments listed in EPIP-3.01 contacted? \_\_\_\_\_
3. List the names of those actually contacted (one from each department).

<u>Name</u>	<u>Department</u>
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____

4. What time was Security notified the station would be evacuated? \_\_\_\_\_
5. Was EPIP-3.04 (Accivation of EOF) accomplished? \_\_\_\_\_
6. Was EPIP-5.03 (Personnel Accountability) accomplished? \_\_\_\_\_
7. Was EPIP-5.04 (Access Control) complied with? \_\_\_\_\_

REMARKS: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

VIRGINIA ELECTRIC AND POWER COMPANY  
SURRY EMERGENCY EXERCISE

CRITIQUE SHEET

Q. C. OBSERVER \_\_\_\_\_

DATE \_\_\_\_\_

PUBLIC NEWS CENTER - OJRP

1. What time was the Public News Center manned? \_\_\_\_\_
2. Was communications established with the EOF? \_\_\_\_\_
3. Did news releases follow the established format? \_\_\_\_\_
4. What time was assistance requested by the Recovery Manager? \_\_\_\_\_

REMARKS: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

APPENDIX G

USEFUL INFORMATION



USEFUL INFORMATION

	<u>Page No.</u>
1. Routes to Surry Power Station	1
2. Nearby Accommodations	2
3. Schedule for Jamestown - Scotland Ferry	4
4. Road Map from Richmond	5
5. Road Map from Norfolk	6

USEFUL INFORMATION

ROUTES TO SURRY POWER STATION

BY AIR: Patrick Henry International Airport

Byrd International Airport - Richmond

Norfolk International Airport

BY BUS: Direct service by Greyhound and Trailway to Richmond, Newport News, Williamsburg, and Norfolk.

BY CAR: Refer to the maps on following pages.

The station is about 60 miles North of Norfolk, 70 miles South of Richmond and 35 miles Northwest of Newport News traveling the following road network:

FROM NEWPORT NEWS

Exit I-64 traveling west on Mercury Boulevard (Newport News) which becomes State Route 17/258, cross the James River Bridge (17/258) and exit right at State Route 32 which intersects State Route 10 (Benns Church). Turn north (right) on State Route 10 and travel about 20 miles. Exit right on State Route 650, travel 5 miles and Surry Power Station will be on your right.

BY TRAIN: AM-TRAK with connections in Richmond, Williamsburg, Newport News and Norfolk.

NEARBY ACCOMMODATIONS

Surry (Approximately 10 miles from station)

The Surry House Motel  
Hwy. 10  
(804) 294-3191

Smithfield (Approximately 20 miles from station)

The Smithfield Inn On US 258, 112 Main Street  
Restaurant and Inn  
(804) 357-4358

Newport News (Approximately 35-45 miles from station)

Holiday Inn of Newport News  
Route 17 and 143  
6128 Jefferson Avenue  
Restaurant and Lounge  
(804) 826-4500

King James Motor Hotel  
Intersection Jefferson Avenue and Mercury Boulevard  
6045 Jefferson Avenue  
Restaurant  
(804) 245-2801

Ramada Inn  
Intersection I-64 and Route 17  
950 J. Clyde Morris Boulevard  
Restaurant & Lounge  
(804) 595-4460

Others in Newport News

Budget Lodge of America (804) 595-5647

Colonial Courts Motel (804) 595-3343

Econo Travel Hotel (804) 599-3237

The Patton Motel (804) 595-7671

Travelers Inn Motel (804) 874-0201

Williamsburg (Approximately 35 miles by ferry; approximately 80 miles using  
shortest road network)

Patrick Henry Inn  
York and Page Streets  
(804) 229-9540

Holiday Inn - East  
814 Capitol Landing Road  
Travel lodge and Restaurant  
(804) 229-0200

Holiday Inn - West  
902 Richmond Road  
Travel lodge and Restaurant  
(804) 229-5060

Ramada Inn - East  
351 York Street  
Travel lodge and Restaurant  
(804) 229-4100

Ramada Inn - West  
3052 Richmond Road  
Travel lodge and Restaurant  
(804) 565-2000

Others in Williamsburg

Captain John Smith (804) 220-0710

Colonial Motel (804) 229-3621

Hilton Inn (804) 220-2500

King William Inn (804) 229-4933

Hopewell (Approximately 45 miles to station)

City Point Inn  
Intersection of Foute 10 & 36  
Travel lodge and Restaurant  
(804) 458-5950

Chester (Approximately 60 miles from station)

Days Inn  
Intersection of I-95 and Route 10  
Restaurant  
(804) 848-5871

Holiday Inn  
Intersection of I-95 and Route 10  
Restaurant  
(804) 748-6321

Howard Johnson's  
Intersection of I-95 and Route 10  
Restaurant  
(804) 748-5010

Height Restriction - 12'6"  
 Weight Restrictions:  
 16 Tons per Vehicle  
 28 Tons per Semi-trailer  
 Combination

SCHEDULE

JAMESTOWN-SCOTLAND FERRY

Schedule and Fares Subject to  
 Change without Notice

Revised October 1, 1980  
 Subject to Change Without Notice

Two-Axle (Gross Weight 3 Tons or Less)  
 One Way . . . . . 1.00  
 Multi-Axle Single Unit & Two-Axle  
 Greater than 3 Tons  
 Gross Weight, One Way . . . . . 4.00  
 Multi-Axle Multi-Unit  
 One Way . . . . . 6.00  
 Pedestrian or Bicycle . . . . . 0.15

Operated by  
 Virginia Department of Highways  
 and Transportation  
 Richmond, Virginia  
 786-2838

Commuter Book Tickets  
 Two-Axle (Gross Weight 3 Tons or Less)  
 20 Tickets per Book . . . . . \$5.00/Book


SEPT. 16 - MAY 31  
 MONDAY THRU THURSDAY

SEPT 16 - MAY 31  
 FRIDAY - SATURDAY - SUNDAY  
 JUNE 1 - SEPT 15  
 EVERYDAY

Leave Scotland Wharf on Route 31	Leave Glass House Point on Route 31	Leave Scotland Wharf on Route 31	Leave Glass House Point on Route 31
*5:00 AM	*5:20 AM	*5:00 AM	*5:20 AM
5:40 AM	6:05 AM	5:40 AM	6:05 AM
6:30 AM	6:50 AM	6:30 AM	6:50 AM
7:15 AM	7:35 AM	7:15 AM	7:35 AM
8:00 AM	8:30 AM	8:00 AM	8:30 AM
9:00 AM	9:30 AM	9:00 AM	9:30 AM
10:00 AM	10:30 AM	10:00 AM	10:30 AM
11:00 AM	11:30 AM	10:30 AM	11:00 AM
12:00 PM	12:30 PM	11:00 AM	11:30 AM
1:00 PM	1:30 PM	11:30 AM	12:00 PM
2:00 PM	2:30 PM	12:00 PM	12:30 PM
2:30 PM	3:00 PM	12:30 PM	1:00 PM
3:00 PM	3:30 PM	1:00 PM	1:30 PM
3:30 PM	4:00 PM	1:30 PM	2:00 PM
4:00 PM	4:30 PM	2:00 PM	2:30 PM
4:30 PM	5:00 PM	2:30 PM	3:00 PM
5:00 PM	5:30 PM	3:00 PM	3:30 PM
5:30 PM	6:00 PM	3:30 PM	4:00 PM
6:00 PM	6:30 PM	4:00 PM	4:30 PM
7:00 PM	7:30 PM	4:30 PM	5:00 PM
8:00 PM	8:30 PM	5:00 PM	5:30 PM
9:00 PM	9:30 PM	5:30 PM	6:00 PM
10:00 PM	10:30 PM	6:00 PM	6:30 PM
11:00 PM	11:30 PM	6:30 PM	7:00 PM
12:00 AM	12:30 AM	7:00 PM	7:30 PM
		7:00 PM	7:30 PM
		8:00 PM	8:30 PM
		9:00 PM	9:30 PM
		10:00 PM	10:30 PM
		11:00 PM	11:30 PM
		12:00 AM	12:30 AM

\*MON THRU FRI ONLY


\*MON THRU FRI ONLY



**DIRECTIONS from Byrd International Airport to Surry Power Station:**

Route 60 West to Laburnum Avenue South (left). Take Laburnum Avenue to Route 5 East. Take Route 5 East to Route 156 South crossing the Benjamin Harrison Bridge to Route 10. Take Route 10 East to Route 31 North (left). Take Route 31 North back to Route 10 East (right). Take Route 10 East to Route 650 (left) into Surry Power Station.

Total Approx. Distance = 70 miles



APPENDIX H

DIAGRAM OF FACILITIES




DIAGRAM OF FACILITIES


	<u>Page</u>
Surry Nuclear Power Station	1
Control Room and TSC	2
Emergency Operations Facility	3
Corporate Emergency Response Center	4
Map to Corporate Emergency Response Center	5
Local Media Center	6
Map to Local Media Center	7

SURRY NUCLEAR POWER STATION


1. First Aid Station
2. Alt. First Aid Station
3. Control Room
4. Technical Support Center (TSC)
5. Onsite Operational Support Center (OSC)
6. Emergency Operations Facility (EOF)



COMPUTER ROOM AND TSC




EMERGENCY OPERATION FACILITY (EOF)



CORPORATE EMERGENCY RESPONSE PLAN  
SURRY POWER STATION'S TRAINING CENTER SIMULATOR BUILDING  
EMERGENCY OPERATION FACILITY (EOF) FLOOR PLAN  
FLOOR ASSIGNMENT PLAN

CERC FLOOR PLAN



- 1 CERC Drawer
- 2 CERC File Cabinet
- 3 CERC Signs/Status Boards
- 4 CERC Bookcase
- 5 CERC Storage Cabinet

A - Surry EOF Ringdown w/speaker affected plant RED phone and speaker on Response Manager's Table

B - N.A. EOF Ringdown w/speaker

C - System Operator PBX (x393)

D - 771-3199 (also has 4741, 4442, which do not ring) Jack on back of phone on selected line.

E - 649-1476

F - N.A. EOF Jack

G - Surry EOF Jack

H - Status Board

I - "Rover" Board

J - Table for overhead projector

K - Affected station map

L & M - North Anna and Surry maps

INTERSTATE 64

- 1-COLISEUM
- 2-JOHN MARSHALL HOTEL
- 3-VEPCO
- 4-TOBACCO COMPANY REST.
- P-PARKING

LEIGH ST.

CLAY ST.

MARSHALL ST.

BROAD ST.

GRACE ST.

FRANKLIN ST.

MAIN ST.

CARY ST.

CANAL ST.


STATE CAPITOL

DOWNTOWN EXPRESSWAY

INTERSTATE

95


Virginia Electric & Power Company's  
Corporate Emergency Response Center



LOCAL MEDIA CENTER

LEBANON ELEMENTARY SCHOOL

SIBBY, VIRGINIA



.5 Miles to Rte. 10

Rte. 626





APPENDIX I

VOPEX 2-82

## INTENT, SCOPE, AND SCENARIO OF VOPEX 2-82

The intent, scope, and scenario of the Surry Power Station exercise to be conducted on Wednesday, November 10, 1982 are as follows:

### A. Intent

1. Familiarization with the content of State and local government Radiological Emergency Response Plans, Vepco plans, emergency organizations, emergency action levels, and notification procedures.
2. Demonstrate the interface between plans, awareness by all of responsibilities, ability to rapidly notify response organizations and to alert and warn the public.
3. Provide training to all participants in radiological emergency response actions.
4. Test and evaluate the ability of agencies and individuals to properly execute their plans.

### B. Scope

1. A radiological accident will occur at the Surry Power Station of such magnitude that it will initiate emergency responses for three emergency action levels-- Unusual Event, Alert and Site Emergency. The accident will be played in real time and escalated to a Site Emergency. The severity of the accident will require implementation of the Station, State, and local government plans and the mobilization and commitment of State and local personnel and resources adequate to verify the capability to respond to an accident scenario commensurate with that level of play. The exercise will allow free play to the extent feasible and include participation by State agencies tasked in the State Plan, the departments of 10 political subdivisions, Vepco Corporate Headquarters and Surry Power Station. Significant elements of the plans to be tested include:
  - a. Use of the classes of emergency action levels.
  - b. The notification procedures (insta-phone system).
  - c. Staffing EOCs, EOF and media centers.
  - d. Communications; initial and follow-up, and coordinating and updating of information.
  - e. Handling of simulated casualties (on-site to off-site).
  - f. Off-site emergency services assistance.
  - g. Use of protective clothing.
  - h. Deployment of radiological monitoring teams; reporting procedures.
  - i. Public information activities.
  - j. Off-site radiological assessment.
  - k. Recovery actions.
2. In most cases, the emergency response will be real, with the State agencies and local governments responding in accordance with the procedures outlined in their respective plans. By prior agreement, certain response actions will be simulated, other activities will be reduced or eliminated from play. For example: Sirens will not be activated; EBS will not be brought into the play. RACES and CAP (radio communications) will not participate; there will be limited radiological monitoring.

## C. Exercise Scenario

### 1. Scenario Background

- a. The joint, full-scale Exercise, to be known by the acronym "VOPEX-2-82" (Virginia Operations Plan Exercise - No. 2, 1982), will be played on November 10, 1982.
- b. The Exercise play will be structured around a radiological emergency at the Surry Power Station (SPS) which affects surrounding political subdivisions. Provisions of the Vepco Corporate Headquarters, Surry Power Station, State, and affected local government Radiological Emergency Response Plans will be implemented. A Technical Scenario was developed by the Surry Power Station as a basis for realistic exercise play.
- c. The Exercise will be phased and include many of the actions likely to be encountered during an actual emergency situation. The Exercise will cover a period of about six hours and consist of real time Exercise play. Every effort will be made to develop situations which are realistic and which can be fully acted on. Although phases have been identified, it must be realized that real time constraints will preclude actions in some cases to be brought to satisfactory conclusions. Participants are cautioned that the short period of play will cause artificial conditions which may appear abnormal. Nonetheless, the Exercise will provide the training benefits and achieve the objectives intended if each situation presented is acted upon realistically and brought to some conclusion, even though in some cases the action is simulated.
- d. State agencies and local governments participating in the Exercise will include a shift change, either actual or simulated, during the course of Exercise play to demonstrate that this capability exists.

### 2. Phases

The Exercise will be conducted in four phases. The times of each phase are estimated. Actual times will be dictated by the flow of events.

- a. Phase I - will cover the first 1-2 hours of the Exercise. The Exercise will begin with the SPS notifying the State EOC and the six political subdivisions within the plume exposure pathway Emergency Planning Zone (EPZ) of a Notification of Unusual Event at the station by use of the "insta-phone" system.

Note: The Report of Emergency form will be used to record all notifications from the SPS.

- b. Phase II - will cover the next 2-3 hours of the Exercise. The SPS Shift Supervisor reports an Alert to the State EOC and the six applicable local governments.
- c. Phase III - will cover the next 2 hours of the Exercise. The Vepco Emergency Director, located at the EOF, declares a Site Area Emergency and evacuates all non-essential on-site personnel. All appropriate government agencies are notified of conditions at the SPS.

- d. Phase IV - will cover the last hour of the Exercise. This phase will cover the period from "cold" shutdown to the end of the emergency. The Vepco Emergency Director notifies government agencies that the radiological emergency is under control and that the reactor has been brought to a "cold shutdown". Radioactive release from the Station is terminated and conditions have dropped below Site Area Emergency classification. Recovery actions continue to include radiological monitoring and assessment until the State Department of Health notifies the State OEES that the areas are safe for re-entry. OEES, based on Department of Health recommendations, advises local Directors of Emergency Services to allow their people to return to their homes.

### 3. Direction and Control

#### a. Political Subdivisions

Directors of Emergency Services are responsible for the emergency response in their jurisdictions and direct their efforts through their local Coordinator of Emergency Services. The Coordinators activate their RERPs and coordinate their overall response for their political subdivisions from their local EOCs.

#### b. State of Virginia

- (1) The State organization for radiological emergency response is based on normal governmental structures and channels of communications. The Governor, in his role of Director of Emergency Services, directs the response through the State Coordinator of Emergency and Energy Services. The overall State response is coordinated by the State Coordinator from the State EOC. Technical advice and assistance on radiological accident assessment, monitoring, and exposure control is provided by the Department of Health which furnishes personnel for the State Radiological Emergency Response Team (RERT).
- (2) When notified of a radiological emergency, the State EOC will be activated and commence emergency response operations. Activities of the State RERT will be directed from the State EOC initially and from the EOF when directed.
- (3) The Emergency Operations Facility (EOF) will be activated by Vepco immediately whenever an Alert or Site or General Emergency occurs at the SPS. The EOF will be located in the Training Building, near site. Federal, State, and Vepco representatives will operate from the EOF and joint radiological assessment and data analysis will be performed.
- (4) Press facilities will be established in the Corporate Headquarters Building, One James River Plaza, Richmond. An alternate news media center will be established at the Lebanon Elementary School. Briefings will be presented when warranted.

c. Implementation of Exercise Requirements

It is anticipated that implementation of some of the Exercise requirements will be simulated. In these cases, participants will carry out all coordination required as though action were actually to be taken. Instructions will be issued, although NOT implemented. All actions taken or simulated will be recorded in communication logs maintained by all agencies and separate offices participating in the Exercise.

d. Exercise Message Indicator

During the Exercise all messages, regardless of the mode of transmission or receipt, will start and end with the Exercise indicator "VOPEX MESSAGE". EXAMPLE:

"VOPEX MESSAGE" - This is Deputy Smith. Traffic Control has been established at S.R. 650 and S.R. 10. "VOPEX MESSAGE".

4. Abbreviated Scenario (Time/Events)

<u>Time</u>	<u>Event</u>
9:30 a.m.	Exercise Commences NOTE: Hurricane Watch exists - heavy winds.
9:40 a.m.	Notification of Unusual Event - Personal Injury. NOTE: An SPS employee is injured and requires evacuation to MCV.
10:40 a.m.	Notification of Unusual Event - Plant problem.
12:30 p.m.	Alert declared.
14:50 p.m.	Site Area Emergency declared.
15:20 p.m.	Evacuation of non-essential on-site personnel.
15:50 p.m.	Release is terminated.
17:00 p.m.	Exercise terminated.