MAL FURM A (7.77) LICENSEE EVENT REPORT CONTROL BLOCK: 10 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION) 0 1 N J S G S 2 2 C 0 -J (5) LICENSEE CODE CON 0 1 LO 0 5 0 0 0 3 1 1 0 0 9 2 9 8 2 8 1 0 2 0 8 2 9 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80 BOURCE EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10) On September 29, 1982, during daily surveillance, the Control Room Operator observed 0 2 that the service water flow to No. 23 Containment Fan Coil Unit (CFCU) was less than 03 the 2500 GPM required by the Technical Specifications. The unit was declared in-04 operable, and Action Statement 3.6.2.3.a was entered. The containment spray systems 0 5 were operable. The occurrence constituted operation in a degraded mode in accordance 0 6 with Technical Specification 6.9.1.9.b. 0 7 (82-105, 82-099, 82-098, 82-088, 82-083) DB CODE SUBCODE COMP SUBCODE CODE COMPONENT CODE SUBCODE Z (13) 0 9 B VALVEX 14 (12 A (15 H (16) 13 18 SEQUENTIAL OCCURRENCE REVISION EVENT YEAR REPORT NO. CODE LER RO NO 8 1 7 1 0 3 0 NUMBER RIME COMP COMPONENT (22) HOURS FORMAUB SUBMITTED SUPPLIER Z (21) 0 0 Y 3 N 24 00 A 18 (25) 11 3 (26) CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) The low service water flow was caused by American oysters plugging Valve 23SW57. 10 The oysters were removed and the valve was reassembled. The unit was satisfactorily 1 1 tested and the action statement was terminated. An improved chlorination program is 1 2 under development to eliminate oysters from the service water system. 1 3 1 4 FACILIT METHOD OF DISCOVERY OTHER STATUS (30) S POWER DISCOVERY DESCRIPTION (32) 1 5 (28 B (31) Surveillance Testing NA 10 ACTIVITY CONTENT 80 OF RELEASE AMOUNT OF ACTIVITY (35) ELEASED LOCATION OF RELEASE (36) 234 1 6 12 (33) NA NA 11 80 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39) 0(37) 1 7 z (38) 0 NA INJURIES 13 PERSONNEL DESCRIPTION (41) 1 B 0.00 NA 12 OSS OF OR DAMAGE TO FACILITY (3) DESCRIPTION 1 9 10 8211300196 821119 PDR ADOCK 05000311 PUBLICITY DESCRIPTION 45 NAC USE ONLY IN 44 20 S PDR NA PHONE 609/935-6000 Ext R. Frahm NAME OF PREPARER. 2079