

CONTROL BLOCK: [] [] [] [] [] [] [] [] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | S | C | V | C | S | I | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 0 | 0 | 0 | 4 | [] | 5

CONT

01 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 9 | 5 | 7 | 1 | 0 | 3 | 0 | 8 | 2 | 8 | 1 | 1 | 2 | 4 | 8 | 2 | 8

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | On October 30, 1982, with the Plant in Mode 4, Source Range Channel NI-32 failed low. The channel was declared inoperable per Technical Specification 3.3.1, Action Statement 5. No adverse consequences resulted from this event as Source Range Channel NI-31 remained operable.

09 | SYSTEM CODE | I | A | 11 | CAUSE CODE | E | 12 | CAUSE SUBCODE | A | 13 | COMPONENT CODE | E | L | E | C | O | N | 14 | COMP. SUBCODE | Z | 15 | VALVE SUBCODE | Z | 16

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | The event occurred due to loose connection on DB voltage attenuator connector. Source Range Channel was removed from service, and the connection was repaired. The channel was returned to operable status November 1, 1982, upon satisfactory performance of the applicable Surveillance Test Procedure.

15 | FACILITY STATUS | B | 28 | % POWER | 0 | 0 | 0 | 29 | OTHER STA/US | N/A | 30 | METHOD OF DISCOVERY | A | 31 | DISCOVERY DESCRIPTION | Operator Observation | 32

16 | ACTIVITY CONTENT RELEASED OF RELEASE | Z | 33 | AMOUNT OF ACTIVITY | N/A | 35 | LOCATION OF RELEASE | N/A | 36

17 | PERSONNEL EXPOSURES NUMBER | 0 | 0 | 0 | 37 | TYPE | Z | 38 | DESCRIPTION | N/A | 39

18 | PERSONNEL INJURIES NUMBER | 0 | 0 | 0 | 40 | DESCRIPTION | N/A | 41

19 | LOSS OF OR DAMAGE TO FACILITY TYPE | Z | 42 | DESCRIPTION | N/A | 43

20 | PUBLICITY ISSUED DESCRIPTION | N | 44 | DESCRIPTION | N/A | 45

NAME OF PREPARER | C. J. McKinney | PHONE: (803) 345-5209