



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

December 31, 1982

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Inoperable Shutdown Cooling
Loop
LER 82-154/03 L-0
AECM-82/643

On December 4, 1982, with the reactor in cold shutdown, Shutdown Cooling (SDC) loop A of the Residual Heat Removal System was declared inoperable in order to perform a hydrostatic test of Standby Service Water loop A. This event is reported in accordance with Technical Specifications 3.4.9.2 and 6.9.1.13.b. Attached is LER 82-154/03 L-0.

Yours truly,

James P. McGaughey, Jr.
FOR J.P. McGaughey, Jr.

JPM:sap
Attachment

- cc: Mr. N. L. Stampley (w/a)
- Mr. R. B. McGehee (w/o)
- Mr. T. B. Conner (w/o)
- Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8301070231 821231
PDR ADOCK 05000416
S PDR

OFFICIAL COPY

IE 22