



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

January 11, 1983

JAMES P. McGAUGHY, JR.  
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 3100  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Division I and II Diesels  
Declared Inoperable  
LER 82-165/03 L-0  
AECM-83/018

On December 13, 1982, the Division I and II diesels were administratively declared inoperable due to discovery of unqualified cable in the diesel generator control circuitry. Only one Emergency Core Cooling System remained operable, therefore, Limiting Conditions for Operation were entered in accordance with Technical Specifications 3.E.1.2 and 3.5.2.

Yours truly,

*James P. McGaughy, Jr.*  
FOR J.P. McGaughy, Jr.

JPM:sap  
Attachment

cc: Mr. N. L. Stampley (w/a)  
Mr. R. B. McGehee (w/o)  
Mr. T. B. Conner (w/o)  
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk (w/a)  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

8301170268 830111  
PDR ADOCK 05000416  
S PDR

Member Middle South Utilities System

OFFICIAL COPY  
IE 22