LICENSEE EVENT REPORT

	CONTROL BLOCK: [] [] [] [] [] [] [] [] [] [
0 1	M I D C C 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 1 1 4 5 5 LICENSE NUMBER 25 26 LICENSE TYPE JO 57 CAT 58
CON'T	REPORT L 6 0 5 0 0 0 0 3 1 5 0 0 0 9 8 2 8 0 1 0 6 8 3 9 EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10
0 2	DURING NORMAL OPERATIONS, AN OPERATOR ON TOUR DISCOVERED THAT FIRE DOOR #455 WAS
0 3	BLOCKED OPEN WITH NO FIRE WATCH ESTABLISHED. THIS CONSTITUTED A. INOPERABLE
0 4	PENETRATION FIRE BARRIER AND WAS NON-CONSERVATIVE WITH RESPECT TO TECHNICAL
0 5	SPECIFICATION 3.7.10. ACTION REQUIREMENTS WERE MET. THE PUBLIC HEALTH AND SAFETY
0 6	WERE NOT AFFECTED.
0 7	
7 8	9 80
0 9	SYSTEM CODE SUBCODE SU
	17) REPORT 8 2 1 0 6 27 28 29 30 31 0 0 0 0 0 0 0 0 0
1 0	CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) [THE OPEN DOOR WAS IMMEDIATELY CLOSED UPON DISCOVERY. A THOROUGH INVESTIGATION BY
11	PLANT PERSONNEL WAS UNSUCCESSFUL IN DETERMINING THE PERSON RESPONSIBLE FOR THE DOOR
1 2	BEING BLOCKED OPEN. ALL PERSONNEL THAT WERE CONTACTED DURING THIS INVESTIGATION WERE
1 3	REMINDED OF THEIR RESPONSIBILITY REGARDING FIRE DOORS.
14	
	9 ACILITY STATUS ** POWER OTHER STATUS OTH
	LEASED OF RELEASE AMOUNT OF ACTIVITY 35 NA LOCATION OF RELEASE 36 NA LOCATION OF RELEASE 36 NA LOCATION OF RELEASE 36 NA
1 7	PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39 NA
1 2	9 PERSONNEL INJURIES 14 NA NA NA
1 9	DOSS OF OR DAMAGE TO FACILITY 43 TYPE DESCRIPTION NA NA
2 0	PUBLICITY SSUED DESCRIPTION 45 B301170389 830103 PDR ADOCK 05000315 S PDR SDESCRIPTION 45 PDR DESCRIPTION 45
8	NAME OF PREPARER R. A. Palmer PHONE 616/_ 465/5901 80.