SHAW, PITTMAN, POTTS & TROWBRIDGE A PARTNERSHIP OF PROFESSIONAL CORPORATIONS 1800 M STREET, N. W. WASHINGTON, D. C. 20036 12021 822-1000

RAMSAY D. POTTS. P.C.

STEUART L. PITTMAN. P.C.

GEORGE F. TROWBRIDGE. P.C.

STEPHEN D. POTTS. P.C.

GERALD CHARNOFF P.C.

GERALD CHARNOFF P.C.

GERALD CHARNOFF P.C.

GEORGE M. ROGERS. JR. P.C.

GEORGE M. ROGERS. JR. P.C.

GEORGE M. ROGERS. JR. P.C.

GEORGE M. CHARLES P.C.

JOHN B. RININELANDER. P.C.

JOHN B. RININELANDER. P.C.

JOHN B. RININELANDER. P.C.

JOHN E. STEVEN L. MELIZER. P.C.

DEAN D. AULICK. P.C.

JOHN E. STEVEN L. MELIZER. P.C.

DEAN D. AULICK. P.C.

JOHN E. STEVEN L. MELIZER. P.C.

DEAN D. AULICK. P.C.

JOHN E. STEVEN L. MELIZER. P.C.

DEAN D. AULICK. P.C.

JOHN E. STEVEN L. MELIZER. P.C.

DEAN D. AULICK. P.C.

JOHN E. STEVEN L. MELIZER. P.C.

DEAN D. AULICK. P.C.

JOHN E. STEVEN L. MELIZER. P.C.

JOHN F. DEALY\*

CABLE "SHAWLAW"

JOHN F. DEALY\*

COUNSEL

COUNSEL

CARLETON S. JONES, P.C.

VICTORIA J. PERKINS

PACHN HID NOLL P12:02

RAND L. ALLEN
TIMOTRY B. MCBRIDE
ELISABETH M. PENDLETON
PAUL A. KAPLAN
HARRY H. GLASSPIEGEL
JEFFERY L. YABLON
JACK MCKAY
THOMAS H. MCCORMICK
SUSAN M. FREUND
JOHN L. CARR. JR.
PHILIP J. HARVEY PHILIP J. HARVEY ROBERT M. GORDON BARBARA J. MORGEN BONNIE S. GOTTLIEB HOWARD H SHAFFERMAN DEBORAH B BAUSER SCOTT A ANENBERG CAMPBELL KILLEFER SETH H. HOOGASIAN SHEILA McC. HARVEY DELISSA A. RIDGWAY

KENNETH J. HAUTMAN DAVID LAWRENCE MILLER ANNE M. KRAUSKOPF ANNE M. KRAUSKOPP
FREDERICK L. KLEIN
GORDON R. KANOFSKY
JEFFREY S. GIANCOLA
HANNAH E. M. LIEBERMAN
SANDRA E. FOLSOM
MARCIA R. NIRENSTEIN
JUDITH A. SANDLER
FOWARD D. YOUNG III EDWARD D. YOUNG, III ROBERT L. WILLMORE ANDREW D. ELLIS WENDELIN A. WHITE STANLEY M. BARG KRISTI L. LIMBO LESLIE K. SMITH LESLIE K. SMITH
VIRGINIA S. RUTLEDGE
KATHERINE P. CHEEK
JANICE LEHRER-STEIN
TRAVIS T. SROWN. JR
GAIL E. CURREY
RICHARD S. KRONTHAL
STEPHEN B. HEMAIN THOT ADMITTED IN D.C.

January 17, 1983

WRITER'S DIRECT DIAL NUMBER 822-1090

Director Office of Nuclear Reactor Regulation U.S. Nuclear Regulatory Commission Washington, D.C. 20555

> Order for Modification of License (47 Fed. Reg. 57166): Sacramento Municipal Utility District (Rancho Seco Nuclear Generating Station) Docket No. 50-312

Dear Sir:

On December 22, 1982, the Nuclear Regulatory Commission published in the Federal Register an Order for Modification of License concerning the Rancho Seco Nuclear Generating Station. The Order provided that licensee Sacramento Municipal Utility District may request a hearing with respect to the Order within 25 days of the date of its publication in the Federal Register (i.e., by January 17, 1983).

The Order would require that Licensee install an inadequate core cooling instrumentation system consisting of subcooling margin monitors, core-exit thermocouples and a reactor coolant inventory tracking system, all of which conform to the design parameters specified in NUREG-0737 Item II.F.2. The Order also establishes timing requirements for the design, installation and operation of this system.

The Rancho Seco Nuclear Generating Station already includes subcooling margin monitors and core exit thermocouples. It will also have a reactor coolant inventory tracking system.

8301190223 830117 PDR ADOCK 05000312 PDR

DS03

SHAW, PITTMAN, POTTS & TROWBRIDGE

Director, Office of Nuclear Reactor Regulation January 17, 1983 Page Two

This system will include a wide range hot leg level monitor to provide inventory tracking when reactor coolant pumps are not in operation. To provide inventory tracking when reactor coolant pumps are on, Licensee will commit to install a reactor coolant pump monitor.

Although the Rancho Seco facility will have a reactor sociant inventory tracking system, that system will not include a reactor vessel head level monitor. While such a monitor is not explicitly required by Section III of the Order, Section II of the Order states that differential pressure measurement techniques for reactor coolant inventory tracking are acceptable if they monitor the inventory over the range from the vessel upper head to the bottom of the hot leg as a minimum. The Rancho Seco system will not meet this criterion. Because of the B&W once through steam generator design, a reactor vessel head monitor is neither required nor useful at Rancho Seco.

Licensee is sponsoring further analysis to confirm that a reactor vessel head monitor is not needed at Rancho Seco. Licensee will submit the results of this analysis to the NRC for its review by April 15, 1983. Licensee believes that it would be appropriate to await completion of this further analysis and the NRC's review before determining whether a hearing should be requested. If the NRC Staff upon completion of its review takes the position that a reactor vessel head monitor is still required for Rancho Seco, Licensee respectfully requests an extension of time within which to request a hearing until 30 days after notification by the NRC Staff of that position.

The Office of Executive Legal Director has indicated that it does not object to the requested extension. If this request for extension is not granted, Licensee hereby requests a hearing on the Order.

Sincerely,

L.omas A. Baxter

Tione A Batter

Counsel for Licensee Sacramento Municipal Utility District

cc: Docketing and Service Section, Office of the Secretary Office of Executive Legal Director