NRC FORM 366
(7-77)

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | NJSGS2 (2) | 00-000000-00 (3) | 41111 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
01 | REPORT SOURCE L (6) | 05000311 (7) | 063082 (8) | 122982 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 At 1837 hours, June 30, 1982, during routine operation, No. 22 Feedwater Pump tripped
03 due to low suction pressure. The operator immediately reduced turbine load, and
04 control rod insertion commenced, resulting in Axial Flux Distribution (AFD) going out
05 of the target band. Action Statement 3.2.1.a was entered accordingly. By 1857 hours,
06 AFD was within the target band, with a total of 19 minutes penalty accumulated. The
07 occurrence constituted operation in a degraded mode in accordance with Technical
08 Specification 6.9.1.9.b.

09 | SYSTEM CODE CH (11) | CAUSE CODE X (12) | CAUSE SUBCODE Z (13) | COMPONENT CODE TURBIN (14) | COMP. SUBCODE Z (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 82 — SEQUENTIAL REPORT NO. 057 — OCCURRENCE CODE 03 — REPORT TYPE X — REVISION NO. 1

ACTION TAKEN G (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT B (20) | SHUTDOWN METHOD Z (21) | HOURS 0009 (22) | ATTACHMENT SUBMITTED Y (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER A (25) | COMPONENT MANUFACTURER D055 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 At 1857 hours, June 30, 1982, with AFD back in the target band, the action statement
11 was terminated. The feedwater pump trip was due to a decrease in suction pressure
12 associated with placing No. 26A Feedwater Heater in service. Operating instructions
13 have been revised to ensure the piping is vented and filled prior to opening the feed-
14 water heater isolation valves.

15 | FACILITY STATUS E (28) | % POWER 100 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Operator Observation

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 | PERSONNEL EXPOSURES NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 | PERSONNEL INJURIES NUMBER 000 (40) | DESCRIPTION (41) NA

19 | LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION NA (43)

20 | PUBLICITY ISSUED N (44) | DESCRIPTION (45) NA

8301190232 830110
PDR ADOCK 05000311
S PDR

NRC USE ONLY

NAME OF PREPARER R. Heller PHONE: (609)935-6000 Ext 3078