

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | C | A | 5 | 0 | S | 2 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5

CON'T
01 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 0 | 3 | 6 | 1 | 7 | 1 | 2 | 0 | 6 | 8 | 2 | 8 | 0 | 1 | 0 | 5 | 8 | 3 | 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | At 1200 on December 6, 1982, while the plant was in Mode 1, two fire spray systems
03 | in the cable spreading room of the Control Building were declared inoperable in
04 | order to repair a leaking valve. Inoperability of the system did not affect
05 | public health or safety.
06 |
07 |
08 |

09 | SYSTEM CODE: A B (11) CAUSE CODE: E (12) CAUSE SUBCODE: B (13) COMPONENT CODE: V A L V E X (14) COMP. SUBCODE: E (15) VALVE SUBCODE: D (16)
7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 | 24 | 25 | 26 | 27 | 28 | 29 | 30 | 31 | 32 | 33 | 34 | 35 | 36 | 37 | 38 | 39 | 40 | 41 | 42 | 43 | 44 | 45 | 46 | 47 | 48 | 49 | 50

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | The event was due to damaged seating surfaces of manual shutoff valve SA2301MU121
11 | which resulted in minor leakage. The valve was replaced with an identical valve
12 | at 2152 on December 6, 1982, and the system declared operable. No further corrective
13 | action is planned to prevent recurrence as this was an isolated event.
14 |

15 | FACILITY STATUS: B (28) % POWER: 0 5 0 (29) OTHER STATUS: N/A (30) METHOD OF DISCOVERY: B (31) ROUTINE OBSERVATION (32)
16 | ACTIVITY CONTENT: Z (33) Z (34) AMOUNT OF ACTIVITY: N/A (35) LOCATION OF RELEASE: N/A (36)
17 | PERSONNEL EXPOSURES: 0 0 0 (37) Z (38) DESCRIPTION: N/A (39)
18 | PERSONNEL INJURIES: 0 0 0 (40) DESCRIPTION: N/A (41) 830 1200088 S
19 | LOSS OF OR DAMAGE TO FACILITY: Z (42) DESCRIPTION: N/A (43)
20 | PUBLICITY: N (44) DESCRIPTION: N/A (45)

NAME OF PREPARER: H.B. Ray HB Ray / TVL... PHONE: 714-492-7700