



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

January 13, 1983

JAMES P. McGAUGHY, JR.  
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 3100  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Quality Assurance Audit  
Identifies a Requirement of  
Technical Specification  
4.7.8 Not Met  
LER 82-173/03 L-0  
AECM-83/027

On December 15, 1982, a Quality Assurance audit identified that a requirement of Technical Specification 4.7.8 had not been met on several dates. This specification requires the temperatures in selected areas to be determined at least once per 12 hours. Attached is LER 82-173/03 L-0.

Yours truly,

JPM:sap  
Attachment

- cc: Mr. N. L. Stampley (w/a)
- Mr. R. B. McGehee (w/o)
- Mr. T. B. Conner (w/o)
- Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk (w/a)  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

8301200238 830113  
PDR ADOCK 05000416  
S PDR

03 JAN 17 11:26

OFFICIAL COPY

TE 22