NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01	LICENSEE CODE: G A E I H 2 (2) LICENSE NUMBER: 0 0 - 0 0 0 0 0 - 0 0 (3) LICENSE TYPE: 4 1 1 1 1 (4) CAT (5)
CON'T 01	REPORT SOURCE: L (6) DOCKET NUMBER: 0 5 0 0 0 3 6 6 (7) EVENT DATE: 1 2 1 7 8 2 (8) REPORT DATE: 0 1 1 1 8 3 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 On 12/17/82, wnile reviewing surveillance assignment sheets, personnel
03 discovered that the "CALIBRATION OF TELEDYNE-GROTECH PRA-103 PEAK-RECOR-
04 DING ACCELEROMETERS" procedure had not been perfoımed at the required 18
05 month frequency as specified in the Unit 2 T.S. Table 4.3.6.2-1. The
06 due date for calibration was 7/23/82, with the maximum allowable extens-
07 ion date of 12/6/82. The health and safety of the public were not affe-
08 cted by this repetitive event as last reported on LER 50-366/1982-143.

	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
09	Z Z (11)	A (12)	C (13)	Z Z Z Z Z Z (14)	Z (15)	Z (16)

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	8 2	—	1 4 4	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
H (18)	Z (19)	Z (20)	Z (21)	0 0 0 0	N (23)	N (24)	Z (25)	Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The cause of this event has been attributed to personnel oversight.
11 When the calibration was discovered to be overdue, the required procedure
12 was performed and satisfactorily completed on 12/20/82. The responsible
13 personnel have been made aware of the Unit 2 Tech. Spec. frequency
14 requirements for seismic instruments.

	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
15	E (28)	0 9 9 (29)	NA	B (31)	Personnel Observation

	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
16	Z (33)	Z (34)	NA	NA

PERSONNEL EXPOSURES

	NUMBER	TYPE	DESCRIPTION (39)
17	0 0 0 (37)	Z (38)	NA

PERSONNEL INJURIES

	NUMBER	DESCRIPTION (41)
18	0 0 0 (40)	NA

LOSS OF OR DAMAGE TO FACILITY (43)

	TYPE	DESCRIPTION
19	Z (42)	NA

8301200289 830111
PDR ADOCK 05000366
S PDR

PUBLICITY

	ISSUED	DESCRIPTION	NRC USE ONLY
20	N (44)	NA	

NAME OF PREPARER S. B. Tipps PHONE: (912) 367-7851

GPO 917-926