

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 F L S L S 1 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5

LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 37 CAT 38

CON'T

01 L 6 0 5 0 0 0 3 3 5 7 1 2 2 5 8 2 3 0 1 1 2 8 3 9

REPORT SOURCE 30 31 DOCKET NUMBER 38 39 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During normal full power operation, one of four redundant 120 volt AC

03 instrument power busses was lost when the output breaker of the 1A

04 static inverter opened. The event caused a loss of one channel of the

05 reactor protection and engineered safeguards systems. The bus was

06 immediately returned to service by use of the associated maintenance

07 bypass bus. The health and safety of the public were not affected by

08 this event. See ER 82-26 for a similar occurrence.

09 E D 11 X 12 Z 13 G E N E R A 14 F 15 Z 16

SYSTEM CODE 9 10 CAUSE CODE 11 CAUSE SUBCODE 12 COMPONENT CODE 13 COMP SUBCODE 14 VALVE SUBCODE 15

17 8 2 0 6 7 0 3 L 0

LER/RO REPORT NUMBER 21 22 SEQUENTIAL REPORT NO. 24 25 OCCURRENCE CODE 28 29 REPORT TYPE 30 REVISION NO. 32

ACTION TAKEN 33 E 34 Z 35 Z 36 Z 37 0 38 0 39 0 40 0 41 N 42 Y 43 A 44 A 45 4 46 9 47 9

EFFECT ON PLANT 35 SHUTDOWN METHOD 36 HOURS 37 ATTACHMENT SUBMITTED 40 NPRO-4 FORM SUB. 42 PRIME COMP SUPPLIER 43 COMPONENT MANUFACTURER 44

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Investigation into the event revealed a defective output frequency

11 module. The module was adjusted, the output breaker reclosed, and the

12 line up returned to normal.

13

14

15 E 23 0 9 9 29 NA A 31 Operator Observation

FACILITY STATUS 23 % POWER 29 OTHER STATUS 30 METHOD OF DISCOVERY 31 DISCOVERY DESCRIPTION 32

16 Z 33 Z 34 NA NA

ACTIVITY CONTENT 33 RELEASED OF RELEASE 34 AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36

17 0 0 0 37 38 NA

PERSONNEL EXPOSURES 37 NUMBER 38 TYPE 39 DESCRIPTION 39

18 0 0 0 40 41 NA

PERSONNEL INJURIES 40 NUMBER 41 DESCRIPTION 41

19 Z 42 NA

LOSS OF OR DAMAGE TO FACILITY 42 TYPE 43 DESCRIPTION 43

20 N 44 NA

PUBLICITY 44 ISSUED 45 DESCRIPTION 45

8301210012 830112
PDR ADOCK 05000335
S PDR

NAME OF PREPARER T. S. Rotella PHONE 305-465-3550

NRC USE ONLY