


THE CINCINNATI GAS & ELECTRIC COMPANY



CINCINNATI, OHIO 45201

January 9, 1983
QA-2195

E. A. BORGMANN
SENIOR VICE PRESIDENT

U. S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

Attention: Mr. J. G. Keppler
Regional Administrator

RE: WM. H. ZIMMER NUCLEAR POWER STATION I
10CFR50.55(e) ITEM M-72 - LACK OF DOCUMENTATION
FOR FIRE PROTECTION SYSTEM, DOCKET NO. 50-358,
CONSTRUCTION PERM. NO. CPPR-88, W.O. 57300, JOB
E-5590, FILE NO. NRC-8, M-72

Gentlemen:

This letter constitutes an interim report concerning the subject condition, initially reported to the Commission as a potentially reportable deficiency under 10CFR50.55(e).

In the process of reviewing commitments made relative to fire protection, it was found that CG&E committed to provide a quality assurance program to cover the design, procurement, installation and testing of the fire protection systems for the Zimmer Station.

Preliminary checks indicate that S&L did not fulfill the requirements of Branch Technical Position APCSB 9.5-1, Appendix A, relative to design and procurement, and these requirements were not adequately translated into design drawings or specifications by S&L.

Preliminary checks of on-site records indicate a lack of documentation concerning the installation and testing of the fire protection systems.

We are in the process of doing a more extensive document review and will submit a follow-up report by February 15, 1983.

8301210181 830109
PDR ADOCK 05000358
S PDR


IEJ
JAN 17 1983

Mr. J. G. Keppler
Region III
January 5, 1983 - QA-2195
Page 2

We trust the above will be found acceptable as an interim report under 10CFR50.55(e).

Very truly yours,

THE CINCINNATI GAS & ELECTRIC COMPANY



By
E. A. BORGMANN
SENIOR VICE PRESIDENT

FJS:ar
cc: NRC Office of Inspection & Enforcement
Washington, D.C. 20555
NRC Senior Resident Inspector
Attn: W. F. Christianson
Zimmer Project Inspector
Region III