

## LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 M I D C C 2 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30  
LICENSEE CODE LICENSE NUMBER LICENSE TYPE JO CAT 58

CON'T  
0 1  
7 8  
REPORT SOURCE L 6 0 5 0 0 0 3 1 6 7 1 2 2 3 8 2 3 0 1 2 1 8 3 9  
60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80  
DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10  
0 2 DURING REFUELING OPERATIONS, DOOR #411A TO THE UNIT 2 CONTROL ROOM WOULD NOT  
0 3 CLOSE FULLY BY ITSELF. THIS CONSTITUTED AN INOPERABLE PENETRATION FIRE BARRIER  
0 4 WHICH IS NON-CONSERVATIVE WITH RESPECT TO T.S. 3.7.10. ACTION REQUIREMENTS WERE  
0 5 MET AND PUBLIC HEALTH AND SAFETY WERE NOT AFFECTED.  
0 6  
0 7  
0 8  
0 9  
7 8 9 10

0 3  
7 8  
SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP SUBCODE VALVE SUBCODE  
A B 11 X 12 Z 13 X X X X X X 14 Z 15 Z 16  
9 10 11 12 13 14 15 16 17 18 19 20  
EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.  
8 2 1 1 4 0 3 L 0  
21 22 23 24 25 26 27 28 29 30 31 32

0 3  
7 8  
LER RO REPORT NUMBER 17  
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER  
E 18 Z 19 Z 20 Z 21 0 0 0 0 N 23 N 24 A 25 X 9 9 9 9 26  
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27  
1 3 THE FAILURE WAS DUE TO THE VENTILATION FLOW PATTERN EXISTING DURING WORK IN THE  
1 4 CONTROL ROOM CABLE VAULT. INVESTIGATION WILL CONTINUE IN AN ATTEMPT TO LESSEN THE  
1 5 IMPACT OF VENTILATION FLOW ON THE CONTROL ROOM DOOR.  
1 6  
1 7  
1 8  
7 8 9 10

1 5  
7 8  
FACILITY STATUS % POWER OTHER STATUS 30 METHOD OF DISCOVERY DISCOVERY DESCRIPTION 32  
H 28 0 0 0 29 NA A 31 SECURITY OFFICER OBSERVATION  
9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

1 5  
7 8  
ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36  
Z 33 Z 34 NA NA  
9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

1 7  
7 8  
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39  
0 0 0 37 Z 38 NA  
9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

1 5  
7 8  
PERSONNEL INJURIES NUMBER DESCRIPTION 41  
0 0 0 40 NA  
9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

1 9  
7 8  
LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION 43  
Z 42 NA  
9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

2 3  
7 8  
PUBICITY ISSUED DESCRIPTION 45  
N 44 NA  
9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

8301280102 830121  
PDR ADOCK 05000316  
S PDR

NRC USE ONLY  
68 69 70 71 72 73 74 75 76 77 78 79 80  
NAME OF PREPARER R. H. PIEHL PHONE: 616-465-5901