

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | N C B E P 2 | 0 0 - 0 0 0 0 0 - 0 0 | 3 4 1 1 1 1 | 4 | 5
7 8 | 9 | 14 15 | 25 26 | 30 | 57 CAT 58

CON'T
0 1 | L | 0 5 0 - 0 3 2 4 | 7 1 2 2 2 8 2 | 8 | 0 1 2 1 8 3 | 9
7 8 | 60 61 | 68 69 | 74 75 | 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
0 2 | Routine surveillance during unit shutdown operation revealed the local meter
0 3 | indicator of PCIS reactor level trip module, 2-B21-LTM-N024A-1, showed an upscale
0 4 | indication of reactor level while the local meter indicator of redundant instrument
0 5 | 2-B21-LTM-N024B-1 showed an expected indication of 198.0". These instruments
0 6 | actuate on reactor low level No. 2 and provide input for PCIS group Nos. 1 and 3.
0 7 | This event did not affect the health and safety of the public.

0 8 | Technical Specifications 3.3.2, 6.9.1.9b | 9 80

0 5 | SYSTEM CODE S D (11) CAUSE CODE E (12) CAUSE SUBCODE E (13) COMPONENT CODE I N S T R U (14) COMP. SUBCODE T (15) VALVE SUBCODE Z (16)
7 8 | 9 10 | 11 12 | 13 18 | 19 20

17 | LER/RO REPORT NUMBER 8 2 | EVENT YEAR 21 22 | SEQUENTIAL REPORT NO. 1 3 4 | OCCURRENCE CODE 0 3 | REPORT TYPE L | REVISION NO. 0
7 8 | 21 22 | 23 24 26 | 27 28 29 | 30 31 | 32

ACTION TAKEN E (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS 0 0 0 0 (22) | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. Y (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER R 3 6 9 (26)
7 8 | 33 34 | 35 36 | 37 40 | 41 42 | 43 44 | 45 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
1 0 | An investigation showed LTM-N024A-1 and its respective transmitter, 2-B21-LT-N024A-1,
1 1 | were both functioning out of calibration tolerances due to instrument drift. Both
1 2 | instruments, Model No. 1152, were calibrated and returned to service. This is the
1 3 | first reportable event involving these instruments in this particular application.
1 4 | Therefore, no further action regarding this event is required.

1 5 | FACILITY STATUS G (28) | % POWER 0 0 0 (29) | OTHER STATUS NA (30) | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION Operator Surveillance (32)
7 8 | 9 10 | 11 13 | 44 45 46 | 80

1 6 | ACTIVITY CONTENT Z (33) | RELEASED OF RELEASE Z (34) | AMOUNT OF ACTIVITY NA (35) | LOCATION OF RELEASE NA (36)
7 8 | 9 10 | 11 44 | 45 80

1 7 | PERSONNEL EXPOSURES NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION NA (39)
7 8 | 9 11 12 | 13 80

1 8 | PERSONNEL INJURIES NUMBER 0 0 0 (40) | DESCRIPTION NA (41)
7 8 | 9 11 12 | 13 80

1 9 | LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION NA (43)
7 8 | 9 10 | 11 80

2 0 | ISSUED DESCRIPTION N (44) | PUBLICATION 8302010375 830121 PDR ADOCK 05000324 S PDR
7 8 | 9 10 | 80 80

917-925