

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | I | L | D | R | S | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 4 | 1 | 1 | 1 | 1 | _____

01 | REPORT SOURCE | L | 0 | 5 | 0 | 0 | 0 | 2 | 3 | 7 | 0 | 1 | 0 | 8 | 8 | 3 | 0 | 1 | 1 | 9 | 8 | 3 | _____

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES

02 | During surveillances DIS 1400-5 and DOS 6600-1, the diesel generator (D/G) low water
03 | pressure alarm was received. When the diesel was manually stopped, it did not run
04 | for the normal coastdown of 5 minutes because of the low water pressure alarm. D/G
05 | was declared inoperable (T.S. 3.9.A.2.). The event was of minimal safety signifi-
06 | cance since normal power was available and the D/G would have been available during
07 | accident conditions. There was no effect on public health or safety. Previous simi-
08 | lar occurrence was reported by R.O. 82-45/01T-0 on Docket 50-249.

09 | SYSTEM CODE | CAUSE CODE | CAUSE SUBCODE | COMPONENT CODE | COMP. SUBCODE | VALVE SUBCODE
| I | E | E | I | N | S | T | R | U | S | Z |
17 | LER/RO REPORT NUMBER | EVENT YEAR | SEQUENTIAL REPORT NO. | OCCURRENCE CODE | REPORT TYPE | REVISION NO.
| 8 | 3 | 0 | 0 | 3 | 0 | 3 | L | 0 |
ACTION TAKEN | FUTURE ACTION | EFFECT ON PLANT | SHUTDOWN METHOD | HOURS | ATTACHMENT SUBMITTED | NPRD-4 FORM SUB. | PRIME COMP. SUPPLIER | COMPONENT MANUFACTURER
| A | Z | Z | Z | 0 | 0 | 0 | 0 | N | Y | N | S | 3 | 4 | 5 |

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS

10 | The cause of this event was due to a bad Low Cooling Water Pressure Switch. The
11 | switch, class 9012, type ACW5548, was replaced with class 9012 type GAW-5 and Unit
12 | 2/3 D/G successfully tested. The Unit 2/3 D/G declared operable prior to the seven
13 | day requirement in the Tech. Spec. The monthly surveillance will continue to be per-
14 | formed per DOS 6600-1.

15 | FACILITY STATUS | % POWER | OTHER STATUS | METHOD OF DISCOVERY | DISCOVERY DESCRIPTION
| H | 0 | 0 | 0 | N/A | B | Diesel Surveillance

16 | ACTIVITY CONTENT | AMOUNT OF ACTIVITY | LOCATION OF RELEASE
| Z | N/A | N/A

17 | PERSONNEL EXPOSURES | TYPE | DESCRIPTION
| 0 | 0 | 0 | Z | N/A

18 | PERSONNEL INJURIES | DESCRIPTION
| 0 | 0 | 0 | 0 | N/A

19 | LOSS OF OR DAMAGE TO FACILITY | DESCRIPTION
| Z | N/A

20 | PUBLICITY | DESCRIPTION
| N | N/A

8302010381 830119
PDR ANOCK 05000237
S PDR

NRC USE ONLY

NAME OF PREFERER: B. A. Schroeder PHONE: 815-942-2920, X-42