

MINIMUM FREQUENCIES FOR EQUIPMENT TESTS

	<u>Test</u>	<u>Frequency</u>	<u>FSAR Sect. Reference</u>
1. Control Rod Assemblies	Rod drop times of full length rods	All rods during each refueling shutdown or following each removal of the reactor vessel head: affected rods following maintenance on or modification to the control rod drive system which could affect performance of those specific rods	7
1a. Reactor Trip Breakers	Open trip	Monthly	-
2. Control Rod Assemblies	Partial movement of all rods	Every 2 weeks	7
3. Pressurizer Safety Valves	Set point	Per ASME Code, Section XI - Inservice Testing Program	-
4. Main Steam Safety Valves	Set point	Per ASME Code, Section XI - Inservice Testing Program	-
5. Reactor Cavity	Water level	Prior to moving fuel assemblies or control rods and at least once every day while the cavity is flooded.	-
6. Pressurizer PORV Block Valves	Functional	Quarterly	-
7. Pressurizer PORVs	Functional	Every 18 months	-
8. Deleted			
9. Primary System Leakage	Evaluate	Daily	4
10. Deleted			
11. Turbine stop valves, governor valves, and intercept valves. (Part of turbine overspeed protection.)	Functional	Monthly ⁽¹⁾	10
12. Deleted			

(1) This test may be waived for end of cycle operations when boron concentrations are less than 150 ppm provided more than 60 days do not elapse following the last test.

Prairie Island Unit 1
Prairie Island Unit 2

Amendment No. 26, 47, 49, 57, 60
Amendment No. 20, 41, 43, 51, 54