

Docket No. 50-346

License No. NPF-3

Serial No. 906

January 31, 1983



RICHARD P. CROUSE  
Vice President  
Nuclear  
(419) 259-5221

Director of Nuclear Reactor Regulation  
Attention: Mr. John F. Stolz  
Operating Reactor Branch No. 4  
Division of Operating Reactors  
United States Nuclear Regulatory Commission  
Washington, D.C. 20555

Dear Mr. Stolz:

This letter is transmitting, per our response of December 14, 1982 (Serial No. 885), a partial submittal of the information requested in your letter of September 23, 1982 (Log No. 1097) concerning "Control of Heavy Loads at Nuclear Power Plants (NUREG-0612)" for the Davis-Besse Nuclear Power Station Unit No. 1.

The letter of September 23, 1982 contained a Technical Evaluation Report (TER) for Davis-Besse with some open items and a partial response is provided below:

ITEM: 2.1.3 - Load Handling Procedures (Guideline 2, NUREG-0612, Section 5.1.1(2)) page 15 (TER)

RESPONSE: The procedures identified in the TER have been updated to comply with NUREG-0612.

ITEM: 2.2.3 - Special review for Heavy Loads over the core (Interim Protection Measure 6, NUREG-0612, Section 5.3(6)) page 26 (TER).

RESPONSE: Toledo Edison has performed the special reviews for the interim protection Measure 6 of NUREG-0612.

ITEM: 2.1.5 - Special Lifting Devices (Guideline 4, NUREG-0612, Section 5.1.1(4)). Toledo Edison Exception 3 as identified on page 16 of the TER. (ANSI N14.6-1978 Section 5.3.3).

RESPONSE: Toledo Edison will perform load testing in accordance with ANSI N14.6-1978 Section 5.3.3 for identified overstressed conditions in accordance with the standard.

A033

Docket No. 50-346  
License No. NPF-3  
Serial No. 906  
January 31, 1983  
Page 2

In accordance with our December 14, 1982 letter, a response will be provided on the remaining open items by April 1, 1983.

Toledo Edison plans to submit a Phase II submittal in accordance with NUREG-0612. We will provide a date for submittal two (2) weeks after the above open items are submitted.

Very truly yours,



RPC:GAB:lah

cc: DB-1 NRC Resident Inspector