

ATTACHMENT 2

Proposed Changes to Technical Specification Pages:

Unit 1, page 3/4 3-47
Unit 1, page 3/4 3-48
Unit 2, page 3/4 3-47
Unit 2, page 3/4 3-48

TABLE 3.3-8

METEOROLOGICAL MONITORING INSTRUMENTATION

<u>INSTRUMENT</u>	<u>LOCATION</u>	<u>MINIMUM OPERABLE</u>
1. WIND SPEED		
a. Meteorological Tower, Nominal Elev. 33 ft. (Primary)		1 of X ³
b. Meteorological Tower, Nominal Elev. 150 ft. (Primary)		
c. Meteorological Tower, Nominal Elev. 33 ft. (Backup)		
2. WIND DIRECTION		
a. Meteorological Tower, Nominal Elev. 33 ft. (Primary)		1 of X ³
b. Meteorological Tower, Nominal Elev. 150 ft. (Primary)		
c. Meteorological Tower, Nominal Elev. 33 ft. (Backup)		

TABLE 4.3-5

METEOROLOGICAL MONITORING INSTRUMENTATION
SURVEILLANCE REQUIREMENTS

<u>INSTRUMENT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>
1. WIND SPEED*		
a. Nominal Elev. 33 ft. (Primary)	D	SA
b. Nominal Elev. 150 ft. (Primary)	D	SA
c. Nominal Elev. 33 ft. (Backup)	D	SA
2. WIND DIRECTION		
a. Nominal Elev. 33 ft. (Primary)	D	SA
b. Nominal Elev. 150 ft. (Primary)	D	SA
c. Nominal Elev. 33 ft. (Backup)	D	SA

*CHANNEL CALIBRATIONS of these instruments shall be performed according to the manufacturers recommendations.

TABLE 3.3-8

METEOROLOGICAL MONITORING INSTRUMENTATION

<u>INSTRUMENT</u>	<u>LOCATION</u>	<u>MINIMUM OPERABLE</u>
1. WIND SPEED		
a. Meteorological Tower, Nominal Elev. 33 ft. (Primary)		1 of X ³
b. Meteorological Tower, Nominal Elev. 150 ft. (Primary)		
c. Meteorological Tower, Nominal Elev. 33 ft. (Backup)		
2. WIND DIRECTION		
a. Meteorological Tower, Nominal Elev. 33 ft. (Primary)		1 of X ³
b. Meteorological Tower, Nominal Elev. 150 ft. (Primary)		
c. Meteorological Tower, Nominal Elev. 33 ft. (Backup)		

TABLE 4.3-5

METEOROLOGICAL MONITORING INSTRUMENTATION
SURVEILLANCE REQUIREMENTS

<u>INSTRUMENT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>
1. WIND SPEED*		
a. Nominal Elev. 33 ft. (Primary)	D	SA
b. Nominal Elev. 150 ft. (Primary)	D	SA
c. Nominal Elev. 33 ft. (Backup)	D	SA
2. WIND DIRECTION		
a. Nominal Elev. 33 ft. (Primary)	D	SA
b. Nominal Elev. 150 ft. (Primary)	D	SA
c. Nominal Elev. 33 ft. (Backup)	D	SA

*CHANNEL CALIBRATIONS of these instruments shall be performed according to the manufacturers recommendations.