

NEDO-22128
DRF L12-00525
82NED051
Class I
May 1982

GENERAL ELECTRIC BOILING WATER REACTOR
EXTENDED LOAD LINE LIMIT ANALYSIS
FOR
SUSQUEHANNA STEAM ELECTRIC STATION
UNIT 1

NUCLEAR POWER SYSTEMS DIVISION • GENERAL ELECTRIC COMPANY
SAN JOSE, CALIFORNIA 95125

GENERAL  ELECTRIC

8302090323 830203
PDR ADOCK 05000387
P PDR

IMPORTANT NOTICE REGARDING
CONTENTS OF THIS REPORT
PLEASE READ CAREFULLY

This report was prepared by General Electric solely for Pennsylvania Power and Light Company (PP&L) for PP&L's use in supporting the operation of Susquehanna Steam Electric Station. The information contained in this report is believed by General Electric to be an accurate and true representation of the facts known, obtained or provided to General Electric at the time this report was prepared.

The only undertakings of the General Electric Company respecting information in this document are contained in the General Electric Company Load Line Limit Analysis Quotation No. 185, dated January 15, 1981. The use of this information except as defined by said contract, or for any purpose other than that for which it is intended, is not authorized; and with respect to any such unauthorized use, neither General Electric Company nor any of the contributors to this document makes any representation or warranty (express or implied) as to the completeness, accuracy or usefulness of the information contained in this document, or that such use of such information may not infringe privately owned rights; nor do they assume any responsibility for liability or damage of any kind which may result from such use of such information.

CONTENTS

	<u>Page</u>
1. SUMMARY	1-1
2. INTRODUCTION	2-1
3. DISCUSSION	3-1
3.1 Background	3-1
3.2 Analytical Basis	3-1
3.3 Analysis and Results	3-2
3.3.1 Stability	3-2
3.3.2 Loss-of-Coolant Accident	3-3
3.3.3 Pressurization Transients	3-3
3.3.4 Rod Withdrawal Error	3-6
4. APPLICATION	4-1
5. REFERENCES	5-1

TABLES

<u>Table</u>	<u>Title</u>	<u>Page</u>
3-1	Plant Characteristics	3-7
3-2a	Transient Input Data and Operating Conditions for License Basis Point	3-8
3-2b	Transient Input Data and Operating Conditions for 100% Intercept Point	3-9
3-2c	Transient Input Data and Operating Conditions for Rod Block Intercept Point	3-10
3-2d	Transient Input Data and Operating Conditions for Increased Flow Points	3-11
3-3a	GETAB Analysis Initial Conditions for License Basis Point	3-12
3-3b	GETAB Analysis Initial Conditions for 100% Intercept Point	3-13
3-3c	GETAB Analysis Initial Conditions for Rod Block Intercept Point	3-14
3-3d	GETAB Analysis Initial Conditions for Increased Flow Points	3-15
3-4	ASME Pressure Vessel Code Compliance: MSIV Closure, Flux Scram	3-16
3-5	Transient Summary--Turbine Trip Without Bypass	3-18
3-6	Transient Summary--Load Rejection Without Bypass	3-19
3-7	Transient Summary--Loss of Feedwater Heating	3-20
3-8	Transient Summary--Feedwater Controller Failure	3-21
3-9	Transient Summary--High Pressure Coolant Injection	3-22
3-10	ODYN Transient Results for Off-Rated Core Flow Conditions	3-23

ILLUSTRATIONS

<u>Figure</u>	<u>Title</u>	<u>Page</u>
1-1	Power/Flow Map	1-2
3-1	Susquehanna Operating Power Flow Map	3-25
3-2	Axial Power Shape for 100% and 87% Core Flow, Plant H	3-26
3-3	Axial Power Shape for 100% and 111% Rated Core Flow, Plant F	3-27
3-4	Void Reactivity versus Delta Void for LR w/o BP at 100/100 and 100/87, Plant H	3-28
3-5	Void Reactivity versus Delta Void for TT w/2 BP at 100/111 and 100/100, Plant F	3-29
4-1	Core Flow-Recirculation Flow Relationship for Jet-Pump Plants	4-3

1. SUMMARY

This report justifies the expansion of the operating region of the power/flow map for Susquehanna Steam Electric Station Unit 1 (SSES-1). The underlying technical analysis is referred to as the Extended Load Line Limit Analysis (ELLLA).

Previous analyses of this type, the Load Line Limit Analysis (LLLA), for BWR/4's routinely included analyses at rated power and minimum flows of 91 to 94% of rated. In early 1981, an ELLLA was performed for a typical BWR/3 to support operation at rated power with flow as low as 87%. This work draws on the previous analyses to develop a set of restricted generic conclusions regarding applicability of the license basis safety analyses to operation within this expanded domain (Figure 1-1). It is further shown that the SSES-1 equilibrium cycle for the current GE fuel type meets the conditions of validity of the generic conclusions, and hence that for SSES-1, Cycle 1, the consequences of events initiated from within the extended domain are bounded by the consequences of the same events initiated from the license basis condition.

These analyses show that ascension to full power may proceed along a modified power/flow line bounded by the 108% rod block* line up to the 100% power/87% flow point as shown in Figure 1-1.

The discussion and analyses presented show that all safety bases normally applied to Susquehanna Steam Electric Station Unit 1 are satisfied throughout Cycle 1 for operation within this envelope.

*RB = $0.58 W + 50\%$, where W is recirculation flow in percent of rated.




Figure 2-1. Power/Flow Map

2. INTRODUCTION

Two factors which restrict the flexibility of a BWR during power ascension in proceeding from the low-power/low-core-flow condition to the high-power/high-core-flow condition are: (1) the FSAR power/flow curve, and (2) Preconditioning Interim Operating Management Recommendations (PCIOMRs).

If the rated load line control rod pattern is maintained as core flow is increased, changing equilibrium xenon concentrations will result in less than rated power at rated core flow. In addition, fuel pellet-cladding interaction considerations inhibit withdrawal of control rods at high power levels. The combination of these two factors can result in the inability to attain rated core power directly.

This report provides the analytical basis for Susquehanna Steam Electric Station operation during Cycle 1 under a modified operating envelope to permit the direct ascension to full power within the design bases previously applied.

The operating envelope is modified to include the extended operating region bounded by the 108% APRM rod block line, the rated power line, and the rated load line.

3. DISCUSSION

3.1 BACKGROUND

Operation of the Susquehanna Steam Electric Station Unit 1 utilizing the power/flow map is described in Chapter 4 of the FSAR (Reference 1). This section of the FSAR describes the basic operating envelope (Figure 4.4-5) within which normal reactor operations are conducted and provides the basic philosophy behind the power/flow curve. FSAR Figure 4.4-5 is reproduced as Figure 3-1 of this document.

This analysis expands the operating domain to allow power ascension along the 108% APRM rod block* line to 100% power at 87% flow. Rated power operation at any flow between 87% and 100% is acceptable.

Certain terminology from the previous Load Line Limit Analyses is retained herein:

Rod Block Intercept Point - 85% power/61% flow.

100% Intercept Point - lowest flow point of which rated power operation is acceptable. (87% flow for SSES-1).

Rod Intercept Line - a straight line between the Rod Block Intercept Point and the 100% Intercept Point. Because the latter point lies on the APRM Rod Block line, no Rod Intercept Line exists for SSES-1.

3.2 ANALYTICAL BASIS

To provide relief from the operating restrictions inherently imposed during ascension to power by the existing power/flow curve and PCIOMRs, a modified power/flow curve has been derived. In deriving this operating curve, five design basis objectives were specified:

*RB = 0.58 W+50% where W is recirculation flow in percent of rated.

1. For those transients and accidents that are sensitive to variations in power and flow, the 105% power/100% flow (licensing basis) point must be shown to be a more limiting condition than any condition within the expanded operating region (i.e., the shaded region of Figure 2-1).
2. In no instance shall the ratio of power to flow intentionally exceed the ratio defined by the APRM rod block line.
3. The slope of the APRM rod block line must be such that flow increases are capable of compensating for xenon buildup while increasing reactor power.
4. The consequences of all accidents and transients analyzed in the FSAR and subsequent amendments and the license submittals must remain within the limits normally specified for such events.
5. Reactor power ascension from minimum recirculation pump speed to full power shall be directly attainable through combined control rod movement and recirculation flow increase without violation of either the power/flow line or PCIOMRs.

To meet these objectives, analyses were performed for typical BWRs and conclusions were drawn concerning the safety consequences of operation in the extended operating region (shaded area of Figure 1-1). It was shown by specific analyses for the SSES-1 equilibrium cycle of the current GE fuel type that these conclusions were applicable to SSES-1, Cycle 1.

3.3 ANALYSIS AND RESULTS

3.3.1 Stability

3.3.1.1 Channel Hydrodynamic Conformance to the Ultimate Performance Criterion

The channel performance calculation for SSES-1, Cycle 1, was presented in Reference 1. The decay ratios are reproduced below:

<u>Channel Hydrodynamic Performance</u>	<u>Extrapolated Rod Block Line* - Natural Circulation Power</u>
<u>Channel Type</u>	<u>Decay Ratio</u>
P8x8R Channel	0.81

At this most responsive condition, the most responsive channels are clearly within the bounds of the ultimate performance criteria of ≤ 1.0 decay ratio at all attainable operating conditions.

3.3.1.2 Reactor Conformance to Ultimate Performance Criterion

The decay ratios determined from the limiting reactor core stability conditions are presented in Reference 1. The most responsive case for this analysis is the extrapolated rod block line* - natural circulation condition.

<u>Reactor Core Stability</u>	<u>Extrapolated Rod Block Line* - Natural Circulation Power</u>
Decay Ratio, X_2/X_0	0.96

These calculations show the reactor to be in compliance with the ultimate performance criteria, including the most responsive condition.

3.3.2 Loss-of-Coolant Accident

A discussion of low-flow effects on LOCA analyses for all operating plants (Reference 2) has been presented to and was approved by the NRC (Reference 3). The LOCA analysis for SSES-1 (contained in Reference 1) is applicable in the power flow domain discussed in this report.

3.3.3 Pressurization Transients

As shown in Reference 1, the most limiting transient for SSES-1 equilibrium cycle is the Load Rejection without bypass. The results of numerous transient

*RB $\leq 0.58 W + 50\%$, where W is recirculation flow in % of rated.

evaluations (Tables 3-1 through 3-9) at various power/flow conditions demonstrate that transients originated from within the extended operating domain are less severe than the limiting transient at the license basis condition.

This trend was specifically demonstrated for SSES-1 equilibrium cycle by analyzing the Load Rejection w/o Bypass, Feedwater Controller Failure, and MSIV Closure with Flux Scram events at the limiting point in the extended region (100/87), and comparing the results to those for the licensing basis point (105/100). Those comparisons are shown in Tables 3-4, 3-6, and 3-8, and show that the (100/87) point results are bounded by the licensing basis results. The SSES-1 analyses were performed for the equilibrium cycle of the current GE fuel type with current GE models and are bounding for SSES-1, Cycle 1.

3.3.3.1 Changes in Nuclear Characteristics

The end-of-cycle (EOC) conditions for the various plants and power/flow conditions were calculated in different ways depending on the plant cycle operating plan. For Plant H (see Tables 3-1 through 3-9), the 100/100 EOC point was determined by assuming rated operation (100/100), and by a Haling power shape throughout the cycle (normal practice). The reduced flow points were determined by using the same exposure point and simply reducing the flow. In this case, the exposures for all three points (100/100, 100/92, and 100/87) were identical, only the power shape changed. For other plants, different combinations of Haling "burns" were assumed resulting in unique exposures for each power/flow combination. For Plant F, the 100/100 EOC was determined using the normal Haling assumptions. The 100/111 EOC was then determined by using a 100/111 Haling starting from the 100/100 EOC. On the other hand, the Plant G and L EOCs were determined by using Haling assumptions throughout the cycle, i.e., 100/100 and 100/105 over entire cycle to define the two distinct EOC conditions.

From a transient viewpoint, the important nuclear characteristics which are affected when changing from a high to low flow condition (100/100 to 100/87 or 100/111 to 100/100, etc.) are the scram and void reactivities.

The scram response improves (more negative reactivity) when the flow is reduced. This results because as the flow is reduced, the boiling boundary moves lower in the core, thus causing the axial power shape to peak more

toward the bottom (Figures 3-2 and 3-3). This, in turn, results in a stronger scram response because the control rods become "effective" earlier during insertion.

The impact on void reactivity, of changing between high and low flow conditions, is primarily affected by exposure. Since the high and low flow conditions represent only a slight change in exposure, it is expected that the void reactivity characteristics should be very similar. This trend can be observed by comparing Figures 3-4 and 3-5.

In comparing the various Haling assumptions, both the "F" and "G/L" assumptions define unique EOC nuclear conditions (exposure and power shape) while that applied to H resulted in only a change to the power shape. Since the calculated exposure differences are rather small, all three of these calculational methods yield similar results.

3.3.3.2 Evaluation of Transient Results

This section provides transient result comparisons between high and low flow initial conditions for various plants, and justification for extending the conclusions reached to SSES-1, Cycle 1.

The transient results of primary importance for this study are Δ CPR and peak vessel pressure. Either of these have the potential to impact operation. To ensure that the reduced flow condition (100/87) is bounded by the reference licensing condition, (105/100) it is necessary to consider Δ CPR and the peak vessel pressures.

It was established that the reduced flow condition has an improved scram characteristic and similar void reactivity. Therefore transients originated from the reduced flow condition should exhibit a marked improvement. Demonstrating this trend are the Table 3-10 results for Plants H, F, M, and K.

The Plant H results for 100/100, 100/92 and 100/87, show a clear trend of decreasing Δ CPR with decreasing flow for both LR w/o BP and FWCF. The peak vessel pressure for the MSIV flux scram event was unchanged between 100/100 and 100/92 (the 100/87 condition was not evaluated).

The Plant F results also clearly show Δ CPR improvement for the transient originated from the lower flow condition. The Plant F analysis is somewhat unusual because it assumes that 1/2 of the turbine bypass functions and the scram signal is delayed 0.20 sec after start of turbine stop valve closure.

The net effect is that the TT w/1/2 BP for Plant F is less sensitive to the scram than other plants would be and thus the improvement due to the enhanced scram is understated.

3.3.4 Rod Withdrawal Error

The effective RBM setpoint is a function of power and flow. Above the rated rod line, the rod block will occur with less rod withdrawal. Thus, the evaluation at rated is conservative for operation above the rated load line.

Table 3-1
PLANT CHARACTERISTICS

	Plant											
	A	B	C	D	E	F	G	H	K	L	M	SSES-1
Number of Fuel Bundles	560	764	560	764	368	240	560	484	548	560	560	764
Rated Thermal Power (MWt)	2436	3293	2436	3293	1593	997	2436	1670	2381	2436	2436	3293
Rated Core Flow (Mlb/hr)	77.0	102.5	77.0	102.5	49.0	29.7	77.0	57.6	73.5	78.5	77.0	100.0
Relief Valve Setpoint (psig)	1090	1105	1105	1105	1090	1065	1090	1108	1080	1080	1090	1110
Relief Valve Capacity (No./%NBR)	11/85.7	11/66.0	11/87.4	11/66.0	6/72.0	4/79.0	11/89.6	7/83.0	7/57.1	11/85.7	11/85.7	16/99.0
Safety Valve Setpoint (psig)	--	1250	--	1230	1240	1210	--	--	1240	--	--	--
Safety Valve Capacity (No./%NBR)	--	2/14.8	--	2/13.6	2/18.9	6/122.4	--	--	3/14.8	--	--	--
Control Rod Drive Specification	67b	67B	67B	67B	67B	67B & MST*	67B	67B	67B	67B	67B	67B

*T (% insertion) = 0.375 (5), 0.776 (20), 1.57 (50), 2.75 (90), + 200 msec interrogation delay.

Table 3-2a

TRANSIENT INPUT DATA AND OPERATING CONDITIONS FOR LICENSE BASIS POINT

	Plant											
	A	B	C	D	E	F	G	H	K	L	M	SSS-1
Thermal Power (MWt/%)	2533/104	3441/104	2533/104	3440/104	1657/104	997/100	2536/104	1670/100	2482/104	2537/104	2535/104	3440/105
Steam Flow (Mlb/hr/%)	10.96/105	14.10/105	10.99/105	14.0/105	7.18/105	4.07/100	11.0/105	6.78/100	9.56/105	10.5/105	10.96/105	14.15/105
Core Flow (Mlb/hr/%)	77.0/100	102.5/100	77.0/100	102.5/100	49.0/100	29.7/100	77.0/100	57.6/100	73.5/100	78.5/100	77.0/100	100.0/100
Dome Pressure (psig)	1019	1020	1020	1019	1020	1005	1020	1025	1020	1020	1019	1020
Turbine Pressure (psig)	958	960	960	959	960	960	960	978	960	960	959	960
NDP Void Coefficient (c/%Rg)	-8.76	-6.66	-8.10	-8.32	-9.35	-8.93	-7.68	-6.57			--	
TAP Void Coefficient (c/%Rg)	-10.93	-8.32	-10.13	-10.40	-11.69	-11.16	-10.00	-8.22			--	
NDP Doppler Coefficient (c/°F)	-0.1985	-0.2283	-0.1938	-0.2318	-0.2302	-0.222	-0.225	-0.223			--	
TAP Doppler Coefficient (c/°F)	-0.1886	-0.2169	-0.1841	-0.2202	-0.2187	-0.211	-0.214	-0.212			--	
Average Fuel Temperature (°F)	1519	1337	1538	1360	1359	1377	1357	1171			--	
NDP Scram Worth (\$)	-39.09	-39.28	-38.85	-36.75	-39.17	-46.31	-38.36	-37.05			--	
TAP Scram Worth (\$)	-31.27	-31.42	-31.08	-29.40	-31.34	-37.05	-30.69	-29.64			--	

Table 3-2b

TRANSIENT INPUT DATA AND OPERATING CONDITIONS FOR 100% INTERCEPT POINT

	Plant										SSES-1
	A	B	C	D	E	F	G	H*	K	L	
Thermal Power (MWt/%)	2436/100	3293/100	2436/100	3293/100	1593/100	N/A	2436/100	1670/100	2381/100	2436/100	3293/100
Steam Flow (Mlb/hr/%)	10.47/100	13.42/100	10.47/100	13.38/100	6.84/100		10.47/100	6.77/100	9.57/100	10.03/100	13.46/100
Core Flow (Mlb/hr/%)	72.4/94	93.3/94	72.4/94	93.3/94	45.2/92.2		72.3/94	53.0/92	73.5/94	73.8/94	87.0/87
Dome Pressure (psig)	1012	1013	1014	1013	1014		1021	1022	1014	1013	1003
Turbine Pressure (psig)	957	978	959	958	960		967	977	959	958	948
NDP Void Coefficient (c/%Rg)	-9.16	-6.95	-8.65	-8.90	-9.98		-7.65		--		
TAP Void Coefficient (c/%Rg)	-11.45	-8.69	-10.81	-11.12	-12.47		-10.49				
NDP Doppler Coefficient (c/°F)	-0.2278	-0.2281	-0.2219	-0.2305	-0.2283		-0.225				
TAP Doppler Coefficient (c/°F)	-0.2164	-0.2167	-0.2108	-0.2190	-0.2169		-0.214				
Average Fuel Temperature (°F)	1472	1295	1490	1317	1321		1357				
NDP Scram Worth (\$)	-39.39	-39.41	-38.81	-36.84	-39.29		-38.46				
TAP Scram Worth (\$)	-31.51	-31.53	-31.05	-29.47	-31.43		-30.77				

N/A - Not Analyzed

*Plant H analyzed at 92 & 87% flow.

Table 3-2c

TRANSIENT INPUT DATA AND OPERATING CONDITIONS FOR ROD BLOCK INTERCEPT POINT

	nt										
	A	B	C	D	E	F	G	H	K	L	M
Thermal Power (MWt/%)	2071/85	2799/85	2071/85	2799/85	1354/85	N/A	2071/85	1420/85	N/A	2071/85	N/A
Steam Flow (Mlb/hr/%)	8.72/83.3	11.18/83.3	8.72/83.3	11.13/83.2	5.70/83.3		8.72/83.3	5.64/83.3		8.35/83.3	
Core Flow (Mlb/hr/%)	46.97/61	62.53/61	46.97/61	62.53/61	29.9/61		47.0/61	35.1/61		47.9/61	
Dome Pressure (psig)	992	992	993	992	993		1078	1004		992	
Turbine Pressure (psig)	954	953	955	954	956		988	972		953	
NDP Void Coefficient (c/%Rg)	-10.27	-7.95	-9.60	-10.42	-11.26		-8.97				
TAP Void Coefficient (c/%Rg)	-12.84	-9.94	-12.00	-13.02	-14.08		-11.31				
NDP Doppler Coefficient (c/°F)	-0.2275	-0.2269	-0.2217	-0.2283	-0.2258		-0.2277				
TAP Doppler Coefficient (c/°F)	-0.2161	-0.2155	-0.2106	-0.2169	-0.2145		-0.2163				
Average Fuel Temperature (°F)	1303	1163	1317	1180	1183		1357				
NDP Scram Worth (\$)	-39.64	-40.69	-38.71	-36.60	-39.13		-38.63				
TAP Scram Worth (\$)	-31.71	-32.55	-30.97	-29.28	-31.30		-30.90				

N/A - Not Analyzed

Table 3-2d

TRANSIENT INPUT DATA AND OPERATING CONDITIONS
FOR INCREASED FLOW POINTS

	Plant							
	A-E	F	F ^a	G	H	K	L	M
Thermal Power (Mwt/%)	N/A	997/100	997/100	2540/104	N/A	N/A	2543/104	N/A
Steam Flow (Mlb/hr/%)		4.07/100	4.07/100	10.99/105			10.53/105	
Core Flow (Mlb/hr/%)		33.0/111	33.0/111	80.9/105			82.4/105	
Dome Pressure (psig)		1004	1004	1019			1020	
Turbine Pressure (psig)		958	958	959			959	
NDP Void Coefficient (ζ /Rg)		-9.15	-7.08					
TAP Void Coefficient (ζ /Rg)		-10.19	-8.85					
NDP Doppler Coefficient (ζ /°F)		-0.222	-0.222					
TAP Doppler Coefficient (ζ /°F)		-0.211	-0.210					
Average Fuel Temperature (°F)		1377	1377					
NDP Scram Worth (\$)								
TAP Scram Worth (\$)								

N/A - Not Analyzed

^aFeedwater temperature reduction

Table 3-3a

GETAB ANALYSIS INITIAL CONDITIONS FOR LICENSE BASIS POINT

	Plant											
	A	B	C	D	E	F	G	H	K	L	M	SES-1
Core Power (MWt)	2436	3293	2436	3293	1593	947	2436	1670	2381	2436	2436	3293
Core Flow (Mlb/hr)	77.0	102.5	77.0	102.5	49.0	29.7	77.0	57.6	73.5	78.5	77.0	100.0
Reactor Pressure (psia)	1035	1035	1035	1035	1035	1035	1035	1038	1035	1035	1035	1046
Inlet Enthalpy (Btu/lb)	526.9	521.5	526.9	521.5	526.3	520.7	526.9	524.3	520.4	523.7	526.9	521.7
Nonfuel Power Fraction	0.04	0.04	0.04	0.04	0.04	0.035	0.04	0.035	0.04	0.04	0.04	0.04
Axial Peaking Factor	1.40	1.40	1.40	1.40	1.40	1.40	1.40	1.40	1.40	1.40	1.40	1.40
7x7 Fuel												
Local peaking factor	1.24		1.24	1.24	1.24				1.24	1.24		
Radial peaking factor	1.17		1.23	1.37	1.22				1.21	1.33		
R-factor	1.100		1.100	1.080	1.100				1.100	1.100		
Bundle power (MWt)	5.012		5.267	5.794	5.173				5.489	5.651		
Bundle flow (10 ³ lb/hr)	127.2		125.8	122.5	126.2				122.6	125.5		
8x8 Fuel												
Local peaking factor	1.22		1.22		1.22			1.22			1.22	
Radial peaking factor	1.24		1.32		1.29			1.52			1.35	
R-factor	1.098		1.098		1.098			1.098			1.093	
Bundle power (MWt)	5.306		5.306		5.466			5.131			5.753	
Bundle flow (10 ³ lb/hr)	118.3		116.2		116.0			104.2			115.0	
8x8R Fuel												
Local peaking factor	1.22	1.26	1.20	1.20			1.20	1.20	1.20	1.20	1.20	
Radial peaking factor	1.39	1.61	1.46	1.56			1.52	1.67	1.54	1.60	1.50	
R-factor	1.051	1.051	1.051	1.056			1.051	1.052	1.051	1.052	1.051	
Bundle power (MWt)	5.966	6.935	6.220	6.529			6.489	5.618	6.553	6.815	6.397	
Bundle flow (10 ³ lb/hr)	118.2	109.3	117.0	110.6			112.1	97.2	110.4	112.2	115.2	
PBx8R Fuel												
Local peaking factor							1.20	1.20		1.20	1.20	1.20
Radial peaking factor							1.52	1.63		1.66	1.48	1.54
R-factor							1.051	1.052		1.052	1.051	1.050
Bundle power (MWt)							6.472	5.496		6.828	6.397	6.496
Bundle flow (10 ³ lb/hr)							112.4	97.9		113.0	115.2	104.2

Table 3-3b

GETAB ANALYSIS INITIAL CONDITIONS FOR 100% INTERCEPT POINT

	Plant												SSES-1
	A	B	C	D	E	F	G	H*	H*	K	L	M	
Core Power (MWt)	2436	3293	2436	3293	1593	N/A	2436	1620	1670	2381	2436	2436	3293
Core Flow (Mlb/hr)	72.4	96.4	72.4	93.3	45.2		72.4	53.0	50.4	69.1	73.8	72.4	87.0
Reactor Press a (psia)	1034	1034	1033	1033	1034		1034	1037	1036	1034	1034	1034	1033
Inlet Enthalpy (Btu/lb)	525.5	519.9	525.6	518.8	524.5		525.5	522.1	520.8	518.5	522.2	525.5	517.9
Nonfuel Power Fraction	0.04	0.04	0.04	0.04	0.04		0.04	0.035	0.035	0.04	0.04	0.04	0.04
Axial Peaking Factor	1.40	1.40	1.40	1.40	1.40		1.40	1.40	1.40	1.40	1.40	1.40	1.40
7x7 Fuel													
Local peaking factor	1.24		1.24	1.24	1.24					1.24	1.24	1.22	
Radial peaking factor	1.19		1.25	1.36	1.22					1.24	1.36	1.36	
R-factor	1.100		1.100	1.080	1.100					1.100	1.100	1.098	
Bundle power (MWt)	5.058		5.336	5.749	5.179					5.466	5.798	5.784	
Bundle flow (10 ³ lb/hr)	119.2		117.5	104.0	116.1					115.1	125.5	107.2	
8x8 Fuel													
Local peaking factor	1.22		1.22	1.22	1.22			1.22	1.22	1.22			
Radial peaking factor	1.27		1.35	1.40	1.30			1.52	1.52	1.52			
R-factor	1.098		1.098	1.096	1.098			1.098	1.098	1.098			
Bundle power (MWt)	5.402		5.736	5.912	5.515			5.143	5.100	6.454			
Bundle flow (10 ³ lb/hr)	110.1		108.1	93.7	106.1			95.2	90.2	98.8			
8x8R Fuel													
Local peaking factor	1.20	1.24	1.22	1.20			1.20	1.20	1.20	1.20	1.20	1.20	
Radial peaking factor	1.40	1.58	1.48	1.53			1.51	1.67	1.67	1.53	1.62	1.50	
R-factor	1.051	1.051	1.051	1.058			1.051	1.052	1.052	1.051	1.052	1.051	
Bundle power (MWt)	5.942	6.637	6.310	6.401			6.389	5.612	5.600	6.551	6.879	6.402	
Bundle flow (10 ³ lb/hr)	110.1	94.8	108.9	92.4			105.6	88.8	87.8	102.1	112.9	107.7	
P8x8R Fuel													
Local peaking factor							1.20	1.20	1.20	1.20	1.20	1.20	1.20
Radial peaking factor							1.49	1.63	1.63	1.52	1.61	1.47	1.49
R-factor							1.051	1.052	1.052	1.051	1.052	1.051	1.050
Bundle power (MWt)							6.389	5.494	5.500	6.472	6.858	6.280	6.259
Bundle flow (10 ³ lb/hr)							105.6	89.5	87.8	103.3	114.0	108.4	91.3

*Plant H analyzed at 92 and 87% flow

N/A - Not Analyzed

Table 3-3c

GETAB ANALYSIS INITIAL CONDITIONS FOR ROD BLOCK INTERCEPT POINT

	Plant										
	A	B	C	D	E	F	G	H	K	L	M
Core Power (MWt)	2071	2799	2071	2799	1354	N/A	2071	1420	N/A	2071	N/A
Core Flow (Mlb/hr)	47.0	62.5	47.0	62.5	29.9		47.0	35.1		47.9	
Reactor Pressure (psia)	1008	1007	1007	1007	1007		1008	1010		1008	
Inlet Enthalpy (Btu/lb)	513.2	506.7	513.3	506.4	512.4		513.2	510.2		509.4	
Nonfuel Power Fraction	0.04	0.04	0.04	0.04	0.04		0.04	0.035		0.04	
Axial Peaking Factor	1.40	1.40	1.40	1.40	1.40		1.40	1.40		1.40	
7x7 Fuel											
Local peaking factor	1.23		1.24	1.24	1.24					1.24	
Radial peaking factor	1.32		1.32	1.38	1.28					1.44	
R-factor	1.100		1.100	1.080	1.100					1.100	
Bundle power (MWt)	4.761		4.793	4.952	4.610						
Bundle flow (10 ³ lb/hr)	75.3		75.2	74.2	76.2						
8x8 Fuel											
Local peaking factor	1.22		1.22	1.22	1.22			1.22			
Radial peaking factor	1.44		1.47	1.44	1.41			1.65			
R-factor	1.098		1.098	1.096	1.098			1.098			
Bundle power (MWt)	5.205		5.320	5.140	5.074			4.729			
Bundle flow (10 ³ lb/hr)	68.2		67.6	66.0	68.2			61.1			
8x8R Fuel											
Local peaking factor	1.20	1.24	1.22	1.20			1.20	1.20		1.20	
Radial peaking factor	1.57	1.54	1.59	1.55			1.61	1.79		1.65	
R-factor	1.051	1.051	1.051	1.058			1.051	1.052		1.052	
Bundle power (MWt)	5.684	5.503	5.756	5.504			5.75	5.109			
Bundle flow (10 ³ lb/hr)	68.2	61.8	68.5	66.9			60.8	57.7			
P8x8R Fuel											
Local peaking factor							1.20	1.20		1.20	
Radial peaking factor							1.59	1.76		1.60	
R-factor							1.051	1.052		1.052	
Bundle power (MWt)							5.75	5.041			
Bundle flow (10 ³ lb/hr)							66.5	58.0			

N/A - Not Analyzed

Table 3-3d

GETAB ANALYSIS INITIAL CONDITIONS FOR INCREASED FLOW POINTS

	Plant						
	A-E	F	G	H	K	L	M
Core Power (MWt)	N/A	997	2541	N/A	N/A		N/A
Core Flow (Mlb/hr)		33.0	80.9				
Reactor Pressure (psia)		1037	1043				
Inlet Enthalpy (Btu/lb)		523.4	528.4				
Nonfuel Power Fraction		0.04	0.04				
Axial Peaking Factor		1.40	1.40				
7x7 Fuel							
Local peaking factor							
Radial peaking factor							
R-factor							
Bundle power (MWt)							
Bundle flow (10 ³ lb/hr)							
8x8 Fuel							
Local peaking factor							
Radial peaking factor							
R-factor							
Bundle power (MWt)							
Bundle flow (10 ³ lb/hr)							
8x8R Fuel							
Local peaking factor		1.20	1.20				
Radial peaking factor		1.56	1.51				
R-factor		1.052	1.051				
Bundle power (MWt)		6.354	6.693				
Bundle flow (10 ³ lb/hr)		114.3	118.3				
P8x8R Fuel							
Local peaking factor		1.20	1.20				
Radial peaking factor		1.53	1.49				
R-factor		1.052	1.051				
Bundle power (MWt)		6.231	6.617				
Bundle flow (10 ³ lb/hr)		115.2	119.0				

N/A - Not Analyzed

Table 3-4

ASME PRESSURE VESSEL CODE COMPLIANCE: MSIV CLOSURE, FLUX SCRAM

<u>Plant</u>	<u>Initial Power/Flow</u>	<u>Peak Neutron Flux ϕ (% initial)</u>	<u>Peak Heat Flux Q/A (% initial)</u>	<u>Peak Steamline Pressure P_{sl} (psig)</u>	<u>Peak Vessel Pressure P_v (psig)</u>
A	(104P, 100F)	849	127	1217	1264
	(100P, 94F)	1005	128	1211	1254
	(85P, 61F)	834	126	1186	1211
B	(104P, 100F)	491	122	1242	1277
	(100P, 94F)	521	122	1226	1260
	(85P, 61F)	504	120	1192	1217
C	(104P, 100F)	741	125	1218	1263
	(100P, 94F)	860	131	1211	1252
	(85P, 61F)	706	131	1189	1214
D	(104P, 100F)	783	125	1266	1295
	(100P, 91F)	797	130	1251	1280
	(85P, 61F)	405	124	1193	1217
E	(104P, 100F)	770	126	1245	1287
	(100P, 92.2F)	939	126	1247	1271
	(85P, 61F)	897	124	1196	1217
F	(100P, 111F)	617	129	1260	1303
G	(104P, 100F)	677*	122	1203	1234
	(100P, 94F)	632*	122	1201	1231
	(91P, 75F)	507*	123	1180	1205
	(85P, 61F)	405*	123	1182	1199
	(104P, 105F)	702*	122	1202	1235

Table 3-4

ASME PRESSURE VESSEL CODE COMPLIANCE: MSIV CLOSURE, FLUX SCRAM
(Continued)

<u>Plant</u>	<u>Initial Power/Flow</u>	<u>Peak Neutron Flux ϕ (% initial)</u>	<u>Peak Heat Flux Q/A (% initial)</u>	<u>Peak Steamline Pressure P_{sl} (psig)</u>	<u>Peak Vessel Pressure P_v (psig)</u>
	(100P, 100F)	658*	128	1222	1244
	(100P, 92F)	662*	127	1223	1243
H	(100P, 87F)	635*	127		
	(92P, 75F)	525*	128	1207	1228
	(85P, 61F)	444*	128	1187	1207
	(104P, 100F)	446*	124	1243	1270
K	(100P, 94F)	440*	122	1234	1261
	(104P, 100F)	568*	120	1199	1232
L	(100P, 94F)	538*	122	1192	1224
	(91P, 75F)	421*	120	1169	1195
	(85P, 61F)	348*	120	1164	1183
	(104P, 105F)	576*	120	1199	1233
	(104P, 100F)	693*	124	1236	1275
M	(100P, 94F)	616*	124	1229	1266
SSES-1	(105P, 100F)	602	124	1246	1276
	(100P, 87F)	523	123	1239	1266

*% Nominal Rated

Table 3-5
TRANSIENT SUMMARY--TURBINE TRIP WITHOUT BYPASS

Plant	Analysis	Initial Power (% NBR)	Initial Flow (% NBR)	$\dot{\phi}$ (% initial)	\dot{Q}/A (% initial)	\dot{P}_{sl} (psig)	\dot{P}_j (psig)	ΔCPR			
								7x7	8x8	8x8R	P8x8R
A	R	104	100	353	114	1177	1220	0.22	0.30	0.29	--
A	R	100	94	354	114	1172	1215	0.22	0.29	0.29	--
A	R	85	61	247	106	1158	1182	0.09	0.13	0.13	--
B	R	104	100	183	172	1198	1225	--	0.12	0.12	--
B	R	100	94	173	102	1185	1211	--	0.12	0.12	--
B	R	85	61	150	100	1160	1180	--	0.06	0.06	--
C	R	104	100	260	110	1171	1217	0.16	0.23	0.22	--
C	R	100	94	254	113	1167	1209	0.15	0.21	0.21	--
C	R	85	61	169	105	1155	1178	0.04	0.07	0.07	--
D	R	104	100	249	109	1186	1228	0.13	0.18	0.18	--
D	R	100	91	249	108	1176	1214	0.12	0.17	0.17	--
D	R	85	61	162	105	1152	1175	0.01	0.02	0.03	--
E	R	104	100	333	115	1207	--	0.20	0.28	--	--
E	R	100	92	325	113	1187	--	0.18	0.26	--	--
E	R	85	61	181	101	1149	--	0.04	0.06	--	--
F ^{b,c}	\emptyset	100	100	889	121	1110	1139	--	--	0.25	0.29
F ^{b,c}	\emptyset	100	111	924	121	1109	1143	--	--	0.28	0.32
F ^{a,b,c}	\emptyset	100	111	849	120	1109	1143	--	--	0.26	0.30
F ^{b,c,d}	\emptyset	100	111	924	121	1108	1141	--	--	0.28	0.32
F ^{b,d,e}	\emptyset	100	100	628	116	1103	1129	--	--		
F ^{b,d,e}	\emptyset	100	111	723	118	1103	1134	--	--	0.22	0.26

^a Feedwater temperature reduction

^b 1/2 bypass failure

^c No position scram

^d Measured scram time

^e Position scram with 200 msec delay

^f % nominal rated

R - REDY, \emptyset -ODYN

Table 3-6

TRANSIENT SUMMARY--LOAD REJECTION WITHOUT BYPASS

Plant	Analysis	Initial Power (% NBR)	Initial Flow (% NBR)	$\bar{\phi}$ (% initial)	\bar{Q}/A (% initial)	\bar{P}_{s1} (psig)	\bar{P}_v (psig)	ACPR			
								7x7	8x8	8x8R	PSx8R
A	R	104	100	376	115	1178	1225	0.23	0.31	0.30	--
A	R	100	94	360	115	1173	1216	0.22	0.29	0.29	--
A	R	85	61	251	107	1157	1182	0.09	0.13	0.13	--
B	R	104	100	201	104	1203	1229	--	0.14	0.14	--
B	R	100	94	191	103	1189	1215	--	0.14	0.14	--
B	R	85	61	167	102	1162	1183	--	0.09	0.09	--
C	R	104	100	302	111	1172	1219	0.18	0.25	0.25	--
C	R	100	94	284	114	1168	1210	0.16	0.22	0.22	--
C	R	85	61	168	106	1154	1177	0.04	0.07	0.07	--
D	R	104	100	277	111	1189	1233	0.15	0.21	0.21	--
D	R	100	91	267	115	1180	1219	0.14	0.19	0.19	--
D	R	85	61	176	107	1153	1177	0.03	0.05	0.06	--
E	R	104	100	367	116	1209	--	0.22	0.30	--	--
E	R	100	92	348	114	1188	--	0.19	0.27	--	--
E	R	85	61	179	101	1149	--	0.04	0.07	--	--
F	NOT ANALYZED										
G	\emptyset	104	100	507 ^b	114	1186	1208	--	--	0.17	0.17
G	\emptyset	100	94	489 ^b	114	1180	1202	--	--	--	--
G	\emptyset	91	75	424 ^b	113	1175	1194	--	--	--	--
G	\emptyset	85	61	323 ^b	111	1165	1183	--	--	--	--
G	\emptyset	104	105	501 ^b	113	1184	1207	--	--	0.17	0.18
G ^a	\emptyset	105	100	503 ^b	115	1178	1200	--	--	0.18	0.18
G ^a	\emptyset	105	105	481 ^b	114	1184	1206	--	--	0.18	0.18
H	\emptyset	100	100	679 ^b	124	1206	1230	--	0.35	0.35	0.39
H	\emptyset	100	92	631 ^b	122	1206	1228	--	0.31	0.31	0.34
H	\emptyset	92	75	396 ^b	120	1183	1202	--	0.25	0.25	0.28
H	\emptyset	85	61	329 ^b	122	1195	1208	--	0.23	0.24	0.26
H	\emptyset	100	87	576 ^b	121	1205	1227	--	0.30	0.30	0.33
K	\emptyset	104	100	502 ^u	117	1179	1213	0.14	0.19	0.19	0.19
K	\emptyset	100	94	469 ^b	117	1174	1206	0.13	0.17	0.17	0.19
L	\emptyset	104	100	338 ^b	108	1166	1189	--	--	--	--
L	\emptyset	100	94	320 ^b	108	1160	1182	--	--	--	--
L	\emptyset	91	75	267 ^b	108	1145	1168	--	--	--	--
L	\emptyset	85	61	216 ^b	106	1145	1160	--	--	--	--
L	\emptyset	104	105	333 ^b	108	1167	1191	0.07	--	0.11	0.11
L ^a	\emptyset	105	105	336 ^b	108	1165	1188	0.08	--	0.11	0.11
L ^a	\emptyset	105	100	346 ^b	109	1166	1187	0.08	--	0.11	0.11
M	\emptyset	104	100	653	120	1208	1246	--	0.22	0.22	0.24
M	\emptyset	100	94	596	120	1197	1231	--	0.20	0.20	0.23
SSES-1 Cycle 1	\emptyset	105	109	447	118	1189	1218	--	--	--	0.19
SSES-1 Cycle 1	\emptyset	100	87	453	117	1183	1204	--	--	--	0.18

^a feedwater temperature reduction

^b nominal rated

Table 3-7
 TRANSIENT SUMMARY--LOSS OF FEEDWATER HEATING

Plant	Analysis	Initial Power (% NBR)	Initial Flow (% NBR)	$\dot{\phi}$ (% initial)	\dot{Q}/A (% initial)	\dot{P}_{sl} (psig)	\dot{P}_v (psig)	ΔCPR			
								7x7	8x8	8x8R	P8x8R
A	R	104	100	116	114	1018	1068	0.11	0.13	0.13	--
A	R	100	94	116	114	1012	1057	0.11	0.13	0.13	--
A	R	85	61	117	117	994	1020	0.13	0.15	0.15	--
B	R	104	100	116	115	1008	1064	--	0.13	0.13	--
B	R	100	94	116	116	1002	1053	--	0.13	0.13	--
B	R	85	61	121	121	988	1019	--	0.19	0.19	--
C	R	104	100	178	116	1019	1068	0.11	0.13	0.13	--
C	R	100	94	116	114	1013	1057	0.12	0.14	0.14	--
C	R	85	61	111	111	992	1017	0.13	0.15	0.15	--
D	R	104	100	117	117	1012	1068	0.15	0.16	0.16	--
D	R	100	91	118	117	1004	1053	0.13	0.14	0.14	--
D	R	85	61	123	128	990	1022	0.18	0.19	0.20	--
E	R	104	100	121	119	1023	--	0.14	0.16	--	--
E	R	100	92	121	120	1016	--	0.14	0.17	--	--
E	R	85	61	125	124	999	--	0.19	0.21	--	--
F	R	100	100	112	111	1002	1043	--	--	0.14	0.14
F	R	100	111	116	113	1041	1083	--	--	0.14	0.14
F ^a	R	100	111	110	110	1023	1073	--	--	0.14	0.14

^aMST

Table 3-8

TRANSIENT SUMMARY--FEEDWATER CONTROLLER FAILURE

Plant	Analysis	Initial Power (% NBR)	Initial Flow (% NBR)	ϕ (% initial)	Q/A (% initial)	P _{sl} (psig)	P _v (psig)	ACPR			
								7x7	8x8	8x8R	PSx8R
A	R	104	100	242	114	1152	1200	0.18	0.25	0.25	--
A	R	100	94	241	115	1150	1193	0.19	0.26	0.26	--
A	R	85	61	184	111	1138	1160	0.13	0.17	0.17	--
B	R	104	100	144	106	1153	1187	--	0.09	0.09	--
B	R	100	94	134	107	1148	1179	--	0.09	0.10	--
B	R	85	61	136	109	1137	1156	--	0.13	0.13	--
C	R	104	100	109	105	1028	1076	0.05	0.06	0.06	--
C	R	100	94	112	110	1022	1067	0.06	0.07	0.08	--
C	R	85	61	117	111	996	1021	0.09	0.10	0.11	--
D	R	104	100	185	---	1147	1193	0.11	0.16	0.16	--
D	R	100	91	174	115	1142	1181	0.09	0.13	0.13	--
D	R	85	61	176	116	1127	1149	0.10	0.12	0.12	--
E	R	104	100	211	111	1146	--	0.14	0.21	--	--
E	R	100	92	188	106	1142	--	0.11	0.17	--	--
E	R	85	61	133	109	1127	--	0.09	0.11	--	--
F	\emptyset	100	100	214	105	1031	1062	--	--	--	--
F	\emptyset	100	111	181	104	1021	1062	--	--	--	--
F ^a	\emptyset	100	111	180	105	1021	1063	--	--	--	--
G	\emptyset	104	100	293 ^b	114	1151	1182	--	--	0.15	0.16
G	\emptyset	100	94	274 ^b	114	1139	1172	--	--	0.15	0.17
G	\emptyset	91	75	256 ^b	114	1133	1160	--	--	0.15	0.16
G	\emptyset	85	61	207 ^b	113	1128	1145	--	--	0.13	0.14
G	\emptyset	104	105	286 ^b	114	1143	1177	--	--	0.16	0.17
G ^a	\emptyset	105	100	317 ^b	119	1148	1177	--	--	0.17	0.18
G ^a	\emptyset	105	105	125 ^b	112	1111	1134	--	--	0.08	0.08
G ^a	\emptyset	95	105	311 ^b	121	1129	1158	--	--	0.21	0.23
H	\emptyset	100	100	518 ^b	124	1169	1201	--	0.33	0.34	0.37
H	\emptyset	100	92	488 ^b	123	1169	1197	--	0.30	0.30	0.33
H	\emptyset	100	87	465 ^b	122	1170	1194	--	0.29	0.30	0.32
H	\emptyset	92	75	345 ^b	118	1166	1184	--	0.23	0.24	0.26
H	\emptyset	85	61	230 ^b	116	1147	1170	--	0.17	0.19	0.21
K	\emptyset	104	100	314 ^b	114	1135	1172	0.09	0.13	0.14	0.16
K	\emptyset	100	94	282 ^b	116	1131	1165	0.13	0.17	0.17	0.19
L	\emptyset	104	100	147 ^b	108	1137	1161	0.08	--	0.11	0.11
L	\emptyset	100	94	191 ^b	110	1128	1158	0.07	--	0.11	0.12
L	\emptyset	91	75	188 ^b	110	1124	1144	0.07	--	0.11	0.12
L	\emptyset	85	61	146 ^b	109	1119	1138	0.06	--	--	--
L	\emptyset	104	105	198 ^b	110	1136	1166	0.07	--	0.11	0.12
L ^a	\emptyset	105	105	234 ^b	115	1131	1163	0.11	--	0.15	0.16
L ^a	\emptyset	105	100	126 ^b	111	1107	1128	0.06	--	0.08	0.08
M	\emptyset	104	100	362*	118	1173	1216	--	0.17	0.17	0.19
M	\emptyset	100	94	332*	118	1170	1210	--	0.16	0.17	0.18
SSFS-1	\emptyset	105	100	264	115	1159	1188	--	--	--	0.16
SSFS-1	\emptyset	100	87	266	115	1152	1172	--	--	--	0.16

^aFeedwater temperature reduction^b% nominal rated

Table 3-9

TRANSIENT SUMMARY--HIGH PRESSURE COOLANT INJECTION

Plant	Analysis	Initial Power (% NBR)	Initial Flow (% NBR)	$\dot{\phi}$ (% initial)	\dot{Q}/A (% initial)	\bar{P}_{si} (psig)	\bar{P}_v (psig)	ΔCPR			
								7x7	8x8	8x8R	P8x8R
A	R	104	100	120	113	1017	1068	0.10	0.12	0.12	--
A	R	100	94	123	114	1012	1058	0.11	0.14	0.14	--
A	R	85	61	119	118	995	1021	0.10	0.12	0.12	--
B	R	104	100	113	109	1007	1063	--	0.10	0.10	--
B	R	100	94	115	111	1002	1053	--	0.09	0.09	--
B	R	85	61	117	115	987	1018	--	0.13	0.13	--
C	R	104	100	122	113	1018	1068	0.11	0.14	0.14	--
C	R	100	94	123	117	1012	1057	0.12	0.15	0.15	--
C	R	85	61	120	111	993	1018	0.14	0.16	0.16	--
D	R	104	100	115	111	1010	1065	0.10	0.12	0.12	--
D	R	100	91	115	111	1003	1052	0.09	0.09	0.10	--
D	R	85	61	117	120	987	1019	0.12	0.13	0.13	--
E	R	104	100	--	--	--	--	0.12	0.14	--	--
E	R	100	92	--	--	--	--	0.12	0.14	--	--
E	R	85	61	--	--	--	--	0.16	0.18	--	--

Table 3-10

ODYN TRANSIENT RESULTS FOR OFF-RATED
CORE FLOW CONDITIONS

	Power/ Flow	$\hat{\phi}$ (%)	\hat{Q}/A (%)	Peak Pressure (psig)		Δ CPR
				Steamline	Vessel	
<u>H</u>						
LR w/o BP						
	100/100	689.3	123.9	1206	--	0.39
	100/92	630.7	121.8	1206	--	0.34
	100/87	576.0	120.6	1205	--	0.33
FWCF						
	100/100	547.4	123.9	1169	--	0.37
	100/92	487.7	123.3	1169	--	0.33
	100/87	464.7	122.1	1170	--	0.32
MSIV FS						
	100/100	657.9	127.3	--	1243	--
	100/92	651.8	126.5	--	1243	--
<u>F</u>						
TT w/1/2 BP						
	100/111	723.0	117.5	1103	--	0.26
	100/100	628.0	115.5	1103	--	0.22
<u>G (w/RPT)</u>						
LR w/o BP						
	104/105	501.0	113.3	1184	--	0.18
	104/100	507.0	113.6	1186	--	0.17
FWCF						
	104/105	286.0	114.5	1143	--	0.17
	104/100	293.0	114.1	1151	--	0.16
MSIV FS						
	104/105	702.0	121.8	--	1235	--
	104/100	677.0	121.6	--	1234	--

Table 3-10

ODYN TRANSIENT RESULTS FOR OFF-RATED
CORE FLOW CONDITIONS (Continued)

	Power/ Flow	$\hat{\phi}$ (%)	\hat{Q}/A (%)	Peak Pressure (psig)		ΔCPR
				Steamline	Vessel	
<u>L</u> (w/RPT)						
LR w/o BP	104/105	333.0	108.1	1166	--	0.11
	104/100	337.9	108.4	1166	--	0.11
FWCF	104/105	198.0	110.2	1136	--	0.12
	104/100	146.8	107.5	1137	--	0.11
MSIV FS	104/105	576.0	119.6	--	1233	--
	104/100	567.5	120.0	--	1232	--
<u>M</u>						
LR w/o BP	104/100	653.0	120.4	1208	--	0.24
	100/94	596.0	119.8	1197	--	0.23
FWCF	104/100	362.0	117.5	1173	--	0.19
	100/94	332.0	117.5	1170	--	0.18
MSIV FS	104/100	693.0	124.3	--	1275	--
	100/94	616.0	123.8	--	1266	--
<u>K</u>						
LR w/o BP	104/100	501.5	117.3	1179	--	0.21
	100/94	468.5	116.6	1174	--	0.19
FWCF	104/100	314.4	114.1	1135	--	
	100/94	281.9	116.1	1131	--	0.15
MSIV FS	104/100	445.5	123.7	--	1270	--
	100/94	440.1	122.1	--	1261	--




Figure 3-1. Susquehanna Operating Power-Flow Map




Figure 3-2. Axial Power Shape for 100% and 87% Core Flow, Plant H




Figure 3-3. Axial Power Shape for 100% and 111% Rated Core Flow, Plant F




Figure 3-4. Void Reactivity versus Delta Void for LR w/o BP at 100/100 and 100/87, Plant H




Figure 3-5. Void Reactivity versus Delta Void for TT /1/2 BP at 100/111 and 100/100, Plant F

4. APPLICATION

The method of analyses described in this report in support of operation along the modified power/flow line are of a bounding type that can be applied to evaluate all BWR/3 and BWR4 plants whose operation is guided by a power/flow curve.

The rod block intercept point of 100% power/87% flow lies along the APRM flow-biased rod block line having a slope represented by the equation:

$$0.58W + 50\%$$

where

W = recirculation flow rate in percent of rated

The relationship between core flow and recirculation flow is shown in Figure 4-1.

Currently, most BWRs operate on the basis of a power/flow curve approximated by the equation:

$$0.65W + 35\%*$$

with the APRM flow-biased rod block represented by the equation,

$$0.66W + 42%*$$

The less restrictive equation (0.58W + 50%) was approved by the United States Nuclear Regulatory Commission (Reference 4) and the analyses for this report were performed with this line as the upper bound of the proposed operating envelope.

Operation utilizing the current SSES-1 technical specification rod block line (0.66W + 42%) can be effected in the same manner as using the proposed

*Several plants vary a few percent from these values.

APRM rod block line, except the intersection with the 100% power line would occur at slightly higher power and flow (Figure 1-1). This is within the analyzed envelope and, therefore, conforms with the bases and conclusions of this report.




Figure 4-1. Core Flow-Recirculation Flow Relationship for Jet-Pump Plants

5. REFERENCES

1. "Final Safety Analysis Report, Susquehanna Steam Electric Station."
2. R. L. Gridley, (GE) letter to D. G. Eisenhut (NRC), "Review of Low-Core Flow Effects on LOCA Analysis for Operating BWRs," May 8, 1978.
3. D. G. Eisenhut (NRC), letter to R. L. Gridley, enclosing "Safety Evaluation Report Revision of Previously Imposed MAPLHGR (ECCS-LOCA) Restrictions for BWRs at Less Than Rated Flow," May 19, 1978.
4. Safety Evaluation by the Office of Nuclear Reactor Regulation Supporting Amendment No. 59 to Provisional Operating License No. DPR-19, Amendment No. 52 to Facility Operating License No. DPR-25, Amendment No. 70 to Facility Operating License No. DPR-29, and Amendment No. 64 to Facility Operating License No. DPR-30, Commonwealth Edison Company and Iowa-Illinois Gas and Electric Company, Dresden Station Unit Nos. 2 and 3, Quad Cities Station Unit Nos. 1 and 2, Docket Nos. 50-237, 50-249, 50-254, and 50-265.