NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | MSGGS1 (2) | 00-00000-00 (3) | 4 | 1111 (4) | (5)
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
01 | REPORT SOURCE L (6) | 05000416 (7) | 011283 (8) | 021183 (9)
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | On January 12 and 20, 1983, one smoke detector in Zone 1-15 (Control Building
03 | elevation 148 feet) and eight detectors in Zone 2-18 (Auxiliary Building elevation
04 | 119 feet) were covered during planned maintenance functions to prevent false alarms
05 | or damage to the units. Hourly fire watches were established in accordance with
06 | T.S.3.3.7.9. This had no effect on the health and safety of the public and did not
07 | constitute a threat to plant safety. This is reported pursuant to T.S.6.9.1.13.b.
08 |
7 8 9 80

09 | SYSTEM CODE AB (11) | CAUSE CODE X (12) | CAUSE SUBCODE Z (13) | COMPONENT CODE INSTRU (14) | COMP. SUBCODE E (15) | VALVE SUBCODE Z (16)
7 8 9 10 11 12 13 18 19 20

(17) LER/RO REPORT NUMBER | EVENT YEAR 83 | — | SEQUENTIAL REPORT NO. 019 | / | OCCURRENCE CODE 03 | REPORT TYPE L | — | REVISION NO. 0
21 22 23 24 26 27 28 29 30 31 32

ACTION TAKEN X (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0000 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER A (25) | COMPONENT MANUFACTURER H260 (26)
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | Smoke detectors were covered during planned maintenance. They were uncovered
11 | and returned to service at the finish of each job. All corrective action is
12 | considered complete. This is submitted as a final report.
13 |
14 |
7 8 9 80

15 | FACILITY STATUS B (28) | % POWER 000 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Planned Action
7 8 9 10 12 13 44 45 46 80

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA
7 8 9 10 11 44 45 80

17 | PERSONNEL EXPOSURES NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA
7 8 9 11 12 13 80

18 | PERSONNEL INJURIES NUMBER 000 (40) | DESCRIPTION (41) NA
7 8 9 11 12 80

19 | LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION (43) NA
7 8 9 10 80

20 | PUBLICITY ISSUED N (44) | DESCRIPTION (45) | NRC USE ONLY
7 8 9 10 68 69 80

8302170127 830211
PDR ADOCK 05000416
S PDR

NAME OF PREPARER Original signed by M. Scott Freeman PHONE

GPO 917-926