



CONNECTICUT YANKEE ATOMIC POWER COMPANY

HADDAM NECK PLANT

RR#1 • BOX 127E • EAST HAMPTON, CT 06424-9341

November 7, 1990
EN-90-0861

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Subject: Haddam Neck Plant, 1990 Steam Generator Plugging Report

In accordance with the reporting requirements of Haddam Neck Technical Specifications, Paragraph 4.4.5.5, the results of Steam Generator tube plugging conducted during the 1990 outage from October 29 to November 3, are provided below:

Steam Generator	Number of Tubes Plugged During the 1990 Outage	Total Tubes Plugged to Date
1	0	210
2	1	371
3	0	89
4	0	389

Very truly yours,

John P. Stetz
Station Director

cc:

Mr. Thomas T. Martin
Regional Administrator, Region I
475 Allendale Road
King of Prussia, PA. 19406

J.T. Shedlosky
Sr. Resident Inspector
Haddam Neck

Abol 1/10

9011190300 901107
PDR ADOCK 05000213
R PDC