



PEACH BOTTOM—THE POWER OF EXCELLENCE

D. B. Miller, Jr.
Vice President

PHILADELPHIA ELECTRIC COMPANY

PEACH BOTTOM ATOMIC POWER STATION
R. D. 1, Box 208
Delta, Pennsylvania 17314
(717) 456-7014

February 27, 1991

Docket Nos. 50-277
50-278

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

SUBJECT: Semi-Annual Effluent Release Report No. 30
July 1, 1990 through December 31, 1990
Peach Bottom Atomic Power Station Unit Nos. 2 and 3

Gentlemen:

Enclosed are two copies of the Semi-Annual Effluent Release Report No. 29, July 1, 1990 through December 31, 1990 for Peach Bottom Atomic Power Station Unit Nos. 2 and 3.

This report is being submitted in compliance with 10 CFR 50.36(a)(2) and the Technical Specifications of Operating Licenses DPR-44 and DPR-56, and to fulfill the requirements of Regulatory Guide 10.1.

During the report period, no revisions were made to the Offsite Dose Calculation Manual (ODCM).

Sincerely,

AAF ~~CAF~~ MJB
DBM/AAF/DPL/MJB:cmc

Enclosures

cc: R.A. Burricelli, Public Service Electric & Gas
T.M. Gerusky, Commonwealth of Pennsylvania
J.J. Lyash, USNRC Senior Resident Inspector
R. McLean, State of Maryland
T.T. Martin, Administrator, Region I, USNRC
H.C. Schwemm, Atlantic Electric
J. Urban, Delmarva Power
INPO Records Center

ICC154.doc

9103050391 901231
PDR ADDCK 05000277
R PDR

IF48
11

PEACH BOTTOM ATOMIC POWER STATION
Unit Numbers 2 and 3
Docket Numbers 50-277 and 50-278

SEMI-ANNUAL EFFLUENT RELEASE REPORT

NO. 30

JULY 1, 1990 THROUGH DECEMBER 31, 1990

Submitted to
The United States Nuclear Regulatory Commission
Pursuant to
Facility Operating Licenses DPR-44 and DPR-56

Table of Contents

| | Page No. |
|--|----------|
| I. Introduction | 1 |
| II. Tables | |
| 1A. Gaseous Effluents - Summation of All Releases | 2 |
| 1B. Gaseous Effluents for Release Point - Main Stack | 3 |
| 1C. Gaseous Effluents for Release Point - U2 & U3 Roof Vents | 5 |
| 2A. Liquid Effluents - Summation of All Releases | 7 |
| 2B. Liquid Effluents | 8 |
| III. Classes of Solid Radioactive Waste Shipments | 10 |
| IV. Attachments | |
| A. Supplemental Information | 11 |

Technical Concurrences: (for accuracy of information)

Martin B. Ryan

Sr. Engineer - Radwaste

A. D. Odell

Sr. Chemist

SEMI-ANNUAL EFFLUENT RELEASE REPORT
JULY 1, 1990 THROUGH DECEMBER 31, 1990

I. INTRODUCTION

In accordance with the Unique Reporting Requirements of Technical Specification 6.9.2h (2) applicable during the reporting period, this report summarizes the Effluent Release Data for Peach Bottom Atomic Power Station Units 2 and 3 for the period July 1, 1990 through December 31, 1990. The notations E and E- are used to denote positive and negative exponents to the base 10.

The release of radioactive materials during the reporting period was within the Technical Specification limits. There were no changes made to the Off-Site Dose Calculation Manual (ODCM) during the reporting period.

There were no known unplanned releases of liquid radioactive material.

EFFLUENT & WASTE DISPOSAL SEMI-ANNUAL REPORT (7/1/90 - 12/31/90)

Table 1A Page 1 of 1
Gaseous Effluents - Summation of All Releases

| | Units | Quarter 3 | Quarter 4 | Est. Error Total % |
|--|--------------|--------------|--------------|-----------------------|
| A. Fission & activation gasses | | | | |
| 1. Total release | Ci | 5.27E3 | 2.05E3 | 54.0 E0 |
| 2. Average release rate for period | μ Ci/sec | 6.70E2 | 2.61E2 | |
| 3. Gamma Air Dose | Millirad | 3.06E-2 | 6.97E-2 | |
| Percent of Technical Specification | % | 3.06E-1 | 6.97E-1 | |
| 4. Beta Air Dose | Millirad | 4.40E-2 | 8.18E-2 | |
| Percent of Technical Specification | % | 2.20E-1 | 4.09E-1 | |
| B. Iodines | | | | |
| 1. Total iodine - 131 | Ci | 6.37E-3 | 4.00E-3 | 61.0 E0 |
| 2. Average release rate for period | μ Ci/sec | 8.10E-4 | 5.09E-4 | |
| 3. Critical Organ dose | Millirem | 2.45E-2 | 4.58E-2 | |
| Percent of Technical Specification | % | 1.63E-1 | 3.05E-1 | |
| C. Particulates | | | | |
| 1. Particulates with half-lives greater than 8 days (includes Alpha and Strontium 89-90) | Ci | 1.86E-3 | 1.08E-3 | 61.0 E0 |
| 2. Average release rate for period | μ Ci/sec | 2.37E-4 | 1.37E-4 | |
| 3. Gross Alpha Radioactivity | Ci | 5.88E-5 | 2.31E-5 | |
| D. Tritium | | | | |
| 1. Total release | Ci | 1.11E1 | 8.29E0 | 94.0 E0 |
| 2. Average release rate for period | μ Ci/sec | 1.41E0 | 1.06E0 | |

EFFLUENT & WASTE DISPOSAL SEMI-ANNUAL REPORT (7/1/90 - 12/31/90)

Table 1B Page 1 of 2

Gaseous Effluents For Release Point - Main Stack

| Nuclides Released | Units | Continuous Mode | | Batch Mode | |
|-------------------|-------|-----------------|-----------|------------|-----------|
| | | Quarter 3 | Quarter 4 | Quarter 3 | Quarter 4 |
| 1. Fission gasses | | | | | |
| Krypton - 85M | Ci | 2.46E2 | 4.44E1 | 0.00 E0 | 0.00 E0 |
| Krypton - 87 | Ci | 1.36E2 | 8.16E1 | 0.00 E0 | 0.00 E0 |
| Krypton - 88 | Ci | 1.64E2 | 9.09E1 | 0.00 E0 | 0.00 E0 |
| Xenon - 133 | Ci | 4.18E3 | 1.11E3 | 0.00 E0 | 0.00 E0 |
| Xenon - 135 | Ci | 1.04E2 | 3.03E2 | 0.00 E0 | 0.00 E0 |
| Xenon - 135M | Ci | 5.13E1 | 7.92E1 | 0.00 E0 | 0.00 E0 |
| Xenon - 138 | Ci | 7.55E0 | 3.88E1 | 0.00 E0 | 0.00 E0 |
| Xenon - 133M | Ci | 5.08E1 | 0.00E0 | 0.00 E0 | 0.00 E0 |
| Xenon - 131M | Ci | 4.92E1 | 3.30E1 | 0.00 E0 | 0.00 E0 |
| Unidentified | Ci | 0.00E0 | 0.00E0 | 0.00 E0 | 0.00 E0 |
| Total for Period | Ci | 4.99E3 | 1.78E3 | 0.00 E0 | 0.00 E0 |
| 2. Iodines | | | | | |
| Iodine - 131 | Ci | 4.12E-3 | 8.43E-4 | 0.00 E0 | 0.00 E0 |
| Iodine - 133 | Ci | 1.88E-3 | 5.88E-4 | 0.00 E0 | 0.00 E0 |
| Iodine - 135 | Ci | 3.14E-3 | 0.00E0 | 0.00 E0 | 0.00 E0 |
| Total for Period | Ci | 9.14E-3 | 1.43E-3 | 0.00 E0 | 0.00 E0 |
| 3. Particulates | | | | | |
| Strontium - 89 | Ci | 8.04E-4 | 4.45E-4 | 0.00 E0 | 0.00 E0 |
| Strontium - 90 | Ci | 2.11E-6 | 1.00E-6 | 0.00 E0 | 0.00 E0 |
| Strontium - 91 | Ci | 8.00E-4 | 4.48E-4 | 0.00 E0 | 0.00 E0 |
| Cesium - 134 | Ci | 0.00E0 | 0.00E0 | 0.00 E0 | 0.00 E0 |
| Cesium - 137 | Ci | 6.20E-5 | 1.35E-5 | 0.00 E0 | 0.00 E0 |
| Cesium - 138 | Ci | 3.25E-2 | 3.53E-2 | 0.00 E0 | 0.00 E0 |
| Barium - 139 | Ci | 8.53E-3 | 4.92E-3 | 0.00 E0 | 0.00 E0 |
| Barium - 140 | Ci | 8.66E-4 | 1.07E-3 | 0.00 E0 | 0.00 E0 |
| Lanthanum - 140 | Ci | 5.12E-4 | 2.91E-4 | 0.00 E0 | 0.00 E0 |
| Cobalt - 57 | Ci | 0.00E0 | 0.00E0 | 0.00 E0 | 0.00 E0 |
| Cobalt - 58 | Ci | 0.00E0 | 7.00E-7 | 0.00 E0 | 0.00 E0 |

EFFLUENT & WASTE DISPOSAL SEMI-ANNUAL REPORT (7/1/90 - 12/31/90)

Table 1B Page 2 of 2

Gaseous Effluents For Release Point - Main Stack

| Nuclides Released | Units | Continuous Mode | | Batch Mode | |
|-------------------|-------|-----------------|-----------|------------|-----------|
| | | Quarter 3 | Quarter 4 | Quarter 3 | Quarter 4 |
| Cobalt - 60 | Ci | 0.00 E0 | 0.00E0 | 0.00 E0 | 0.00 E0 |
| Zinc - 65 | Ci | 0.00 E0 | 0.00E0 | 0.00 E0 | 0.00 E0 |
| Yttrium - 91M | Ci | 3.63E-3 | 2.76E-3 | 0.00 E0 | 0.00 E0 |
| Iodine - 133 | Ci | 0.00E0 | 0.00E0 | 0.00 E0 | 0.00 E0 |
| Copper - 64 | Ci | 0.00E0 | 0.00E0 | 0.00 E0 | 0.00 E0 |
| Rubidium - 88 | Ci | 4.02E-3 | 0.00 E0 | 0.00 E0 | 0.00 E0 |
| Rubidium - 89 | Ci | 3.87E-4 | 0.00 E0 | 0.00 E0 | 0.00 E0 |
| Total for Period | Ci | 5.21E-2 | 4.52E-2 | 0.00 E0 | 0.00 E0 |

EFFLUENT & WASTE DISPOSAL SEMI-ANNUAL REPORT (7/1/90 - 12/31/90)

Table 1C Page 1 of 2

Gaseous Effluents For Release Point - Unit 2 & Unit 3 Roof Vents

| Nuclides Released | Units | Continuous Mode | | Batch Mode | |
|-------------------|-------|-----------------|-----------|------------|-----------|
| | | Quarter 1 | Quarter 2 | Quarter 1 | Quarter 2 |
| 1. Fission gasses | | | | | |
| Krypton - 85M | Ci | 0.00 E0 | 4.50E0 | 0.00 E0 | 0.00 E0 |
| Krypton - 87 | Ci | 0.00 E0 | 0.00E0 | 0.00 E0 | 0.00 E0 |
| Krypton - 88 | Ci | 0.00 E0 | 0.00E0 | 0.00 E0 | 0.00 E0 |
| Xenon - 133 | Ci | 9.97E1 | 4.36E1 | 0.00 E0 | 0.00 E0 |
| Xenon - 135 | Ci | 8.24E1 | 9.43E1 | 0.00 E0 | 0.00 E0 |
| Xenon - 135M | Ci | 1.96E1 | 0.00E0 | 0.00 E0 | 0.00 E0 |
| Xenon - 138 | Ci | 0.00E0 | 0.00E0 | 0.00 E0 | 0.00 E0 |
| Unidentified | Ci | 8.12E1 | 1.23E2 | 0.00 E0 | 0.00 E0 |
| Total for Period | Ci | 2.83E2 | 2.65E2 | 0.00 E0 | 0.00 E0 |
| 2. Iodines | | | | | |
| Iodine - 131 | Ci | 2.25E-3 | 3.16E-3 | 0.00 E0 | 0.00 E0 |
| Iodine - 133 | Ci | 7.94E-3 | 1.40E-3 | 0.00 E0 | 0.00 E0 |
| Iodine - 135 | Ci | 0.00E0 | 0.00 E0 | 0.00 E0 | 0.00 E0 |
| Total for Period | Ci | 1.02E-2 | 4.56E-3 | 0.00 E0 | 0.00 E0 |
| 3. Particulates | | | | | |
| Strontium - 89 | Ci | 1.03E-4 | 1.28E-4 | 0.00 E0 | 0.00 E0 |
| Strontium - 90 | Ci | 1.98E-5 | 2.20E-5 | 0.00 E0 | 0.00 E0 |
| Strontium - 91 | Ci | 0.00E0 | 0.00 E0 | 0.00 E0 | 0.00 E0 |
| Cesium - 134 | Ci | 0.00 E0 | 0.00 E0 | 0.00 E0 | 0.00 E0 |
| Cesium - 137 | Ci | 0.00 E0 | 0.00 E0 | 0.00 E0 | 0.00 E0 |
| Cesium - 138 | Ci | 1.89E-2 | 1.27E-2 | 0.00 E0 | 0.00 E0 |
| Barium - 139 | Ci | 1.77E-3 | 1.26E-3 | 0.00 E0 | 0.00 E0 |
| Barium - 140 | Ci | 0.00 E0 | 0.00E0 | 0.00 E0 | 0.00 E0 |
| Lanthanum - 140 | Ci | 0.00 E0 | 0.00E0 | 0.00 E0 | 0.00 E0 |
| Cobalt - 57 | Ci | 0.00 E0 | 0.00E0 | 0.00 E0 | 0.00 E0 |
| Cobalt - 58 | Ci | 0.00 E0 | 0.00E0 | 0.00 E0 | 0.00 E0 |
| Cobalt - 60 | Ci | 0.00 E0 | 0.00E0 | 0.00 E0 | 0.00 E0 |

EFFLUENT & WASTE DISPOSAL SEMI-ANNUAL REPORT (7/1/90 - 12/31/90)

Table 1C Page 2 of 2

Gaseous Effluents For Release Point - Unit 2 & Unit 3 Roof Vents

| Nuclides Released | Units | Continuous Mode | | Batch Mode | |
|-------------------|-------|-----------------|-----------|------------|-----------|
| | | Quarter 1 | Quarter 2 | Quarter 1 | Quarter 2 |
| Zinc - 65 | Ci | 0.00 E0 | 0.00 E0 | 0.00 E0 | 0.00 E0 |
| Yttrium - 91M | Ci | 4.87E-4 | 1.46E-4 | 0.00 E0 | 0.00 E0 |
| Iodine - 133 | Ci | 7.99E-5 | 8.76E-5 | 0.00 E0 | 0.00 E0 |
| Copper - 64 | Ci | 0.00E0 | 0.00E0 | 0.00 E0 | 0.00 E0 |
| Rubidium - 88 | Ci | 4.77E-3 | 2.64E-3 | 0.00 E0 | 0.00 E0 |
| Rubidium - 89 | Ci | 7.85E-4 | 0.00E0 | 0.00 E0 | 0.00 E0 |
| Technetium - 99M | Ci | 3.53E-5 | 2.89E-5 | 0.00 E0 | 0.00 E0 |
| Molybdenum - 99 | Ci | 2.25E-5 | 2.40E-5 | 0.00 E0 | 0.00 E0 |
| Tellurium - 132 | Ci | 6.70E-6 | 0.00E0 | 0.00 E0 | 0.00 E0 |
| Total for Period | Ci | 2.70e-2 | 1.70E-2 | 0.00 E0 | 0.00 E0 |

EFFLUENT & WASTE DISPOSAL SEMI-ANNUAL REPORT (7/1/90 - 12/31/90)

Table 2A Page 1 of 1
Liquid Effluents - Summation of All Releases

| | Units | Quarter 3 | Quarter 4 | Est. Error Total % |
|---|----------|--------------|--------------|-----------------------|
| A. Fission & activation gasses | | | | |
| 1. Total release (not including tritium, gasses, alpha) | Ci | 2.27E-3 | 7.81E-4 | 32.0 E0 |
| 2. Average diluted concentration during period | μCi/ml | 4.07E-11 | 1.18E-10 | |
| 3. Body Dose | Millirem | 4.82E-4 | 1.91E-4 | |
| Percent of Technical Specification | % | 1.61E-2 | 6.37E-3 | |
| 4. Maximally Exposed Organ Dose | Millirem | 8.66E-4 | 4.76E-4 | |
| Percent of Technical Specification | % | 8.66E-3 | 4.76E-3 | |
| B. Tritium | | | | |
| 1. Total release | Ci | 8.37E0 | 1.75E0 | 39.0 E0 |
| 2. Average diluted concentration during period | μCi/ml | 1.50E-7 | 2.62E-7 | |
| C. Dissolved and entrained gasses | | | | |
| 1. Total release | Ci | 2.98E-2 | 2.26E-3 | 42.0 E0 |
| 2. Average diluted concentration during period | μCi/ml | 5.34E-10 | 3.38E-10 | |
| D. Gross alpha radioactivity | | | | |
| 1. Total release | Ci | 9.61E-5 | 8.76E-6 | 39.0 E0 |
| 2. Average diluted concentration during period | μCi/ml | 1.72E-12 | 1.31E-12 | |
| E. Volume of waste released (prior to dilution) | liters | 3.38E6 | 5.03E5 | 32.0 E0 |
| F. Volume of dilution water used during period | liters | 5.58E10 | 6.68E9 | 30.0 E0 |

EFFLUENT & WASTE DISPOSAL SEMI-ANNUAL REPORT (7/1/90 - 12/31/90)

Table 2B Page 1 of 2
Liquid Effluents

| Nuclides Released | Units | Continuous Mode | | Batch Mode | |
|-------------------|-------|-----------------|-----------|------------|-----------|
| | | Quarter 3 | Quarter 4 | Quarter 3 | Quarter 4 |
| Strontium - 89 | Ci | 0.00 E0 | 0.00 E0 | 6.40E-5 | 2.10E-5 |
| Strontium - 90 | Ci | 0.00 E0 | 0.00 E0 | 2.87E-5 | 7.40E-6 |
| Alpha | Ci | 0.00 E0 | 0.00 E0 | 9.61E-5 | 8.76E-5 |
| Tritium | Ci | 0.00 E0 | 0.00 E0 | 8.37E0 | 1.75E0 |
| Phosphorus - 32 | Ci | 0.00 E0 | 0.00 E0 | 2.31E-4 | 1.30E-4 |
| Iron - 55 | Ci | 0.00 E0 | 0.00 E0 | 6.27E-4 | 6.28E-5 |
| Xenon - 131M | Ci | 0.00 E0 | 0.00 E0 | 0.00E0 | 0.00E0 |
| Xenon - 133 | Ci | 0.00 E0 | 0.00 E0 | 1.82E-2 | 1.18E-3 |
| Xenon - 133M | Ci | 0.00 E0 | 0.00 E0 | 6.84E-4 | 0.00E0 |
| Xenon - 135 | Ci | 0.00 E0 | 0.00 E0 | 1.09E-2 | 1.07E-3 |
| Krypton - 85M | Ci | 0.00 E0 | 0.00 E0 | 0.00E0 | 0.00E0 |
| Krypton - 87 | Ci | 0.00 E0 | 0.00 E0 | 0.00E0 | 0.00E0 |
| Krypton - 88 | Ci | 0.00 E0 | 0.00 E0 | 0.00E0 | 0.00E0 |
| Xenon - 135M | Ci | 0.00 E0 | 0.00 E0 | 2.76E-5 | 0.00E0 |
| Manganese - 54 | Ci | 0.00 E0 | 0.00 E0 | 0.00E0 | 2.77E-5 |
| Cesium - 134 | Ci | 0.00 E0 | 0.00 E0 | 1.09E-5 | 1.53E-6 |
| Cesium - 137 | Ci | 0.00 E0 | 0.00 E0 | 2.02E-4 | 4.26E-5 |
| Cesium - 138 | Ci | 0.00 E0 | 0.00 E0 | 0.00E0 | 0.00E0 |
| Zinc - 65 | Ci | 0.00 E0 | 0.00 E0 | 0.00E0 | 7.21E-5 |
| Sodium - 24 | Ci | 0.00 E0 | 0.00 E0 | 0.00E0 | 0.00E0 |
| Cobalt - 58 | Ci | 0.00 E0 | 0.00 E0 | 9.61E-6 | 2.14E-5 |
| Cobalt - 60 | Ci | 0.00 E0 | 0.00 E0 | 8.02E-5 | 7.83E-5 |
| Iodine - 131 | Ci | 0.00 E0 | 0.00 E0 | 0.00E0 | 1.77E-4 |
| Iodine - 133 | Ci | 0.00 E0 | 0.00 E0 | 0.00E0 | 0.00E0 |
| Molybdenum - 99 | Ci | 0.00 E0 | 0.00 E0 | 0.00E0 | 0.00E0 |
| Iodine - 135 | Ci | 0.00 E0 | 0.00 E0 | 0.00E0 | 0.00E0 |
| Barium - 140 | Ci | 0.00 E0 | 0.00 E0 | 0.00E0 | 0.00E0 |
| Neptunium - 239 | Ci | 0.00 E0 | 0.00 E0 | 0.00E0 | 0.00E0 |
| Chromium - 51 | Ci | 0.00 E0 | 0.00 E0 | 8.27E-4 | 9.51E-5 |

EFFLUENT & WASTE DISPOSAL SEMI-ANNUAL REPORT (7/1/90 - 12/31/90)

Table 2B Page 2 of 2
Liquid Effluents

| Nuclides Released | Units | Continuous Mode | | Batch Mode | |
|--------------------------|-------|-----------------|-----------|------------|-----------|
| | | Quarter 3 | Quarter 4 | Quarter 3 | Quarter 4 |
| Yttrium - 91M | Ci | 0.00 E0 | 0.00 E0 | 0.00E0 | 0.00 E0 |
| Strontium - 91 | Ci | 0.00 E0 | 0.00 E0 | 0.00E0 | 0.00 E0 |
| Antimony - 122 | Ci | 0.00 E0 | 0.00 E0 | 0.00E0 | 0.00 E0 |
| Tellurium - 132 | Ci | 0.00 E0 | 0.00 E0 | 0.00E0 | 0.00 E0 |
| Niobium - 95 | Ci | 0.00 E0 | 0.00 E0 | 1.78E-5 | 1.97E-5 |
| Lanthanum - 140 | Ci | 0.00 E0 | 0.00 E0 | 4.18E-5 | 0.00E0 |
| Cadmium - 109 | Ci | 0.00 E0 | 0.00 E0 | 0.00E0 | 0.00E0 |
| Cesium - 136 | Ci | 0.00 E0 | 0.00 E0 | 0.00E0 | 0.00E0 |
| Antimony - 124 | Ci | 0.00 E0 | 0.00 E0 | 0.00E0 | 0.00E0 |
| Iron - 59 | Ci | 0.00 E0 | 0.00 E0 | 0.00E0 | 0.00E0 |
| Tellurium - 129M | Ci | 0.00 E0 | 0.00 E0 | 0.00E0 | 0.00E0 |
| Tellurium - 131M | Ci | 0.00 E0 | 0.00 E0 | 0.00E0 | 0.00E0 |
| Zirconium - 95 | Ci | 0.00 E0 | 0.00 E0 | 0.00E0 | 0.00E0 |
| Cerium - 141 | Ci | 0.00 E0 | 0.00 E0 | 0.00E0 | 0.00E0 |
| Silver - 110M | Ci | 0.00 E0 | 0.00 E0 | 1.31E-4 | 2.98E-5 |
| Total for Period (above) | Ci | 0.00 E0 | 0.00 E0 | 8.40218E0 | 1.75304E0 |

ATTACHMENT A
SUPPLEMENTAL INFORMATION

Facility: Peach Bottom Units 2 & 3

Licenses: DPR-44
DPR-56

1. **Regulatory Limits (Technical Specification Limits)**

A. Noble Gases:

- | | |
|--|--|
| 1. ≤ 500 mRem/Yr - total body ≤ 3000 mRem/Yr - skin | - "instantaneous" limits Tech. Spec. 3.8.C.1.a |
| 2. ≤ 10 mRad - air gamma ≤ 20 mRad - air beta | - quarterly air dose limits Tech. Spec. 3.8.C.2.a |
| 3. ≤ 20 mRad - air gamma ≤ 40 mRad - air beta | - yearly air dose limits Tech. Spec. 3.8.C.2.b |

B. Iodines, Tritium, Particulates with Half Life > 8 days:

- | | |
|---|---|
| 1. ≤ 1500 mRem/Yr - any organ (inhalation path) | - "instantaneous" limits Tech. Spec. 3.8.C.1.b |
| 2. ≤ 15 mRem - any organ | - quarterly dose limits Tech. Spec. 3.8.C.3.a |
| 3. ≤ 30 mRem - any organ | - yearly dose limits Tech. Spec. 3.8.C.3.b |

C. Liquid Effluents:

- | | |
|--|--|
| 1. Concentration ≤ 10 CFR 20, Appendix B, Table II, Col. 2 | - "instantaneous" limits Tech. Spec. 3.8.B.1 |
| 2. ≤ 3.0 mRem - total body ≤ 10 mRem - any organ | - quarterly dose limits Tech. Spec. 3.8.B.2.a |
| 3. ≤ 6.0 mRem - total body ≤ 20 mRem - any organ | - yearly dose limits Tech. Spec. 3.8.B.2.b |

ATTACHMENT A
SUPPLEMENTAL INFORMATION

2. Maximum Permissible Concentrations:

MPCs are not used to calculate permissible release rates and concentrations for gaseous releases.

The MPCs specified in 10 CFR 20, Appendix B, Table II, Column 2, for identified nuclides are used to calculate permissible release rates and concentrations for liquid release per Peach Bottom Technical Specification 3.8.B.1.

3. Average Energy:

Not Applicable

4. Measurements and Approximations of Total Radioactivity:

A. Fission and Activation Gases:

The method used is the Nuclear Data 6700 Counting System
- Gas Marinelli -

B. Iodine:

The method used is the Nuclear Data 6700 Counting System
- Charcoal Cartridge -

C. Particulates:

The method used is the Nuclear Data 6700 Counting System
- Air Particulate Sample, (47 mm filter) -

D. Liquid Effluents:

The method used is the Nuclear Data 6700 Counting System and the Radwaste Liquid Discharge Pre-Release Method with a liter marinelli.

ATTACHMENT A
SUPPLEMENTAL INFORMATION

5. **Batch Releases:**

| A. <u>Liquid:</u> | <u>QTR 3</u> | <u>QTR 4</u> |
|--|--------------|--------------|
| Number of batch releases: | 50 | 12 |
| Total time for batch releases (minutes): | 12103 | 1886 |
| Maximum time period for batch release (minutes): | 380 | 355 |
| Average time period for batch release (minutes): | 242 | 157 |
| Minimum time period for batch release (minutes): | 15 | 30 |
| Dilution flow (liters): | 5.58E10 | 6.68e9 |

B. Gaseous:

Not Applicable

6. **Abnormal Releases:**

A. Liquid:

None

B. Gaseous:

None

EFFLUENT & WASTE DISPOSAL SEMI-ANNUAL REPORT (7/1/90 - 12/31/90)

PEACH BOTTOM UNITS 2 & 3
 JULY 1, 1990 TO DECEMBER 31, 1990
 CLASSES OF SOLID RADIOACTIVE WASTE SHIPMENTS

| Total # of Shipments | Waste Description (source of waste) | Container/Type | Individual Volume (cubic ft.) | Total Volume (cubic ft.) | Total Curie | Principal Radionuclides |
|----------------------|-------------------------------------|-------------------------|-------------------------------|--------------------------|-------------|--------------------------------------|
| Class A | | | | | | |
| 56 | Dewatered Resin | HIC/Type A Cask | 202.1 | 11317.6 | 1.70E+05 | Cs-137, I-131, Co-60, Zn-65, La-140 |
| 1 | DAW | Metal Drum/Type A Cask | 7.5 | 600.0 | 3.09E-01 | Co-60, Cs-137, Ru-106, Co-57, Sb-125 |
| 52 | DAW | Metal Drum/STC | variable | (*) 2229.7 | 8.59E+00 | Co-60, Fe-55, Zn-65, Cs-137, Cs-134 |
| 10 | DAW | Metal Drum/STC | variable | (**) 211.6 | 9.83E-02 | Co-60, Cs-137, Fe-55, Zn-65, Cs-134 |
| 1 | Filters | HIC/Type A Cask | 170.8 | 170.8 | 2.83E+00 | Co-60, Zn-65, Fe-55, Cs-134, Cs-137 |
| Class B | | | | | | |
| 2 | Dewatered Resin | HIC/Type A Cask | 202.1 | 404.2 | 2.24E+01 | Cs-137, Co-60, Cs-134, Zn-65, Ni-63 |
| 2 | Dewatered Resin | HIC/Type B Cask | 132.4 | 264.8 | 7.46E+02 | Cr-51, Co-60, Zn-65, Co-58, Fe-55 |
| Class C | | | | | | |
| 1 | Irradiated Metal | Steel Liner/Type B Cask | 57.4 | 57.4 | 2.39E+03 | Co-60, Fe-55, Ni-63, C-14, TC-99 |
| Totals | | | | | | |
| 125 | | | | 15256.1 | 1.73E+05 | |

NOTES:

* - Indicates actual total PECO radwaste shipped from Quadrex, after volume reduction, to the burial site.

** - Indicates actual total PECO radwaste shipped from SEG, after volume reduction, to the burial site.