

CALVERT CLIFFS

UNIT 1

STEAM GENERATORS #11 AND #12

EDDY CURRENT TESTING

FINAL REPORT

MAY/JUNE 1990

Reviewed by:

Paul A Klein

P. A. Klein

Prepared by:

Karin M Hoffman

K. M. Hoffman

TABLE OF CONTENTS

I. INTRODUCTION

II. DISCUSSION

APPENDIX I . . . Eddy Current Test Results for SG 11

- A. List with Plot of All Indications
- B. List with Plot of <20% Indications
- C. List with Plot of 20% - 39% Indications
- D. List with Plot of >39% Indications
- E. List with Plot of Tubes Dented
- F. List with Plot of Tubes Plugged During May/June 1990
- G. List with Plot of all Tubes Plugged

APPENDIX II . . . Eddy Current Test Results for SG 12

- A. List with Plot of All indications
- B. List with Plot of <20% Indications
- C. List with Plot of 20% - 39% Indications
- D. List with Plot of >39% Indications
- E. List with Plot of Tubes Dented
- F. List with Plot of Tubes Plugged During May/June 1990
- G. List with Plot of all Tubes Plugged

APPENDIX III . . . Steam Generator Inspection Information

- A. Steam Generator Support Location and Nomenclature
- B. Steam Generator Tube Sheet Pattern and Number System
- C. Eddy Current Inspection Acronyms

I. INTRODUCTION

Zetec, Inc. and NDE Technology were contracted in January, 1990 to provide equipment and personnel along with BG&E with the eddy current examination of the Calvert Cliffs Unit 1 Steam Generators in Lusby, Maryland. Zetec, Inc. provided twelve people for data acquisition and thirteen people for the primary data evaluation. NDE Technology provided four people for the secondary data evaluation.

This report summarizes the May/June, 1990 eddy current inspection results of Calvert Cliffs Unit 1 Steam Generators.

II. DISCUSSION

The MIZ-18A eddy current system and qualified operators inspected the Calvert Cliffs Unit 1 Steam Generators 11 and 12. The system uses eddy current as the probing media to measure variations in effective conductivity and/or permeability of the tube being tested.

An alternating voltage is impressed across the test coil. The magnetic field developed by current flow in the test coil causes eddy currents to flow in the tube wall. The corresponding magnetic field caused by eddy current flow in the tube wall is out of phase with the field developed by the current in the test coil. Since these fields tend to cancel one another, the coil voltage is decreased in proportion to the magnitude of eddy current flow in the test piece. The magnitude of eddy currents in the test piece, thus the coil voltage, is dependent on the electrical properties of the tube being tested. The electrical properties which affect the flow of eddy currents are permeability and conductivity. In non-magnetic materials, such as Ni-Cr-Fe alloys, conductivity is usually the only significant variable. When the effective conductivity decreases due to a discontinuity in the tube wall, the coil voltage increases in direct relationship with the effective conductivity change. Thus, the amount of increase in coil voltage is related to the size of the discontinuity in the tube wall. The coil voltage is sinusoidal, thus it can be described with a single vector having magnitude and phase.

The BG&E Technical Specification edc, current (ET) testing plan for the refueling outage selected 100% of the tubes for full length inspection each steam generator (SG).

The examination inspected 16,874 (100%) SG tubes through their entire length. 222 tubes had indications of 20% through-wall degradation or greater. Seven (7) tubes which exceeded the plugging limit of 40% thru wall degradation were removed from service.

As a preventative measure, 5 additional tubes with indications in the sludge pile area were plugged. Of these 5 additional tubes taken out of service, four were in SG 11 and one was in SG 12. Previous metallurgical examination of Unit 1 tubing has shown degradation in this area was caused by Intergranular Attack (IGA). Even though these 5 tubes had indications less than the plugging limit, the tubes were plugged due to the potential for a local active IGA degradation mechanism.

SG's 11 and 12 were examined using the Zetec MIZ-18A digital data acquisition system. The frequencies selected were 800, 400, 100, and 30 KHz - all of which were run in the differential and absolute modes. The examination utilized a standard A.560-SF/RM bobbin coil probe. The MIZ-18A digital data acquisition system provided on-line data digitization and storage onto magnetic tape cartridges. The digital signal was also converted to analog where selected frequencies were recorded on strip chart media as an aid to the analyst.

Prior to any ET analysis, the primary, secondary, and Computer Data Screening (CDS) analysts were required to take a BG&E analyst qualification examination. All analysts passed the BG&E site specific test. In addition, CDS, with qualified analysts, was tested and passed the examination.

Each tube's ET data was analyzed by two independent teams of qualified and certified personnel and by computer analysis. Zetec Analysis Software Edition 18.6, Rev. 5 with strip charts was used by each team of analysts. Additionally, all stored digital data was analytically processed by Zetec's CDS program using HP350/360 computers. All distorted and pluggable indications were retested. After all data review was completed, the primary and secondary lead analysts compared results with the CDS results and a final report was produced. Any final resolution was performed by BG&E Level III personnel. Figure II-1 illustrates the outage data analysis process.

In addition to the standard Bobbin ET testing, a large number of tubes were inspected using motorized rotating pancake coil (MRPC) probes. A sample of approximately 20% of the tubes in each SG were examined with the MRPC technique on the hot leg side of the generators in the roll transition region at the top of the tubesheet. This sample was concentrated in the sludge pile region and included 50% of the tubes considered to be in the sludge pile. This expanded MRPC sample was performed to address concerns over circumferential cracking in this region found at other plants. Selected SG U-bend tubing was also inspected utilizing U-bend MRPC probes on both SG's. No evidence of circumferential cracking was detected in either steam generator.

Indications were found in a total of 234 tubes from the 8,421 tubes examined in SG 11 and 204 tubes from the 8,453 tubes examined in SG 12. Seven tubes were found to have indications which exceeded the Technical Specification plugging limit of 40% loss of nominal wall thickness. An additional 5 tubes were plugged as a preventative measure. Of the total 12 tubes plugged during this Inservice Inspection, 9 tubes were plugged in SG 11 and 3 tubes were plugged in SG 12. Table II-1 is a summary of the Calvert Cliffs Unit One 1990 Eddy Current examination results.

Various plots illustrating the locations and distribution of tube indications and a listing of tubes plugged this inspection for SG's 11 and 12 are provided in Appendix I and II respectively. The SG sketch in Appendix III shows the various tube support locations within the SG's and the nomenclature used throughout this report.

All indications found were on tube outside surfaces. The tubing ET indications can be placed into one of three major location categories:


- just below and above the top of the tubesheet
- at supports, or
- in free span areas between and not associated with supports

These inspection results are similar to that reported for Calvert Cliffs Unit 2. There are no apparent differences between Unit 1 and Unit 2 that indicate a unique problem in any particular SG. This is to be expected since operating and chemistry conditions have remained similar between the two plants.

Indications found just below and above the top of the tubesheet are in regions of higher sludge levels. Most of these indications are on the inlet tubesheet side and produce relatively low magnitude signals. In late 1986, tube specimens underwent metallurgical and chemical evaluations. Results show that these indications are caused by IGA.

FIGURE II - 1

Data Analysis Process



— — — = INFORMATION FLOW

— — — — = DATA TAPE FLOW

TABLE II - 1

Unit Two Eddy Current Inspection Results

	SG 11	SG 12
Number of Tubes Inspected	8,421	8,453
Percent of Tubes Inspected (full length)	100%	100%
Number of Distorted Indications	15	12
Number of Tubes with Distorted Indications	15	12
Percent of Tubes with Distorted Indications	0.18%	0.14%
Number of Indications <20% (Imperfections)	137	100
Number of Tubes with <20% Indications	134	98
Percent of Tubes with <20% Indications	1.59%	1.16%
Number of Indications 20-39% (Degraded)	118	118
Number of Tubes with 20-39% Indications	106	110
Percent of Tubes with 20-39% Indications	1.26%	1.30%
Number of Indications >39% (Defective)	6	2
Number of Tubes with >39% Indications	5	2
Percent of Tubes with >39% Indications	0.06%	0.02%
Number of Tubes Plugged this Outage	9	3
Total Tubes Plugged each Steam Generator	107	70

NOTE: Tubes which contained more than one indication in more than one category (20%, 20-39%, and 40% and greater), are listed in all appropriate categories.

ET indications seen at support locations appear to be caused by isolated, random tube wear. Wear marks at a support contact region were confirmed on one tube removed from SG 11 in 1983. Note that most indications at supports occur at the vertical middle (VM), diagonal (DH & DC), and vertical hot and cold (VH & VC) leg side supports.

ET indications seen in free span areas are typically low magnitude signals. Three tube specimens containing free span indications were removed from SG 11, one in November, 1983 and two in November, 1986. Investigations of the free span indications showed these indications are manufacturing imperfections. There is no correlation of free span indications with respect to location, elevation, inlet side or outlet side; tube manufacturing imperfections would be expected to produce random occurrences like this.

Corrective measures have been initiated to minimize further degradation to the SG's. During the 1986 outage the removal of all major copper components from the feedwater and condensate systems was completed. The installation of a nitrogen blanketing system on all condensate storage tanks is being completed to reduce auxiliary feedwater and condensate makeup oxygen.

Current chemistry procedures require action to be taken below the Utility/EPRI Steam Generator Reliability Project (SGRP) PWR Secondary Water Chemistry Guideline Action Levels. This enables corrective measures to be initiated before conditions become degraded in the SG's.

APPENDIX I

Eddy Current Test Results for SG 11

- A. List with Plot of All Indications
- B. List with Plot of <20% Indications
- C. List with Plot of 20% - 39% Indications
- D. List with Plot of >39% Indications
- E. List with Plot of Tubes Dented
- F. List with Plot of Tubes Plugged During May/June
1990
- G. List with Plot of all Tubes Plugged

STEAM GENERATOR 11

A. List with Plot of All Indications

All Eddy Current Indications - All Elevations

PLANT: CALVERT CLIFFS UNIT 1

GENERATOR: 11

OUTAGE: 5/90

1 = >30 DEG


2 = 20-30 (10%)

3 = <20 (324)

TOTAL TUBES : 8519
STAYS : 7

TOTAL TUBES ASSIGNED : 234

180 DEG



Plant: CALVERT CLIFFS UNIT 1
Outage: 5/90

Steam Generator: 11

QUERY: All Eddy Current Indications - All Elevations

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
27	7	5/90	OD	24	8	TW	+3.50
23	15	5/90	OD	16	8	TW	+5.40
75	15	5/90	OD	1	8	C1	+5.60
52	16	5/90	OD	0.75	8	C4	+8.00
72	16	5/90	OD	0.42	8	CTS-SF	+10.00
62	18	5/90	OD	0.57	8	CB	+1.40
80	18	5/90	OD	0.60	8	C1	+1.60
42	20	5/90	OD	0.71	8	C2	+2.10
79	21	5/90	OD	0.85	8	C1	+1.40
78	21	5/90	OD	0.51	8	C7	+8.50
9	25	5/90	OD	2.93	8	VM	+0.30
77	25	5/90	OD	0.68	8	VM	+2.60
9	25	5/90	OD	1.11	8	VM	
93	25	5/90	OD	0.94	8	VH	+2.60
32	28	5/90	OD	1.64	8	CTS-SF	+5.50
73	29	5/90	OD	0.78	8	CB	+10.60
6	30	5/90	OD	0.62	8	C2	+10.60
72	30	5/90	OD	0.69	8	C1	+10.60
92	30	5/90	OD	1.29	8	HS	+7.50
112	34	5/90	OD	0.51	8	C4	+34.40
32	36	5/90	OD	0.51	8	HS	+11.00
24	37	5/90	OD	0.54	8	HTS-SF	+1.00
26	38	5/90	OD	1.72	8	HTS-SF	+1.10
46	38	5/90	OD	0.81	8	VM	+0.10
86	38	5/90	OD	1.16	8	VM	
116	38	5/90	OD	0.61	8	HTS-SF	+1.00
25	39	5/90	OD	0.91	8	C10	+1.00
86	46	5/90	OD	0.87	8	HTS-SF	+0.80
98	46	5/90	OD	1.42	8	C2	+10.20
38	48	5/90	OD	1.23	8	C1	+18.60
74	50	5/90	OD	0.52	8	HTS-SF	+1.70
96	50	5/90	OD	0.59	8	C1	+13.44
31	51	5/90	OD	0.79	8	C7	+12.30
39	51	5/90	OD	0.65	8	HTS-SF	+0.93
43	51	5/90	OD	0.73	8	HTS-SF	+2.10
48	51	5/90	OD	1.04	8	H1	+1.90
50	51	5/90	OD	0.60	8	HTS-SF	+0.60
43	52	5/90	OD	1.36	8	HTS-SF	+2.40
95	52	5/90	OD	1.16	8	C4	+27.90
5	54	5/90	OD	0.75	8	C3	+9.60
42	54	5/90	OD	0.49	8	HTS-SF	+8.70
50	54	5/90	OD	0.51	8	HTS-SF	+0.90
43	54	5/90	OD	1.71	8	HTS-SF	+1.40
95	54	5/90	OD	0.41	8	HTS-SF	+0.80
5	54	5/90	OD	0.65	8	H9	+0.80
42	54	5/90	OD	2.04	8	HTS-SF	+1.70
53	54	5/90	OD	0.44	8	HTS-SF	+0.70
65	54	5/90	OD	2.27	8	HTS-SF	+1.20
6	56	5/90	OD	.86	8	H3	+0.80
24	56	5/90	OD	1.04	8	HTS-SF	+0.90
64	56	5/90	OD	0.95	8	H4	+18.60
3	57	5/90	OD	0.59	8	HTS-SF	+0.70
5	57	5/90	OD	0.58	8	CTS-SF	+1.20
11	57	5/90	OD	0.72	8	HTS-SF	+0.80
23	57	5/90	OD	0.59	8	HTS-SF	+0.70
27	57	5/90	OD	0.74	8	HTS-SF	+0.70
35	57	5/90	OD	2.10	8	HTS-SF	+1.40
57	57	5/90	OD	0.53	8	HTS-SF	+3.50
81	57	5/90	OD	0.51	8	HTS-SF	+0.50
10	58	5/90	OD	0.71	8	HTS-SF	+1.20
16	58	5/90	OD	0.73	8	HTS-SF	+1.00
50	58	5/90	OD	0.97	8	HTS-SF	+3.00
58	58	5/90	OD	0.94	8	HTS-SF	+0.90
55	59	5/90	OD	1.04	8	H6	+1.00
77	59	5/90	OD	0.68	8	HTS-SF	+13.90
125	59	5/90	OD	0.69	8	C3	+16.60

Plant: CALVERT CLIFFS UNIT 1
 Outage: 5/90

Steam Generator: 11

QUERY: All Eddy Current Indications - All Elevations

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
60	60	5/90	OD	0.83	C4	EE	-300
		5/90	OD	0.70	HTS	EE	0
		5/90	OD	1.35	HTS	EE	100
11	61	5/90	OD	0.84	H4	EE	200
51	63	5/90	OD	0.62	HTS	EE	300
61	65	5/90	OD	0.80	H6	EE	400
129	65	5/90	OD	0.89	HTS	EE	500
60	66	5/90	OD	0.75	HTS	EE	600
62	66	5/90	OD	1.21	HTS	EE	700
66	66	5/90	OD	0.60	HTS	EE	800
108	66	5/90	OD	1.07	HTS	EE	900
61	67	5/90	OD	0.70	HTS	EE	1000
63	67	5/90	OD	0.66	HTS	EE	1100
77	67	5/90	OD	0.75	HTS	EE	1200
131	67	5/90	OD	0.85	HTS	EE	1300
133	67	5/90	OD	1.40	HTS	EE	1400
56	68	5/90	OD	0.70	HTS	EE	1500
60	68	5/90	OD	0.66	HTS	EE	1600
100	68	5/90	OD	0.78	HTS	EE	1700
65	69	5/90	OD	0.69	HTS	EE	1800
34	70	5/90	OD	1.21	HTS	EE	1900
58	70	5/90	OD	0.40	HTS	EE	2000
70	70	5/90	OD	1.10	HTS	EE	2100
100	70	5/90	OD	0.49	HTS	EE	2200
55	71	5/90	OD	0.56	HTS	EE	2300
133	71	5/90	OD	0.62	HTS	EE	2400
60	72	5/90	OD	0.57	HTS	EE	2500
62	72	5/90	OD	0.94	HTS	EE	2600
66	72	5/90	OD	0.91	HTS	EE	2700
68	72	5/90	OD	0.94	HTS	EE	2800
72	72	5/90	OD	0.84	HTS	EE	2900
92	72	5/90	OD	1.32	HTS	EE	3000
66	74	5/90	OD	1.32	HTS	EE	3100
67	75	5/90	OD	1.47	HTS	EE	3200
69	75	5/90	OD	1.44	HTS	EE	3300
71	75	5/90	OD	1.04	HTS	EE	3400
48	76	5/90	OD	1.07	HTS	EE	3500
70	76	5/90	OD	1.15	HTS	EE	3600
70	78	5/90	OD	0.68	HTS	EE	3700
66	80	5/90	OD	0.58	HTS	EE	3800
80	80	5/90	OD	0.75	HTS	EE	3900
128	80	5/90	OD	0.91	CTS-SF	EE	4000
140	80	5/90	OD	0.73	CTS	EE	4100
67	81	5/90	OD	1.15	C4	EE	4200
93	81	5/90	OD	0.64	DH	EE	4300
129	81	5/90	OD	0.84	C6	EE	4400
133	81	5/90	OD	0.67	HTS-SF	EE	4500
75	83	5/90	OD	0.86	HS	EE	4600
103	83	5/90	OD	0.60	HS	EE	4700
139	83	5/90	OD	1.66	CTS-SF	EE	4800
		5/90	OD	1.04	HTS-SF	EE	4900
74	84	5/90	OD	0.69	HTS	EE	5000
78	84	5/90	OD	0.72	HTS	EE	5100
98	84	5/90	OD	0.61	CTS	EE	5200
71	85	5/90	OD	0.69	HTS	EE	5300
77	85	5/90	OD	1.05	HTS	EE	5400
79	85	5/90	OD	0.61	HTS	EE	5500
81	85	5/90	OD	0.73	HTS	EE	5600
71	87	5/90	OD	0.90	HTS	EE	5700
77	87	5/90	OD	1.01	HTS	EE	5800
117	87	5/90	OD	0.94	DC	EE	5900
		5/90	OD	0.73			6000

Plant: CALVERT CLIFFS UNIT 1
Outage: 5/90

Steam Generator: 11

QUERY: All Eddy Current Indications - All Elevations

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
70	88	5/90	OD	1.119683010-0.900456374	0.85	HHTSS	+ 2.900
		5/90	OD	-0.656	0.656	HHTSS	+ 0.600
72	88	5/90	OD	1.12211-0.900456374	1.221	HHTSS	+ 0.800
80	88	5/90	OD	0.12568	0.930	C3	+ 2.900
82	88	5/90	OD	2.10.600	0.000	VH	+ 1.000
106	88	5/90	OD	1.11.806	0.920	HHTSS	+ 0.700
70	90	5/90	OD	1.11.806	0.920	HHTSS	+ 0.700
76	90	5/90	OD	1.11.806	0.920	HHTSS	+ 0.700
78	90	5/90	OD	1.11.806	0.920	HHTSS	+ 0.700
76	92	5/90	OD	1.11.806	0.920	HS	+ 1.000
108	92	5/90	OD	1.11.806	0.920	H7	+ 0.400
105	93	5/90	OD	1.11.806	0.920	GTS-SF	+ 1.000
		5/90	OD	1.11.806	0.920	GTS	+ 0.700
		5/90	OD	1.11.806	0.920	C4	+ 0.900
71	95	5/90	OD	1.11.806	0.920	C1	+ 1.000
129	95	5/90	OD	1.11.806	0.920	HTS-SF	+ 0.900
72	96	5/90	OD	1.11.806	0.920	C1	+ 0.400
76	98	5/90	OD	1.11.806	0.920	H7	+ 0.900
69	99	5/90	OD	1.11.806	0.920	H5	+ 0.600
127	99	5/90	OD	1.11.806	0.920	HTS-SF	+ 0.400
66	100	5/90	OD	1.11.806	0.920	C4	+ 0.600
70	100	5/90	OD	1.11.806	0.920	HHTSS	+ 1.500
86	100	5/90	OD	1.11.806	0.920	HHTSS	+ 0.600
108	100	5/90	OD	1.11.806	0.920	H2	+ 0.900
63	101	5/90	OD	1.11.806	0.920	HHTSS	+ 0.500
65	101	5/90	OD	1.11.806	0.920	HHTSS	+ 0.800
105	101	5/90	OD	1.11.806	0.920	HHTSS	+ 1.900
54	102	5/90	OD	1.11.806	0.920	HHTSS	+ 2.000
62	102	5/90	OD	1.11.806	0.920	HHTSS	+ 1.600
64	102	5/90	OD	1.11.806	0.920	HHTSS	+ 1.100
66	103	5/90	OD	1.11.806	0.920	HHTSS	+ 1.400
53	105	5/90	OD	1.11.806	0.920	HHTSS	+ 1.200
57	105	5/90	OD	1.11.806	0.920	HHTSS	+ 1.200
61	105	5/90	OD	1.11.806	0.920	HHTSS	+ 1.200
89	105	5/90	OD	1.11.806	0.920	HHTSS	+ 1.200
66	106	5/90	OD	1.11.806	0.920	HHTSS	+ 1.200
106	106	5/90	OD	1.11.806	0.920	HHTSS	+ 1.200
106	106	5/90	OD	1.11.806	0.920	HHTSS	+ 1.200
108	106	5/90	OD	1.11.806	0.920	HHTSS	+ 1.200
109	106	5/90	OD	1.11.806	0.920	HHTSS	+ 1.200
53	109	5/90	OD	1.11.806	0.920	HHTSS	+ 1.200
61	109	5/90	OD	1.11.806	0.920	HHTSS	+ 1.200
115	109	5/90	OD	1.11.806	0.920	HHTSS	+ 1.200
16	110	5/90	OD	1.11.806	0.920	HHTSS	+ 1.200
18	110	5/90	OD	1.11.806	0.920	HHTSS	+ 1.200
20	110	5/90	OD	1.11.806	0.920	HHTSS	+ 1.200
44	110	5/90	OD	1.11.806	0.920	HHTSS	+ 1.200
86	110	5/90	OD	1.11.806	0.920	HHTSS	+ 1.200
5	111	5/90	OD	1.11.806	0.920	HHTSS	+ 1.200
29	111	5/90	OD	1.11.806	0.920	HHTSS	+ 1.200
43	111	5/90	OD	1.11.806	0.920	HHTSS	+ 1.200
77	111	5/90	OD	1.11.806	0.920	HHTSS	+ 1.200
91	111	5/90	OD	1.11.806	0.920	HHTSS	+ 1.200
15	111	5/90	OD	1.11.806	0.920	HHTSS	+ 1.200
20	112	5/90	OD	1.11.806	0.920	HHTSS	+ 1.200
30	112	5/90	OD	1.11.806	0.920	HHTSS	+ 1.200
54	113	5/90	OD	1.11.806	0.920	HHTSS	+ 1.200
11	113	5/90	OD	1.11.806	0.920	HHTSS	+ 1.200
51	113	5/90	OD	1.11.806	0.920	HHTSS	+ 0.900

Plant: CALVERT CLIFFS UNIT 1
 Outage: 5/90

Steam Generator: 11

QUERY: All Eddy Current Indications - All Elevations

ROW	LINE	CUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
53		/90	OD	4	0.67	BA	.70
101	1-1-2	/90	OD		0.47	BAA	.70
131	2-2-3	/90	OD		0.94	BAB	.60
42	2-2-4	/90	OD		0.47	ABA	.70
44	3-1-4	/90	OD		0.96	AAB	.70
46	1-1-4	/90	OD		0.66	BBB	.70
124	1-1-6	/90	OD	1.0	0.64	BBB	.70
128	1-1-6	/90	OD		0.75	CCC	.70
22	1-1-7	/90	OD		0.00	CCC	.70
19	1-1-7	/90	OD		0.00	CCC	.70
47	1-1-8	/90	OD		0.00	CCC	.70
42	1-1-9	/90	OD		0.00	CCC	.70
116	1-1-9	/90	OD		0.00	CCC	.70
93	1-1-9	/90	OD		0.00	CCC	.70
94	1-1-9	/90	OD		0.00	CCC	.70
1	1-1-10	/90	OD		0.00	CCC	.70
116	1-1-10	/90	OD		0.00	CCC	.70
70	1-2-6	/90	OD		0.00	DD	.50
114	1-2-6	/90	OD		0.00	DD	.50
35	1-2-7	/90	OD		0.00	DD	.50
30	1-2-7	/90	OD		0.00	DD	.50
117	1-2-11	/90	OD		0.00	DD	.50
175	1-2-11	/90	OD		0.00	DD	.50
76	1-2-11	/90	OD		0.00	DD	.50
104	2-3-0	/90	OD		0.00	DD	.70
114	2-4-0	/90	OD		0.00	DD	.70
210	2-4-1	/90	OD		0.00	DD	.70
104	2-4-2	/90	OD		0.00	DD	.70
91	2-4-3	/90	OD		0.00	DD	.70
30	2-4-4	/90	OD		0.00	DD	.70
33	2-4-4	/90	OD		0.00	DD	.70
45	2-4-5	/90	OD		0.00	DD	.70
44	2-4-6	/90	OD		0.00	DD	.70
44	2-4-7	/90	OD		0.00	DD	.70
1	2-4-8	/90	OD		0.00	DD	.70
29	2-4-9	/90	OD		0.00	DD	.70
44	2-4-10	/90	OD		0.00	DD	.70
44	2-4-11	/90	OD		0.00	DD	.70
29	2-4-12	/90	OD		0.00	DD	.70
29	2-4-13	/90	OD		0.00	DD	.70
29	2-4-14	/90	OD		0.00	DD	.70
29	2-4-15	/90	OD		0.00	DD	.70
29	2-4-16	/90	OD		0.00	DD	.70
29	2-4-17	/90	OD		0.00	DD	.70
29	2-4-18	/90	OD		0.00	DD	.70
29	2-4-19	/90	OD		0.00	DD	.70
29	2-4-20	/90	OD		0.00	DD	.70
29	2-4-21	/90	OD		0.00	DD	.70
29	2-4-22	/90	OD		0.00	DD	.70
29	2-4-23	/90	OD		0.00	DD	.70
29	2-4-24	/90	OD		0.00	DD	.70
					0.72	HTS - PF	

TOTAL TUBES FOUND

234

TOTAL INDICATIONS FOUND

261

TOTAL TUBES IN INPUT FILE

6519

TOTAL TUBES INSPECTED

8421

STEAM GENERATOR 11

B. List with Plot of <20% Indications

Less Than 20% Eddy Current Indications - All Elevations


PLANT: CALVERT CLIFFS UNIT 1

OUTAGE: 5/90
1 - <20% (134)

GENERATION: 11

TOTAL TUBES : 8619
STAYS : 7

TOTAL TUBES ASSIGNED : 134



Plant: CALVERT CLIFFS UNIT 1
 Outage: 5/90

Steam Generator: 11

QUERY: Less Than 20% Eddy Current Indications - All Elevations

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
23	15	5/90	OD	16	0.43	CTS-SF	+ 500 .400
9	5/90	OD		3	2.93	VM	+ 500 .600
77	5/90	OD		4	0.65	VM	+ 500 .300
9	5/90	OD		18	1.11	VM	+ 500 .600
93	5/90	OD		6	0.94	VH	+ 500 .600
73	5/90	OD		7	1.54	CTS-SF	+ 500 .300
77	5/90	OD		8	0.78	CB	+ 500 .600
79	5/90	OD		9	0.69	C1	+ 500 .100
93	5/90	OD		10	1.29	H5	+ 500 .600
73	5/90	OD		11	0.67	HTS-S	+ 500 .100
79	5/90	OD		12	1.16	HTS-S	+ 500 .100
93	5/90	OD		13	0.61	VM	+ 500 .800
73	5/90	OD		14	0.87	HTS-S	+ 500 .100
79	5/90	OD		15	1.11	HTS-S	+ 500 .100
93	5/90	OD		16	0.67	HTS-S	+ 500 .600
73	5/90	OD		17	0.67	VM	+ 500 .100
79	5/90	OD		18	0.23	HTS-S	+ 500 .100
93	5/90	OD		19	0.69	C1	+ 500 .44
73	5/90	OD		20	0.73	HTS-S	+ 500 .100
79	5/90	OD		21	0.04	HTS-S	+ 500 .400
93	5/90	OD		22	1.16	HTS-S	+ 500 .400
73	5/90	OD		23	0.05	HTS-S	+ 500 .700
79	5/90	OD		24	0.57	HTS-S	+ 500 .700
93	5/90	OD		25	0.74	HTS-S	+ 500 .400
73	5/90	OD		26	0.71	HTS-S	+ 500 .700
79	5/90	OD		27	0.73	HTS-S	+ 500 .700
93	5/90	OD		28	0.97	HTS-S	+ 500 .400
73	5/90	OD		29	0.74	HTS-S	+ 500 .700
79	5/90	OD		30	0.71	HTS-S	+ 500 .700
93	5/90	OD		31	0.97	HTS-S	+ 500 .400
73	5/90	OD		32	0.74	HTS-S	+ 500 .700
79	5/90	OD		33	0.71	HTS-S	+ 500 .700
93	5/90	OD		34	0.97	HTS-S	+ 500 .400
73	5/90	OD		35	0.74	HTS-S	+ 500 .700
79	5/90	OD		36	0.71	HTS-S	+ 500 .700
93	5/90	OD		37	0.97	HTS-S	+ 500 .400
73	5/90	OD		38	0.74	HTS-S	+ 500 .700
79	5/90	OD		39	0.71	HTS-S	+ 500 .700
93	5/90	OD		40	0.97	HTS-S	+ 500 .400
73	5/90	OD		41	0.74	HTS-S	+ 500 .700
79	5/90	OD		42	0.71	HTS-S	+ 500 .700
93	5/90	OD		43	0.97	HTS-S	+ 500 .400
73	5/90	OD		44	0.74	HTS-S	+ 500 .700
79	5/90	OD		45	0.71	HTS-S	+ 500 .700
93	5/90	OD		46	0.97	HTS-S	+ 500 .400
73	5/90	OD		47	0.74	HTS-S	+ 500 .700
79	5/90	OD		48	0.71	HTS-S	+ 500 .700
93	5/90	OD		49	0.97	HTS-S	+ 500 .400
73	5/90	OD		50	0.74	HTS-S	+ 500 .700
79	5/90	OD		51	0.71	HTS-S	+ 500 .700
93	5/90	OD		52	0.97	HTS-S	+ 500 .400
73	5/90	OD		53	0.74	HTS-S	+ 500 .700
79	5/90	OD		54	0.71	HTS-S	+ 500 .700
93	5/90	OD		55	0.97	HTS-S	+ 500 .400
73	5/90	OD		56	0.74	HTS-S	+ 500 .700
79	5/90	OD		57	0.71	HTS-S	+ 500 .700
93	5/90	OD		58	0.97	HTS-S	+ 500 .400
73	5/90	OD		59	0.74	HTS-S	+ 500 .700
79	5/90	OD		60	0.71	HTS-S	+ 500 .700
93	5/90	OD		61	0.97	HTS-S	+ 500 .400
73	5/90	OD		62	0.74	HTS-S	+ 500 .700
79	5/90	OD		63	0.71	HTS-S	+ 500 .700
93	5/90	OD		64	0.97	HTS-S	+ 500 .400
73	5/90	OD		65	0.74	HTS-S	+ 500 .700
79	5/90	OD		66	0.71	HTS-S	+ 500 .700
93	5/90	OD		67	0.97	HTS-S	+ 500 .400
73	5/90	OD		68	0.74	HTS-S	+ 500 .700
79	5/90	OD		69	0.71	HTS-S	+ 500 .700
93	5/90	OD		70	0.97	HTS-S	+ 500 .400
73	5/90	OD		71	0.74	HTS-S	+ 500 .700
79	5/90	OD		72	0.71	HTS-S	+ 500 .700
93	5/90	OD		73	0.97	HTS-S	+ 500 .400
73	5/90	OD		74	0.74	HTS-S	+ 500 .700
79	5/90	OD		75	0.71	HTS-S	+ 500 .700
93	5/90	OD		76	0.97	HTS-S	+ 500 .400
73	5/90	OD		77	0.74	HTS-S	+ 500 .700
79	5/90	OD		78	0.71	HTS-S	+ 500 .700

Plant: CALVERT CLIFFS UNIT 1
Outage: 5/90

Steam Generator: 11

QUERY: Less Than 20% Eddy Current Indications - All Elevations

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
128	80	5/90	OD		0.91	H4	+24.16
93	81	5/90	OD		1.15	C4	+15.00
109	81	5/90	OD		0.64	DH	+10.60
75	83	5/90	OD		0.67	HTS-SF	+1.00
103	83	5/90	OD		0.60	H5	+16.80
78	84	5/9	OD		1.90	HTT	+11.55
79	85	5/9	OD		0.62	HTT	+11.75
71	87	5/9	OD		0.90	HTT	+10.50
77	87	5/90	OD		0.94	HTT	+10.50
80	88	5/90	OD		0.66	HTS-SF	+10.50
106	90	5/90	OD		1.54	HTS-SF	+1.60
76	92	5/90	OD		1.03	C4	+34.00
105	93	5/90	OD		0.69	C4	+1.45
71	95	5/90	OD		0.77	HTS-SF	+1.92
127	98	5/90	OD		1.24	HTS-SF	+1.40
86	99	5/90	OD		0.40	C1	+34.00
105	100	5/90	OD		0.89	C1	+1.60
65	101	5/90	OD		0.82	HTT	+1.40
62	102	5/90	OD		0.60	HTT	+1.00
64	102	5/90	OD		0.43	HTT	+1.00
53	105	5/90	OD		0.73	HTT	+1.40
57	105	5/90	OD		0.82	HTT	+1.00
61	105	5/90	OD		0.70	HTT	+1.00
89	105	5/90	OD		0.88	HTT	+1.00
56	106	5/90	OD		0.27	HTT	+1.00
60	106	5/90	OD		0.53	HTT	+1.00
122	106	5/90	OD		0.52	HTS-SF	+1.00
333	109	5/90	OD		0.51	HTS-SF	+1.00
61	109	5/90	OD		0.71	HTS-SF	+1.00
115	109	5/90	OD		1.02	H8	+1.00
118	110	5/90	OD		1.06	HTS-SF	+1.00
44	110	5/90	OD		0.51	HTS-SF	+1.00
86	110	5/90	OD		0.89	C3	+1.14
5	111	5/90	OD		0.73	HTS-SF	+1.00
43	111	5/90	OD		0.43	HTS-SF	+1.00
91	111	5/90	OD		0.60	H1	+1.11
16	112	5/90	OD		0.99	HTS-SF	+1.11
20	112	5/90	OD		0.50	HTS-SF	+1.11
54	112	5/90	OD		0.68	HTS-SF	+1.11
11	113	5/90	OD		1.01	HTS-SF	+1.00
101	113	5/90	OD		0.49	HTS-SF	+1.00
42	114	5/90	OD		0.47	HTS-SF	+1.00
44	114	5/90	OD		0.88	HTS-SF	+1.00
19	117	5/90	OD		0.50	CT2	+17.60
47	117	5/90	OD		0.91	HTT	+2.00
42	118	5/90	OD		0.97	HTT	+1.70
31	119	5/90	OD		1.24	HTM	+0.70
9	121	5/90	OD		0.65	CTS	+35.80
115	121	5/90	OD		0.65	CTS	+35.80
26	122	5/90	OD		0.75	CTS	+34.00
30	122	5/90	OD		0.90	ATS	+34.00
116	122	5/90	OD		0.91	CD	+1.00
114	126	5/90	OD		0.43	HTS-SF	+1.00
35	127	5/90	OD		0.57	HTS-SF	+1.00
30	128	5/90	OD		0.93	HTS-SF	+1.00
32	128	5/90	OD		0.60	HTS-SF	+0.70
17	131	5/90	OD		0.65	DC	+24.00
115	131	5/90	OD		1.14	H4	+24.00
76	132	5/90	OD		0.91	H4	+24.00
80	140	5/90	OD		0.58	CD	+34.00
104	141	5/90	OD		0.59	DC	+34.00
91	149	5/90	OD		0.60	DC	+34.00
65	149	5/90	OD		0.90	DC	+34.00

Plant: CALVERT CLIFFS UNIT 1
Outage: 5/90

Steam Generator: 11

QUERY: Less Than 20% Eddy Current Indications - All Elevations

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES	
83	149	5/90	OD	15	8	TW	0.68 H2	+ 8.00
8	150	5/90	OD	10	8	TW	1.80 VM	
72	152	5/90	OD	16	8	TW	0.64 H3	+32.20

TOTAL TUBES FOUND = 134
TOTAL INDICATIONS FOUND = 137

TOTAL TUBES IN INPUT FILE = 8519
TOTAL TUBES INSPECTED = 8421

STEAM GENERATOR 11

C. List with Plot of 20% - 39% Indications

20-39% EDDY CURRENT INDICATIONS - ALL ELEVATIONS


PLANT: CALVERT CLIFFS UNIT 1

OUTAGE: 5/90

± = 20-39 (106)

TOTAL TUBES : 8519
STAYS (E) : 7

TOTAL TUBES ASSIGNED : 105



Plant: CALVERT CLIFFS UNIT 1
Outage: 5/90

Steam Generator: 11

QUERY: 20-39% EDDY CURRENT INDICATIONS - ALL ELEVATIONS

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
27	7	5/90	OD	0.47	HTS-SF	+ 3.50	
75	15	5/90	OD	1.07	C1	+ 15.60	
52	16	5/90	OD	0.75	C4	+ 2.80	
78	16	5/90	OD	0.42	CTS-SF	+ 3.20	
62	18	5/90	OD	0.57	C5	+ 1.40	
80	18	5/90	OD	0.60	C1	+ 19.60	
42	10	5/90	OD	0.71	H2	+ 21.60	
79	21	5/90	OD	0.85	C1	+ 17.40	
78	22	5/90	OD	0.51	C7	+ 8.60	
6	30	5/90	OD	0.62	C2	+ 16.30	
112	34	5/90	OD	0.51	C4	+ 34.40	
116	35	5/90	OD	0.91	C10	+ 1.00	
85	46	5/90	OD	1.42	HTS-SF	+ 10.20	
38	48	5/90	OD	0.52	C7	+ 1.30	
96	50	5/90	OD	0.79	HTS-SF	+ 12.00	
31	55	5/90	OD	0.65	HTS-SF	+ 0.90	
48	56	5/90	OD	0.60	HTS-SF	+ 27.90	
95	57	5/90	OD	0.75	C4	+ 2.70	
42	58	5/90	OD	0.61	HTS-SF	+ 0.80	
50	59	5/90	OD	1.71	HTS-SF	+ 19.90	
52	59	5/90	OD	0.41	HTS-SF	+ 1.70	
122	59	5/90	OD	0.65	HTS-SF	+ 0.70	
47	59	5/90	OD	0.44	HTS-SF	+ 1.30	
53	59	5/90	OD	0.37	HTS-SF	+ 0.70	
65	59	5/90	OD	0.86	HTS-SF	+ 1.30	
57	67	5/90	OD	2.10	HTS-SF	+ 0.80	
81	57	5/90	OD	0.53	HTS-SF	+ 3.50	
55	59	5/90	OD	1.04	HTS-SF	+ 1.00	
77	59	5/90	OD	0.68	H6	+ 13.90	
125	59	5/90	OD	0.69	C3	+ 5.30	
51	60	5/90	OD	0.87	HTS-SF	+ 3.30	
60	60	5/90	OD	0.62	HTS-SF	+ 22.00	
61	67	5/90	OD	0.75	HTS-SF	+ 1.70	
77	67	5/90	OD	0.73	VH	+ 1.50	
133	67	5/90	OD	0.72	CTS-SF	+ 22.50	
100	68	5/90	OD	0.78	C1	+ 0.80	
70	70	5/90	OD	1.10	HTS-SF	+ 21.10	
133	71	5/90	OD	0.63	H3	+ 7.80	
66	80	5/90	OD	0.66	H3	+ 5.10	
80	80	5/90	OD	0.52	H1	+ 29.50	
140	80	5/90	OD	0.75	H2	+ 18.40	
67	81	5/90	OD	0.70	CTS-SF	+ 19.60	
133	81	5/90	OD	0.73	C5	+ 10.20	
103	83	5/90	OD	0.84	C6	+ 11.30	
139	83	5/90	OD	0.67	H5	+ 4.60	
74	84	5/90	OD	0.86	HTS-SF	+ 8.20	
98	84	5/90	OD	1.66	HTS-SF	+ 0.70	
71	85	5/90	OD	0.72	HTS-SF	+ 9.60	
77	85	5/90	OD	0.61	HTS-SF	+ 21.80	
81	85	5/90	OD	0.69	HTS-SF	+ 0.70	
77	87	5/90	OD	1.05	H5	+ 1.60	
117	87	5/90	OD	0.72	HTS-SF	+ 17.00	
70	88	5/90	OD	1.05	DC	+ 0.40	
70	88	5/90	OD	0.73	HTS-SF	+ 13.60	
70	88	5/90	OD	0.85	HTS-SF	+ 0.60	
72	88	5/90	OD	0.66	HTS-SF	+ 20.80	
82	88	5/90	OD	1.09	C3	+ 9.50	
76	90	5/90	OD	0.93	HTS-SF	+ 3.30	
78	90	5/90	OD	1.36	HTS-SF	+ 0.70	
108	92	5/90	OD	0.81	H7	+ 4.50	
105	93	5/90	OD	0.88	HTS-SF	+ 3.70	
105	93	5/90	OD	0.51	C7	+ 0.10	
105	93	5/90	OD	0.74	C1	+ 35.90	
129	95	5/90	OD	0.66	C1	+ 10.50	

Plant: CALVERT CLIFFS UNIT 1
 Outage: 5/90

Steam Generator: 1¹

QUERY: 20-39% EDDY CURRENT INDICATIONS - ALL ELEVATIONS

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
72	96	5/90	OD	6	TW	H7	+ 3.40
69	99	5/90	OD	6	TW	HTS-SF	+ 0.80
66	100	5/90	OD	6	TW	HTS-SF	+ 2.00
70	100	5/90	OD	6	TW	HTS-SF	+ 1.10
		5/90	OD	6	TW	HTS-SF	+ 1.30
108	100	5/90	OD	6	TW	HTS-SF	+ 2.70
63	101	5/90	OD	6	TW	HTS-SF	+ 1.80
65	101	5/90	OD	6	TW	HTS-SF	+ 2.50
54	102	5/90	OD	6	TW	HTS-SF	+ 0.60
64	102	5/90	OD	6	TW	HTS-SF	+ 1.50
65	102	5/90	OD	6	TW	HTS-SF	+ 1.60
92	108	5/90	OD	6	TW	HTS-SF	+ 8.30
53	109	5/90	OD	6	TW	HTS-SF	+ 0.60
16	110	5/90	OD	6	TW	HTS-SF	+ 0.50
20	110	5/90	OD	6	TW	HTS-SF	+ 0.80
86	110	5/90	OD	6	TW	HTS-SF	+ 21.90
29	111	5/90	OD	6	TW	HTS-SF	+ 0.80
77	111	5/90	OD	6	TW	HTS-SF	+ 29.00
30	112	5/90	OD	6	TW	HTS-SF	+ 1.20
9	113	5/90	OD	6	TW	HTS-SF	+ 0.80
131	113	5/90	OD	6	TW	HTS-SF	+ 3.90
46	114	5/90	OD	6	TW	HTS-SF	+ 0.50
52	114	5/90	OD	6	TW	HTS-SF	+ 33.60
124	114	5/90	OD	6	TW	HTS-SF	+ 37.30
128	114	5/90	OD	6	TW	HTS-SF	+ 0.30
22	116	5/90	OD	6	TW	H1	+ 33.00
116	118	5/90	OD	6	TW	C9	+ 11.00
128	118	5/90	OD	6	TW	C6	+ 8.20
9	119	5/90	OD	6	TW	VM	+ 0.70
35	119	5/90	OD	6	TW	HTS-SF	+ 0.90
36	120	5/90	OD	6	TW	HTS-SF	+ 1.00
33	123	5/90	OD	6	TW	HTS-SF	+ 6.30
116	124	5/90	OD	6	TW	HTS-SF	+ 24.90
70	126	5/90	OD	6	TW	HTS-SF	+ 25.40
76	128	5/90	OD	6	TW	HTS-SF	+ 1.30
76	132	5/90	OD	6	TW	HTS-SF	+ 1.40
		5/90	OD	6	TW	HTS-SF	+ 2.20
104	132	5/90	OD	6	TW	HTS-SF	+ 6.40
114	132	5/90	OD	6	TW	HTS-SF	+ 25.90
21	135	5/90	OD	6	TW	HTS-SF	+ 0.90
89	143	5/90	OD	6	TW	HTS-SF	+ 16.00
30	144	5/90	OD	6	TW	HTS-SF	+ 26.50
34	144	5/90	OD	6	TW	HTS-SF	+ 27.40
49	153	5/90	OD	6	TW	HTS-SF	+ 26.90
46	158	5/90	OD	6	TW	HTS-SF	+ 4.10
12	160	5/90	OD	6	TW	HTS-SF	+ 18.50
8	164	5/90	OD	6	TW	HTS-SF	+ 20.10
29	165	5/90	OD	6	TW	HTS-SF	+ 20.10

TOTAL TUBES FOUND = 106
 TOTAL INDICATIONS FOUND = 118

TOTAL TUBES IN INPUT FILE = 8519
 TOTAL TUBES INSPECTED = 8421

STEAM GENERATOR 11

D. List with Plot of >39% Indications

40% And Greater Eddy Current Indications - All Elevations

PLANT: CALVERT CLIFFS UNIT 1


OUTAGE: 5/90

↓ = >30 %

TOTAL TUBES : 8519
STAYS (B) : 7

TOTAL TUBES ASSIGNED : 5

280 DEG



Plant: CALVERT CLIFFS UNIT 1
Outage: 5/90

Steam Generator: 11

QUERY: 40% and Greater Eddy Current Indications - All Elevations

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
60	60	6/90	DD	6%	% TW	0.70 HTD-SPF	+ 0.80
139	80	5/90	DD	57%	% TW	1.04 HTD-SPF	+20.00
		6/90	DD	53%	% TW	0.89 HTD-SPF	+19.80
70	90	6/90	DD	59%	% TW	0.82 HTD-SPF	+ 1.10
81	117	6/90	DD	52%	% TW	0.46 HTD-SPF	+ 0.90
83	118	5/90	DD	48%	% TW	0.67 HTD-SPF	+ 0.70

TOTAL TUBES FOUND = 8
TOTAL INDICATIONS FOUND = 6

TOTAL TUBES IN INPUT FILE = 8519
TOTAL TUBES INSPECTED = 8421

STEAM GENERATOR 11

E. List with Plot of Tubes Dented

ALL DENT INDICATIONS - ALL ELEVATIONS

PLANT: CALVERT CLIFFS UNIT 1

OUTAGE: 5/90


1 = >49.99 (238)
 4 = 20.00-29.99 (194)
 7 = 5.00-9.99 (548)

TOTAL TUBES : 8519
 STAYS (E) : 7

2 = 40.00-49.99 (800)
 5 = 15.00-19.99 (350)
 8 = <5.00 (23)

TOTAL TUBES ASSIGNED : 7865

GENERATOR: 2A



Plant: CALVERT CLIFFS UNIT 1
Outage: 5/90

Steam Generators: 11

QUERY: ALL DENT INDICATIONS + ALL ELEVATIONS

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
15	3	5/90	DENT		16,68	DH	
31	5	5/90	DENT		VM		- 1.80
31	5	5/90	DENT		DH		
31	5	5/90	DENT		VM		
31	7	5/90	DENT		VM		
31	8	5/90	DENT		VM		
31	8	5/90	DENT		VM		
47	8	5/90	DENT		VM		+14.90
26	8	5/90	DENT		VM		
41	8	5/90	DENT		VM		+22.40
69	8	5/90	DENT		VM		
121	8	5/90	DENT		VM		+ 1.40
21	8	5/90	DENT		VM		
51	8	5/90	DENT		VM		
41	8	5/90	DENT		VM		
40	17	5/90	DENT		HTG-SF		+18.10
15	17	5/90	DENT		VM		+ 9.20
11	17	5/90	DENT		VM		
40	18	5/90	DENT		VM		+ 9.20
13	19	5/90	DENT		VM		+ 9.20
19	19	5/90	DENT		VM		
11	19	5/90	DENT		VM		
19	19	5/90	DENT		VM		+ 7.80
19	19	5/90	DENT		DH		
19	19	5/90	DENT		VM		
19	19	5/90	DENT		VM		- 1.10
19	19	5/90	DENT		VM		+23.90
69	19	5/90	DENT		VM		+22.50
16	19	5/90	DENT		VM		+36.80
18	19	5/90	DENT		VM		
16	19	5/90	DENT		DC5		- 1.30
16	19	5/90	DENT		DC		+ 7.30
16	19	5/90	DENT		DCD		+27.60
49	19	5/90	DENT		DC1		+24.70
69	19	5/90	DENT		DC15		+ 8.30
20	49	5/90	DENT		HTG-SF		+15.80
49	49	5/90	DENT		HTG		+32.20
49	49	5/90	DENT		HTG		+18.10
11	49	5/90	DENT		HTG		
47	49	5/90	DENT		HTG		+35.10
54	49	5/90	DENT		HTG		+23.00
47	49	5/90	DENT		HTG		+ 0.80
47	49	5/90	DENT		HTG		+32.50
47	49	5/90	DENT		HTG		+ 2.60
41	55	5/90	DENT		HTG		
40	55	5/90	DENT		HTG		
55	55	5/90	DENT		HTG		
15	55	5/90	DENT		HTG		
41	55	5/90	DENT		HTG		
91	55	5/90	DENT		HTG		
93	55	5/90	DENT		HTG		
97	55	5/90	DENT		HTG		
92	55	5/90	DENT		HTG		
94	55	5/90	DENT		HTG		
98	55	5/90	DENT		HTG		
100	55	5/90	DENT		HTG		
116	55	5/90	DENT		HTG		+14.40
127	55	5/90	DENT		HTG		+ 8.00
91	55	5/90	DENT		HTG		
40	40	5/90	DENT		HTG		+33.80
58	40	5/90	DENT		HTG		+11.70
94	40	5/90	DENT		HTG		
100	40	5/90	DENT		HTG		
102	40	5/90	DENT		HTG		
59	41	5/90	DENT		HTG-SF		+22.20

Plant: CALVERT CLIFFS UNIT 1
 Outage: 5/90

Steam Generator: 11

QUERY: ALL DENT INDICATIONS - ALL ELEVATIONS

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
91	41	5/90	DENT		87.62	H9	
93	41	5/90	DENT		17.86	H9	
95	41	5/90	DENT		66.17	H9	
97	41	5/90	DENT		43.74	H9	
99	41	5/90	DENT		20.65	H9	
101	41	5/90	DENT		78.86	H9	
103	41	5/90	DENT		26.15	H9	
117	41	5/90	DENT		6.30	H9	+ 6.50
10	42	5/90	DENT		10.89	VM	
92	42	5/90	DENT		42.84	H9	
94	42	5/90	DENT		10.87	H9	
96	42	5/90	DENT		73.43	H9	
98	42	5/90	DENT		72.18	H9	
100	42	5/90	DENT		74.54	H9	
102	42	5/90	DENT		67.90	H9	
104	42	5/90	DENT		26.60	H9	
106	42	5/90	DENT		29.60	H9	
91	43	5/90	DENT		49.74	H9	
93	43	5/90	DENT		46.60	H9	
95	43	5/90	DENT		60.00	H9	
97	43	5/90	DENT		148.00	H9	
99	43	5/90	DENT		64.00	H9	
103	43	5/90	DENT		71.94	H9	
105	43	5/90	DENT		76.95	H9	
119	43	5/90	DENT		8.64	H9	+19.60
	44	5/90	DENT		6.78	H9	+20.50
92	44	5/90	DENT		92.78	0101101101101101	
94	44	5/90	DENT		132.00	0101101101101101	+ 7.60
96	44	5/90	DENT		47.00	0101101101101101	
98	44	5/90	DENT		77.00	0101101101101101	
100	44	5/90	DENT		80.00	0101101101101101	
102	44	5/90	DENT		79.04	0101101101101101	
104	44	5/90	DENT		78.11	0101101101101101	
106	44	5/90	DENT		11.00	0101101101101101	
110	44	5/90	DENT		14.40	0101101101101101	
112	44	5/90	DENT		18.93	0101101101101101	
91	45	5/90	DENT		50.17	0101101101101101	
93	45	5/90	DENT		151.70	0101101101101101	
95	45	5/90	DENT		44.00	0101101101101101	
97	45	5/90	DENT		150.00	0101101101101101	
99	45	5/90	DENT		7.74	0101101101101101	
101	45	5/90	DENT		14.14	0101101101101101	
103	45	5/90	DENT		80.00	0101101101101101	
105	45	5/90	DENT		10.00	0101101101101101	
109	45	5/90	DENT		10.44	0101101101101101	+13.50
	45	5/90	DENT		10.00	0101101101101101	
115	45	5/90	DENT		10.00	0101101101101101	
10	46	5/90	DENT		121.00	0101101101101101	
92	46	5/90	DENT		21.00	0101101101101101	
94	46	5/90	DENT		22.00	0101101101101101	
96	46	5/90	DENT		70.43	0101101101101101	
98	46	5/90	DENT		74.93	0101101101101101	
100	46	5/90	DENT		50.79	0101101101101101	
102	46	5/90	DENT		37.00	0101101101101101	
110	46	5/90	DENT		112.00	0101101101101101	
114	46	5/90	DENT		59.00	0101101101101101	
41	47	5/90	DENT		111.00	0101101101101101	
91	47	5/90	DENT		73.00	0101101101101101	
93	47	5/90	DENT		92.00	0101101101101101	
95	47	5/90	DENT		72.94	0101101101101101	
97	47	5/90	DENT		17.20	0101101101101101	
99	47	5/90	DENT		46.00	0101101101101101	
105	47	5/90	DENT		120.00	0101101101101101	
115	47	5/90	DENT		101.00	0101101101101101	
100	48	5/90	DENT		101.00	0101101101101101	
102	48	5/90	DENT		120.00	0101101101101101	

Plant: CALVERT CLIFFS UNIT 1
 Outage: 5/90

Steam Generator: 11

QUERY: ALL DENT INDICATIONS - ALL ELEVATIONS

JW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
110	48	5/90	DENT		16.01	H9	
114	48	5/90	DENT		35.09	H9	
91	49	5/90	DENT		38.96	C9	+ 1.80
93	49	5/90	" AT		38.07	H9	
95	49	5/90	" AT		38.85	H9	
101	49	5/90	" AT		38.49	H9	
103	49	5/90	DENT		19.00	H9	
105	49	5/90	DENT		10.00	H9	
109	49	5/90	DENT		28.61	H7	
111	49	5/90	DENT		28.72	H9	
115	49	5/90	DENT		28.75	H9	
92	50	5/90	DENT		10.17	H9	
94	50	5/90	DENT		28.51	H9	
96	50	5/90	DENT		28.51	H9	
100	50	5/90	DENT		28.59	H9	
102	50	5/90	DENT		28.60	H9	
104	50	5/90	DENT		12.00	H9	
31	51	5/90	DENT		6.00	H9	
91	51	5/90	DENT		34.00	H9	+ 0.36
93	51	5/90	DENT		7.00	H9	
95	51	5/90	DENT		68.00	H9	
101	51	5/90	DENT		41.00	H9	
103	51	5/90	DENT		63.00	H9	
105	51	5/90	DENT		54.00	H9	
94	51	5/90	DENT		91.00	H9	
100	51	5/90	DENT		63.00	H9	
102	51	5/90	DENT		95.00	H9	
104	51	5/90	DENT		78.00	H9	
106	51	5/90	DENT		74.00	H9	
21	51	5/90	DENT		17.00	H9	
99	51	5/90	DENT		77.00	H9	
99	51	5/90	DENT		89.00	H9	
101	51	5/90	DENT		100.00	H9	
103	51	5/90	DENT		110.00	H9	
105	51	5/90	DENT		110.00	H9	
107	51	5/90	DENT		110.00	H9	
109	51	5/90	DENT		110.00	H9	
111	51	5/90	DENT		110.00	H9	
92	54	5/90	DENT		67.00	H9	
94	54	5/90	DENT		76.00	H9	
96	54	5/90	DENT		47.00	H9	
98	54	5/90	DENT		67.00	H9	
100	54	5/90	DENT		67.00	H9	
102	54	5/90	DENT		42.00	H9	
104	54	5/90	DENT		10.00	H9	
110	54	5/90	DENT		50.00	H9	
91	55	5/90	DENT		49.00	H9	
93	55	5/90	DENT		100.00	H9	
97	55	5/90	DENT		66.00	H9	
99	55	5/90	DENT		110.00	H9	
101	55	5/90	DENT		110.00	H9	
103	55	5/90	DENT		110.00	H9	
105	55	5/90	DENT		110.00	H9	
111	55	5/90	DENT		110.00	H9	
114	55	5/90	DENT		110.00	H9	+ 9.70
120	55	5/90	DENT		110.00	H9	+27.50
74	55	5/90	DENT		34.00	H9	
92	56	5/90	DENT		77.00	H9	
94	56	5/90	DENT		77.00	H9	
96	56	5/90	DENT		67.00	H9	
100	56	5/90	DENT		10.00	H9	
102	56	5/90	DENT		10.00	H9	

Plant: CALVERT CLIFFS UNIT 1
 Outage: 5/90

Steam Generator: 11

QUERY: ALL DENT INDICATIONS - ALL ELEVATIONS

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
104	56	5/90	DENT		751.	6H	
106	56	5/90	DENT		751.	6H	
110	56	5/90	DENT		751.	6H	
112	56	5/90	DENT		751.	6H	
91	57	5/90	DENT		111.	6H	
93	57	5/90	DENT		111.	6H	
95	57	5/90	DENT		111.	6H	
97	57	5/90	DENT		111.	6H	
99	57	5/90	DENT		111.	6H	
101	57	5/90	DENT		111.	6H	
103	57	5/90	DENT		111.	6H	
105	57	5/90	DENT		111.	6H	
107	57	5/90	DENT		111.	6H	
111	57	5/90	DENT		111.	6H	
40	57	5/90	DENT		111.	6H	
92	58	5/90	DENT		111.	6H	+37.80
94	58	5/90	DENT		111.	6H	+ 0.20
95	58	5/90	DENT		111.	6H	
98	58	5/90	DENT		111.	6H	
100	58	5/90	DENT		111.	6H	
102	58	5/90	DENT		111.	6H	
96	59	5/90	DENT		111.	6H	
91	59	5/90	DENT		111.	6H	
93	59	5/90	DENT		111.	6H	
95	59	5/90	DENT		111.	6H	
97	59	5/90	DENT		111.	6H	
105	59	5/90	DENT		111.	6H	
40	60	5/90	DENT		111.	6H	+24.10
92	60	5/90	DENT		111.	6H	
94	60	5/90	DENT		111.	6H	
96	60	5/90	DENT		111.	6H	
98	60	5/90	DENT		111.	6H	
41	61	5/90	DENT		111.	6H	
47	61	5/90	DENT		111.	6H	
91	61	5/90	DENT		111.	6H	
93	61	5/90	DENT		111.	6H	
95	61	5/90	DENT		111.	6H	
97	61	5/90	DENT		111.	6H	
99	61	5/90	DENT		111.	6H	
101	61	5/90	DENT		111.	6H	
10	61	5/90	DENT		111.	6H	
105	61	5/90	DENT		111.	6H	
107	61	5/90	DENT		111.	6H	
109	61	5/90	DENT		111.	6H	
113	61	5/90	DENT		111.	6H	
115	61	5/90	DENT		111.	6H	
92	62	5/90	DENT		111.	6H	
94	62	5/90	DENT		111.	6H	
96	62	5/90	DENT		111.	6H	
98	62	5/90	DENT		111.	6H	
100	62	5/90	DENT		111.	6H	
102	62	5/90	DENT		111.	6H	
110	62	5/90	DENT		111.	6H	
128	62	5/90	DENT		111.	6H	
81	63	5/90	DENT		111.	6H	
73	63	5/90	DENT		111.	6H	
95	63	5/90	DENT		111.	6H	
101	63	5/90	DENT		111.	6H	
103	63	5/90	DENT		111.	6H	
105	63	5/90	DENT		111.	6H	
107	63	5/90	DENT		111.	6H	
109	63	5/90	DENT		111.	6H	
92	64	5/90	DENT		111.	6H	+13.60
94	64	5/90	DENT		111.	6H	
98	64	5/90	DENT		111.	6H	
100	64	5/90	DENT		111.	6H	

Plant: CALVERT CLIFFS UNIT 1
 Outage: 5/90

Steam Generator: 11

QUERY: ALL DENT INDICATIONS - ALL ELEVATIONS

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
102	64	5/90	DENT		50.456	H9	
104	64	5/90	DENT		18.494	H9	
106	64	5/90	DENT		49.432	H9	
45	65	5/90	DENT		7.427	C9	+ 4.00
57	65	5/90	DENT		6.020	H9	+37.30
91	65	5/90	DENT		6.144	H9	
93	65	5/90	DENT		6.144	H9	
97	65	5/90	DENT		6.144	H9	
99	65	5/90	DENT		6.144	H9	
101	65	5/90	DENT		6.144	H9	
103	65	5/90	DENT		6.144	H9	
105	65	5/90	DENT		6.144	H9	
92	66	5/90	DENT		6.144	H9	
94	66	5/90	DENT		6.144	H9	
98	66	5/90	DENT		6.144	H9	
100	66	5/90	DENT		6.144	H9	
102	66	5/90	DENT		6.144	H9	
110	66	5/90	DENT		6.144	H9	+22.50
91	67	5/90	DENT		6.144	H9	+ 2.40
93	67	5/90	DENT		6.144	H9	
95	67	5/90	DENT		6.144	H9	
97	67	5/90	DENT		6.144	H9	
99	67	5/90	DENT		6.144	H9	
103	67	5/90	DENT		6.144	H9	
105	67	5/90	DENT		6.144	H9	
66	68	5/90	DENT		6.144	H9	+10.00
76	68	5/90	DENT		6.144	H9	+17.00
92	68	5/90	DENT		6.144	H9	
94	68	5/90	DENT		6.144	H9	
100	68	5/90	DENT		6.144	H9	+17.40
91	69	5/90	DENT		6.144	H9	
93	69	5/90	DENT		6.144	H9	
95	69	5/90	DENT		6.144	H9	
97	69	5/90	DENT		6.144	H9	
99	69	5/90	DENT		6.144	H9	
129	69	5/90	DENT		6.144	H9	+20.70
40	70	5/90	DENT		6.144	H9	
92	70	5/90	DENT		6.144	H9	
94	70	5/90	DENT		6.144	H9	
96	70	5/90	DENT		6.144	H9	
98	70	5/90	DENT		6.144	H9	
100	70	5/90	DENT		6.144	H9	
102	70	5/90	DENT		6.144	H9	
120	70	5/90	DENT		6.144	H9	+18.60
		5/90	DENT		6.144	H9	+ 9.60
		5/90	DENT		6.144	H9	+ 3.40
91	71	5/90	DENT		10.420	H9	
93	71	5/90	DENT		10.420	H9	
95	71	5/90	DENT		10.420	H9	
97	71	5/90	DENT		10.420	H9	
99	71	5/90	DENT		10.420	H9	
101	71	5/90	DENT		10.420	H9	
107	71	5/90	DENT		10.420	H9	
72	72	5/90	DENT		40.626	H9	+20.20
92	72	5/90	DENT		40.626	H9	
96	72	5/90	DLNT		40.626	H9	
98	72	5/90	DENT		40.626	H9	
100	72	5/90	DENT		40.626	H9	
102	72	5/90	DCNT		40.626	H9	
104	72	5/90	DENT		40.626	H9	
110	72	5/90	DENT		40.626	H9	
120	72	5/90	DENT		40.626	H9	
91	73	5/90	DENT		40.626	H9	
93	73	5/90	DENT		40.626	H9	

Plant: CALVERT CLIFFS UNIT 1
 Outage: 5/90

Steam Generators: 11

QUERY: ALL DENT INDICATIONS - ALL ELEVATIONS

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
95	73	5/90	DENT		28.92	H9	
		5/90	DENT		7.35	C9	
97	73	5/90	DENT		80.05	H9	
99	73	5/90	DENT		47.67	H9	
52	74	5/90	DENT		17.77	C4	+ 2.70
58	74	5/90	DENT		6.49	H7	
		5/90	DENT		16.61	C6	+21.80
92	74	5/90	DENT		49.97	H9	
94	74	5/90	DENT		72.70	H9	
102	74	5/90	DENT		103.29	H9	
69	75	5/90	DENT		100.00	H8	+21.10
91	75	5/90	DENT		70.00	H9	
93	75	5/90	DENT		47.00	H9	
95	75	5/90	DENT		28.06	H9	
99	75	5/90	DENT		6.84	VM	+29.00
111	75	5/90	DENT		12.91	H9	
92	76	5/90	DENT		61.45	H9	
94	76	5/90	DENT		18.75	H9	
110	76	5/90	DENT		10.00	H1	+28.80
41	77	5/90	DENT		5.52	VM	+24.20
69	77	5/90	DENT		27.66	H9	
91	77	5/90	DENT		35.19	H9	
93	77	5/90	DENT		50.74	H9	
95	77	5/90	DENT		70.76	H9	
97	77	5/90	DENT		13.00	H9	
99	77	5/90	DENT		45.97	H9	
92	78	5/90	DENT		13.00	H9	
94	78	5/90	DENT		13.00	H9	
96	78	5/90	DENT		13.00	H9	
100	78	5/90	DENT		7.9	H5	+15.60
		5/90	DENT		9.0	H5	+16.20
102	78	5/90	DENT		26.00	H9	
132	78	5/90	DENT		15.00	H9	+42.30
91	79	5/90	DENT		40.00	H9	
93	79	5/90	DENT		60.00	H9	
95	79	5/90	DENT		70.00	H9	
97	79	5/90	DENT		90.34	H9	
99	79	5/90	DENT		122.64	H9	
101	79	5/90	DENT		101.69	H9	
135	79	5/90	DENT		7.90	CTS-SF	+21.40
92	80	5/90	DENT		49.20	H9	
94	80	5/90	DENT		58.19	H9	
96	80	5/90	DENT		62.06	H9	
102	80	5/90	DENT		7.06	H9	
91	81	5/90	DENT		36.14	H9	
95	81	5/90	DENT		117.80	H9	
97	81	5/90	DET		94.85	H9	
99	81	5/90	DENT		79.67	H9	
101	81	5/90	DENT		24.83	H9	
119	81	5/90	DENT		8.42	O10	
40	81	5/90	DENT		2.15	HTS-SF	+1.30
92	82	5/90	DENT		21.99	H9	+19.00
94	82	5/90	DENT		103.01	H9	
96	82	5/90	DENT		151.30	H9	
98	82	5/90	DENT		97.16	H9	
100	82	5/90	DENT		145.40	H9	
102	82	5/90	DENT		123.11	H9	
104	82	5/90	DENT		10.17	H9	
108	82	5/90	DENT		70.48	H9	
110	82	5/90	DENT		10.20	H9	
37	82	5/90	DENT		7.89	VM	
91	82	5/90	DENT		32.06	H9	
95	82	5/90	DENT		67.79	H9	
97	82	5/90	DENT		160.70	H9	
99	82	5/90	DENT		101.60	H9	
101	82	5/90	DENT		48.21	H9	

Plant: CALVERT CLIFFS UNIT 1
 Outage: 5/90

Steam Generator 11

QUERY: ALL DENT INDICATIONS - ALL ELEVATIONS

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
105	83	5/90	DENT	22.00	H9		
40	84	5/90	DENT	7.93	VM		
9	84	5/90	DENT	9.11	HTS-SF		
4	84	5/90	DENT	27.08	H9		
76	84	5/90	DENT	9.86	VM		+17.50
		5/90	DENT	82.16	H9		
98	84	5/90	DENT	99.80	H9		
100	84	5/90	DENT	80.92	H9		
102	84	5/90	DENT	20.10	H9		
104	84	5/90	DENT	17	H9		
108	84	5/90	DENT	42.40	H9		
110	84	5/90	DENT	11.50	H9		
91	85	5/90	DENT	0.04	C9		+ 5.00
		5/90	DENT	0.11	C9		+ 6.00
93	85	5/90	DENT	79.12	HTS-SF		
95	85	5/90	DENT	80.11	H9		
97	85	5/90	DENT	79.41	H9		
99	85	5/90	DENT	87.71	H9		
101	85	5/90	DENT	16.00	H9		
103	85	5/90	DENT	104.00	H9		
105	85	5/90	DENT	34.40	H9		
107	85	5/90	DENT	44.90	H9		
109	85	5/90	DENT	56.70	H9		
115	85	5/90	DENT	56.70	H9		
92	86	5/90	DENT	1.00	H9		
94	86	5/90	DENT	1.00	H9		
96	86	5/90	DENT	1.00	H9		
98	86	5/90	DENT	1.00	H9		
100	86	5/90	DENT	1.00	H9		
106	86	5/90	DENT	1.00	H9		
108	86	5/90	DENT	1.00	H9		
110	86	5/90	DENT	1.00	H9		
114	86	5/90	DENT	1.00	H9		
116	86	5/90	DENT	1.00	H9		
91	87	5/90	DENT	1.00	H9		
93	87	5/90	DENT	117.80	H9		
95	87	5/90	DENT	130.90	H9		
97	87	5/90	DENT	116.60	H9		
99	87	5/90	DENT	119.40	H9		
103	87	5/90	DENT	1.00	H9		
105	87	5/90	DENT	1.00	H9		
107	87	5/90	DENT	1.00	H9		
109	87	5/90	DENT	1.00	H9		
92	88	5/90	DENT	1.00	H9		
94	88	5/90	DENT	1.00	H9		
96	88	5/90	DENT	1.00	H9		
98	88	5/90	DENT	1.00	H9		
100	88	5/90	DENT	1.00	H9		
114	88	5/90	DENT	1.00	H9		
91	89	5/90	DENT	1.00	H9		
93	89	5/90	DENT	1.00	H9		
95	89	5/90	DENT	1.00	H9		
97	89	5/90	DENT	1.00	H9		
101	89	5/90	DENT	1.00	H9		
103	89	5/90	DENT	1.00	H9		
105	89	5/90	DENT	1.00	H9		
109	89	5/90	DENT	1.00	H9		
113	89	5/90	DENT	1.00	H9		
119	89	5/90	DENT	1.00	H9		
127	89	5/90	DENT	1.00	H9		+19.40
92	90	5/90	DENT	1.00	H9		
94	90	5/90	DENT	1.00	H9		
96	90	5/90	DENT	1.00	H9		
98	90	5/90	DENT	1.00	H9		
100	90	5/90	DENT	1.00	H9		

Plant: CALVERT CLIFFS UNIT 1
Outage: 5/90

Steam Generator 11

QUERY: ALL DENT INDICATIONS - ALL ELEVATIONS

ROW	LINE	OUTAGE	INDICATION	VALUE	V-LTS	LOCATION	INCHES
102	90	5/90	DENT	16.43	H9		
110	90	5/90	DENT	16.07	H9		
114	90	5/90	DENT	17.45	H9		
91	91	5/90	DENT	6.86	C9		+ 1.80
				41.79	H9		
93	91	5/90	DENT	50.70	H9		
95	91	5/90	DENT	23.00	H9		
97	91	5/90	DENT	44.96	H9		
99	91	5/90	DENT	46.63	H9		
103	91	5/90	DENT	10.36	H9		
109	91	5/90	DENT	19.11	H9		
117	91	5/90	DENT	8.78	C10		
60	92	5/90	DENT	8.51	CTS-SF		+ 6.80
92	94	5/90	DENT	109.30	H9		
94	94	5/90	DENT	56.01	H9		
96	94	5/90	DENT	61.73	H9		
98	94	5/90	DENT	60.83	H9		
100	94	5/90	DENT	44.63	H9		
106	94	5/90	DENT	49.00	H9		
110	94	5/90	DENT	24.91	H9		
128	94	5/90	DENT	80.11	CTS-C		+22.60
91	93	5/90	DENT	70.70	H9		
93	93	5/90	DENT	67.27	H9		
95	93	5/90	DENT	44.44	H9		
97	93	5/90	DENT	60.00	H9		
107	93	5/90	DENT	10.70	H9		
109	93	5/90	DENT	49.00	H9		
94	94	5/90	DENT	15.00	H9		
96	94	5/90	DENT	15.00	H9		
102	94	5/90	DENT	45.00	H9		
104	94	5/90	DENT	45.00	H9		
106	94	5/90	DENT	70.00	H9		
108	94	5/90	DENT	41.19	H9		
110	94	5/90	DENT	19.02	H9		
				10.26	C1		+33.90
118	94	5/90	DENT	69.33	H10		
91	95	5/90	DENT	27.65	H9		
93	95	5/90	DENT	97.17	H9		
95	95	5/90	DENT	40.74	H9		
97	95	5/90	DENT	90.24	H9		
99	95	5/90	DENT	69.01	H9		
101	95	5/90	DENT	66.16	H9		
103	95	5/90	DENT	66.86	H9		
105	95	5/90	DENT	65.80	H9		
107	95	5/90	DENT	33.00	H9		
109	95	5/90	DENT	14.00	H9		
117	95	5/90	DENT	70.64	H10		
119	95	5/90	DENT	14.00	H9		
92	96	5/90	DENT	40.00	H9		
94	96	5/90	DENT	40.00	H9		
96	96	5/90	DENT	40.00	H9		
100	96	5/90	DENT	40.00	H9		
108	96	5/90	DENT	40.00	H9		
110	96	5/90	DENT	40.00	H9		
112	96	5/90	DENT	40.00	H9		
118	96	5/90	DENT	17.00	H10		
47	97	5/90	DENT	55.66	H4		+ 6.20
91	97	5/90	DENT	13.47	C9		+ 1.90
				13.40	H9		
93	97	5/90	DENT	130.00	H9		
95	97	5/90	DENT	82.66	H9		
97	97	5/90	DENT	134.00	H9		
99	97	5/90	DENT	66.29	H9		
107	97	5/90	DENT	6.05	H9		
109	97	5/90	DENT	61.20	H9		
117	97	5/90	DENT	6.77	C10		
92	98	5/90	DENT	34.55	H9		

Plant: CALVERT C IFFS UNIT 1
 Outage: 5/90

Steam Generator: 11

QUERY: ALL DENT INDICATIONS - ALL ELEVATIONS

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
94	98	5/90	DENT		34.00	HT	
96	98	5/90	DENT		114.00	HT	
98	98	5/90	DENT		74.00	HT	
100	98	5/90	DENT		11.00	HT	
102	98	5/90	DENT		114.00	HT	
110	98	5/90	DENT		74.00	HT	
35	99	5/90	DENT		114.00	HT	
91	99	5/90	DENT		74.00	HT	
93	99	5/90	DENT		114.00	HT	
95	99	5/90	DENT		74.00	HT	
77	99	5/90	DENT		114.00	HT	
99	99	5/90	DENT		74.00	HT	
101	99	5/90	DENT		114.00	HT	
103	99	5/90	DENT		74.00	HT	
105	99	5/90	DENT		114.00	HT	
107	99	5/90	DENT		74.00	HT	
117	97	5/90	DENT		114.00	HT	
119	99	5/90	DENT		74.00	HT	
121	99	5/90	DENT		114.00	HT	
92	100	5/90	DENT		114.00	HT	
94	100	5/90	DENT		114.00	HT	
96	100	5/90	DENT		114.00	HT	
100	100	5/90	DENT		114.00	HT	
102	100	5/90	DENT		114.00	HT	
104	100	5/90	DENT		114.00	HT	+ 6.20
108	100	5/90	DENT		114.00	HT	
118	100	5/90	DENT		114.00	HT	
37	101	5/90	DENT		114.00	HT	+ 36.80
		5/90	DENT		114.00	HT	+ 36.80
		5/90	DENT		114.00	HT	+ 1.40
		5/90	DENT		114.00	HT	+ 2.70
39	101	5/90	DENT		114.00	HT	+ 22.70
69	101	5/90	DENT		114.00	HT	
91	101	5/90	DENT		114.00	HT	
93	101	5/90	DENT		114.00	HT	
95	101	5/90	DENT		114.00	HT	
97	101	5/90	DENT		114.00	HT	
99	101	5/90	DENT		114.00	HT	
101	101	5/90	DENT		114.00	HT	
103	101	5/90	DENT		114.00	HT	
105	101	5/90	DENT		114.00	HT	
107	101	5/90	DENT		114.00	HT	
117	101	5/90	DENT		114.00	HT	+ 15.00
121	101	5/90	DENT		114.00	HT	+ 15.50
		5/90	DENT		114.00	HT	
133	101	5/90	DENT		114.00	HT	+ 18.30
42	101	5/90	DENT		114.00	HT	
46	101	5/90	DENT		114.00	HT	+ 24.30
70	101	5/90	DENT		114.00	HT	
92	101	5/90	DENT		114.00	HT	
94	101	5/90	DENT		114.00	HT	
96	101	5/90	DENT		114.00	HT	
98	101	5/90	DENT		114.00	HT	
100	101	5/90	DENT		114.00	HT	
102	101	5/90	DENT		114.00	HT	
108	101	5/90	DENT		114.00	HT	
122	103	5/90	INT		74.00	HT	
21	103	5/90	INT		74.00	HT	
43	103	5/90	DENT		74.00	HT	
45	103	5/90	DENT		47.70	HT	
91	103	5/90	DENT		47.70	HT	
93	103	5/90	DENT		73.60	HT	

Plant: CALVERT CLIFFS UNIT 1
 Outage: 5/90

Steam Generator 11

QUERY: ALL DENT INDICATIONS - ALL ELEVATIONS

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
95	103	5/90	DENT		29.93	H9	
97	103	5/90	DENT		61.13	H9	
99	103	5/90	DEJT		103.98	H9	
101	103	5/90	DCNT		103.70	H9	
103	103	5/90	DENT		33.95	H9	
105	103	5/90	DENT		54.40	H9	
107	103	5/90	DENT		103.96	H9	
92	104	5/90	DENT		103.79	H9	
94	104	5/90	DENT		103.90	H9	
96	104	5/90	DENT		86.40	H9	
98	104	5/90	DENT		62.23	H9	
102	104	5/90	DENT		5.17	H9	
106	104	5/90	DENT		61.74	H9	
91	105	5/90	DENT		5.20	H9	
		5/90	DENT		64.33	H9	
93	105	5/90	DENT		75.51	H9	
95	105	5/90	DENT		48.23	H9	
97	105	5/90	DENT		103.60	H9	
99	105	5/90	DENT		103.60	H9	
101	105	5/90	DENT		14.00	H9	
111	105	5/90	DENT		10.00	DC	
117	105	5/90	DENT		103.66	VM	
		5/90	DENT		18.00	H10	+ 3.20
119	105	5/90	DENT		21.31	H10	
121	105	5/90	DENT		19.60	H10	
123	105	5/90	DENT		7.33	H10	
125	106	5/90	DENT		11.15	C6	
92	106	5/90	DENT		44.05	H9	
94	106	5/90	DENT		49.07	H9	
96	106	5/90	DENT		13.04	H9	
98	106	5/90	DENT		13.79	H9	
120	106	5/90	DENT		9.11	C9	+13.60
		5/90	DENT		16.98	H10	
122	106	5/90	DENT		30.98	H10	
91	107	5/90	DENT		73.70	H9	
93	107	5/90	DENT		103.00	H9	
95	107	5/90	DENT		67.18	DC	
97	107	5/90	DENT		103.00	DC	+15.50
		5/90	DENT		44.00	H9	
99	107	5/90	DENT		44.00	H9	
101	107	5/90	DEJT		77.00	H9	
103	107	5/90	DENT		77.00	H9	
107	107	5/90	DSNT		11.00	H9	
123	107	5/90	DENT		103.00	H10	
92	108	5/90	DENT		145.00	H9	
94	108	5/90	DCNT		145.00	H9	
96	108	5/90	DENT		107.40	H9	
98	108	5/90	DENT		80.96	H9	
100	108	5/90	DENT		70.21	H9	
102	108	5/90	DENT		69.93	H9	
104	108	5/90	DENT		69.72	H9	
106	108	5/90	DENT		69.01	H9	
108	108	5/90	DENT		137.31	H9	
110	108	5/90	DENT		137.31	H10	
91	109	5/90	DENT		69.66	H9	
93	109	5/90	DENT		48.82	H9	
95	109	5/90	DENT		48.74	H9	
97	109	5/90	DENT		90.04	H9	
99	109	5/90	DENT		74.70	H9	
101	109	5/90	DENT		74.72	H9	
103	109	5/90	DENT		103.75	H9	
119	109	5/90	DENT		103.81	H10	
121	109	5/90	DENT		103.83	H10	
26	110	5/90	DENT		6.41	DC	
66	110	5/90	DENT		6.12	VM	
92	110	5/90	DENT		20.08	H9	
94	110	5/90	DENT		32.48	H9	+22.60

Plant: CALVERT CLIFFS UNIT 1
 Outage: 5/90

Steam Generator: 11

QUERY: ALL DENT INDICATIONS - ALL ELEVATIONS

ROW	LINE	OUTAGE	INDICATION	VALVE	VOLTS	LOCATION	INCHES
96	110	5/90	DENT		16.04	H9	
98	110	5/90	DENT		19.40	H9	
106	110	5/90	DENT		15.48	H9	
120	110	5/90	DENT		5.21	H9	+ 9.60
128	110	5/90	DENT		22.80	C1	+30.90
		5/90	DENT		17.49	H9	
91	111	5/90	DENT		48.78	H9	
93	111	5/90	DENT		51.04	H9	
95	111	5/90	DENT		34.18	H9	
103	111	5/90	DENT		7.33	C9	
		5/90	DENT		10.74	H9	
123	111	5/90	DENT		12.03	C10	
		5/90	DENT		7.19	H7	+ 8.80
30	112	5/90	DENT		7.36	C2	+11.00
92	112	5/90	DENT		20.74	H9	
94	112	5/90	DENT		43.90	H9	
96	112	5/90	DENT		22.27	H9	
98	112	5/90	DENT		16.06	H9	
102	112	5/90	DENT		23.79	H9	
120	112	5/90	DENT		58.50	H10	
122	112	5/90	DENT		18.62	H10	
69	113	5/90	DENT		5.04	VM	+24.40
83	113	5/90	DENT		6.00	H3	+31.50
91	113	5/90	DENT		43.30	H9	
93	113	5/90	DENT		94.15	H9	
95	113	5/90	DENT		31.50	H9	
97	113	5/90	DENT		95.18	H9	
99	113	5/90	DENT		138.30	H9	
101	113	5/90	DENT		63.92	H9	
103	113	5/90	DENT		54.64	H9	
105	113	5/90	DENT		48.97	H9	
117	113	5/90	DENT		46.18	H10	
121	113	5/90	DENT		50.69	H10	
123	113	5/90	DENT		56.16	H10	
8	114	5/90	DENT		10.04	C6	+ 6.40
12	114	5/90	DENT		17.18	C6	+ 9.90
		5/90	DENT		12.17	H6	+ 7.60
92	114	5/90	DENT		45.40	H9	
94	114	5/90	DENT		84.04	H9	
96	114	5/90	DENT		61.07	H9	
98	114	5/90	DENT		48.74	H9	
100	114	5/90	DENT		37.03	H9	
102	114	5/90	DENT		58.00	H9	
104	114	5/90	DENT		19.00	H9	
106	114	5/90	DENT		24.00	H9	
118	114	5/90	DENT		24.00	H10	
122	114	5/90	DENT		60.00	H10	
123	114	5/90	DENT		10.00	H10	+ 8.00
93	115	5/90	DENT		94.00	H9	
95	115	5/90	DENT		14.00	H9	
97	115	5/90	DENT		14.00	H9	
101	115	5/90	DENT		14.00	H9	
121	115	5/90	DENT		5.40	H10	
12	116	5/90	DENT		11.14	H6	+ 7.60
94	116	5/90	DENT		28.00	H9	
96	116	5/90	DENT		29.00	H9	
98	116	5/90	DENT		10.10	H9	
97	117	5/90	DENT		10.10	H9	
107	117	5/90	DENT		16.00	H9	
12	118	5/90	DENT		12.00	H6	+ 7.70
102	118	5/90	DENT		10.00	H9	
91	119	5/90	DENT		19.47	C9	+ 2.00
97	119	5/90	DENT		14.66	H9	
99	119	5/90	DENT		128.74	C9	
98	120	5/90	DENT		18.56	H9	
102	120	5/90	DENT		18.56	C9	

Plant: CALVERT CLIFFS UNIT 1
 Outage: 5/90

Steam Generator: 11

QUERY: ALL DENT INDICATIONS - ALL ELEVATIONS

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
106	120	5/90	DENT		37.886	H9	
69	1201	5/90	DENT		5.400	VM	+21.60
91	1201	5/90	DENT		10.488	CD	+7.30
		5/90	DENT		10.488	CD	+7.90
		5/90	DENT		10.488	CD	+8.30
93	1201	5/90	DENT		10.488	CD	+8.30
97	1201	5/90	DENT		14.000	HH	
105	1201	5/90	DENT		12.190	HH	
107	1201	5/90	DENT		40.000	HH	
109	1201	5/90	DENT		7.190	HH	+1.00
		5/90	DENT		7.190	HH	+1.00
		5/90	DENT		7.190	HH	+1.00
30	122	5/90	DENT		10.888	HH	+1.50
38	123	5/90	DENT		15.160	HH	+1.50
92	123	5/90	DENT		20.740	HH	+1.50
94	123	5/90	DENT		64.144	HH	+2.60
96	123	5/90	DENT		10.000	HH	
102	123	5/90	DENT		7.555	HH	+17.80
103	123	5/90	DENT		11.999	HH	+8.10
104	123	5/90	DENT		6.727	HH	+24.10
93	123	5/90	DENT		7.190	HH	+2.10
95	123	5/90	DENT		10.000	HH	
97	123	5/90	DENT		10.004	HH	+1.40
101	123	5/90	DENT		11.999	HH	
123	123	5/90	DENT		11.999	HH	
92	1234	5/90	DENT		11.999	HH	
94	1234	5/90	DENT		11.999	HH	
96	1234	5/90	DENT		11.999	HH	
98	1234	5/90	DENT		11.999	HH	+14.60
91	1235	5/90	DENT		11.999	HH	
93	1235	5/90	DENT		11.999	HH	
99	1235	5/90	DENT		11.999	HH	
121	1235	5/90	DENT		11.999	HH	+15.50
82	1236	5/90	DENT		11.999	HH	+15.00
		5/90	DENT		11.999	HH	+1.00
		5/90	DENT		11.999	HH	+10.20
		5/90	DENT		11.999	HH	+3.80
		5/90	DENT		11.999	HH	+15.40
		5/90	DENT		11.999	HH	+15.90
94	1236	5/90	DENT		11.999	HH	
92	1236	5/90	DENT		11.999	HH	
94	1236	5/90	DENT		11.999	HH	
96	1236	5/90	DENT		11.999	HH	
98	1236	5/90	DENT		11.999	HH	
67	1237	5/90	DENT		11.999	HH	+24.30
91	1237	5/90	DENT		11.999	HH	+2.00
93	1237	5/90	DENT		11.999	HH	
95	1237	5/90	DENT		11.999	HH	
97	1237	5/90	DENT		11.999	HH	
14	1238	5/90	DENT		11.999	HH	+9.00
92	1238	5/90	DENT		11.999	HH	
98	1238	5/90	DENT		11.999	HH	
110	1238	5/90	DENT		11.999	HH	
38	130	5/90	DENT		11.999	HH	
93	131	5/90	DENT		11.999	HH	+32.30

Plant: CALVERT CLIFFS UNIT 1
 Outage: 5/90

Steam Generator: 11

QUERY: ALL DENT INDICATIONS ~ ALL ELEVATIONS

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
92	132	5/90	DENT	140.86	H9		
6	134	5/90	DENT	134.19	C6		+ 6.00
		5/90	DENT	136.19	C6		+ 6.00
80	134	5/90	DENT	136.26	H8		+14.812
91	135	5/90	DENT	136.39	C9		
97	135	5/90	DENT	136.48	C9		
31	137	5/90	DENT	136.53	VM		
97	137	5/90	DENT	136.55	H9		
96	138	5/90	DENT	136.58	A9		
37	139	5/90	DENT	136.60	VM		
32	140	5/90	DENT	136.62	C4		+ 7.10
86	140	5/90	DENT	136.65	H5		+ 3.80
93	140	5/90	DENT	136.68	H9		
35	141	5/90	DENT	136.70	VM		
93	141	5/90	DENT	136.72	HTS-SF		+ 78.60
38	142	5/90	DENT	136.74	C4		+ 27.00
64	142	5/90	DENT	136.76	DH		
90	142	5/90	DENT	136.78	VM		
21	143	5/90	DENT	136.89	C4		+ 30.90
67	143	5/90	DENT	136.90	C7		+ 2.20
37	145	5/90	DENT	136.94	VM		+ 3.90
		5/90	DENT	136.97	VM		+ 1.80
85	147	5/90	DENT	137.03	H1		+22.80
4	148	5/90	DENT	137.07	VM		
		5/90	DENT	137.08	VM		
37	151	5/90	DENT	137.08	VM		
38	152	5/90	DENT	137.08	C6		+ 6.00
103	152	5/90	DENT	137.50	C6		+ 7.00
103	152	5/90	DENT	137.51	C6		+ 8.00
31	153	5/90	DENT	137.58	VM		
69	153	5/90	DENT	137.43	DC		+ 7.90
12	154	5/90	DENT	137.06	C6		+ 7.80
14	154	5/90	DENT	137.47	C6		+ 8.80
42	154	5/90	DENT	137.70	C7		
		5/90	DENT	137.70	C7		
		5/90	DENT	137.99	C6		+ 1.10
48	154	5/90	DENT	138.25	C6		+20.10
34	156	5/90	DENT	138.49	DM		+ 8.20
38	156	5/90	DENT	138.64	H2		+ 33.00
31	157	5/90	DENT	138.75	C9		
37	157	5/90	DENT	138.79	VM		+ 5.00
37	157	5/90	DENT	138.82	H7		+ 34.80
55	159	5/90	DENT	139.89	VM		
15	161	5/90	DENT	139.77	C6		+ 8.20
31	161	5/90	DENT	139.71	VM		

TOTAL TUBES FOUND = 786
 TOTAL INDICATIONS FOUND = 849

TOTAL TUBES IN INPUT FILE = 8519
 TOTAL TUBES INSPECTED = 8421

STEAM GENERATOR 11

F. List with Plot of Tubes Plugged
During May/June 1990

TUBES PLUGGED 5/90 OUTAGE

PLANT: CALVERT CLIFFS UNIT 1

OUTAGE: 5/90


1 = MECH-OE (0)
4 = CONST (0)

TOTAL TUBES : 8519
STAYS : 7

GENERATOR: 1#

2 = 244W (0)

TOTAL TUBES ASSIGNED : 9



Plant: CALVERT CLIFFS UNIT 1
 Outage: 5/90

Steam Generator: 11

QUERY OUTPUT

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
10	24	5/90	PLUGGED	MECH-W		HTS-PP	
		5/90	PLUGGED	MECH-W		CTS-PP	
60	60	5/90	PLUGGED	MECH-W		HTS-PP	
		5/90	PLUGGED	MECH-W		CTS-PP	
13	61	5/90	PLUGGED	MECH-W		HTS-PP	
		5/90	PLUGGED	MECH-W		CTS-PP	
129	71	5/90	PLUGGED	MECH-W		HTS-PP	
		5/90	PLUGGED	MECH-W		CTS-PP	
113	91	5/90	PLUGGED	MECH-W		HTS-PP	
		5/90	PLUGGED	MECH-W		CTS-PP	
139	83	5/90	PLUGGED	MECH-W		HTS-PP	
		5/90	PLUGGED	MECH-W		CTS-PP	
70	90	5/90	PLUGGED	MECH-W		HTS-PP	
		5/90	PLUGGED	MECH-W		CTS-PP	
51	113	5/90	PLUGGED	MECH-W		HTS-PP	
		5/90	PLUGGED	MECH-W		CTS-PP	
53	113	5/90	PLUGGED	MECH-W		HTS-PP	
		5/90	PLUGGED	MECH-W		CTS-PP	

TOTAL TUBES FOUND = 9
 TOTAL INDICATIONS FOUND = 18

TOTAL TUBES IN INPUT FILE = 8519
 TOTAL TUBES INSPECTED = 8421

STEAM GENERATOR 11

G. List with Part of all Tubes Plugged

ALL TUBES PLUGGED


PLANT: CALVERT CLIFFS UNIT 1
CUTAGES: 12/80 06/82 10/83 04/85 10/86 04/88 5/90

1 = MECH-DE (19)
4 = COHET (0)

TOTAL TUBES : 8519
STAYS : 7

2 = MECH-N (82)
3 = WELD-DE (86)

TOTAL TUBES ASSIGNED : 107



Plant: CALVERT CLIFFS UNIT 1
 Dutages: 12/80 06/82 10/83 04/85 10/P 04/86

Steam Generators: 11
 5/90

QUERY: ALL TUBES PLUGGED

ROW	LINE	DUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
39	5	10/86	PLUGGED	MECH-DE		HTS-1R	
		10/86	PLUGGED	MECH-DE		CTB-1R	
50	16	04/88	PLUGGED	MECH-W		HTS-1R	
		04/88	PLUGGED	MECH-W		CTB-1R	
95	23	06/82	PLUGGED	MECH-W	1.00	HTS-1R	
		06/82	PLUGGED	MECH-W		CTB-1R	
10	24	5/90	PLUGGED	MECH-W		HTS-1R	
		5/90	PLUGGED	MECH-W		CTB-1R	
101	27	10/86	PLUGGED	MECH-DE		HTS-1R	
		10/86	PLUGGED	MECH-DE		CTB-1R	
104	32	06/82	PLUGGED	MECH-W		HTS-1R	
		06/82	PLUGGED	MECH-W		CTB-1R	
27	33	04/88	PLUGGED	MECH-W		HTS-1R	
		04/88	PLUGGED	MECH-W		CTB-1R	
108	34	10/86	PLUGGED	MECH-DE		HTS-1R	
		10/86	PLUGGED	MECH-DE		CTB-1R	
120	48	06/82	PLUGGED	MECH-W		HTS-1R	
		06/82	PLUGGED	MECH-W		CTB-1R	
45	51	04/88	PLUGGED	MECH-W		HTS-1R	
		04/88	PLUGGED	MECH-W		CTB-1R	
46	52	04/88	PLUGGED	MECH-W		HTS-1R	
		04/88	PLUGGED	MECH-W		CTB-1R	
45	55	04/88	PLUGGED	MECH-W		HTS-1R	
		04/88	PLUGGED	MECH-W		CTB-1R	
50	56	04/88	PLUGGED	MECH-W		HTS-1R	
		04/88	PLUGGED	MECH-W		CTB-1R	
52	56	10/86	PLUGGED	MECH-DE		HTS-1R	
		10/86	PLUGGED	MECH-DE		CTB-1R	
54	56	04/88	PLUGGED	MECH-W		HTS-1R	
		04/88	PLUGGED	MECH-W		CTB-1R	
51	57	10/86	PLUGGED	MECH-DE		HTS-1R	
		10/86	PLUGGED	MECH-DE		CTB-1R	
53	57	10/86	PLUGGED	WELD-1000		HTS-1R	
		10/86	PLUGGED	WELD-1000		CTB-1R	
55	57	04/88	PLUGGED	MECH-12		HTS-1R	
		04/88	PLUGGED	MECH-12		CTB-1R	
59	57	04/88	PLUGGED	MECH-12		HTS-1R	
		04/88	PLUGGED	MECH-12		CTB-1R	
52	58	04/88	PLUGGED	MECH-12		HTS-1R	
		04/88	PLUGGED	MECH-12		CTB-1R	
54	58	04/88	PLUGGED	MECH-12		HTS-1R	
		04/88	PLUGGED	MECH-12		CTB-1R	
56	58	04/88	PLUGGED	MECH-12		HTS-1R	
		04/88	PLUGGED	MECH-12		CTB-1R	
60	60	5/90	PLUGGED	MECH-12		HTS-1R	
		5/90	PLUGGED	MECH-12		CTB-1R	
13	61	5/90	PLUGGED	MECH-12		HTS-1R	
		5/90	FLUGGED	MECH-12		CTB-1R	
135	61	06/82	PLUGGED	MECH-12		HTS-1R	
		06/82	PLUGGED	MECH-12		CTB-1R	
56	62	04/88	PLUGGED	MECH-12		HTS-1R	
		04/88	PLUGGED	MECH-12		CTB-1R	
114	62	10/86	PLUGGED	MECH-1200		HTS-1R	
		10/86	PLUGGED	MECH-1200		CTB-1R	
136	62	06/82	PLUGGED	MECH-12		HTS-1R	
		06/82	PLUGGED	MECH-12		CTB-1R	
135	63	06/82	PLUGGED	MECH-12		HTS-1R	
		06/82	PLUGGED	MECH-12		CTB-1R	
136	64	06/82	PLUGGED	MECH-12		HTS-1R	
		06/82	PLUGGED	MECH-12		CTB-1R	
137	65	06/82	PLUGGED	MECH-12		HTS-1R	
		06/82	PLUGGED	MECH-12		CTB-1R	
104	66	06/82	PLUGGED	MECH-12		HTS-1R	
		04/88	PLUGGED	MECH-12		CTB-1R	
134	66	06/82	PLUGGED	MECH-12		HTS-1R	
		06/82	PLUGGED	MECH-12		CTB-1R	
137	67	10/86	PLUGGED	MECH-DE		HTS-1R	

Plant: CALVERT CLIFFS UNIT 1
 Outages 12/80 06/87 10/83 04/85

10/86 04/88

Steam Generator 11
 5/90

QUERY: ALL TUY

AGED

C-100

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
136	68	10/86 04/88 04/88	PLUGGED PLUGGED PLUGGED	MECH-CE MECH-W MECH-W	HTS-PE	HTS-PE	HTS-PE
138	68	04/88 04/88	PLUGGED PLUGGED	MECH-W MECH-W	HTS-PE	HTS-PE	HTS-PE
129	71	5/90 5/90	PLUGGED PLUGGED	MECH-W MECH-W	HTS-PE	HTS-PE	HTS-PE
139	73	10/86 10/86	PLUGGED PLUGGED	MECH-CE MECH-CE	HTS-PE	HTS-PE	HTS-PE
139	75	04/88 04/88	PLUGGED PLUGGED	MECH-W MECH-W	HTS-PE	HTS-PE	HTS-PE
138	76	04/88 04/88	PLUGGED PLUGGED	MECH-W MECH-W	HTS-PE	HTS-PE	HTS-PE
139	77	10/86 10/86	PLUGGED PLUGGED	MECH-CE MECH-CE	HTS-PE	HTS-PE	HTS-PE
137	79	10/86 10/86	PLUGGED PLUGGED	MECH-CE MECH-CE	HTS-PE	HTS-PE	HTS-PE
138	80	04/85 04/85	PLUGGED PLUGGED	MECH-W MECH-W	HTS-PE	HTS-PE	HTS-PE
113	81	5/90 5/90	PLUGGED PLUGGED	MECH-W MECH-W	HTS-PE	HTS-PE	HTS-PE
139	81	04/85 04/85	PLUGGED PLUGGED	MECH-W MECH-W	HTS-PE	HTS-PE	HTS-PE
72	82	10/86 10/86	PLUGGED PLUGGED	WELD-CE WELD-CE	HTS-PE	HTS-PE	HTS-PE
140	82	04/85 04/85	PLUGGED PLUGGED	MECH-W MECH-W	HTS-PE	HTS-PE	HTS-PE
71	83	04/88 04/88	PLUGGED PLUGGED	MECH-W MECH-W	HTS-PE	HTS-PE	HTS-PE
139	83	5/90 5/90	PLUGGED PLUGGED	MECH-W MECH-W	HTS-PE	HTS-PE	HTS-PE
114	84	10/86 10/86	PLUGGED PLUGGED	MECH-CE MECH-CE	HTS-PE	HTS-PE	HTS-PE
120	84	06/82 06/82	PLUGGED PLUGGED	MECH-W MECH-W	HTS-PE	HTS-PE	HTS-PE
69	85	04/88 04/88	PLUGGED PLUGGED	MECH-W MECH-W	HTS-PE	HTS-PE	HTS-PE
75	85	04/88 04/88	PLUGGED PLUGGED	MECH-W MECH-W	HTS-PE	HTS-PE	HTS-PE
74	86	04/88 04/88	PLUGGED PLUGGED	MECH-W MECH-W	HTS-PE	HTS-PE	HTS-PE
75	87	04/88 04/88	PLUGGED PLUGGED	MECH-W MECH-W	HTS-PE	HTS-PE	HTS-PE
139	87	04/88 04/88	PLUGGED PLUGGED	MECH-W MECH-W	HTS-PE	HTS-PE	HTS-PE
74	88	04/88 04/88	PLUGGED PLUGGED	MECH-W MECH-W	HTS-PE	HTS-PE	HTS-PE
78	88	04/88 04/88	PLUGGED PLUGGED	MECH-W MECH-W	HTS-PE	HTS-PE	HTS-PE
71	89	04/88 04/88	PLUGGED PLUGGED	MECH-W MECH-W	HTS-PE	HTS-PE	HTS-PE
73	89	04/88 04/88	PLUGGED PLUGGED	MECH-W MECH-W	HTS-PE	HTS-PE	HTS-PE
75	89	04/85 04/85	PLUGGED PLUGGED	MECH-W MECH-W	HTS-PE	HTS-PE	HTS-PE
77	89	04/88 04/88	PLUGGED PLUGGED	MECH-W MECH-W	HTS-PE	HTS-PE	HTS-PE
79	89	04/88 04/88	PLUGGED PLUGGED	MECH-W MECH-W	HTS-PE	HTS-PE	HTS-PE
70	90	5/90 5/90	PLUGGED PLUGGED	MECH-W MECH-W	HTS-PE	HTS-PE	HTS-PE
72	90	04/88 04/88	PLUGGED PLUGGED	MECH-W MECH-W	HTS-PE	HTS-PE	HTS-PE
74	90	10/86 10/86	PLUGGED PLUGGED	WELD-CE MECH-W	HTS-PE	HTS-PE	HTS-PE
69	91	04/85 04/85	PLUGGED PLUGGED	MECH-W MECH-W	HTS-PE	HTS-PE	HTS-PE

Plant: CALVERT CLIFFS UNIT 1
 Outages: 12/80 06/82 10/83 04/85 10/86 04/86

Steam Generators: 11
 5/90

QUERY: ALL TUBES PLUGGED

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
73	91	04/85	PLUGGED	MECH-W	CTS-PP		
		04/85	PLUGGED	MECH-W	HTS-PP		
75	91	04/85	PLUGGED	MECH-W	CTS1-PP		
		04/85	PLUGGED	MECH-W	HTS1-PP		
77	91	10/86	PLUGGED	WELD-CE	HTS-PP		
		10/86	PLUGGED	WELD-CE	CTS-PP		
139	91	04/85	PLUGGED	MECH-W	CTS-PP		
		04/85	PLUGGED	MECH-W	HTS-PP		
70	92	04/86	PLUGGED	MECH-W	HTS1-PP		
		04/86	PLUGGED	MECH-W	CTB1-PP		
72	92	04/85	PLUGGED	MECH-W	CTB1-PP		
		04/85	PLUGGED	MECH-W	HTB1-PP		
74	92	04/86	PLUGGED	MECH-W	ETB1-PP		
		04/86	PLUGGED	MECH-W	UTB1-PP		
69	93	04/86	PLUGGED	MECH-W	ITB1-PP		
		04/86	PLUGGED	MECH-W	OTB1-PP		
71	93	04/86	PLUGGED	MECH-W	ETB1-PP		
		04/86	PLUGGED	MECH-W	CTB1-PP		
75	93	04/86	PLUGGED	MECH-W	HTB1-PP		
		04/86	PLUGGED	MECH-W	CTB1-PP		
52	94	10/86	PLUGGED	WELD-CE	ETB1-PP		
		10/86	PLUGGED	WELD-CE	CTS1-PP		
104	102	06/82	PLUGGED	MECH-W	CTS1-PP		
		06/82	PLUGGED	MECH-W	OTB1-PP		
134	102	06/82	PLUGGED	MECH-W	CTB1-PP		
		06/82	PLUGGED	MECH-W	ITB1-PP		
136	106	10/83	PLUGGED	MECH-W	ITB1-PP		
		10/83	PLUGGED	MECH-W	ITB1-PP		
134	108	04/86	PLUGGED	MECH-W	HTB1-PP		
		04/86	PLUGGED	MECH-W	OTB1-PP		
57	109	04/86	PLUGGED	MECH-W	ITB1-PP		
		04/86	PLUGGED	MECH-W	CTB1-PP		
52	110	04/86	PLUGGED	MECH-W	HTB1-PP		
		04/86	PLUGGED	MECH-W	OTB1-PP		
54	110	04/86	PLUGGED	MECH-W	HTB1-PP		
		04/86	PLUGGED	MECH-W	CTB1-PP		
51	111	04/86	PLUGGED	MECH-W	HTB1-PP		
		04/86	PLUGGED	MECH-W	OTB1-PP		
53	111	04/85	PLUGGED	MECH-W	HTB1-PP		
		04/85	PLUGGED	MECH-W	OTB1-PP		
51	113	5/90	PLUGGED	MECH-W	HTB1-PP		
		5/90	PLUGGED	MECH-W	OTB1-PP		
53	113	5/90	PLUGGED	MECH-W	HTB1-PP		
		5/90	PLUGGED	MECH-W	OTB1-PP		
106	118	10/86	PLUGGED	MECH-CE	ITB1-PP		
		10/86	PLUGGED	MECH-CE	CTB1-PP		
2	120	10/86	PLUGGED	MECH-CE	HTB1-PP		
		10/86	PLUGGED	MECH-CE	OTB1-PP		
120	120	06/82	PLUGGED	MECH-W	CTB1-PP		
		06/82	PLUGGED	MECH-W	ITB1-PP		
1	121	10/86	PLUGGED	MECH-CE	HTB1-PP		
		10/86	PLUGGED	MECH-CE	OTB1-PP		
3	121	10/86	PLUGGED	MECH-CE	ITB1-PP		
		10/86	PLUGGED	MECH-CE	CTB1-PP		
2	122	10/86	PLUGGED	MECH-CE	HTB1-PP		
		10/86	PLUGGED	MECH-CE	OTB1-PP		
1	123	10/86	PLUGGED	MECH-CE	ITB1-PP		
		10/86	PLUGGED	MECH-CE	CTB1-PP		
103	125	04/86	PLUGGED	MECH-W	OTB1-PP		
		04/86	PLUGGED	MECH-W	ITB1-PP		
70	128	10/86	PLUGGED	WELD-CE	HTB1-PP		
		10/86	PLUGGED	WELD-CE	OTB1-PP		
31	135	04/86	PLUGGED	MECH-W	HTB1-PP		
		04/86	PLUGGED	MECH-W	OTB1-PP		
104	136	06/82	PLUGGED	MECH-W	OTB1-PP		
		06/82	PLUGGED	MECH-W	ITB1-PP		
9	141	04/86	PLUGGED	MECH-W	CTB1-PP		

Plant: CALVERT CLIFFS UNIT 1
Dutages: 12/80 06/82 10/83 04/85

10/86 04/88

Steam Generators: 11
5/90

QUERY: ALL TUBES PLUGGED

ROW	LINE	DUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
		04/85	PLUGGED	MECH-W		HTS-PF	
99	143	10/83	PLUGGED	MECH-W		CTS-PF	
		10/83	PLUGGED	MECH-W		HTS-PF	
62	144	04/85	PLUGGED	MECH-W		CTS-PF	
		04/85	PLUGGED	MECH-W		HTS-PF	
96	144	10/83	PLUGGED	MECH-W		CTS-PF	
		10/83	PLUGGED	MECH-W		HTS-PF	
11	147	04/88	PLUGGED	MECH-W		HTS-PF	
		04/88	PLUGGED	MECH-W		CTS-PF	
11	153	10/86	PLUGGED	MECH-CE		HTS-PF	
		10/86	PLUGGED	MECH-CE		CTS-PF	
11	163	10/86	PLUGGED	MECH-CE		HTS-PF	
		10/86	PLUGGED	MECH-CE		CTS-PF	
TOTAL TUBES FOUND				=	107		
TOTAL INDICATIONS FOUND				=	214		

APPENDIX II

Eddy Current Test Results for SG 12

- A. List with Plot of All Indications
- B. List with Plot of <20% Indications
- C. List with Plot of 20% - 39% Indications
- D. List with Plot of >39% Indications
- E. List with Plot of Tubes Dented
- F. List with Plot of Tubes Plugged During May/June
1990
- G. List with Plot of all Tubes Plugged

STEAM GENERATOR 12

A. List with Plot of All Indications

All Eddy Current Indications - All Elevations

PLANT: CALVERT CLIFFS UNIT 1

OUTAGE: 5/90

GENERATOR: 12

1 = >39 (6)


2 = 20-39 (110)

3 = <20 (92)

TOTAL TUBES : 8519
STAYS (8) : 7

180 DEG

TOTAL TUBES ASSIGNED : 204



Plant: CALVERT CLIFFS UNIT 1
 Outage: 5/90

Steam Generator: 12

QUERY: All Eddy Current Indications - All Elev.tions

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
7	1	5/90	OD	8	%	TW	1.01 H4
37	7	5/90	OD	12	%	TW	0.64 H2
48	8	5/90	OD	17	%	TW	1.09 H5
3	9	5/90	OD	38	%	TW	1.17 C5
34	12	5/90	OD	31	%	TW	0.80 HTS-SF
35	15	5/90	OD	28	%	TW	0.48 HTS-SF
42	16	5/90	OD	13	%	TW	1.28 H1
44	18	5/90	OD	18	%	TW	0.57 H6
19	19	5/90	OD	7	%	TW	0.96 HTS-SF
83	1	5/90	OD	33	%	TW	1.15 H6
		5/90	OD	12	%	TW	0.83 H7
44	20	5/90	OD	22	%	TW	0.58 H2
		5/90	OD	24	%	TW	0.67 H5
64	20	5/90	OD	35	%	TW	0.74 H5
85	21	5/90	OD	11	%	TW	0.78 H5
64	24	5/90	OD	10	%	TW	0.56 H6
		5/90	OD	10	%	TW	0.72 H6
9	25	5/90	OD	38	%	TW	0.83 VM
19	25	5/90	OD	10	%	TW	0.94 HTS-SF
39	25	5/90	OD	4	%	TW	0.66 HTS-SF
3	31	5/90	OD	11	%	TW	0.73 HTS-SF
48	32	5/90	OD	36	%	TW	0.71 DH
27	33	5/90	OD	13	%	TW	0.73 H5
20	34	5/90	OD	22	%	TW	0.88 HTS-SF
96	34	5/90	OD	22	%	TW	0.99 C7
41	39	5/90	OD	44	%	TW	0.71 H6
30	40	5/90	OD	17	%	TW	1.72 HTS-SF
100	40	5/90	OD	92	%	TW	1.08 C5
29	41	5/90	OD	16	%	TW	0.78 HTS-SF
97	41	5/90	OD	38	%	TW	0.67 C5
2	42	5/90	OD	24	%	TW	0.51 HTS-SF
62	42	5/90	OD	26	%	TW	1.31 HTS-SF
2	44	5/90	OD	21	%	TW	1.03 HTS-SF
39	45	5/90	OD	19	%	TW	8.97 HTS-SF
73	45	5/90	OD	13	%	TW	0.54 H3
21	47	5/90	OD	19	%	TW	0.59 C3
41	49	5/90	OD	36	%	TW	0.38 HTS-SF
51	49	5/90	OD	26	%	TW	0.53 H4
53	49	5/90	OD	10	%	TW	0.63 C6
44	50	5/90	OD	16	%	TW	0.84 HTS-SF
84	50	5/90	OD	15	%	TW	3.92 HTS-SF
86	50	5/90	OD	15	%	TW	40.85 HTS-SF
47	51	5/90	OD	17	%	TW	1.34 VM
79	53	5/90	OD	26	%	TW	0.54 C4
53	55	5/90	OD	17	%	TW	0.80 H3
85	55	5/90	OD	11	%	TW	4.81 HTS-SF
47	57	5/90	OD	21	%	TW	0.53 HTS-SF
53	57	5/90	OD	24	%	TW	0.68 C3
79	57	5/90	OD	34	%	TW	0.81 C4
42	58	5/90	OD	38	%	TW	0.85 C5
48	58	5/90	OD	12	%	TW	0.72 C3
52	60	5/90	OD	22	%	TW	0.60 HTS-SF
35	61	5/90	OD	18	%	TW	0.66 HTS-SF
41	61	5/90	OD	25	%	TW	0.64 H2
69	61	5/90	OD	16	%	TW	0.43 H5
79	61	5/90	OD	19	%	TW	0.58 DH
95	61	5/90	OD	15	%	TW	1.47 H8
56	62	5/90	OD	37	%	TW	0.96 H7
60	62	5/90	OD	27	%	TW	2.23 HTS-SF
90	62	5/90	OD	26	%	TW	0.69 HTS-SF
17	63	5/90	OD	23	%	TW	0.81 C4
59	63	5/90	OD	29	%	TW	0.43 C2
87	63	5/90	OD	15	%	TW	0.88 HTS-SF
34	64	5/90	OD	12	%	TW	0.71 H7
60	64	5/90	OD	35	%	TW	0.58 H4
64	64	5/90	OD	37	%	TW	0.77 HTS-SF
		5/90	OD	24	%	TW	0.75 HTS-SF

Plant: CALVERT CLIFFS UNIT 1
 Outage: 5/90

Steam Generator: 12

QUERY: All Eddy Current Indications - All Elevations

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
78	64	5/90	OD	24	%	TW	0.94 C7
58	66	5/90	OD	13	%	TW	0.60 HTS-SF
64	68	5/90	OD	27	%	TW	0.47 HTS-SF
		5/90	OD	19	%	TW	0.79 HTS-SF
66	68	5/90	OD	15	%	TW	1.30 HTS-SF
106	68	5/90	OD	38	%	TW	0.69 H5
125	69	5/90	OD	16	%	TW	3.14 VC
70	70	5/90	OD	23	%	TW	0.53 HTS-SF
65	71	5/90	OD	13	%	TW	0.78 HTS-SF
71	71	5/90	OD	16	%	TW	0.82 HTS-SF
53	73	5/90	OD	23	%	TW	0.63 VM
95	73	5/90	OD	12	%	TW	2.23 VM
97	73	5/90	OD	19	%	TW	0.86 VM
72	74	5/90	OD	13	%	TW	0.90 HTS-SF
84	74	5/90	OD	34	%	TW	0.52 VH
133	75	5/90	OD	13	%	TW	0.89 VM
79	77	5/90	OD	22	%	TW	0.53 H1
70	78	5/90	OD	27	%	TW	0.83 HTS-SF
72	78	5/90	OD	45	%	TW	0.61 HTS-SF
76	78	5/90	OD	32	%	TW	1.35 HTS-SF
		5/90	OD	19	%	TW	1.19 HTS-SF
51	79	5/90	OD	38	%	TW	0.53 C4
71	79	5/90	OD	22	%	TW	0.77 HTS-SF
77	79	5/90	OD	15	%	TW	0.98 HTS-SF
79	79	5/90	OD	38	%	TW	0.71 C2
74	80	5/90	OD	48	%	TW	0.54 HTS-SF
78	80	5/90	OD	18	%	TW	1.09 C5
84	80	5/90	OD	29	%	TW	0.64 H3
43	81	5/90	OD	11	%	TW	0.69 HTS-SF
71	81	5/90	OD	10	%	TW	2.29 HTS-SF
77	81	5/90	OD	27	%	TW	1.72 HTS-SF
79	83	5/90	OD	22	%	TW	0.90 HTS-SF
83	83	5/90	OD	25	%	TW	1.75 HTS-SF
85	83	5/90	OD	7	%	TW	0.98 HTS-SF
97	83	5/90	OD	17	%	TW	0.99 H5
79	85	5/90	OD	8	%	TW	1.12 HTS-SF
81	85	5/90	OD	26	%	TW	1.49 HTS-SF
48	86	5/90	OD	12	%	TW	1.02 C3
76	86	5/90	OD	23	%	TW	1.009 HTS-SF
84	86	5/90	OD	17	%	TW	0.70 HTS-SF
51	87	5/90	OD	11	%	TW	0.50 C1
		5/90	OD	22	%	TW	0.62 C1
75	87	5/90	OD	27	%	TW	1.15 HTS-SF
77	67	5/90	OD	18	%	TW	2.00 HTS-SF
		5/90	OD	20	%	TW	0.83 HTS-SF
81	87	5/90	OD	32	%	TW	0.53 HTS-SF
78	88	5/90	OD	19	%	TW	1.36 HTS-SF
		5/90	OD	33	%	TW	0.52 HTS-SF
82	88	5/90	OD	26	%	TW	0.84 HTS-SF
104	88	5/90	OD	19	%	TW	0.67 VM
41	89	5/90	OD	38	%	TW	0.62 H1
73	89	5/90	OD	32	%	TW	1.32 HTS-SF
75	89	5/90	OD	21	%	TW	0.93 HTS-SF
72	90	5/90	OD	33	%	TW	0.57 HTS-SF
74	90	5/90	OD	18	%	TW	1.03 HTS-SF
		5/90	OD	10	%	TW	0.40 HTS-SF
80	90	5/90	OD	27	%	TW	0.57 HTS-SF
82	90	5/90	OD	26	%	TW	1.76 HTS-SF
100	90	5/90	OD	25	%	TW	1.27 H3
73	91	5/90	OD	12	%	TW	1.12 HTS-SF
75	91	5/90	OD	26	%	TW	1.72 HTS-SF
77	91	5/90	OD	24	%	TW	0.56 HTS-SF
79	91	5/90	OD	16	%	TW	0.80 HTS-SF
83	91	5/90	OD	31	%	TW	0.62 H6
		5/90	OD	37	%	TW	0.70 H7
70	92	5/90	OD	34	%	TW	0.81 HTS-SF
74	92	5/90	OD	21	%	TW	1.00 HTS-SF

Plant: CALVERT CLIFFS UNIT 1
 Outage: 5/90

Steam Generator: 12

QUERY: All Eddy Current Indications - All Elevations

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
79	93	5/90	OD	28	8	TW	+ 0.50
68	94	5/90	OD	293	8	TW	+ 0.60
70	94	5/90	OD	306	8	TW	+ 0.70
78	94	5/90	OD	308	8	TW	+ 2.10
80	94	5/90	OD	306	8	TW	+ 0.80
		5/90	OD	306	8	TW	+ 1.10
69	95	5/90	OD	306	8	TW	+ 1.40
68	96	5/90	OD	306	8	TW	+ 33.20
67	97	5/90	OD	306	8	TW	+ 2.10
69	97	5/90	OD	306	8	TW	+ 0.90
137	97	5/90	OD	306	8	TW	+ 0.60
68	98	5/90	OD	306	8	TW	+ 10.40
112	98	5/90	OD	306	8	TW	+ 0.60
35	99	5/90	OD	306	8	TW	+ 13.50
62	100	5/90	OD	306	8	TW	+ 1.00
66	100	5/90	OD	306	8	TW	+ 23.30
68	100	5/90	OD	306	8	TW	+ 1.40
70	100	5/90	OD	306	8	TW	+ 1.60
118	100	5/90	OD	306	8	TW	+ 1.30
62	102	5/90	OD	306	8	TW	+ 0.60
68	102	5/90	OD	306	8	TW	+ 0.80
70	102	5/90	OD	306	8	TW	+ 1.40
62	104	5/90	OD	306	8	TW	+ 1.40
58	106	5/90	OD	306	8	TW	+ 1.80
110	106	5/90	OD	306	8	TW	+ 1.70
57	107	5/90	OD	306	8	TW	+ 0.50
6	108	5/90	OD	306	8	TW	+ 0.10
16	108	5/90	OD	306	8	TW	+ 1.10
18	108	5/90	OD	306	8	TW	+ 2.50
60	108	5/90	OD	306	8	TW	+ 1.50
11	109	5/90	OD	306	8	TW	+ 1.00
10	110	5/90	OD	306	8	TW	+ 0.20
54	110	5/90	OD	306	8	TW	+ 10.50
70	110	5/90	OD	306	8	TW	+ 1.40
19	111	5/90	OD	306	8	TW	+ 0.90
25	111	5/90	OD	306	8	TW	+ 0.70
47	111	5/90	OD	306	8	TW	+ 37.70
81	111	5/90	OD	306	8	TW	+ 14.70
131	111	5/90	OD	306	8	TW	+ 0.90
38	112	5/90	OD	306	8	TW	+ 1.70
44	112	5/90	OD	306	8	TW	+ 1.10
23	113	5/90	OD	306	8	TW	+ 0.80
43	113	5/90	OD	306	8	TW	+ 0.80
47	113	5/90	OD	306	8	TW	+ 0.27
51	113	5/90	OD	306	8	TW	+ 0.74
55	113	5/90	OD	306	8	TW	+ 0.64
42	114	5/90	OD	306	8	TW	+ 0.75
78	114	5/90	OD	306	8	TW	+ 23.50
53	115	5/90	OD	306	8	TW	+ 1.90
42	116	5/90	OD	306	8	TW	+ 0.60
44	116	5/90	OD	306	8	TW	+ 3.80
52	116	5/90	OD	306	8	TW	+ 2.10
45	117	5/90	OD	306	8	TW	+ 0.90
47	117	5/90	OD	306	8	TW	+ 2.40
55	117	5/90	OD	306	8	TW	+ 1.30
38	118	5/90	OD	306	8	TW	+ 1.10
44	118	5/90	OD	306	8	TW	+ 2.50
53	119	5/90	OD	306	8	TW	+ 0.70
78	120	5/90	OD	306	8	TW	+ 17.80
11	127	5/90	OD	306	8	TW	+ 30.50
68	128	5/90	OD	306	8	TW	+ 0.90
27	129	5/90	OD	306	8	TW	+ 22.20
117	129	5/90	OD	306	8	TW	

Plant: CALVERT CLIFFS UNIT 1
 Outage: 5/90

Steam Generator: 12

QUERY: All Eddy Current Indications - All Elevations

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
26	130	5/90	OD	10	% TW	0.94 HTS-SF	+ 0 .90
70	134	5/90	OD	18	% TW	0.58 H5	+15 .30
13	135	5/90	OD	37	% TW	1.08 C5	+11 .80
31	137	5/90	OD	14	% TW	0.69 H1	+16 .10
5	139	5/90	OD	15	% TW	0.83 C4	+16 .60
21	145	5/90	OD	16	% TW	0.90 HTS-SF	+23 .50
14	146	5/90	OD	10	% TW	0.60 HTS-SF	+29 .40
48	146	5/90	OD	25	% TW	0.60 H2	+36 .60
22	148	5/90	OD	19	% TW	0.68 CTS-SF	+35 .90
32	148	5/90	OD	15	% TW	1.10 C6	+15 .20
6	150	5/90	OD	15	% TW	0.54 C2	+5 .20
70	150	5/90	OD	31	% TW	0.64 C3	+22 .50
8	152	5/90	OD	25	% TW	1.29 VM	
64	152	5/90	OD	25	% TW	0.60 DH	+26 .90
77	153	5/90	OD	11	% TW	1.31 H4	+31 .60
52	154	5/90	OD	10	% TW	0.78 C5	+26 .50
12	156	5/90	OD	13	% TW	0.97 C2	+25 .80
47	157	5/90	OD	27	% TW	0.71 H7	+9 .80
53	159	5/90	OD	24	% TW	0.93 C3	+23 .80

TOTAL TUBES FOUND = 204
 TOTAL INDICATIONS FOUND = 220

TOTAL TUBES IN INPUT FILE = 8519
 TOTAL TUBES INSPECTED = 8453

STEAM GENERATOR 12

B. List with Plot of <20% Indications

Less Than 20% Eddy Current Indications - All Elevations

PLANT: CALVERT CLIFFS UNIT 1

GENERATOR: 12


OUTAGE: 5/90

↓ = <20% (red)

TOTAL TUBES : 6519
STAYS (R) : 7

180 DEG

TOTAL TUBES ASSIGNED : 96



Plant: CALVERT CLIFFS UNIT 1
 Outage: 5/90

Steam Generator: 12

QUERY: Less Than 20% Eddy Current Indications - All Elevations

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
7	1	5/90	OD	8	.%	TW	1.01 H4
37	7	5/90	OD	12	.	TW	0.64 H2
48	8	5/90	OD	17	.	TW	.09 H5
42	16	5/90	OD	13	.	TW	.28 H1
44	18	5/90	OD	18	.	TW	.57 H6
19	19	5/90	OD	7	.	TW	.96 HTS-SF
83	19	5/90	OD	12	.	TW	0.83 H7
64	20	5/90	OD	9	.	TW	0.72 H5
64	24	5/90	OD	11	.	TW	0.56 H6
	5	5/90	OD	10	.	TW	0.72 H6
19	26	5/90	OD	10	.	TW	0.94 CTS-SF
39	26	5/90	OD	4	.	TW	0.66 CTS-SF
3	31	5/90	OD	11	.	TW	0.73 CTS-SF
27	33	5/90	OD	13	.	TW	0.73 H5
30	40	5/90	OD	17	.	TW	1.72 HTS-SF
29	41	5/90	OD	16	.	TW	0.78 HTS-SF
39	45	5/90	OD	19	.	TW	8.97 HTS-SF
73	45	5/90	OD	13	.	TW	0.54 H3
21	47	5/90	OD	19	.	TW	0.59 C3
53	49	5/90	OD	10	.	TW	0.63 C6
44	50	5/90	OD	16	.	TW	0.84 HTS-SF
84	50	5/90	OD	15	.	TW	39.27 HTS-SF
86	50	5/90	OD	15	.	TW	40.85 HTS-SF
47	51	5/90	OD	17	.	TW	1.34 VM
53	55	5/90	OD	17	.	TW	0.80 H3
85	55	5/90	OD	11	.	TW	4.81 HTS-SF
42	58	5/90	OD	12	.	TW	0.72 C3
52	60	5/90	OD	18	.	TW	0.68 HTS-SF
41	61	5/90	OD	16	.	TW	0.43 H5
79	61	5/90	OD	15	.	TW	1.47 H8
59	63	5/90	OD	15	.	TW	0.88 HTS-SF
87	63	5/90	OD	12	.	TW	0.71 H7
58	66	5/90	OD	13	.	TW	0.60 HTS-SF
64	68	5/90	OD	19	.	TW	0.79 HTS-SF
66	68	5/90	OD	15	.	TW	1.30 HTS-SF
125	69	5/90	OD	16	.	TW	3.14 VC
65	71	5/90	OD	13	.	TW	0.78 HTS-SF
71	71	5/90	OD	16	.	TW	0.82 HTS-SF
95	73	5/90	OD	12	.	TW	2.23 VM
97	73	5/90	OD	19	.	TW	0.86 VM
72	74	5/90	OD	13	.	TW	0.90 HTS-SF
133	75	5/90	OD	13	.	TW	0.89 VM
76	78	5/90	OD	19	.	TW	1.19 HTS-SF
77	79	5/90	OD	15	.	TW	0.98 HTS-SF
78	80	5/90	OD	15	.	TW	1.09 C5
43	81	5/90	OD	11	.	TW	0.69 HTS-SF
71	81	5/90	OD	10	.	TW	2.29 HTS-SF
85	83	5/90	OD	7	.	TW	0.98 HTS-SF
97	83	5/90	OD	17	.	TW	0.99 H5
79	85	5/90	OD	8	.	TW	1.12 HTS-SF
48	86	5/90	OD	12	.	TW	1.02 C3
84	86	5/90	OD	17	.	TW	0.70 HTS-SF
51	87	5/90	OD	11	.	TW	0.50 C1
77	87	5/90	OD	18	.	TW	2.00 HTS-SF
78	88	5/90	OD	19	.	TW	1.36 HTS-SF
104	88	5/90	OD	19	.	TW	0.67 VM
74	90	5/90	OD	18	.	TW	1.03 HTS-SF
	5	5/90	OD	18	.	TW	0.40 HTS-SF
73	91	5/90	OD	13	.	TW	1.12 HTS-SF
79	91	5/90	OD	12	.	TW	0.80 HTS-SF
69	97	5/90	OD	16	.	TW	1.29 HTS-SF
68	98	5/90	OD	8	.	TW	3.37 HTS-SF
112	98	5/90	OD	18	.	TW	1.83 H6
35	99	5/90	OD	10	.	TW	0.75 C4
68	100	5/90	OD	15	.	TW	1.29 HTS-SF
68	102	5/90	OD	11	.	TW	1.14 HTS-SF
58	106	5/90	OD	15	.	TW	0.75 HTS-SF

Plant: CALVERT CLIFFS UNIT 1
 Outage: 5/90

Steam Generator: 12

QUERY: Less Than 20% Eddy Current Indications - All Elevations

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
6	108	5/90	OD	18 % TW	0.77	HTS-SF	+ 0.90
16	108	5/90	OD	12 % TW	0.51	HTS-SF	+ 1.10
60	108	5/90	OD	15 % TW	1.78	HTS-SF	+ 2.50
54	110	5/90	OD	13 % TW	0.71	HTS-SF	+ 2.20
70	110	5/90	OD	10 % TW	0.65	H2	+ 10.50
25	111	5/90	OD	8 % TW	0.98	HTS-SF	+ 0.90
47	111	5/90	OD	18 % TW	0.43	HTS-SF	+ 0.70
38	112	5/90	OD	7 % TW	1.02	HTS-SF	+ 0.90
44	112	5/90	OD	11 % TW	0.45	HTS-SF	+ 1.70
23	113	5/90	OD	11 % TW	0.78	HTS-SF	+ 1.10
43	113	5/90	OD	8 % TW	0.89	HTS-SF	+ 2.00
47	113	5/90	OD	12 % TW	1.27	HTS-SF	+ 0.50
51	113	5/90	OD	12 % TW	0.74	HTS-SF	+ 2.80
78	114	5/90	OD	10 % TW	1.02	VH	+ 23.50
53	115	5/90	OD	19 % TW	0.60	HTS-SF	+ 1.90
44	116	5/90	OD	12 % TW	0.80	HTS-SF	+ 3.80
52	116	5/90	OD	17 % TW	0.77	HTS-SF	+ 2.10
45	117	5/90	OD	17 % TW	0.49	HTS-SF	+ 2.40
55	117	5/90	OD	13 % TW	1.46	HTS-SF	+ 1.30
38	118	5/90	OD	7 % TW	0.73	HTS-SF	+ 1.10
53	119	5/90	OD	4 % TW	0.71	HTS-SF	+ 0.70
11	127	5/90	OD	12 % TW	1.00	DH	
26	130	5/90	OD	10 % TW	0.94	HTS-SF	+ 0.90
70	134	5/90	OD	18 % TW	0.58	H5	+ 15.30
5	139	5/90	OD	15 % TW	0.83	C4	+ 15.60
21	145	5/90	OD	16 % TW	0.90	HTS-SF	+ 23.50
14	146	5/90	OD	10 % TW	0.60	HTS-SF	+ 29.40
22	148	5/90	OD	19 % TW	0.68	CTS-SF	+ 35.90
32	148	5/90	OD	15 % TW	1.10	C6	+ 15.20
6	150	5/90	OD	15 % TW	0.54	C2	+ 5.20
77	153	5/90	OD	11 % TW	1.31	H4	+ 31.20
52	154	5/90	OD	10 % TW	0.78	C5	+ 26.50
12	156	5/90	OD	13 % TW	0.97	C2	+ 25.80

TOTAL TUBES FOUND = 98
 TOTAL INDICATIONS FOUND = 100

TOTAL TUBES IN INPUT FILE = 8519
 TOTAL TUBES INSPECTED = 8453

STEAM GENERATOR 12

C. List with Plot of 20% - 39% Indications

20-30% Eddy Current Indications - All Elevations


PLANT: CALVERT CLIFFS UNIT 1

OUTAGE: 5/90

↓ = 20-39 (110)

TOTAL TUBES : 8519
STAYS (θ) : 7

TOTAL TUBES ASSIGNED : 110



Plant: CALVERT CLIFFS UNIT 1
Outage: 5/90

Steam Generator: 12

QUERY: 20-30% Eddy Current Indications - All Elevations

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
3	9	5/90	OD	38	1.17	C5	+ 4.10
34	1	5/90	OD	31	0.80	HTS-SF	+ 30.40
35	1	5/90	OD	38	0.48	HTS-SF	+ 2.90
83	1	5/90	OD	38	1.15	H6	+ 21.90
44	21	5/90	OD	38	0.58	H2	+ 20.30
85	25	5/90	OD	38	0.67	H5	+ 12.70
9	25	5/90	OD	38	0.78	H5	+ 10.90
48	44	5/90	OD	38	0.71	DH	+ 6.00
20	44	5/90	OD	38	0.88	HTS-SF	+ 33.70
96	44	5/90	OD	38	0.99	C7	+ 1.40
41	44	5/90	OD	38	0.71	H6	+ 1.90
100	44	5/90	OD	38	1.08	C5	+ 1.40
97	44	5/90	OD	38	0.67	CTS-SF	+ 2.10
6	44	5/90	OD	38	1.31	CTS-SF	+ 0.50
41	44	5/90	OD	38	1.03	CTS-SF	+ 0.50
51	44	5/90	OD	38	0.38	HTS-SF	+ 0.80
79	44	5/90	OD	38	0.53	H4	+ 24.70
47	44	5/90	OD	38	0.54	C4	+ 25.50
63	44	5/90	OD	38	0.68	HTS-SF	+ 1.50
79	57	5/90	OD	38	0.85	C5	+ 22.40
48	58	5/90	OD	38	0.68	HTS-SF	+ 20.80
35	61	5/90	OD	38	0.64	H2	+ 1.50
69	61	5/90	OD	38	0.58	DH	+ 0.90
95	61	5/90	OD	38	0.96	H7	+ 0.60
56	62	5/90	OD	38	2.33	HTS-SF	+ 1.30
60	62	5/90	OD	38	0.69	HTS-SF	+ 24.70
90	62	5/90	OD	38	0.81	C4	+ 22.60
17	63	5/90	OD	38	0.43	C2	+ 1.00
34	64	5/90	OD	38	0.58	H4	+ 1.70
60	64	5/90	OD	38	0.77	HTS-SF	+ 0.60
64	64	5/90	OD	38	0.75	HTS-SF	+ 0.70
78	64	5/90	OD	38	0.94	C7	+ 0.60
64	68	5/90	OD	38	0.47	HTS-SF	+ 0.70
106	68	5/90	OD	38	0.69	H5	+ 22.10
70	70	5/90	OD	38	0.53	HTS-SF	+ 1.10
53	73	5/90	OD	38	0.63	VM	+ 11.00
84	74	5/90	OD	38	0.52	VH	+ 20.40
79	77	5/90	OD	38	0.53	H1	+ 6.60
70	78	5/90	OD	38	0.83	HTS-SF	+ 0.70
76	78	5/90	OD	38	1.35	HTS-SF	+ 0.80
51	79	5/90	OD	38	0.53	C4	+ 6.70
71	79	5/90	OD	38	0.77	HTS-SF	+ 1.10
79	79	5/90	OD	38	0.71	C2	+ 16.30
84	80	5/90	OD	38	0.64	H3	+ 34.90
77	81	5/90	OD	38	1.72	HTS-SF	+ 1.60
79	83	5/90	OD	38	0.90	HTS-SF	+ 2.50
83	83	5/90	OD	38	1.75	HTS-SF	+ 0.80
81	85	5/90	OD	38	1.49	HTS-SF	+ 0.50
76	86	5/90	OD	38	1.09	HTS-SF	+ 27.90
51	87	5/90	OD	38	0.62	C1	+ 1.50
75	87	5/90	OD	38	1.15	HTS-SF	+ 1.50
77	87	5/90	OD	38	0.85	HTS-SF	+ 1.70
81	87	5/90	OD	38	0.55	HTS-SF	+ 1.50
78	88	5/90	OD	38	0.85	HTS-SF	+ 1.10
82	88	5/90	OD	38	0.84	HTS-SF	+ 1.30
41	89	5/90	OD	38	0.67	H1	+ 20.40
73	89	5/90	OD	38	1.32	HTS-SF	+ 1.00
75	90	5/90	OD	38	0.93	HTS-SF	+ 1.10
80	90	5/90	OD	38	0.57	H3	+ 0.70
82	90	5/90	OD	38	1.72	HTS-SF	+ 29.40
1	91	5/90	OD	38	1.72	HTS-SF	+ 1.50

Plant: CALVERT CLIFFS UNIT 1
 Outage: 5/90

Steam Generator: 12

QUERY: 20-30% Eddy Current Indications - All Elevations

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
77	91	5/90	OD	24	0.56	HTS-SF	+ 2.70
83	91	5/90	OD	31	0.62	H5	+ 21.30
		5/90	OD	37	0.70	H7	+ 13.20
70	92	5/90	OD	34	0.81	HTS-SF	+ 1.20
74	92	5/90	OD	21	1.00	HTS-SF	+ 1.70
		5/90	OD	28	1.13	HTS-SF	+ 0.50
79	93	5/90	OD	23	1.49	HTS-SF	+ 0.60
68	94	5/90	OD	26	1.78	HTS-SF	+ 0.70
70	94	5/90	OD	28	0.35	HTS-SF	+ 2.10
78	94	5/90	OD	26	1.36	HTS-SF	+ 0.80
80	94	5/90	OD	22	0.81	HTS-SF	+ 1.10
		5/90	OD	24	0.57	HTS-SF	+ 1.80
		5/90	OD	25	0.49	HTS-SF	+ 1.40
69	95	5/90	OD	25	1.13	H5	+ 33.20
68	96	5/90	OD	25	0.57	HTS-SF	+ 2.10
67	97	5/90	OD	28	0.80	HTS-SF	+ 0.90
137	97	5/90	OD	28	1.14	C10	+ 10.40
62	100	5/90	OD	21	0.92	HTS-SF	+ 1.00
66	100	5/90	OD	26	0.84	C3	+ 23.30
		5/90	OD	27	0.88	HTS-SF	+ 1.40
70	100	5/90	OD	28	0.79	H5-SF	+ 1.30
		5/90	OD	28	1.02	HTS-SF	+ 0.50
118	100	5/90	OD	28	0.52	VM	+ 8.20
62	102	5/90	OD	28	1.19	HTS-SF	+ 0.60
70	102	5/90	OD	28	0.78	HTS-SF	+ 1.40
62	104	5/90	OD	29	1.53	HTS-SF	+ 1.40
110	106	5/90	OD	29	0.68	H7	+ 17.10
57	107	5/90	OD	29	2.55	HTS-SF	+ 0.70
18	108	5/90	OD	28	0.25	HTS-SF	+ 1.10
11	109	5/90	OD	28	1.03	HTS-SF	+ 1.50
10	110	5/90	OD	29	0.86	HTS-SF	+ 0.70
19	111	5/90	OD	29	0.76	HTS-SF	+ 1.40
81	111	5/90	OD	29	1.29	HTS-SF	+ 37.90
131	111	5/90	OD	29	0.54	C8	+ 14.70
55	113	5/90	OD	29	0.84	HTS-SF	+ 0.80
42	114	5/90	OD	29	0.75	H1	+ 8.80
42	116	5/90	OD	29	1.01	HTS-SF	+ 0.60
47	117	5/90	OD	29	0.86	HTS-SF	+ 0.90
44	118	5/90	OD	29	0.83	HTS-SF	+ 0.50
78	120	5/90	OD	29	0.72	H2	+ 17.80
68	128	5/90	OD	29	1.08	C4	+ 30.50
27	129	5/90	OD	21	0.80	HTS-SF	+ 0.90
117	129	5/90	OD	26	0.64	HTS-SF	+ 22.20
13	135	5/90	OD	27	1.08	C5	+ 11.80
31	137	5/90	OD	24	0.69	H1	+ 2.10
48	146	5/90	OD	25	0.60	H2	+ 25.60
70	150	5/90	OD	21	0.64	C3	+ 23.50
8	152	5/90	OD	25	1.29	VM	+ 26.90
64	152	5/90	OD	25	0.60	DH	+ 9.80
47	157	5/90	OD	27	0.71	H7	+ 23.80
53	159	5/90	OD	24	0.93	C3	

TOTAL TUBES FOUND = 110
 TOTAL INDICATIONS FOUND = 118

TOTAL TUBES IN INPUT FILE = 8519
 TOTAL TUBES INSPECTED = 8453

STEAM GENERATOR 12

D. List with Plot of >39% Indications

Eddy Current Indications 40% And Greater Thru Wall - All Elevations

PLANT: CALVERT CLIFFS UNIT 1

GENERATOR: 12


OUTAGE: 5/90

1 = >39 [2]

TOTAL TUBES : 8519
STAYS : 7

TOTAL TUBES ASSIGNED : 2

130 DEG



Plant: CALVERT CLIFFS UNIT 1
Outage: 5/90

Steam Generator: 12

QUERY: Eddy Current Indications 40% And Greater Thru Wall - All Elevations

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
72	78	5/90	OD	45	% TW	0.61	HTS-SF + 0.90
74	80	5/90	OD	48	% TW	0.54	HTS-SF + 1.00
TOTAL TUBES FOUND				=	3		
TOTAL INDICATIONS FOUND				=	2		
TOTAL TUBES IN INPUT FILE				=	8519		
TOTAL TUBES INSPECTED				=	8453		

STEAM GENERATOR 12

E. List with Plot of Tubes Dented

All Dent Indications - All Levels

PLANT: CALVERT CLIFFS UNIT 1

GENERATOR: 12

OUTAGE: 5/90

1 = >49.99 (558)
4 = 20.00-29.99 (80)
7 = 5.00-9.99 (154)

2 = 40.00-49.99 (101)
5 = 15.00-19.99 (53)
8 = <5.00 (3)

10 = 30.00-39.99 (104)
0 = 10.00-14.99 (74)

TOTAL TUBES : 8519
STAYS (0) : 7


TOTAL TUBES ASSIGNED : 1127

270 DEG

-140
-135
-130
-125
-120
-115
-110
-105
-100
-95
-90
-85
-80
-75
-70
-65
-60
-55
-50
-45
-40
-35
-30
-25
-20
-15
-10
-5
0

HOT NARROW

<-- HOTWIDE -->



Plant: CALVERT CLIFFS UNIT 1
 Outage: 5/90

Steam Generator: 12

QUERY: All Dent Indications - All Elevations

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
10		5/90	DENT		9.41	H5	+11.20
14		5/90	DENT		5.00	H4	+5.60
20		5/90	DENT		5.34	H5	+17.10
32	4	5/90	DENT		5.34	CTS-SF	+18.50
15	7	5/90	DENT		20.25	H6	+8.70
42	12	5/90	DENT		6.23	DC	
132	17	5/90	DENT		5.32	H6	+20.40
137	17	5/90	DENT		9.50	C6	+7.50
17	17	5/90	DENT		5.43	H1	+12.70
76	18	5/90	DENT		5.67	VM	-1.80
13	19	5/90	DENT		6.66	VH	+16.90
562	20	5/90	DENT		9.36	C6	+7.50
155	21	5/90	DENT		6.99	DH	+5.60
67	21	5/90	DENT		10.11	H7	+24.30
42	24	5/90	DENT		8.03	H8	
13	25	5/90	DENT		10.27	C6	+23.80
76	26	5/90	DENT		11.64	C6	+25.30
13	27	5/90	DENT		6.00	C7	
25	27	5/90	DENT		8.98	C6	+7.70
67	27	5/90	DENT		5.65	VH	+16.10
82	28	5/90	DENT		10.63	C6	+7.80
90	30	5/90	DENT		8.55	C6	+0.90
11	31	5/90	DENT		8.33	H7	+19.20
43	31	5/90	DENT		13.94	H7	+22.40
69	32	5/90	DENT		10.36	VM	
46	32	5/90	DENT		6.62	VM	+7.20
82	32	5/90	DENT		10.08	C7	+12.10
90	32	5/90	DENT		14.21	C7	+13.60
11	33	5/90	DENT		17.01	C7	+14.80
43	33	5/90	DENT		5.74	H4	+31.20
69	34	5/90	DENT		12.60	C1	+29.60
46	34	5/90	DENT		10.19	DC	
82	34	5/90	DENT		5.13	VM	
90	34	5/90	DENT		8.94	CTS-SF	+24.90
11	35	5/90	DENT		11.77	H7	+20.50
46	35	5/90	DENT		6.35	H6	+19.40
82	35	5/90	DENT		7.27	H6	+20.30
90	35	5/90	DENT		30.00	H5	+21.60
11	36	5/90	DENT		6.17	H7	+0.90
46	36	5/90	DENT		11.76	C7	
82	36	5/90	DENT		15.74	H7	+22.80
90	36	5/90	DENT		13.51	H7	+15.80
11	37	5/90	DENT		10.00	H7	+14.00
46	37	5/90	DENT		6.46	C7	+16.80
92	38	5/90	DENT		4.46	C9	
77	38	5/90	DENT		5.37	C3	+36.30
52	38	5/90	DENT		39.92	CTS-SF	+28.50
94	38	5/90	DENT		39.48	H9	
100	38	5/90	DENT		7.15	H4	+35.40
9	39	5/90	DENT		5.48	VM	
29	39	5/90	DENT		10.08	H3	
30	39	5/90	DENT		16.41	H9	
92	39	5/90	DENT		22.11	H9	
94	39	5/90	DENT		16.36	H9	
98	39	5/90	DENT		22.04	C6	+14.50
37	39	5/90	DENT		16.03	C6	+5.10
77	39	5/90	DENT		17.04	C6	+3.60
91	39	5/90	DENT		9.03	C6	+23.30
95	39	5/90	DENT		8.87	C7	
97	39	5/90	DENT		71.95	H9	
92	39	5/90	DENT		30.34	H9	
94	39	5/90	DENT		33.00	H9	
9	39	5/90	DENT		88.85	H9	
100	39	5/90	DENT		74.17	H9	
9	39	5/90	DENT		24.74	H9	
100	39	5/90	DENT		31.57	H9	

Plant: CALVERT CLIFFS UNIT 1
Outage: 5/90

Steam Generator: 12

QUERY: All Dent Indications - All Elevations

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
21	39	5/90	DENT		7.8	VM	+ 6.40
91	39	5/90	DENT		57.5	H9	
93	39	5/90	DENT		152.0	H9	
95	39	5/90	DENT		160.0	H9	
97	39	5/90	DENT		60.0	H9	
99	39	5/90	DENT		40.5	H9	
109	39	5/90	DENT		125.1	H9	
92	40	5/90	DENT		116.7	H9	
94	40	5/90	DENT		100.0	H9	
96	40	5/90	DENT		90.0	H9	
98	40	5/90	DENT		70.0	H9	
100	40	5/90	DENT		40.0	H9	
108	40	5/90	DENT		130.0	H9	
1	41	5/90	DENT		12.6	HTS-SF	+17.00
91	41	5/90	DENT		111.1	H9	
93	41	5/90	DENT		72.4	H9	
99	41	5/90	DENT		76.9	H9	
109	41	5/90	DENT		16.3	H9	
78	42	5/90	DENT		9.4	H7	+21.90
		5/90	DENT		9.4	C7	+11.40
		5/90	DENT		6.6	C7	+17.20
		5/90	DENT		6.6	C8	+ 2.10
92	42	5/90	DENT		135.5	H9	
94	42	5/90	DENT		130.5	H9	
96	42	5/90	DENT		81.5	H9	
100	42	5/90	DENT		34.3	H9	
106	42	5/90	DENT		6.3	C3	
71	43	5/90	DENT		12.1	VM	
91	43	5/90	DENT		10.1	H9	
93	43	5/90	DENT		9.7	C8	+15.90
95	43	5/90	DENT		28.8	H9	
97	43	5/90	DENT		10.4	C9	+ 2.00
99	43	5/90	DENT		114.2	H9	
101	43	5/90	DENT		102.1	H9	
107	43	5/90	DENT		47.2	H9	
109	43	5/90	DENT		31.4	H9	
111	43	5/90	DENT		18.1	H9	
113	43	5/90	DENT		46.3	H9	
92	44	5/90	DENT		30.3	H9	
94	44	5/90	DENT		44.0	H9	
96	44	5/90	DENT		46.0	H9	
98	44	5/90	DENT		10.6	H9	
100	44	5/90	DENT		74.8	H9	
102	44	5/90	DENT		10.5	H9	
104	44	5/90	DENT		8.8	H9	
110	44	5/90	DENT		71.5	H9	
93	45	5/90	DENT		98.9	H9	
95	45	5/90	DENT		21.5	H9	
97	45	5/90	DENT		70.0	H9	
99	45	5/90	DENT		56.0	H9	
103	45	5/90	DENT		56.0	H9	
105	45	5/90	DENT		56.0	H9	
109	45	5/90	DENT		70.0	H9	
111	45	5/90	DENT		65.3	H9	
113	45	5/90	DENT		33.0	H9	
48	46	5/90	DENT		16.1	H7	
92	46	5/90	DENT		54.0	H9	
94	46	5/90	DENT		113.8	H9	+ 5.00
96	46	5/90	DENT		7.9	C7	
98	46	5/90	DENT		73.1	H9	
100	46	5/90	DENT		103.9	H9	
102	46	5/90	DENT		93.9	H9	
108	46	5/90	DENT		73.5	H9	
91	47	5/90	DENT		43.2	H9	

Plant: CALVERT CLIFFS UNIT 1
 Outage: 5/90

Steam Generator: 1A

QUERY: All Dent Indications - All Elevations

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
93	47	5/90	DENT	6.73	C9		
95	47	5/90	DENT	104.20	H9		
97	47	5/90	DENT	107.20	H9		
99	47	5/90	DENT	69.62	H9		
101	47	5/90	DENT	15.92	H9		
103	47	5/90	DENT	25.56	H9		
105	47	5/90	DENT	73.85	H9		
107	47	5/90	DENT	35.49	H9		
109	47	5/90	DENT	35.06	H9		
96	48	5/90	DENT	87.42	H9		
98	48	5/90	DENT	90.61	H9		
100	48	5/90	DENT	8.80	C7		+21.50
		5/90	DENT	5.99	C9		
102	49	5/90	DENT	17.02	H9		
104	49	5/90	DENT	16.17	H9		
106	49	5/90	DENT	10.36	H9		
108	49	5/90	DENT	35.99	H9		
110	49	5/90	DENT	33.99	H9		
29	49	5/90	DENT	7.49	H9		
67	49	5/90	DENT	3.58	VM		
		5/90	DENT	7.50	H7		+10.30
		5/90	DENT	4.14	H7		+11.20
		5/90	DENT	28.29	H7		+25.00
		5/90	DENT	54.28	H8		+1.70
69	49	5/90	DENT	9.03	DH		+14.80
93	49	5/90	DENT	93.64	H9		
95	49	5/90	DENT	11.59	H9		
97	49	5/90	DENT	94.65	H9		
99	49	5/90	DENT	88.73	H9		
101	49	5/90	DENT	31.31	H9		
103	49	5/90	DENT	47.31	H9		
105	49	5/90	DENT	32.34	H9		
107	49	5/90	DENT	27.17	H9		
109	49	5/90	DENT	23.86	H9		
111	49	5/90	DENT	16.96	H9		
94	50	5/90	DENT	12.41	C7		+25.10
		5/90	DENT	12.41	C8		+10.00
96	50	5/90	DENT	16.34	C8		
98	50	5/90	DENT	95.84	H9		
100	50	5/90	DENT	13.70	H9		
		5/90	DENT	11.56	C9		
102	50	5/90	DENT	124.68	H9		
104	50	5/90	DENT	61.18	H9		
106	50	5/90	DENT	68.65	H9		
108	50	5/90	DENT	57.43	H9		
110	50	5/90	DENT	94.94	H9		
21	51	5/90	DENT	6.93	VM		+ 5.40
91	51	5/90	DENT	7.32	H5		+15.10
93	51	5/90	DENT	78.90	H9		
95	51	5/90	DENT	40.17	H9		
97	51	5/90	DENT	77.54	H9		
99	51	5/90	DENT	13.01	H9		
103	51	5/90	DENT	79.98	H9		
105	51	5/90	DENT	75.18	H9		
107	51	5/90	DENT	10.79	H5		+ 8.90
		5/90	DENT	68.57	H9		+ 6.60
109	51	5/90	DENT	9.88	C8		
111	51	5/90	DENT	125.90	H9		
129	51	5/90	DENT	46.48	H9		
14	52	5/90	DENT	5.79	H2		+19.60
52	52	5/90	DENT	11.19	C6		+ 8.50
92	52	5/90	DENT	5.74	H6		+13.80
94	52	5/90	DENT	8.82	H6		+22.60
		5/90	DENT	67.34	H9		
		5/90	DENT	160.90	H9		

Plant: CALVERT CLIFFS UNIT 1
Outage: 5/90

Steam Generator: 12

QUERY: All Dent Indications - All Elevations

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
96	5/90	5/90	DENT	135.90	H9		
98	5/90	5/90	DENT	41.55	H9		
		5/90	DENT	10.29	H9		+ 1.20
		5/90	DENT	8.46	C9		+ 0.60
		5/90	DENT	12.56	C9		- 0.30
		5/90	DENT	20.17	C8		+ 20.60
		5/90	DENT	23.03	C8		+ 19.20
		5/90	DENT	16.29	C8		+ 17.70
		5/90	DENT	5.79	C8		+ 16.00
100		5/90	DENT	97.01	H9		+ 1.20
102		5/90	DENT	129.53	H9		
104		5/90	DENT	120.50	H9		
106		5/90	DENT	125.10	H9		
108		5/90	DENT	77.66	H9		
110		5/90	DENT	104.00	H9		
112		5/90	DENT	53.52	H9		
120		5/90	DENT	7.33	H9		
1		5/90	DENT	30.66	VM		
35		5/90	DENT	16.99	C6		+ 13.50
43		5/90	DENT	5.22	VM		
91		5/90	DENT	37.58	H9		
93		5/90	DENT	140.70	H9		
95		5/90	DENT	169.10	H9		
97		5/90	DENT	94.03	H9		
99		5/90	DENT	66.99	H9		
101		5/90	DENT	43.80	H9		
103		5/90	DENT	51.25	H9		
105		5/90	DENT	138.20	H9		
107		5/90	DENT	38.77	H9		
109		5/90	DENT	43.95	H9		
111		5/90	DENT	48.27	H9		
113		5/90	DENT	38.07	H9		
93		5/90	DENT	61.19	H9		
		5/90	DENT	6.51	C9		
94		5/90	DENT	127.20	H9		
96		5/90	DENT	72.87	H9		
98		5/90	DENT	34.31	H9		
100		5/90	DENT	57.98	H9		
102		5/90	DENT	19.14	H9		
104		5/90	DENT	138.30	H9		
106		5/90	DENT	56.49	H9		
108		5/90	DENT	60.03	H9		
110		5/90	DENT	14.19	H9		
112		5/90	DENT	76.60	H9		
114		5/90	DENT	73.03	H9		
124		5/90	DENT	6.88	H9		
		5/90	DENT	11.02	C7		+ 4.40
9		5/90	DENT	11.35	VM		
21		5/90	DENT	8.00	VM		
91		5/90	DENT	9.34	H9		
93		5/90	DENT	68.50	H9		
95		5/90	DENT	54.30	H9		
97		5/90	DENT	54.23	H9		
99		5/90	DENT	70.04	H9		
101		5/90	DENT	51.22	H9		
103		5/90	DENT	52.11	H9		
105		5/90	DENT	127.00	H9		
107		5/90	DENT	100.50	H9		
109		5/90	DENT	40.50	H9		
111		5/90	DENT	37.69	H9		
113		5/90	DENT	47.60	H9		
115		5/90	DENT	11.74	H9		
92		5/90	DENT	38.01	H9		
94		5/90	DENT	46.66	H9		
96		5/90	DENT	89.69	H9		
98		5/90	DENT	97.54	H9		
100		5/90	DENT	99.57	H9		

Plant: CALVERT CLIFFS UNIT 1
 Outage: 5/20

Steam Generator: 12

QUERY: All Dent Indications - All Elevations

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
102	56	5/90	DENT		90.45	H9	
104	56	5/90	DENT		129.10	H9	
106	56	5/90	DENT		28.96	H9	
108	56	5/90	DENT		69.38	H9	
110	56	5/90	DENT		98.05	H9	
112	56	5/90	DENT		65.62	H9	
114	56	5/90	DENT		9.43	H9	
13	57	5/90	DENT		10.43	H6	+ 7.90
21	57	5/90	DENT		9.71	VM	+ 4.60
91	57	5/90	DENT		8.79	H9	
93	57	5/90	DENT		70.91	H9	
95	57	5/90	DENT		89.47	H9	
97	57	5/90	DENT		78.61	H9	
99	57	5/90	DENT		117.40	H9	
101	57	5/90	DENT		53.75	H9	
103	57	5/90	DENT		58.54	H9	
105	57	5/90	DENT		49.89	H9	
107	57	5/90	DENT		63.21	H9	
109	57	5/90	DENT		121.50	H9	
111	57	5/90	DENT		48.88	H9	
113	57	5/90	DENT		42.01	H9	
92	58	5/90	DENT		34.56	H9	
94	58	5/90	DENT		19.32	H9	
96	58	5/90	DENT		108.40	H9	
98	58	5/90	DENT		79.59	H9	
100	58	5/90	DENT		93.29	H9	
102	58	5/90	DENT		47.77	H9	
104	58	5/90	DENT		67.29	H9	
106	58	5/90	DENT		93.96	H9	
108	58	5/90	DENT		82.84	H9	
114	58	5/90	DENT		5.36	H9	
91	59	5/90	DENT		74.46	H9	
93	59	5/90	DENT		145.80	H9	
95	59	5/90	DENT		16.07	H9	
97	59	5/90	DENT		110.30	H9	+ 0.20
99	59	5/90	DENT		109.50	H9	
103	59	5/90	DENT		99.54	H9	
	59	5/90	DENT		12.40	C3	+16.20
105	59	5/90	DENT		58.02	H9	
107	59	5/90	DENT		92.52	H9	
109	59	5/90	DENT		45.56	H9	
121	59	5/90	DENT		5.95	H10	
92	60	5/90	DENT		97.70	H9	
94	60	5/90	DENT		107.70	H9	
98	60	5/90	DENT		118.70	H9	
100	60	5/90	DENT		125.80	H9	
102	60	5/90	DENT		102.90	H9	
104	60	5/90	DENT		30.22	H9	
106	60	5/90	DENT		36.29	H9	
108	60	5/90	DENT		30.96	H9	
112	60	5/90	DENT		35.38	H9	
91	61	5/90	DENT		6.70	H9	+ 2.10
93	61	5/90	DENT		42.63	H9	
97	61	5/90	DENT		34.03	H9	
99	61	5/90	DENT		107.10	H9	
101	61	5/90	DENT		71.92	H9	
103	61	5/90	DENT		42.82	H9	
107	61	5/90	DENT		65.00	H9	
111	61	5/90	DENT		21.60	H9	
94	62	5/90	DENT		35.51	H9	
96	62	5/90	DENT		19.28	H9	
98	62	5/90	DENT		129.70	H9	
100	62	5/90	DENT		92.29	H9	
102	62	5/90	DENT		33.01	H9	
104	62	5/90	DENT		33.93	H9	
106	62	5/90	DENT		33.53	H9	
108	62	5/90	DENT		50.81	H9	

Plant: CALVERT CLIFFS UNIT 1
 Outage: 5/90

Steam Generator: 12

QUERY: All Dent Indications - All Elevations

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
110	62	5/90	DENT		27.53	H9	
124	62	5/90	DENT		17.45	H9	
93	63	5/90	DENT		51.10	H9	
95	63	5/90	DENT		136.20	H9	
97	63	5/90	DENT		100.00	H9	
99	63	5/90	DENT		20.03	H9	
101	63	5/90	DENT		31.29	H9	
103	63	5/90	DENT		96.80	H9	
105	63	5/90	DENT		87.85	H9	
107	63	5/90	DENT		57.37	H9	
121	63	5/90	DENT		47.69	H9	
70	64	5/90	DENT		7.17	H6	+24.00
		5/90	DENT		12.87	H7	+12.80
		5/90	DENT		17.20	H7	+16.30
92	64	5/90	DENT		65.59	H9	
94	64	5/90	DENT		17.77	H9	
96	64	5/90	DENT		204.60	H9	
98	64	5/90	DENT		118.00	H9	
104	64	5/90	DENT		104.60	H9	
106	64	5/90	DENT		70.88	H9	
108	64	5/90	DENT		47.74	H9	
110	64	5/90	DENT		10.72	H9	
112	64	5/90	DENT		28.88	H9	
114	64	5/90	DENT		37.57	H9	
116	64	5/90	DENT		16.40	C7	+10.00
118	64	5/90	DENT		54.94	H9	
69	65	5/90	DENT		6.26	VM	
95	65	5/90	DENT		73.74	H9	
97	65	5/90	DENT		83.27	H9	
99	65	5/90	DENT		117.30	H9	
101	65	5/90	DENT		93.94	H9	
103	65	5/90	DENT		41.31	H9	
105	65	5/90	DENT		114.10	H9	
107	65	5/90	DENT		5.45	H9	
111	65	5/90	DENT		50.70	H9	
113	65	5/90	DENT		60.64	H9	
115	65	5/90	DENT		42.45	H9	
119	65	5/90	DENT		31.47	H10	
121	65	5/90	DENT		86.49	H10	
123	65	5/90	DENT		66.97	H10	
125	65	5/90	DENT		16.23	VC	+ 2.70
48	66	5/90	DENT		5.97	HTS-SF	+24.00
90	66	5/90	DENT		6.26	VM	
92	66	5/90	DENT		63.99	H9	
98	66	5/90	DENT		121.20	HTS-SF	
		5/90	DENT		158.05	H9	
100	66	5/90	DENT		152.40	H9	
102	66	5/90	DENT		113.80	H9	
104	66	5/90	DENT		152.40	H9	
106	66	5/90	DENT		10.05	H9	
108	66	5/90	DENT		62.43	H9	
110	66	5/90	DENT		129.70	H9	
112	66	5/90	DENT		102.60	H9	
120	66	5/90	DENT		47.84	H9	
91	67	5/90	DENT		49.30	H9	
93	67	5/90	DENT		56.97	H9	
95	67	5/90	DENT		151.20	H9	
97	67	5/90	DENT		64.00	H9	
101	67	5/90	DENT		17.26	H9	
103	67	5/90	DENT		138.30	H9	
105	67	5/90	DENT		98.47	H9	
107	67	5/90	DENT		15.07	H9	
109	67	5/90	DENT		48.63	H9	
121	67	5/90	DENT		37.74	H9	
92	68	5/90	DENT		81.51	H9	
94	68	5/90	DENT		66.00	H9	
96	68	5/90	DENT		107.20	H9	

Plant: CALVERT CLIFFS UNIT 1
 Outage: 7/90

Steam Generator: 12

QUERY: All Dent Indications - All Elevations

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
98	68	5/90	DENT		153.20	H9	
100	68	5/90	DENT		6.61	C8	
		5/90	DENT		14.59	H9	
102	68	5/90	DENT		65.31	H9	
106	68	5/90	DENT		146.50	H9	
108	68	5/90	DENT		119.80	H9	
110	68	5/90	DENT		79.17	H9	
112	68	5/90	DENT		32.66	H9	
114	68	5/90	DENT		59.06	H9	
91	69	5/90	DENT		56.86	H9	
93	69	5/90	DENT		76.46	H9	
95	69	5/90	DENT		28.60	H9	
97	69	5/90	DENT		196.30	H9	
99	69	5/90	DENT		111.00	H9	
101	69	5/90	DENT		21.49	C4	+ 8.80
105	69	5/90	DENT		34.19	H9	
109	69	5/90	DENT		105.20	H9	
111	69	5/90	DENT		79.35	H9	
113	69	5/90	DENT		34.10	H9	
92	70	5/90	DENT		42.05	H9	
94	70	5/90	DENT		71.20	H9	
96	70	5/90	DENT		269.30	H9	
98	70	5/90	DENT		130.80	H9	
100	70	5/90	DENT		59.68	H9	
102	70	5/90	DENT		53.65	H9	
104	70	5/90	DENT		27.50	H9	
106	70	5/90	DENT		54.27	H9	
108	70	5/90	DENT		83.16	H9	
110	70	5/90	DENT		135.90	H9	
112	70	5/90	DENT		70.52	H9	
120	70	5/90	DENT		10.03	H10	
93	71	5/90	DENT		80.11	H9	
95	71	5/90	DENT		109.20	H9	
97	71	5/90	DENT		181.50	H9	
101	71	5/90	DENT		22.92	H9	
103	71	5/90	DENT		104.10	H9	
105	71	5/90	DENT		21.83	H9	
107	71	5/90	DENT		38.71	H9	
109	71	5/90	DENT		24.75	H9	
111	71	5/90	DENT		98.59	H9	
113	71	5/90	DENT		47.37	H9	
92	72	5/90	DENT		7.98	H9	
94	72	5/90	DENT		84.65	H9	
98	72	5/90	DENT		40.89	HTS-SF	
		5/90	DENT		149.10	H9	
100	72	5/90	DENT		136.80	H9	
104	72	5/90	DENT		75.85	H9	
108	72	5/90	DENT		15.23	H9	
110	72	5/90	DENT		34.33	H9	
114	72	5/90	DENT		36.40	H9	
116	72	5/90	DENT		11.65	H9	
69	73	5/90	DENT		10.53	C8	
		5/90	DENT		8.79	C7	+16.90
		5/90	DENT		5.95	C7	+17.50
91	73	5/90	DENT		23.40	H9	
93	73	5/90	DENT		103.70	H9	
97	73	5/90	DENT		69.50	H9	
99	73	5/90	DENT		171.80	H9	
101	73	5/90	DENT		93.85	H9	
103	73	5/90	DENT		100.10	H9	
105	73	5/90	DENT		47.12	H9	
107	73	5/90	DENT		20.04	H9	
111	73	5/90	DENT		6.42	H9	
113	73	5/90	DENT		77.51	H9	
115	73	5/90	DENT		16.62	H9	
74	74	5/90	DENT		9.53	VM	+ 2.00
		5/90	DENT		6.57	VM	+10.60

Plant: CALVERT CLIFFS UNIT 1
 Outage: 5/90

Steam Generator: 12

QUERY: All Dent Indications - All Elevations

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
92	74	5/90	DENT		10.70	H9	
94	74	5/90	DENT		69.63	H9	
96	74	5/90	DENT		134.50	H9	
98	74	5/90	DENT		98.51	H9	
100	74	5/90	DENT		124.40	H9	
102	74	5/90	DENT		96.32	H9	
104	74	5/90	DENT		13.83	H9	
106	74	5/90	DENT		32.38	H9	
108	74	5/90	DENT		18.86	H9	
110	74	5/90	DENT		8.54	H9	
112	74	5/90	DENT		76.95	H9	
114	74	5/90	DENT		82.08	H9	
116	74	5/90	DENT		36.08	H9	
93	75	E/90	DENT		28.40	H9	
95	75	5/90	DENT		33.16	H9	
99	75	5/90	DENT		115.80	H2	
101	75	5/90	DENT		82.61	H9	
103	75	5/90	DENT		99.61	H9	
105	75	5/90	DENT		46.75	H9	
107	75	5/90	DENT		78.04	H9	
109	75	5/90	DENT		46.15	H9	
111	75	5/90	DENT		51.11	H9	
113	75	5/90	DENT		39.54	H9	
115	75	5/90	DENT		8.69	H9	
92	76	5/90	DENT		11.36	H9	
94	76	5/90	DENT		37.17	H9	
96	76	5/90	DENT		90.34	H9	
98	76	5/90	DENT		16.82	H9	
100	76	5/90	DENT		116.20	H9	
102	76	5/90	DENT		62.43	H9	
104	76	5/90	DENT		34.89	H9	
106	76	5/90	DENT		44.35	H9	
108	76	5/90	DENT		57.91	H9	
110	76	5/90	DENT		96.58	H9	
114	76	5/90	DENT		22.82	HTS-SF	+31.30
116	76	5/90	DENT		50.83	H9	
91	77	5/90	DENT		54.16	H9	
	77	5/90	DENT		15.97	C9	
93	77	5/90	DENT		51.81	H9	
	77	5/90	DENT		17.07	C9	
95	77	5/90	DENT		112.10	H9	
97	77	5/90	DENT		98.76	H9	
99	77	5/90	DENT		66.66	H9	
101	77	5/90	DENT		11.12	H9	
103	77	5/90	DENT		15.20	H9	
105	77	5/90	DENT		25.33	H9	
107	77	5/90	DENT		10.85	H9	
109	77	5/90	DENT		47.80	H9	
111	77	5/90	DENT		95.15	H9	
113	77	5/90	DENT		46.22	H9	
115	77	5/90	DENT		27.16	H9	
117	77	5/90	DENT		6.59	H10	
	77	5/90	DENT		5.45	C10	
119	77	5/90	DENT		7.09	H10	
92	78	5/90	DENT		32.28	H9	
94	78	5/90	DENT		75.25	H9	
96	78	5/90	DENT		93.97	H9	
98	78	5/90	DENT		32.07	H9	
100	78	5/90	DENT		8.17	H9	
102	78	5/90	DENT		74.83	H9	
104	78	5/90	DENT		39.29	H9	
110	78	5/90	DENT		27.12	H9	
112	78	5/90	DENT		53.18	H9	
114	78	5/90	DENT		69.36	H9	
116	78	5/90	DENT		47.49	H9	
93	79	5/90	DENT		39.86	H9	
95	79	5/90	DENT		63.15	H9	

Plant: CALVERT CLIFFS UNIT 1
Outage: 5/90

Steam Generator: 12

QUERY: All Dent Indications - All Elevations

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
97	79	5/90	DENT		105.20	H9	
99	79	5/90	DENT		71.37	H9	
101	79	5/90	DENT		52.09	H9	
103	79	5/90	DENT		77.20	H9	
105	79	5/90	DENT		45.81	H9	
109	79	5/90	DENT		37.77	H9	
113	79	5/90	DENT		111.50	H9	
115	79	5/90	DENT		34.60	H9	
121	79	5/90	DENT		8.87	H9	
58	80	5/90	DENT		7.91	C5	+14.00
74	80	5/90	DENT		9.48	C7	+11.30
		5/90	DENT		9.51	C7	+13.30
		5/90	DENT		7.49	C8	+1.00
92	80	5/90	DENT		114.70	H9	
94	80	5/90	DENT		547.30	H9	
96	80	5/90	DENT		176.10	H9	
		5/90	DENT		175.80	H9	
98	80	5/90	DENT		183.90	H9	
100	80	5/90	DENT		162.30	H9	
102	80	5/90	DENT		1424.50	H9	
104	80	5/90	DENT		2009.50	H9	
106	80	5/90	DENT		224.34	H9	
108	80	5/90	DENT		94.92	H9	
110	80	5/90	DENT		91.99	H9	
112	80	5/90	DENT		25.93	H9	
114	80	5/90	DENT		80.41	H9	
116	80	5/90	DENT		10.48	H9	
81	81	5/90	DENT		9.15	C2	+29.30
85	81	5/90	DENT		7.05	H4	+37.10
91	81	5/90	DENT		48.51	H9	
93	81	5/90	DENT		63.12	H9	
95	81	5/90	DENT		9.35	H9	
97	81	5/90	DENT		89.95	H9	
99	81	5/90	DENT		93.05	H9	
101	81	5/90	DENT		87.10	H9	
103	81	5/90	DENT		90.73	H9	
105	81	5/90	DENT		98.62	H9	
107	81	5/90	DENT		104.80	H9	
109	81	5/90	DENT		161.60	H9	
111	81	5/90	DENT		125.50	H9	
113	81	5/90	DENT		86.84	H9	
115	81	5/90	DENT		41.84	H9	
117	81	5/90	DENT		84.01	H9	
		5/90	DENT		20.15	H10	
119	81	5/90	DENT		22.40	H10	
121	81	5/90	DENT		40.27	H10	
44	82	5/90	DENT		23.48	H6	+12.40
94	82	5/90	DENT		83.14	H9	
96	82	5/90	DENT		65.73	H9	
98	82	5/90	DENT		110.00	H9	
100	82	5/90	DENT		142.20	H9	
102	82	5/90	DENT		102.10	H9	
104	82	5/90	DENT		134.00	H9	
106	82	5/90	DENT		83.84	H9	
108	82	5/90	DENT		100.50	H9	
110	82	5/90	DENT		106.00	H9	
112	82	5/90	DENT		96.86	H9	
114	82	5/90	DENT		134.90	H9	
116	82	5/90	DENT		84.39	H9	
118	82	5/90	DENT		28.73	H9	
		5/90	DENT		12.07	H11	
122	82	5/90	DENT		17.97	H10	
69	83	5/90	DENT		4.99	DH	+11.90
93	83	5/90	DENT		109.80	H9	
95	83	5/90	DENT		92.71	H9	
97	83	5/90	DENT		45.54	H9	
99	83	5/90	DENT		133.60	H9	

Plant: CALVERT CLIFFS UNIT 1
 Outage: 5/90

Steam Generator: 12

QUERY: All Dent Indications - All Elevations

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
101	83	5/90	DENT		93.98	H9	
103	83	5/90	DENT		63.55	H9	
105	83	5/90	DENT		49.14	H9	
107	83	5/90	DENT		93.36	H9	
109	83	5/90	DENT		51.34	H9	
111	83	5/90	DENT		58.44	H9	
113	83	5/90	DENT		93.60	H9	
115	83	5/90	DENT		79.02	H9	
117	83	5/90	DENT		58.44	H9	
119	83	5/90	DENT		15.87	H9	
48	84	5/90	DENT		5.30	VM	
		5/90	DENT		5.30	VM	
96	84	5/90	DENT		0.1	200	H9
		5/90	DENT		6.26	C9	
98	84	5/90	DENT		6.87	HTS-SF	
		5/90	DENT		6.01	H9	
100	84	5/90	DENT		120.00	H9	
102	84	5/90	DENT		146.00	H9	
104	84	5/90	DENT		48.92	H9	
106	84	5/90	DENT		13.53	H9	
108	84	5/90	DENT		44.89	H9	
110	84	5/90	DENT		68.45	H9	
112	84	5/90	DENT		30.92	H9	
114	84	5/90	DENT		12.71	H9	
116	84	5/90	DENT		38.30	H9	
118	84	5/90	DENT		21.38	H9	
91	85	5/90	DENT		33.30	H9	
93	85	5/90	DENT		54.63	H9	
95	85	5/90	DENT		54.63	H9	
97	85	5/90	DENT		19.77	H9	
		5/90	DENT		19.77	H9	
99	85	5/90	DENT		04.08	H9	
		5/90	DENT		11.10	HTS-SF	
		5/90	DENT		24.08	H9	
		5/90	DENT		11.10	HTL-SF	
101	85	5/90	DFNT		30.27	H9	
		5/90	DENT		30.27	H9	
		5/90	DENT		30.82	H9	
103	85	5/90	DENT		43.00	H9	
105	85	5/90	DENT		39.09	H9	
107	85	5/90	DENT		12.68	H9	
109	85	5/90	DENT		26.95	H9	
113	85	5/90	DENT		37.44	H9	
115	85	5/90	DENT		62.62	H9	
117	85	5/90	DENT		61.60	H9	
119	85	5/90	DENT		8.78	H9	
121	85	5/90	DENT		5.20	H10	
92	86	5/90	DENT		39.44	H9	
		5/90	DENT		39.44	H9	
94	86	5/90	DENT		59.90	H9	
		5/90	DENT		59.90	H9	
96	86	5/90	DENT		71.70	H9	
		5/90	DENT		71.70	H9	
98	86	5/90	DENT		45.76	H9	
100	86	5/90	DENT		89.09	H9	
		5/90	DENT		89.09	H9	
102	86	5/90	DENT		50.33	H9	
		5/90	DENT		50.33	H9	
104	86	5/90	DENT		63.27	H9	
		5/90	DENT		63.27	H9	
110	86	5/90	DENT		28.21	H9	
		5/90	DENT		28.21	H9	
112	86	5/90	DENT		39.47	H9	
		5/90	DENT		39.47	H9	
114	86	5/90	DENT		10.97	H9	

Plant: CALVERT CLIFFS UNIT 1
 Outage: 5/90

Steam Generator: 12

QUERY: All Dent Indications - All Elevations

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
116	86	5/90	DENT		10.97	H9	
		5/90	DENT		45.08	H9	
118	86	5/90	DENT		45.08	H9	
67	87	5/90	DENT		25.21	H9	
91	87	5/90	DENT		9.04	H7	+19.50
		5/90	DENT		90.98	H9	
93	87	5/90	DENT		90.88	H9	
		5/90	DENT		111.90	H9	
95	87	5/90	DENT		111.90	H9	
		5/90	DENT		179.20	H9	
97	87	5/90	DENT		179.20	H9	
		5/90	DENT		70.77	H9	
99	87	5/90	DENT		70.77	H9	
		5/90	DENT		91.19	H9	
101	87	5/90	DENT		91.19	H9	
		5/90	DENT		55.24	H9	
103	87	5/90	DENT		55.24	H9	
		5/90	DENT		74.02	H9	
105	87	5/90	DENT		74.02	H9	
		5/90	DENT		60.25	H9	
107	87	5/90	DENT		60.25	H9	
		5/90	DENT		43.04	H9	
109	87	5/90	DENT		43.04	H9	
		5/90	DENT		62.59	H9	
111	87	5/90	DENT		62.59	H9	
		5/90	DENT		77.96	H9	
113	87	5/90	DENT		77.96	H9	
		5/90	DENT		58.58	H9	
115	87	5/90	DENT		58.58	H9	
		5/90	DENT		88.03	H9	
117	87	5/90	DENT		88.03	H9	
		5/90	DENT		58.42	H9	
119	87	5/90	DENT		58.42	H9	
		5/90	DENT		24.78	H9	
82	88	5/90	DENT		24.78	H9	
92	88	5/90	DENT		116.00	H1	+ 1.60
94	88	5/90	DENT		143.37	H9	
96	88	5/90	DENT		144.70	H9	
98	88	5/90	DENT		190.10	H9	
100	88	5/90	DENT		136.30	H9	
102	88	5/90	DENT		113.70	H9	
104	88	5/90	DENT		101.10	H9	
106	88	5/90	DENT		73.03	H9	
110	88	5/90	DENT		56.02	H9	
112	88	5/90	DENT		61.20	H9	
114	88	5/90	DENT		42.74	H9	
116	88	5/90	DENT		16.90	H9	
120	88	5/90	DENT		27.80	H9	
122	88	5/90	DENT		25.80	H9	
91	89	5/90	DENT		67.32	H9	
93	89	5/90	DENT		67.40	H9	
95	89	5/90	DENT		109.90	H9	
97	89	5/90	DENT		14.62	C8	+ 7.60
		5/90	DENT		5.22	C9	
99	89	5/90	DENT		135.40	H9	
101	89	5/90	DENT		137.30	H9	
103	89	5/90	DENT		25.71	H9	
105	89	5/90	DENT		80.94	H9	
107	89	5/90	DENT		39.65	H9	
109	89	5/90	DENT		68.65	H9	
111	89	5/90	DENT		78.95	H9	
113	89	5/90	DENT		55.36	H9	
115	89	5/90	DENT		75.27	H9	
117	89	5/90	DENT		34.11	H9	
119	89	5/90	DENT		44.26	H9	
		5/90	DENT		19.60	H9	

Plant: CALVERT CLIFFS UNIT 1
 Outage: 5/90

Steam Generator: 12

QUERY: All Dent Indications - All Elevations

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
121	89	5/90	DENT		46.63	H9	
96	90	5/90	DENT		91.26	H9	
98	90	5/90	DENT		85.60	H9	
102	90	5/90	DENT		37.60	H9	
104	90	5/90	DENT		61.86	H9	
106	90	5/90	DENT		152.30	H9	
108	90	5/90	DENT		155.60	H9	
110	90	5/90	DELT		19.26	H9	
112	90	5/90	DENT		79.54	H9	
114	90	5/90	DENT		50.62	H9	
116	90	5/90	DENT		20.11	H9	
118	90	5/90	DENT		16.44	H9	
95	91	5/90	DENT		19.32	H9	
97	91	5/90	DENT		63.34	H9	
99	91	5/90	DENT		103.70	H9	
101	91	5/90	DLNT		22.56	H9	
103	91	5/90	DENT		41.20	H9	
105	91	5/90	DENT		6.65	H9	
107	91	5/90	DENT		116.70	H9	
109	91	5/90	DENT		35.90	H9	
111	91	5/90	DENT		57.96	H9	
113	91	5/90	DENT		52.43	H9	
115	91	5/90	DENT		12.61	H9	
117	91	5/90	DENT		65.58	H9	
119	91	5/90	DENT		13.36	H9	
94	92	5/90	DENT		43.05	H9	
		5/90	DENT		43.05	H9	
96	92	5/90	DENT		49.03	H9	
		5/90	DENT		49.03	H9	
98	92	5/90	DENT		70.55	H9	
100	92	5/90	DENT		102.20	H9	
		5/90	DENT		102.20	H9	
102	92	5/90	DENT		115.10	H9	
		5/90	DENT		115.10	H9	
104	92	5/90	DENT		71.84	H9	
		5/90	DENT		71.84	H9	
108	92	5/90	DENT		51.50	H9	
110	92	5/90	DENT		76.84	H9	
		5/90	DENT		76.84	H9	
112	92	5/90	DENT		97.09	H9	
114	92	5/90	DENT		19.45	H9	
116	92	5/90	DENT		26.23	H9	
118	92	5/90	DENT		42.21	H9	
120	92	5/90	DENT		7.68	H10	
138	92	5/90	DENT		7.91	VC	+ 30.07
77	93	5/90	DENT		12.96	H5	+ 9.70
		3.90	DENT		7.69	H5	+ 9.20
		5/90	DENT		12.96	H5	+ 9.70
		5/90	DENT		7.69	H5	+ 9.20
91	93	5/90	DENT		37.05	H9	
		5/90	DENT		37.05	H9	
93	93	5/90	DENT		56.27	H9	
		5/90	DENT		56.27	H9	
95	93	5/90	DENT		56.75	H9	
		5/90	DENT		56.75	H9	
97	93	5/90	DENT		21.07	H9	
		5/90	DENT		21.07	H9	
99	93	5/90	DENT		144.70	H9	
		5/90	DENT		144.70	H9	
101	93	5/90	DENT		37.86	H9	
		5/90	DENT		37.86	H9	
103	93	5/90	DENT		82.14	H9	
		5/90	DENT		82.14	H9	
105	93	5/90	DENT		76.43	H9	
		5/90	DENT		76.43	H9	
107	93	5/90	DENT		45.46	H9	
		5/90	DENT		45.46	H9	

Plant: CALVERT CLIFFS UNIT 1
Outage: 5/90

ean Generator 12

QUERY: All Dent Indications - All Elevations

Plant: CALVERT CLIFFS UNIT 1
 Outage: 5/90

Steam Generator: 12

QUERY: All Dent Indications - All Elevations

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
		5/90	DENT		14.60	C9	+ 1.80
		5/90	DENT		91.30	H9	
93	97	5/90	DENT		108.80	H9	
95	97	5/90	DENT		9.03	H9	
97	97	5/90	DENT		25.99	H9	
99	97	5/90	DENT		89.09	H9	
101	97	5/90	DENT		87.42	H9	
103	97	5/90	DENT		115.70	H9	
105	97	5/90	DENT		62.97	H9	
107	97	5/90	DENT		8.82	DH	
119	97	5/90	DENT		41.69	H9	
92	98	5/90	DENT		8.44	H10	
98	98	5/90	DENT		94.55	H9	
100	98	5/90	DENT		146.00	H9	
106	98	5/90	DENT		89.95	H9	
108	98	5/90	DENT		59.85	H9	
91	99	5/90	DENT		40.57	H9	
93	99	5/90	DENT		173.50	H9	
95	99	5/90	DENT		73.14	H9	
99	99	5/90	DENT		67.31	H9	
101	99	5/90	DENT		68.04	H9	+ 3.80
103	99	5/90	DENT		59.72	H9	
105	99	5/90	DENT		56.54	H9	
92	100	5/90	DENT		154.40	H9	
94	100	5/90	DENT		83.65	H9	
100	100	5/90	DENT		149.00	H9	
102	100	5/90	DENT		69.45	H9	
104	100	5/90	DENT		17.95	H9	
106	100	5/90	DENT		43.54	H10	
108	100	5/90	DENT		45.11	H10	
110	100	5/90	DENT		74.61	H9	
1200	100	5/90	DFNT		64.00	H9	
1222	100	5/90	DENT		75.24	H9	
93	101	5/90	DENT		13.37	H9	
97	101	5/90	DENT		7.77	H9	
99	101	5/90	DENT		72.12	H9	
10	101	5/90	DENT		72.98	H9	
1	01	5/90	DENT		64.01	H9	
1	-1	5/90	DENT		36.75	H9	
10	01	5/90	DENT		13.66	H9	
111	101	5/90	DENT		40.22	H10	
113	101	5/90	DENT		79.76	H10	
119	101	5/90	DENT		54.74	H9	
121	101	5/90	DENT		66.03	H9	
92	102	5/90	DENT		15.15	H9	
96	102	5/90	DENT		88.60	H9	
98	102	5/90	DENT		12.72	H9	
100	102	5/90	DENT		64.63	H9	
104	102	5/90	DENT		20.68	H9	
106	102	5/90	DENT		61.30	H9	
108	102	5/90	DENT		96.08	H9	
110	102	5/90	DENT		38.29	H10	
112	102	5/90	DENT		49.75	H10	
118	102	5/90	DENT		8.97	H10	
120	102	5/90	DENT		5.51	H6	+ 220 .80
122	102	5/90	DENT		5.75	H6	+ 230 .80
93	102	5/90	DENT		6.17	H6	+ 24 .80
94	102	5/90	DENT		7.84	H7	
99	102	5/90	DENT		6.29	H7	+ 1.60
101	102	5/90	DENT		6.55	H7	+ 2.10
93	103	5/90	DENT		76.72	H9	
94	103	5/90	DENT		79.23	H9	
101	103	5/90	DENT		120.70	H9	

Plant: CALVERT CLIFFS UNIT 1
Outage: 5/90

Steam Generator: 12

QUERY: All Dent Indications - All Elevations

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
103	103	5/90	DENT		18.11	H9	
107	103	5/90	DENT		23.57	H9	
111	103	5/90	DENT		40.71	H9	
113	103	5/90	DENT		13.01	H9	
92	104	5/90	DENT		58.56	H9	
94	104	5/90	DENT		9.05	H9	
95	104	5/90	DENT		84.89	H9	
98	104	5/90	DENT		14.18	H9	
100	104	5/90	DENT		119.80	H9	
102	104	5/90	DENT		78.18	H9	
106	104	5/90	DENT		104.00	H9	
108	104	5/90	DENT		41.28	H9	
110	104	5/90	DENT		82.94	H9	
122	104	5/90	DENT		7.43	H10	
15	105	5/90	DENT		5.70	CTS-SF	+11.80
69	105	5/90	DENT		8.69	H5	+2.70
71	105	5/90	DENT		7.97	C2	+29.60
91	105	5/90	DENT		103.10	H9	
93	105	5/90	DENT		75.83	H9	
95	105	5/90	DENT		114.20	H9	
97	105	5/90	DENT		103.10	H9	
99	105	5/90	DENT		86.59	H9	+23.60
101	105	5/90	DENT		68.14	H9	
103	105	5/90	DENT		59.45	H9	
109	105	5/90	DENT		64.74	H9	
111	105	5/90	DENT		8.93	VC	
117	105	5/90	DENT		46.06	H10	
119	105	5/90	DENT		57.06	H10	
10	106	5/90	DENT		8.34	C6	+7.70
32	106	5/90	DENT		11.68	H5	+17.50
40	106	5/90	DENT		8.13	VM	
92	106	5/90	DENT		78.27	H9	
94	106	5/90	DENT		127.40	H9	
95	106	5/90	DENT		117.70	H9	
98	106	5/90	DENT		106.60	H9	
100	106	5/90	DENT		161.70	H9	
102	106	5/90	DENT		28.65	H9	
108	106	5/90	DENT		28.69	H9	
136	106	5/90	DENT		5.79	H9	
35	107	5/90	DENT		31.34	H5	+17.40
41	107	5/90	DENT		14.17	HTS-SF	+33.30
57	107	5/90	DENT		7.08	H7	
91	107	5/90	DENT		56.39	H9	
93	107	5/90	DENT		88.26	H9	
95	107	5/90	DENT		57.61	H9	
97	107	5/90	DENT		99.61	H9	
99	107	5/90	DENT		93.11	H9	
101	107	5/90	DENT		93.03	H9	
103	107	5/90	DENT		40.43	H9	
107	107	5/90	DENT		61.03	H9	
109	107	5/90	DENT		49.85	H9	
111	107	5/90	DENT		26.65	H9	
119	107	5/90	DENT		14.26	H10	
135	107	5/90	DENT		7.74	VM	+25.90
92	108	5/90	DENT		79.30	H9	
94	108	5/90	DENT		78.32	H9	
95	108	5/90	DENT		83.74	H9	
95	108	5/90	DENT		65.75	H9	
100	108	5/90	DENT		86.91	H9	
102	108	5/90	DENT		100.90	H9	
106	108	5/90	DENT		47.03	H9	
108	108	5/90	DENT		58.63	H9	
110	108	5/90	DENT		45.74	H9	
7	109	5/90	DENT		12.21	H5	+5.60
13	109	5/90	DENT		9.88	C6	+8.00
91	109	5/90	DENT		48.66	H9	
93	109	5/90	DENT		81.06	H9	

Plant: CALVERT CLIFFS UNIT 1
 Outage: 5/90

Steam Generator: 12

QUERY: All Dent Indications - All Elevations

ROW	LINE	CUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
95	109	5/90	DENT		105.00	H9	
97	109	5/90	DENT		101.60	H9	
99	109	5/90	DENT		98.54	H9	
103	109	5/90	DENT		98.00	H9	
105	109	5/90	DENT		98.00	H9	
107	109	5/90	DENT		48.40	VM	+26.70
109	109	5/90	DENT		48.00	H9	
111	109	5/90	DENT		60.34	H9	
92	110	5/90	DENT		44.62	C9	
94	110	5/90	DENT		100.14	H9	
98	110	5/90	DENT		100.64	H9	
100	110	5/90	DENT		100.64	H9	
102	110	5/90	DENT		100.64	H9	
110	110	5/90	DENT		100.64	H9	
112	110	5/90	DENT		100.64	H10	
90	111	5/90	DENT		9.71	H10	
41	111	5/90	DENT		6.89	H15 - SF	+34.00
91	111	5/90	DENT		8.74	H9	
93	111	5/90	DENT		11.94	H9	
95	111	5/90	DENT		10.90	H9	
97	111	5/90	DENT		11.21	H9	
99	111	5/90	DENT		10.80	H9	
101	111	5/90	DENT		10.88	H9	
105	111	5/90	DENT		10.63	H9	
109	111	5/90	DENT		10.77	H9	
111	111	5/90	DENT		11.00	H10	
117	111	5/90	DENT		10.55	H9	
92	112	5/90	DENT		9.94	H9	
94	112	5/90	DENT		11.24	C9	
96	112	5/90	DENT		11.00	H9	+16.60
98	112	5/90	DENT		10.99	H9	
100	112	5/90	DENT		10.94	H9	
102	112	5/90	DENT		10.90	H9	
108	112	5/90	DENT		10.94	H9	
110	112	5/90	DENT		10.94	H9	
71	113	5/90	DENT		11.07	VM	
91	113	5/90	DENT		10.44	H9	
93	113	5/90	DENT		10.44	H9	
95	113	5/90	DENT		10.44	H9	
97	113	5/90	DENT		10.44	H9	
99	113	5/90	DENT		10.50	H9	
101	113	5/90	DENT		10.50	H9	
103	113	5/90	DENT		10.50	H9	
105	113	5/90	DENT		10.50	H9	
107	113	5/90	DENT		10.51	H9	
109	113	5/90	DENT		10.84	H9	
82	114	5/90	DENT		5.68	H4	+34.30
92	114	5/90	DENT		5.95	C9	
94	114	5/90	DENT		5.94	H9	
96	114	5/90	DENT		6.00	H9	
98	114	5/90	DENT		6.00	H9	
100	114	5/90	DENT		6.00	H9	
102	114	5/90	DENT		6.76	H9	
104	114	5/90	DENT		71.55	H9	
106	114	5/90	DENT		6.01	H9	
108	114	5/90	DENT		7.38	H9	
110	114	5/90	DENT		5.36	H9	
112	114	5/90	DENT		5.36	H9	
114	114	5/90	DENT		5.36	H9	
67	115	5/90	DENT		6.13	C7	+ 8.20
69	115	5/90	DENT		6.75	C8	
		5/90	DENT		13.16	H7	+16.30

Plant: CALVERT CLIFFS UNIT 1
Outage: 5/90

Steam Generator: 12

QUERY: All Dent Indications - All Elevations

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
91	115	5/90	DENT		5.08	H7	+14.10
		5/90	DENT		10.92	C9	+ 1.90
93	115	5/90	DENT		43.33	H9	
		5/90	DENT		6.12	C9	
95	115	5/90	DENT		132.90	H9	
97	1125	5/90	DENT		89.40	H9	
99	1125	5/90	DENT		76.30	H9	
101	1125	5/90	DENT		60.41	H9	
103	1125	5/90	DENT		63.34	H9	
105	1125	5/90	DENT		72.65	H9	
		5/90	DENT		9.88	C9	+ 1.80
107	115	5/90	DENT		64.61	H9	
109	115	5/90	DENT		58.98	H9	
111	115	5/90	DENT		42.81	H9	
113	115	5/90	DENT		62.40	H9	
40	115	5/90	DENT		65.83	C6	+13.80
92	116	5/90	DENT		86.18	H9	
94	116	5/90	DENT		101.70	H9	
96	116	5/90	DENT		54.08	H9	
98	116	5/90	DENT		67.61	H9	
102	116	5/90	DENT		48.21	H9	
104	116	5/90	DENT		49.98	H9	
106	116	5/90	DENT		43.74	H9	
108	116	5/90	DENT		63.98	H9	
110	116	5/90	DENT		54.24	H9	
112	116	5/90	DENT		43.68	H9	
114	116	5/90	DENT		14.91	H9	
5124	116	5/90	DENT		5.80	C9	+ 3.00
91	117	5/90	DENT		5.99	C2	+32.60
93	117	5/90	DENT		63.63	H9	
95	117	5/90	DENT		63.94	H9	
97	117	5/90	DENT		95.39	H9	
99	117	5/90	DENT		19.47	H9	
103	117	5/90	DENT		18.72	H9	
105	117	5/90	DENT		103.80	H9	
109	117	5/90	DENT		65.80	H9	
111	117	5/90	DENT		66.86	H9	
92	118	5/90	DENT		55.34	H9	
94	118	5/90	DENT		54.20	H9	
96	118	5/90	DENT		90.05	H9	
98	118	5/90	DENT		64.46	H9	
100	118	5/90	DENT		46.44	H9	
102	118	5/90	DENT		70.01	H9	
104	118	5/90	DENT		41.86	H9	
108	118	5/90	DENT		41.43	H9	
110	118	5/90	DENT		87.88	H9	
112	118	5/90	DENT		104.80	H9	
114	118	5/90	DENT		13.43	H9	
91	119	5/90	DENT		6.96	H9	
95	119	5/90	DENT		28.65	H9	
97	119	5/90	DENT		88.11	H9	
99	119	5/90	DENT		67.19	H9	
101	119	5/90	DENT		67.19	H9	
103	119	5/90	DENT		94.34	H9	
107	119	5/90	DENT		139.56	H9	
109	119	5/90	DENT		106.77	H9	
111	119	5/90	DENT		94.98	H9	
113	119	5/90	DENT		88.78	H9	
120	120	5/90	DENT		10.71	DC	
94	120	5/90	DENT		32.07	H9	
96	120	5/90	DENT		50.76	H9	
98	120	5/90	DENT		50.87	H9	
100	120	5/90	DENT		111.60	H9	
102	120	5/90	DENT		104.50	H9	
104	120	5/90	DENT		104.70	H9	

Steam Generator: 12

QUERY: All Dent Indications - All Elevations

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
108	120	5/90	DENT		62.55	H9	
110	120	5/90	DENT		62.53	H9	
111	121	5/90	DENT		6.58	C3	+23.20
93	121	5/90	DENT		75.75	H9	
95	121	5/90	DENT		80.10	H9	
97	121	5/90	DENT		65.10	H9	
99	121	5/90	DENT		30.55	H9	
101	121	5/90	DENT		71.13	H9	
103	121	5/90	DENT		87.00	H9	
105	121	5/90	DENT		35.09	H9	
107	121	5/90	DENT		33.98	H9	
109	121	5/90	DENT		15.80	H9	
123	121	5/90	DENT		11.13	C5	+28.70
92	121	5/90	DENT		76.48	H9	
94	122	5/90	DENT		63.02	H9	
96	122	5/90	DENT		47.72	H9	
98	122	5/90	DENT		54.20	H9	
100	122	5/90	DENT		13.94	H9	
106	122	5/90	DENT		74.95	H9	
108	122	5/90	DENT		41.06	H9	
110	122	5/90	DENT		38.71	H9	
112	122	5/90	DENT		36.26	H9	
114	122	5/90	DENT		36.25	H9	
116	122	5/90	DENT		7.29	H9	
7	123	5/90	DENT		14.45	C6	
13	123	5/90	DENT		9.10	C6	+ 5.90
		5/90	DENT		8.97	DC	+ 8.00
39	123	5/90	DENT		6.46	YM	
		5/90	DENT		6.79	C6	+17.90
		5/90	DENT		6.81	C6	+19.30
41	123	5/90	DENT		5.74	C6	+21.30
		5/90	DENT		10.58	H6	+22.60
		5/90	DENT		9.12	H6	+21.70
65	123	5/90	DENT		6.13	H6	+20.20
93	123	5/90	DENT		5.70	H5	+25.60
95	123	5/90	DENT		36.82	H9	
97	123	5/90	DENT		17.55	H8	+ 2.20
99	123	5/90	DENT		33.68	H9	
101	123	5/90	DENT		111.00	H9	
103	123	5/90	DENT		136.67	H9	
107	123	5/90	DENT		11.87	H9	
111	123	5/90	DENT		43.47	H9	
112	123	5/90	DENT		44.00	H9	
120	124	5/90	DENT		44.00	VM	
92	124	5/90	DENT		44.00	H9	
94	124	5/90	DENT		44.00	H9	
96	124	5/90	DENT		50.41	H9	
98	124	5/90	DENT		50.50	H9	
100	124	5/90	DENT		50.55	H9	
102	124	5/90	DENT		44.03	H9	
104	124	5/90	DENT		44.03	H9	
106	124	5/90	DENT		45.01	H9	
108	124	5/90	DENT		50.52	H9	
114	124	5/90	DENT		50.58	H9	
13	125	5/90	DENT		6.43	VM	
		5/90	DENT		7.24	C6	+ 7.80
37	125	5/90	DENT		6.09	C6	+14.10
		5/90	DENT		8.64	C6	+14.80
		5/90	DENT		13.38	C6	+22.60
87	125	5/90	DENT		6.05	H6	+14.60
93	125	5/90	DENT		11.20	VM	+11.50
95	125	5/90	DENT		49.74	H9	
97	125	5/90	DENT		51.75	H9	
99	125	5/90	DENT		96.40	H9	
		5/90	DENT		0.00	OTHER	

Plant: CALVERT CLIFFS UNIT 1
 Outage: 5/90

Steam Generator: 12

QUERY: All Dent Indications - All Elevations

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
101	128	5/90	DENT		48.66	H9	
103	1285	5/90	DENT		59.44	H9	
105	1285	5/90	DENT		46.32	H9	
107	1285	5/90	DENT		57.61	H9	
109	1285	5/90	DENT		58.24	H9	
90	1286	5/90	DENT		5.14	H8	+15.60
92	1286	5/90	DENT		6.98	C9	
94	1286	5/90	DENT		96.98	H9	
96	1286	5/90	DENT		70.07	H9	
98	1286	5/90	DENT		59.67	H9	
100	1286	5/90	DENT		43.07	H9	
102	1286	5/90	DENT		112.00	H9	
104	1286	5/90	DENT		118.30	H9	
106	1286	5/90	DENT		74.08	H9	
108	1286	5/90	DENT		23.40	H9	
110	1286	5/90	DENT		5.05	C3	
			DENT		6.87	H9	
114	128	5/90	DENT		6.31	H9	
13	1287	5/90	DENT		9.27	C6	+ 8.00
91	1287	5/90	DENT		35.16	H9	
95	1287	5/90	DENT		74.76	H9	
97	1287	5/90	DENT		80.82	H9	
99	1287	5/90	DENT		99.26	H9	
103	1287	5/90	DENT		5.11	H9	
92	1288	5/90	DENT		148.60	H9	
94	1288	5/90	DENT		56.96	H9	
98	1288	5/90	DENT		91.07	H9	
100	1288	5/90	DENT		15.12	C4	+17.70
		5/90	DENT		15.30	H9	
83	129	5/90	DENT		7.79	H8	
91	129	5/90	DENT		26.14	C9	
93	1299	5/90	DENT		107.90	H9	
95	1299	5/90	DENT		142.30	H9	
99	1299	5/90	DENT		39.04	H9	
78	1300	5/90	DENT		26.91	n9	
92	1300	5/90	DENT		7.38	H7	+ 3.70
81	1301	5/90	DENT		5.91	H9	
87	1301	5/90	DENT		6.38	C8	+ 7.20
91	1301	5/90	DENT		13.43	VM	+25.60
93	1301	5/90	DENT		55.20	H9	
		5/90	DENT		5.02	H9	
99	131	5/90	DENT		5.78	C9	
70	132	5/90	DENT		9.01	H9	
		5/90	DENT		6.62	C7	+ 2.80
86	132	5/90	DENT		16.01	H7	+18.30
92	132	5/90	DENT		14.02	C4	+21.40
94	132	5/90	DENT		77.16	H9	
98	132	5/90	DENT		45.62	H9	
		5/90	DENT		9.19	H8	+19.60
29	133	5/90	DENT		34.12	H9	
93	133	5/90	DENT		5.81	VM	
78	1334	5/90	DENT		12.82	H9	
47	1335	5/90	DENT		5.44	H1	+28.90
79	1335	5/90	DENT		9.24	C7	
87	1335	5/90	DENT		5.45	CTS-SF	+10.30
78	1336	5/90	DENT		9.07	DH	
86	1336	5/90	DENT		10.39	H8	+ 4.40
104	1336	5/90	DENT		8.51	C8	+ 1.80
13	1339	5/90	DENT		8.93	H9	
78	140	5/90	DENT		6.48	VM	
86	140	5/90	DENT		9.28	CTS-SF	+28.60
92	140	5/90	DENT		14.26	H5	+ 3.80
91	141	5/90	DENT		5.51	H9	
34	142	5/90	DENT		6.50	H9	+24.30
98	142	5/90	DENT		6.28	H6	+10.20
		5/90	DENT		6.66	HTS-SF	+27.30
			DENT		8.07	VH	

Plant: CALVERT CLIFFS UNIT 1
 Outage: 5/90

Steam Generator: 12

QUERY: All Dent Indications - All Elevations

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
13	143	5/90	DENT	7.24	VM		
31	143	5/90	DENT	6.45	CTS-SF	+30.20	
5	145	5/90	DENT	13.44	H5	+36.60	
7	145	5/90	DENT	15.42	H6	+5.600	
15	145	5/90	DENT	8.96	H1	+7.500	
37	145	5/90	DENT	7.68	C6	+16.500	
		5/90	DENT	11.90	C6	+17.800	
86	146	5/90	DENT	11.21	H5	+36.800	
7	149	5/90	DENT	16.14	H6	+5.400	
13	149	5/90	DENT	8.43	C6	+7.700	
9	151	5/90	DENT	6.19	H1	+17.100	
13	151	5/90	DENT	9.20	H6	+7.700	
67	151	5/90	DENT	5.66	C7	+8.900	
		5/90	DENT	5.56	C7	+13.700	
		5/90	DENT	8.95	C7	+16.000	
		5/90	DENT	5.65	C7	+24.500	
10	152	5/90	DENT	10.24	C8	+0.500	
7	152	5/90	DENT	8.77	C1	+38.400	
12	154	5/90	DENT	11.19	C6	+5.800	
36	154	5/90	DENT	5.72	C6	+10.200	
7	155	5/90	DENT	5.12	C4	+26.800	
11	155	5/90	DENT	12.94	C6	+5.600	
13	155	5/90	DENT	7.88	C6	+7.200	
32	156	5/90	DENT	7.67	C6	+7.700	
		5/90	DENT	13.99	VM		
5	163	5/90	DENT	13.44	VM		
14	164	5/90	DENT	9.04	C2	+38.10	
				5.86	CTS-SF	+25.20	

TOTAL TUBES FOUND = 1127

TOTAL INDICATIONS FOUND = 1301

TOTAL TUBES IN INPUT FILE = 8519

TOTAL TUBES INSPECTED = 8453

STEAM GENERATOR 12

F. List with Plot of Tubes Plugged
During May/June 1990

TUBES PLUGGED 5/90 OUTAGE

PLANT: CALVERT CLIFFS UNIT 1

OUTAGE: 5/90

1 = MEDH-CE (1)
4 = CONST (4)


TOTAL TUBES : 8519
STAYS (W) : 7

2 = MEDH-W (2)

GENERATOR: 12

3 = MEDH-GE (3)

TOTAL TUBES ASSIGNED : 3



Plant: CALVERT CLIFFS UNIT 1
Outage: 5/90

Steam Generator: 12

QUERY: TUBES PLUGGED 5/90 DUTAGE

ROW	LINE	DUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
72	78	5/90	PLUGGED	MECH-W		HTS-PR	
		5/90	PLUGGED	MECH-W		CTS-PR	
74	80	5/90	PLUGGED	MECH-W		HTS-PR	
		5/90	PLUGGED	MECH-W		CTS-PR	
123	93	5/90	PLUGGED	MECH-W		HTS-PR	
		5/90	PLUGGED	MECH-W		CTS-PR	
TOTAL TUBES FOUND				#	%		
TOTAL INDICATIONS FOUND				#	%		
TOTAL TUBES IN INPUT FILE				=	8519		
TOTAL TUBES INSPECTED				=	8453		

STEAM GENERATOR 12

G. List with Plot of all Tubes Plugged

ALL TUBES PLUGGED

PLANT: CALVERT CLIFFS UNIT 1 OUTAGES: 01/79 06/82 10/83 04/85 10/86 04/88 5/90


1 = MECH-DE (14)
4 = CONST (5)

TOTAL TUBES
STAYS (W) : 3549
: 7

2 = MECH-W (56)
3 = WELD-DE (10)

GENERATOR: 12

TOTAL TUBES ASSIGNED : 70



Plant: CALVERT CLIFFS UNIT 1
Outages: 01/79 06/82 10/82 04/85 10/86 04/88

Steam Generation: 12
5/90

QUER.: ALL TUBES PLUGGED

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
91	21	06/82	PLUGGED	MECH-N	CTG-PP		
		06/82	PLUGGED	MECH-N	HTG-PP		
9	27	04/85	PLUGGED	MECH-N	CTG-PP		
		04/85	PLUGGED	MECH-N	HTG-PP		
9	29	10/86	PLUGGED	MECH-DE	HTG-PP		
		10/86	PLUGGED	MECH-DE	CTG-PP		
104	34	06/82	PLUGGED	MECH-N	HTG-PP		
		06/82	PLUGGED	MECH-N	CTG-PP		
32	40	07/86	PLUGGED	MECH-N	HTG-PP		
		04/86	PLUGGED	MECH-N	CTG-PP		
31	41	04/86	PLUGGED	MECH-N	HTG-PP		
		04/86	PLUGGED	MECH-N	CTG-PP		
3	43	04/85	PLUGGED	MECH-N	HTG-PP		
		04/85	PLUGGED	MECH-N	CTG-PP		
1	45	04/86	PLUGGED	MECH-N	HTG-PP		
		04/86	PLUGGED	MECH-N	CTG-PP		
120	50	06/82	PLUGGED	MECH-N	HTG-PP		
		06/82	PLUGGED	MECH-N	CTG-PP		
56	58	04/85	PLUGGED	MECH-N	HTG-PP		
		04/85	PLUGGED	MECH-N	CTG-PP		
60	58	04/86	PLUGGED	MECH-N	HTG-PP		
		04/86	PLUGGED	MECH-N	CTG-PP		
56	60	04/85	PLUGGED	MECH-N	HTG-PP		
		04/85	PLUGGED	MECH-N	CTG-PP		
58	60	10/86	PLUGGED	MECH-DE	HTG-PP		
		10/86	PLUGGED	MECH-DE	CTG-PP		
55	61	10/86	PLUGGED	MECH-DE	HTG-PP		
		10/86	PLUGGED	MECH-DE	CTG-PP		
55	62	10/86	PLUGGED	MECH-DE	HTG-PP		
		10/86	PLUGGED	MECH-DE	CTG-PP		
61	65	04/86	PLUGGED	MECH-N	HTG-PP		
		04/86	PLUGGED	MECH-N	CTG-PP		
94	66	10/86	PLUGGED	MECH-DE	HTG-PP		
		04/86	PLUGGED	MECH-DE	CTG-PP		
93	67	10/86	PLUGGED	MECH-DE	HTG-PP		
104	69	06/82	PLUGGED	MECH-N	HTG-PP		
		06/82	PLUGGED	MECH-N	CTG-PP		
134	68	06/82	PLUGGED	MECH-N	HTG-PP		
		06/82	PLUGGED	MECH-N	CTG-PP		
96	72	10/86	PLUGGED	MECH-N	HTG-PP		
		10/86	PLUGGED	MECH-N	CTG-PP		
69	74	04/86	PLUGGED	MECH-N	HTG-PP		
		04/86	PLUGGED	MECH-N	CTG-PP		
72	78	5/90	PLUGGED	MECH-N	HTG-PP		
		5/90	PLUGGED	MECH-N	CTG-PP		
124	78	10/83	PLUGGED	MECH-N	HTG-PP		
		10/83	PLUGGED	MECH-N	CTG-PP		
74	80	5/90	PLUGGED	MECH-N	HTG-PP		
		5/90	PLUGGED	MECH-N	CTG-PP		
120	82	06/82	PLUGGED	MECH-N	HTG-PP		
		06/82	PLUGGED	MECH-N	CTG-PP		
70	84	04/86	PLUGGED	MECH-N	HTG-PP		
		04/86	PLUGGED	MECH-N	CTG-PP		
75	85	04/85	PLUGGED	MECH-N	HTG-PP		
		04/85	PLUGGED	MECH-N	CTG-PP		
77	85	04/86	PLUGGED	MECH-N	HTG-PP		
		04/86	PLUGGED	MECH-N	CTG-PP		
74	86	04/86	PLUGGED	MECH-N	HTG-PP		
		04/86	PLUGGED	MECH-N	CTG-PP		
78	86	04/86	PLUGGED	MECH-N	HTG-PP		
		04/86	PLUGGED	MECH-N	CTG-PP		
120	86	06/82	PLUGGED	MECH-N	HTG-PP		
		06/82	PLUGGED	MECH-N	CTG-PP		
139	87	10/86	PLUGGED	MECH-DE	HTG-PP		
		10/86	PLUGGED	MECH-DE	CTG-PP		
76	88	10/86	PLUGGED	MECH-DE	HTG-PP		
		10/86	PLUGGED	MECH-DE	CTG-PP		

Plant: CALVERT CLIFFS UNIT 1
 Outages: 01/79 06/82 10/83 04/85 10/84 04/86 5/90

Steam Gen.: 1171 12
 5/90

QUERY: ALL TUBES PLUGGED

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
140	88	04/85	PLUGGED	MECH-W		CTB-1P	
		04/85	PLUGGED	MECH-W		ITB-1P	
77	89	04/85	PLUGGED	MECH-W		ITB-1P	
		04/85	PLUGGED	MECH-W		ITB-1P	
76	90	04/85	PLUGGED	MECH-W		ITB-1P	
		04/85	PLUGGED	MECH-W		ITB-1P	
78	90	04/85	PLUGGED	MECH-W		ITB-1P	
		04/85	PLUGGED	MECH-W		ITB-1P	
81	91	04/85	PLUGGED	MECH-W		OTB-1P	
		04/85	PLUGGED	MECH-W		OTB-1P	
76	92	04/85	PLUGGED	MECH-W		OTB-1P	
		04/85	PLUGGED	MECH-W		OTB-1P	
78	92	10/86	PLUGGED	MECH-W		OTB-1P	
		10/86	PLUGGED	MECH-W		OTB-1P	
80	92	10/86	PLUGGED	MECH-W		OTB-1P	
		10/86	PLUGGED	MECH-W		OTB-1P	
73	93	04/85	PLUGGED	MECH-W		OTB-1P	
		04/85	PLUGGED	MECH-W		OTB-1P	
75	93	04/85	PLUGGED	MECH-W		OTB-1P	
		04/85	PLUGGED	MECH-W		OTB-1P	
123	93	5/90	PLUGGED	MECH-W		OTB-1P	
		5/90	PLUGGED	MECH-W		OTB-1P	
74	94	04/85	PLUGGED	MECH-W		OTB-1P	
		04/85	PLUGGED	MECH-W		OTB-1P	
76	94	04/85	PLUGGED	MECH-W		OTB-1P	
		04/85	PLUGGED	MECH-W		OTB-1P	
124	94	04/85	PLUGGED	CONST		OTB-1P	
		04/85	PLUGGED	CONST		OTB-1P	
75	95	04/85	PLUGGED	MECH-W		OTB-1P	
		04/85	PLUGGED	MECH-W		OTB-1P	
70	96	04/85	PLUGGED	MECH-W		OTB-1P	
		04/85	PLUGGED	MECH-W		OTB-1P	
74	96	04/85	PLUGGED	MECH-W		OTB-1P	
		04/85	PLUGGED	MECH-W		OTB-1P	
76	96	04/85	PLUGGED	MECH-W		OTB-1P	
		04/85	PLUGGED	MECH-W		OTB-1P	
71	97	04/85	PLUGGED	MECH-W		OTB-1P	
		04/85	PLUGGED	MECH-W		OTB-1P	
73	97	04/85	PLUGGED	MECH-W		OTB-1P	
		04/85	PLUGGED	MECH-W		OTB-1P	
73	99	04/85	PLUGGED	MECH-W		OTB-1P	
		04/85	PLUGGED	MECH-W		OTB-1P	
104	104	06/82	PLUGGED	MECH-W		OTB-1P	
		06/82	PLUGGED	MECH-W		OTB-1P	
134	104	06/82	PLUGGED	MECH-W		OTB-1P	
		06/82	PLUGGED	MECH-W		OTB-1P	
61	105	04/85	PLUGGED	MECH-W		OTB-1P	
		04/85	PLUGGED	MECH-W		OTB-1P	
10	108	04/85	PLUGGED	MECH-W		OTB-1P	
		04/85	PLUGGED	MECH-W		OTB-1P	
56	108	04/85	PLUGGED	MECH-W		OTB-1P	
		04/85	PLUGGED	MECH-W		OTB-1P	
120	122	06/82	PLUGGED	MECH-W		OTB-1P	
		06/82	PLUGGED	MECH-W		OTB-1P	
70	128	10/86	PLUGGED	MECH-W		OTB-1P	
		10/86	PLUGGED	MECH-W		OTB-1P	
104	138	06/82	PLUGGED	MECH-W		OTB-1P	
		06/82	PLUGGED	MECH-W		OTB-1P	
1	141	04/85	PLUGGED	MECH-W		OTB-1P	
		04/85	PLUGGED	MECH-W		OTB-1P	
85	147	04/85	PLUGGED	MECH-W		OTB-1P	
		04/85	PLUGGED	MECH-W		OTB-1P	
1	155	10/86	PLUGGED	MECH-W		OTB-1P	
		10/86	PLUGGED	MECH-W		OTB-1P	
30	160	04/85	PLUGGED	MECH-W		OTB-1P	
		04/85	PLUGGED	CONST		OTB-1P	
32	160	04/85	PLUGGED	MECH-W		OTB-1P	

***** BASE TURNAROUND CYCLE 3.0***** BUDGET DECEMBER 14, 1980

DELTA AM ***** BARDOCK & WILCOX CO. ***** PAGE 6

5

Plant: CALVERT CLIFFE UNIT 1
Outages: 01/79 06/82 10/83 04/85

10/86 04/88

Steam Generator 1 12
5/90


QUERY: ALL TUBES PLUGGED

ROW	LINE	OUTAGE	INDICATION	VALUE	VOLTS	LOCATION	INCHES
		04/85	PLUGGED	CONST		HTS-PE	
21	161	10/86	PLUGGED	MECH-CE		HTS-PE	
		10/86	PLUGGED	MECH-CE		CTS-PE	
47	161	10/88	PLUGGED	MECH-CE		HTS-PE	
		10/86	PLUGGED	MECH-CE		CTS-PE	
TOTAL TUBES FOUND				#	70		
TOTAL INDICATIONS FOUND				#	139		

APPENDIX III
Steam Generator Inspection Information

- A. Steam Generator Support Location and Nomenclature
- B. Steam Generator Tube Sheet Pattern and Number
System
- C. Eddy Current Inspection Acronyms

A. Steam Generator Support Location and Nomenclature



Rows Contacting Supports Above 8th TS

ROWS	NO. OF SUPPORTS	SUPPORT DESIGNATIONS
1-2	1	VM
3-35	5	DH, VM, DC
36-65	6	H7, DH, VM, DC, C7
66-73	7	H8, H7, DH, VM, DC, C7, C8, C9
74-89	9	VH, VH, H8, H7, DH, VM, DC, C7, C8, VC, C9
90-115	11	H10, VH, H8, H7, DH, VM, DC, C7, C8, VC, C9, C10
116-140	13	

B. S/G TUBE SHEET PATTERN AND NUMBERING SYSTEM

SAMPLE HOT LEG TUBE SHEET MAP

PLANT: CAL VENT CLIFFS

GENERATOR:

TOTAL TUBES: 5419
STAYS (W): 7

• = TUBE LOCATIONS

180 DEG

90 DEG

150 DEG

210 DEG

270 DEG

330 DEG

450 DEG

510 DEG

570 DEG

630 DEG

720 DEG

780 DEG

840 DEG

900 DEG

960 DEG

1020 DEG

1080 DEG

1140 DEG

1200 DEG

1260 DEG

1320 DEG

1380 DEG

1440 DEG

1500 DEG

1560 DEG

1620 DEG

1680 DEG

1740 DEG

1800 DEG

1860 DEG

1920 DEG

1980 DEG

2040 DEG

2100 DEG

2160 DEG

2220 DEG

2280 DEG

2340 DEG

2400 DEG

2460 DEG

2520 DEG

2580 DEG

2640 DEG

2700 DEG

2760 DEG

2820 DEG

2880 DEG

2940 DEG

3000 DEG

3060 DEG

3120 DEG

3180 DEG

3240 DEG

3300 DEG

3360 DEG

3420 DEG

3480 DEG

3540 DEG

3600 DEG

3660 DEG

3720 DEG

3780 DEG

3840 DEG

3900 DEG

HOT TEMPLATES "A"

← LINES →

C. EDDY CURRENT INSPECTION ACRONYMS

DNT - DENT
PLG - PLUG
PV - PERMEABILITY
INC - INCOMPLETE
RT - RETEST
RES - RESTRICTED
RBD - RETEST BAD DATA
DI - DISTORTED INDICATION
UDS - UNDEFINED SIGNAL
INF - INDICATION NOT FOUND
SQR - SQUIRREL
PID - POSITIVE IDENTIFICATION
NT - NO TEST
CU - COPPER
FIX - FIXTURE
TP - TEMPLATE PLUG
BLG - BULGE
IDI - INSIDE DIAMETER INDICATION
IDV - INSIDE DIAMETER VARIATION
INR - INDICATION NOT REPORTABLE
SLG - SLUDGE
XMR - EXTRA HARD ROLL
RTI - ROLL TRANSITION INDICATION
APT - ABSOLUTE POSITIVE TRACE
NDD - NO DETECTABLE DEGRADATION
NRH - NOT ROLLED HOT
NRC - NOT ROLLED COLD