

Regulatory Docket Filo



DOCKET 50-155, LICENSE DPR-20 -PALISADES PLANT

In accordance with previous commitments to the NRC, the CE Owners Group transmitted the generic report for "Overpressure Protection for Operating CE NSSS" dated December 3, 1976 submitted on the Millstone Unit No 2 Docket 50-366. The analysis in the generic report dealt with the 2560 MWt class plant which differs from Palisades in several areas.

The specific analysis to be performed for Falisades will demonstrate differences in operation of and/or equipment related to:

1. Primary Coolant System (PCS).

2. Shutdown Cooling System (SDC).

3. Safety Injection System (SI).

Operational procedures for Palisades require that the secondary side of the plant is cooled down whenever there is a plant shutdown. The Frimary Coolant Pumps (FCP) are operated until there are equilibrium conditions in the PCS (Thot and Toold are essentially equal) and the secondary side pressure is approximately atmospheric. This eliminates potential overpressurization incidents due to inadvertent SI during low pressure/temperature operation.

The Palisades p'ant does not have an interlock in the SDC system operation which isolates the sy tem during a pressure transient. There is a relief valve which has the capacity to relieve full flow of the three charging pumps if the letdown loop is inadvertently isolated during SDC operation.

Power-Operated Relief Valves (PORV) were provided in the initial plant design. At present, the PORV installation is operated with remote manual isolation values closed. If the plant specific analysis demonstrates a need for low set point operation of these values, a new actuation system will have to be provided. This modification could be completed during the planned 1977 refueling outage. Also, if testing of these values is required to determine water relief capacity, it may be more economical to purchase new qualified values.

Plant modifications are scheduled to be completed during the 1977 refueling outage which will provide continuous pressure and temperature recording capability. This modification involves the installation of a new low range pressure transmitter and modification of existing recorders.

In addition to the administrative controls implemented on November 1, 1976, further possible changes to administrative controls are still being considered to minimize the potential for overpressurization incidents. Completion of the CE specific plant analysis for Palisades, by April 1977, will provide the information needed to finalize our plans for pressure protection.

Ralph B Sewell Nuclear Licensing Administrator

CO: JGKeppler

2

NRC FORM 195 (2.76) NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL					DOCKET NUMBER 50-155 FILE NUMBER	
TO: MRC '		FROM _{Consumers} Power Co Jackson, Michigan R B Sewell		DATE OF DOCUMENT		
				DATE RECEIVED 12-8-76		
ORIGINAL COPY	UNCLASSIFIED	RIZED PROP ASSIFIED		INPUT FORM	NUMBER OF COPIES RECEIVED	
DESCRIPTION		-	ENC	LOSURE		
PLANT NAME: P	alisades			DO NOT I. ACKNOWL	EDGED	
SAFETY ASSIGNED AD: BRANCH CHIEF: PROJECT MANAGER: LIC. ASST. :	Zigr	FOR ACTION		RMATION ENVIRO ASSIGNED AD: BRANCH CHIEF: PROJECT MANAGER: LIC. ASST. :	12-8-76 ehf	
		INTERNAL	DISTR	UBUTION		
REC FILE	SYSTEM	S SAFETY	TT	PLANT SYSTEMS	SITE SAFETY &	
NRC PDR	HEINEM	AN	++	TEDESCO	ENVIRO ANALYSIS	
I & E (2)	SCHROE	DER		BENAROYA	DENTON & MULLER	
OELD				LAINAS		
GOSSICK & STAFF	ENGINE	ERING		IPPOLITO	ENVIRO TECH.	
MIPC	MACALR	Y		KIRKWOOD	ERNST	
CASE	KNIGHT				BALLARD	
HANAUER	SIHWEI	L		OPERATING REACTORS	SPANGLER	
HARLESS	PAWLIC	KI		STELLO		
					SITE TECH.	
PROJECT MANAGEME	ENT REACTO	R SAFETY		OPERATING TECH.	GAMMILL	
BOYD	ROSS		1	EISENHUT	STEPP	
P. COLLINS	NOVAK		1	SHAO	HULMAN	
HOUSTON	ROSZTO	CZY	1	BAER	OTTO ANALYCE	
PETERSON	CHECK		1	BUTLER	SITE ANALYSIS	
MELTZ			1	GRIMES	PUDICI	
HELTEMES	AT & I		nr	In onioins	BUNCH	
SKOVHOLT	SALTZM	AN	411	IK IIKII	VPECED	
	RUTBER	G	N	In Unium	CONTROL NUMBER	
	EXTERNA	LDISTRIBUTIO	N		CONTROL NOMBER	
AT DDD . Ch. laite	MI NAT. LA	B:	-+-+	BROOKHAVEN NAT. LAB	- 1	
LFDN: Charlevell	REC V T	E	-++	ULRIKSON (ORNL)		
TIC:	KLO V.I					
TIC: NSIC:	LA PDR				121106	
TIC: NSIC: ASLB:	LA PDR CONSULT	ANTS:		1	12406	

NRC FORM 195 17.76