

GENERAL EMERGENCY | SITE AREA EMERGENCY | ALERT | UNUSUAL EVENT

1 Rad Effluent
RG1.1 Reading on any Table R-1 effluent radiation monitor > column "GE" for > 15 min. (Notes 1, 2, 3, 4)
RG1.2 Dose assessment using actual meteorology indicates doses > 1,000 mrem TEDE or 5,000 mrem thyroid CDE at or beyond the SITE BOUNDARY (Note 4)
RG1.3 Field survey results indicate EITHER of the following at or beyond the SITE BOUNDARY:

2 Irradiated Fuel Event
RG2 Spent fuel pool level cannot be restored to at least the top of the fuel racks for 60 minutes or longer
Table R-1 Effluent Monitor Classification Thresholds
Table R-2 Safe Operation & Shutdown Rooms/Areas

3 Area Rad Levels
Table R-1 Effluent Monitor Classification Thresholds
Table R-2 Safe Operation & Shutdown Rooms/Areas

1 Security
HS1 HOSTILE ACTION within the Protected Area
HA1 HOSTILE ACTION within the OWNER CONTROLLED AREA or airbase attack threat within 30 minutes

2 Seismic Event
NOTE 1: The Emergency Coordinator should declare the event promptly upon determining that time limit has been exceeded, or will likely be exceeded.
NOTE 2: If an ongoing release is detected and the release start time is unknown, assume that the release duration has exceeded the specified time limit.

3 Natural or Tech. Hazard
NOTE 1: The pre-calculated effluent monitor values presented in EALs RA1.1, RS1.1 and RG1.1 should be used for emergency classification assessments until the results from a dose assessment using actual meteorology are available.
NOTE 2: If the equipment in the listed room or area was already inoperable or out-of-service before the event occurred, then no emergency classification is warranted.

4 Fire
NOTE 1: If the loss of containment cooling threshold is exceeded due to loss of both trains of VX-CARF, this EAL only applies if at least one train of VX-CARF is not operating, per design, after the 10 minute actuation delay for greater than or equal to 15 minutes.
NOTE 11: If the affected SAFETY SYSTEM was already inoperable or out of service before the hazardous event occurred, then this emergency classification is not warranted.

5 Hazardous Gases
Table H-2 Safe Operation & Shutdown Rooms/Areas
HA5 Gaseous release IMPEDING access to equipment necessary for normal plant operations, cooldown or shutdown

6 Control Room Evacuation
HS6 Inability to control a key safety function from outside the Control Room
HA6 Control Room evacuation resulting in transfer of plant control to alternate

7 EC Judgment
HG7 Other conditions exist which in the judgment of the Emergency Coordinator warrant declaration of a General Emergency
HS7 Other conditions existing that in the judgment of the Emergency Coordinator warrant declaration of an Alert

E ISFSI
Table E-1 ISFSI Dose Limits
NAC Magnastor
Transnuclear (TN-32)

1 Loss of Essential AC Power
SG1 Prolonged loss of all offsite and all onsite AC power to essential buses for 15 minutes or longer
SS1 Loss of all offsite and all onsite AC power to essential buses for 15 minutes or longer

2 Loss of Vital DC Power
RU2 Unplanned loss of water level above irradiated fuel
RU2.1 Unplanned water level drop in the REFUELING PATHWAY as indicated by low water level alarm or indication

3 Loss of CR Indications
None
Table S-3 Significant Transients
None

4 NCS Activity
None
Table S-2 Safety System Parameters
None

5 NCS Leakage
None
Table S-2 Safety System Parameters
None

6 RPS Failure
None
Table S-4 Communication Methods
None

7 Loss of Comm.
None
Table S-5 Hazardous Events
None

8 CMT Failure
None
Table S-5 Hazardous Events
None

9 Hazardous Event Affecting Safety Systems
None
Table F-2 Containment Radiation - R/hr (EMF51A & B)

F Fission Product Barriers
FG1 Loss of any two barriers
FS1 Loss OR potential loss of any two barriers (Table F-1)
FA1 Any loss OR any potential loss of either Fuel Clad or NCS (Table F-1)

Table F-1 Fission Product Barrier Threshold Matrix
Fuel Clad (FC) Barrier | Reactor Coolant System (NCS) Barrier | Containment (CMT) Barrier
Loss | Potential Loss | Loss | Potential Loss | Loss | Potential Loss

		GENERAL EMERGENCY						SITE AREA EMERGENCY						ALERT						UNUSUAL EVENT						
		1 2 3 4 5 6 NM						1 2 3 4 5 6 NM						1 2 3 4 5 6 NM						1 2 3 4 5 6 NM						
R	Abnorm. Rad Levels / Rad Effluent	1	<p>RG1 Release of gaseous radioactivity resulting in offsite dose greater than 1,000 mrem TEDE or 5,000 mrem thyroid CDE</p> <p>RG1.1 Reading on any Table R-1 effluent radiation monitor > column "SAE" for ≥ 15 min. (Notes 1, 2, 3, 4)</p> <p>RG1.2 Dose assessment using actual meteorology indicates doses > 1,000 mrem TEDE or 5,000 mrem thyroid CDE at or beyond the SITE BOUNDARY (Note 4)</p> <p>RG1.3 Field survey results indicate EITHER of the following at or beyond the SITE BOUNDARY:</p> <ul style="list-style-type: none"> - Closed window dose rates > 1,000 mR/hr expected to continue for ≥ 60 min. - Analyses of field survey samples indicate thyroid CDE > 5,000 mrem for 60 min. of inhalation. (Notes 1, 2) 						<p>RS1 Release of gaseous radioactivity resulting in offsite dose greater than 100 mrem TEDE or 500 mrem thyroid CDE</p> <p>RS1.1 Reading on any Table R-1 effluent radiation monitor > column "SAE" for ≥ 15 min. (Notes 1, 2, 3, 4)</p> <p>RS1.2 Dose assessment using actual meteorology indicates doses > 100 mrem TEDE or 500 mrem thyroid CDE at or beyond the SITE BOUNDARY (Note 4)</p> <p>RS1.3 Field survey results indicate EITHER of the following at or beyond the SITE BOUNDARY:</p> <ul style="list-style-type: none"> - Closed window dose rates > 100 mR/hr expected to continue for ≥ 60 min. - Analyses of field survey samples indicate thyroid CDE > 500 mrem for 60 min. of inhalation. (Notes 1, 2) 						<p>RA1 Release of gaseous or liquid radioactivity resulting in offsite dose greater than 10 mrem TEDE or 50 mrem thyroid CDE</p> <p>RA1.1 Reading on any Table R-1 effluent radiation monitor > column "ALERT" for ≥ 15 min. (Notes 1, 2, 3, 4)</p> <p>RA1.2 Dose assessment using actual meteorology indicates doses > 10 mrem TEDE or 50 mrem thyroid CDE at or beyond the SITE BOUNDARY (Note 4)</p> <p>RA1.3 Analysis of a liquid effluent sample indicates a concentration or release rate that would result in doses > 10 mrem TEDE or 50 mrem thyroid CDE at or beyond the SITE BOUNDARY for 60 min. of exposure (Notes 1, 2)</p> <p>RA1.4 Field survey results indicate EITHER of the following at or beyond the SITE BOUNDARY:</p> <ul style="list-style-type: none"> - Closed window dose rates > 10 mR/hr expected to continue for ≥ 60 min. - Analyses of field survey samples indicate thyroid CDE > 50 mrem for 60 min. of inhalation. (Notes 1, 2) 						<p>RU1 Release of gaseous or liquid radioactivity greater than 2 times the SLC limits for 60 minutes or longer</p> <p>RU1.1 Reading on any Table R-1 effluent radiation monitor > column "UE" for ≥ 60 min. (Notes 1, 2, 3)</p> <p>RU1.2 Sample analysis for a gaseous or liquid release indicates a concentration or release rate > 2 x SLC limits for 60 min. (Notes 1, 2)</p>					
		2	<p>RG2 Spent fuel pool level cannot be restored to at least the top of the fuel racks for 60 minutes or longer</p> <p>RG2.1 Spent fuel pool level cannot be restored to > 25 ft. (746 ft. ele.) (KFP5350 or NVP6530) for ≥ 60 min. (Note 1)</p>						<p>RS2 Spent fuel pool level at the top of the fuel racks</p> <p>RS2.1 Spent fuel pool level ≤ 25 ft. (746 ft. ele.) (KFP5350 or NVP6530)</p>						<p>RA2 Significant lowering of water level above, or damage to, irradiated fuel</p> <p>RA2.1 Uncovery of irradiated fuel in the REFUELING PATHWAY</p> <p>RA2.2 Damage to irradiated fuel resulting in a release of radioactivity</p> <p>AND</p> <p>A Trip 2 radiation alarm on any of the following radiation monitor indications:</p> <ul style="list-style-type: none"> - 1EMF17 (2EMF4) Spent Fuel Building Refueling Bridge - 1EMF16 (2EMF3) Containment Building Refueling Bridge (Mode 6) - 1EMF42 (2EMF42) Fuel Building Ventilation - 1EMF39 (2EMF39) Containment Gas <p>RA2.3 Spent fuel pool level < -15 ft. (756 ft. ele.) (KFP5350 or NVP6530)</p>						<p>RU2 Unplanned loss of water level above irradiated fuel</p> <p>RU2.1 UNPLANNED water level drop in the REFUELING PATHWAY as indicated by low water level alarm or indication</p> <p>AND</p> <p>UNPLANNED rise in corresponding area radiation levels as indicated by EITHER of the following radiation monitors:</p> <ul style="list-style-type: none"> - 1EMF17 (2EMF4) Spent Fuel Building Refueling Bridge (Mode 6) - 1EMF16 (2EMF3) Containment Building Refueling Bridge (Mode 6) 					
		3	<p>RG3 Area Rad Levels</p>						<p>RA3 Radiation levels that IMPEDE access to equipment necessary for normal plant operations, cooldown or shutdown</p> <p>RA3.1 Dose rates > 15 mR/hr in EITHER of the following areas: Control Room (1EMF12) OR Central Alarm Station (by survey)</p> <p>RA3.2 An UNPLANNED event results in radiation levels that prohibit or IMPEDE access to any Table R-2 rooms or areas (Note 5)</p>						<p>RU3 Confirmed SECURITY CONDITION or threat</p> <p>HU1 HOSTILE ACTION within the OWNER CONTROLLED AREA or anytime attack threat within 30 minutes</p> <p>HU1.1 A SECURITY CONDITION that does not involve a HOSTILE ACTION as reported by the Security Shift Supervisor</p> <p>HU1.2 Notification of a credible security threat directed at the site</p> <p>HU1.3 A validated notification from the NRC providing information of an aircraft threat</p>											
H	Hazards	1	<p>HS1 HOSTILE ACTION within the Protected Area</p> <p>HS1.1 A HOSTILE ACTION is occurring or has occurred within the PROTECTED AREA as reported by the Security Shift Supervisor</p>						<p>HA1 HOSTILE ACTION within the OWNER CONTROLLED AREA or anytime attack threat within 30 minutes</p> <p>HA1.1 A HOSTILE ACTION is occurring or has occurred within the OWNER CONTROLLED AREA as reported by the Security Shift Supervisor</p> <p>HA1.2 A validated notification from NRC of an aircraft attack threat within 30 min. of the site</p>						<p>HU2 Seismic event greater than OBE levels</p> <p>HU2.1 Seismic event > OBE as indicated by OBE EXCEEDED alarm on 1AD-13, E7</p>											
		2	<p>None</p>						<p>None</p>						<p>None</p>											
		3	<p>None</p>						<p>None</p>						<p>None</p>											
E	ISFSI	1	<p>None</p>						<p>None</p>						<p>None</p>											
		2	<p>None</p>						<p>None</p>						<p>None</p>											
		3	<p>None</p>						<p>None</p>						<p>None</p>											

		GENERAL EMERGENCY						SITE AREA EMERGENCY						ALERT						UNUSUAL EVENT																																																		
		1 2 3 4 5 6 NM						1 2 3 4 5 6 NM						1 2 3 4 5 6 NM						1 2 3 4 5 6 NM																																																		
C	Cold SD/ Refuel System Malfunc.	1	<p>CG1 Loss of NCS inventory affecting fuel clad integrity with containment challenge</p> <p>CG1.1 NCS water level cannot be monitored for ≥ 30 min. (Note 1)</p> <p>AND</p> <p>Core uncovery is indicated by any of the following:</p> <ul style="list-style-type: none"> - UNPLANNED increase in any Table C-6 sump or tank level due to a loss of NCS inventory - Visual observation of UNISOLABLE NCS leakage - Reactor Building Refueling Bridge Monitor 1EMF16 (2EMF3) reading > 9,000 mR/hr (Mode 6) - Erratic Source Range or Wide Range Flux Monitor indication <p>AND</p> <p>Any Containment Challenge indication, Table C-1</p>						<p>CS1 Loss of NCS inventory affecting core decay heat removal capability</p> <p>CS1.1 NCS water level cannot be monitored for ≥ 30 min. (Note 1)</p> <p>AND</p> <p>Core uncovery is indicated by any of the following:</p> <ul style="list-style-type: none"> - UNPLANNED increase in any Table C-6 sump or tank level due to a loss of NCS inventory - Visual observation of UNISOLABLE NCS leakage - Reactor Building Refueling Bridge Monitor 1EMF16 (2EMF3) reading > 9,000 mR/hr (Mode 6) - Erratic Source Range or Wide Range Flux Monitor indication 						<p>CA1 Loss of NCS inventory</p> <p>CA1.1 Loss of NCS inventory as indicated by NCS water level < 5 in. above hotleg centerline</p> <p>CA1.2 NCS water level cannot be monitored for ≥ 15 min. (Note 1)</p> <p>AND EITHER</p> <ul style="list-style-type: none"> - UNPLANNED increase in any Table C-6 sump or tank level due to a loss of NCS inventory - Visual observation of UNISOLABLE NCS leakage 						<p>CU1 UNPLANNED loss of NCS inventory for 15 minutes or longer</p> <p>CU1.1 UNPLANNED loss of reactor coolant results in NCS water level less than a required lower limit for ≥ 15 min. (Note 1)</p> <p>CU1.2 NCS water level cannot be monitored</p> <p>AND EITHER</p> <ul style="list-style-type: none"> - UNPLANNED increase in any Table C-6 sump or tank level due to a loss of NCS inventory - Visual observation of UNISOLABLE NCS leakage 																																																	
		2	<p>Table C-1 Containment Challenge Indications</p> <ul style="list-style-type: none"> - CONTAINMENT CLOSURE not established (Note 6) - Containment hydrogen concentration > 6% - UNPLANNED rise in containment pressure 						<p>Table C-2 AC Power Sources</p> <p>Offsite</p> <ul style="list-style-type: none"> - ATC (Train A) - SATA (Train A) - ATD (Train B) - SATB (Train B) <p>Onsite</p> <ul style="list-style-type: none"> - D/G 1(2) A (Train A) - D/G 1(2) B (Train B) 						<p>CA2 Loss of all offsite and all onsite AC power to essential buses for 15 minutes or longer</p> <p>CA2.1 Loss of all offsite and all onsite AC power capability to essential 4160V buses 1(2)ETA and 1(2)ETB for ≥ 15 min. (Note 1)</p> <p>CA3 Inability to maintain plant in cold shutdown</p> <p>CA3.1 UNPLANNED increase in NCS temperature to > 200°F for > Table C-3 duration (Notes 1, 9)</p> <p>OR</p> <p>UNPLANNED NCS pressure increase > 20 psig due to a loss of NCS cooling (this does not apply during water-solid plant conditions)</p>						<p>CU2 Loss of all but one AC power source to essential buses for 15 minutes or longer</p> <p>CU2.1 AC power capability, Table C-2, to essential 4160V buses 1(2)ETA and 1(2)ETB reduced to a single power source for ≥ 15 min. (Note 1)</p> <p>AND</p> <p>Any additional single power source failure will result in loss of all AC power to SAFETY SYSTEMS</p>																																																	
		3	<p>Table C-6 Sumps/Tanks</p> <ul style="list-style-type: none"> - NCDT - PRT - CFAE sump - NDNS sump - RHT - WDT - WEFT - SRST 						<p>Table C-3 NCS Heat-up Duration Thresholds</p> <table border="1"> <thead> <tr> <th>NCS Status</th> <th>Containment Closure Status</th> <th>Heat-up Duration</th> </tr> </thead> <tbody> <tr> <td>Intact (but not reduced inventory)</td> <td>N/A</td> <td>60 min.*</td> </tr> <tr> <td>Not intact OR At reduced inventory</td> <td>established</td> <td>20 min.*</td> </tr> <tr> <td></td> <td>not established</td> <td>0 min.</td> </tr> </tbody> </table> <p>* If an NCS heat removal system is in operation within this time frame and NCS temperature is being reduced, the EAL is not applicable</p>						NCS Status	Containment Closure Status	Heat-up Duration	Intact (but not reduced inventory)	N/A	60 min.*	Not intact OR At reduced inventory	established	20 min.*		not established	0 min.	<p>Table C-4 Communication Methods</p> <table border="1"> <thead> <tr> <th>System</th> <th>Onsite</th> <th>ORO</th> <th>NRC</th> </tr> </thead> <tbody> <tr> <td>Public Address</td> <td>X</td> <td></td> <td></td> </tr> <tr> <td>Internal Telephones</td> <td>X</td> <td></td> <td></td> </tr> <tr> <td>Onsite Radios</td> <td>X</td> <td></td> <td></td> </tr> <tr> <td>DEMNET</td> <td></td> <td>X</td> <td></td> </tr> <tr> <td>Offsite Radio System</td> <td></td> <td>X</td> <td></td> </tr> <tr> <td>Commercial Telephones</td> <td></td> <td>X</td> <td>X</td> </tr> <tr> <td>NRC Emergency Telecommunications System (ETS)</td> <td></td> <td></td> <td>X</td> </tr> </tbody> </table>						System	Onsite	ORO	NRC	Public Address	X			Internal Telephones	X			Onsite Radios	X			DEMNET		X		Offsite Radio System		X		Commercial Telephones		X	X	NRC Emergency Telecommunications System (ETS)			X	<p>CU3 UNPLANNED increase in NCS temperature</p> <p>CU3.1 UNPLANNED increase in NCS temperature to > 200°F due to loss of decay heat removal capability</p> <p>CU3.2 Loss of all NCS temperature and NCS level indication for ≥ 15 min. (Note 1)</p> <p>CU4 Loss of Vital DC power for 15 minutes or longer</p> <p>CU4.1 < 105 VDC bus voltage indications on Technical Specification required 125 VDC buses for ≥ 15 min. (Note 1)</p> <p>CU5 Loss of all onsite or offsite communications capabilities</p> <p>CU5.1 Loss of all Table C-4 onsite communication methods OR Loss of all Table C-4 ORO communication methods OR Loss of all Table C-4 NRC communication methods</p>					
		NCS Status	Containment Closure Status	Heat-up Duration																																																																		
		Intact (but not reduced inventory)	N/A	60 min.*																																																																		
		Not intact OR At reduced inventory	established	20 min.*																																																																		
	not established	0 min.																																																																				
System	Onsite	ORO	NRC																																																																			
Public Address	X																																																																					
Internal Telephones	X																																																																					
Onsite Radios	X																																																																					
DEMNET		X																																																																				
Offsite Radio System		X																																																																				
Commercial Telephones		X	X																																																																			
NRC Emergency Telecommunications System (ETS)			X																																																																			
4	<p>None</p>						<p>None</p>						<p>None</p>																																																									
5	<p>None</p>						<p>None</p>						<p>None</p>																																																									
6	<p>None</p>						<p>None</p>						<p>None</p>																																																									
H	Hazards	1	<p>None</p>						<p>None</p>						<p>None</p>																																																							
		2	<p>None</p>						<p>None</p>						<p>None</p>																																																							
		3	<p>None</p>						<p>None</p>						<p>None</p>																																																							
E	ISFSI	1	<p>None</p>						<p>None</p>						<p>None</p>																																																							
		2	<p>None</p>						<p>None</p>						<p>None</p>																																																							
		3	<p>None</p>						<p>None</p>						<p>None</p>																																																							

NOTES

Note 1: The Emergency Coordinator should declare the event promptly upon determining that time limit has been exceeded, or will likely be exceeded.

Note 2: If an ongoing release is detected and the release start time is unknown, assume that the release duration has exceeded the specified time limit.

Note 3: If the effluent flow past an effluent monitor is known to have stopped, indicating that the release path is isolated, the effluent monitor reading is no longer VALID for classification purposes.

Note 4: The pre-calculated effluent monitor values presented in EALs RA1.1, RS1.1 and RG1.1 should be used for emergency classification assessments until the results from a dose assessment using actual meteorology are available.

Note 5: If the equipment in the listed room or area was already inoperable or out-of-service before the event occurred, then no emergency classification is warranted.

Note 6: If CONTAINMENT CLOSURE is re-established prior to exceeding the 30-minute time limit, declaration of a General Emergency is not required.

Note 7: This EAL does not apply to routine traffic impediments such as fog, snow, ice, or vehicle breakdowns or accidents.

Note 8: A manual trip action is any operator action, or set of actions, which causes the control rods to be rapidly inserted into the core, and does not include manually driving in control rods or implementation of boron injection strategies.

Note 9: In the absence of reliable NCS temperature indication caused by the loss of decay heat removal capability, classification should be based on the NCS pressure increase criteria when in Mode 5 or based on time to boil data when in Mode 6.

Note 10: If the loss of containment cooling threshold is exceeded due to loss of both trains of VX-CARF, this EAL only applies if at least one train of VX-CARF is not operating, per design, after the 10 minute actuation delay for greater than or equal to 15 minutes.

Note 11: If the affected SAFETY SYSTEM was already inoperable or out of service before the hazardous event occurred, then this emergency classification is not warranted.

Note 12: If the hazardous event only resulted in VISIBLE DAMAGE, with no indications of degraded performance to at least one train of a SAFETY SYSTEM, then this emergency classification is not warranted.

Date & Time of Shutdown

_____ Date _____ Time _____

