

NINE MILE POINT NUCLEAR STATION / P.O. BOX 32 LYCOMING, NEW YORK 13093 / TELEPHONE (315) 343-2110

July 21, 1981

Mr. Boyce H. Grier, Director  
United States Nuclear Regulatory  
Commission - Region I  
631 Park Avenue  
King of Prussia, Pennsylvania 19406



RE: Docket No. 50-220  
LER 81-27

Dear Mr. Grier:

In accordance with Nine Mile Point Nuclear Station Unit #1 Technical Specifications, we hereby submit the following Licensee Event Report:

81-27 which is being submitted in accordance with  
Section 6.9.2(b)4, Abnormal degradation of  
systems designed to contain radioactive  
material resulting from the fission process.

This report was completed in the format designated in NUREG-0161,  
dated July 1977.

The results of the local leak rate tests given in this LER were reported  
to the NRC Resident Inspector on June 23, 1981, within twenty-four hours  
of completion of the tests. The final sum of all B & C type local leak  
rate tests performed during this outage was less than 60% La. as re-  
quired by Appendix J 10CFR50.

Very truly yours,

*Thomas E. Lempges*

Thomas E. Lempges  
Vice President  
Nuclear Generation

RCN/jl  
Attachments (3 copies)  
xc: Director, Office of I&E (30 copies)  
Director, Office of MIPC (3 copies)

IE22  
5/1