NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | M A P P S 1 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T 01 | REPORT SOURCE L (6) | 0 5 0 - 0 2 9 3 (7) | 0 6 2 1 8 1 (8) | 0 7 2 1 8 1 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 On June 21, 1981 at 1340 hours unidentified drywell leak rate was measured at
03 6.24 gpm. Technical Specifications require that the reactor be in the cold shut-
04 down condition within 24 hours after the unidentified leak rate exceeds 5 gpm.
05 Operating personnel immediately initiated reactor shutdown and notified the NRC
06 Operations Center. The leakage was reduced to within permitted limits within 5
07 hours and the reactor returned to steady state operations.
08

09 SYSTEM CODE: C I (11) | CAUSE CODE: E (12) | CAUSE SUBCODE: X (13) | COMPONENT CODE: V A L V E X (14) | COMP. SUBCODE: E (15) | VALVE SUBCODE: D (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 8 1 | — | SEQUENTIAL REPORT NO. 0 3 3 | / | OCCURRENCE CODE 0 3 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN: E (18) | FUTURE ACTION: Z (19) | EFFECT ON PLANT: B (20) | SHUTDOWN METHOD: Z (21) | HOURS (22): 0 0 0 5 | ATTACHMENT SUBMITTED: N (23) | NPRD-4 FORM SUB.: N (24) | PRIME COMP. SUPPLIER: N (25) | COMPONENT MANUFACTURER: W 0 3 0 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Maintenance personnel, by electrically backseating the inboard cleanup (1201-2)
11 valve, eliminated the excess leakage. The valve was repacked during a forced outage
12 on July 3, 1981.
13
14

15 FACILITY STATUS: E (28) | % POWER: 1 0 0 (29) | OTHER STATUS (30): N.A. | METHOD OF DISCOVERY: A (31) | DISCOVERY DESCRIPTION (32): Operational Event

16 ACTIVITY RELEASED: Z (33) | CONTENT OF RELEASE: Z (34) | AMOUNT OF ACTIVITY (35): N.A. | LOCATION OF RELEASE (36): N.A.

17 PERSONNEL EXPOSURES — NUMBER: 0 0 0 (37) | TYPE: Z (38) | DESCRIPTION (39): N.A.

18 PERSONNEL INJURIES — NUMBER: 0 0 0 (40) | DESCRIPTION (41): N.A.

19 LOSS OF OR DAMAGE TO FACILITY (43) — TYPE: Z (42) | DESCRIPTION: N.A.

20 PUBLICITY — ISSUED: N (44) | DESCRIPTION (45): N.A. | NRC USE ONLY

8107290128 810721
PDR ADOCK 05000293
S PDR

J. Thomas McLoughlin PHONE: 617-746-7900