

## CHARLES CENTER . P. O. BOX 1475 . BALTIMORE, MARYLAND 21203

ARTHUR E. LUNDVALL JR. VICE PRESIDENT SUPPLY

> Office of Nuclear Reactor Regulation U. S. Nuclear Regulatory Commission Washington, D. C. 20555

Attn: Mr. D. G. Eisenhut, Director Division of Licensing

> Calvert Cliffs Nuclear Power Plant Subject: Units Nos. 1 and 2; Dockets Nos. 50-317 and 50-318 Response to NUREG-0737

Reference: (a) Telephone conversation between Mr. E. L. Conner (NRC) and M. D. Fatterson (BG&E) on 8/5/81.

Q. Auguet

AL REGREATOR

1981

Gentlemen:

We are providing the following discussions of the indicated Action Plan items to confirm statements made in a recent telephone conversation (reference (a)).

Item II.B.4.1 Operator Training

This item requires development and implementation of a program to ungrade training on the use of installed equipment and systems to m. the accidents where the reactor core is severely damaged.

Training of operators in accordance with this requirement is in progress. The operators in the class graduating on September 28, 1981 will have completed this training in the course of their license studies.

Lesson plans have been under development since June for retraining all other staff license holders. The retraining program will begin in October and will be completed by January 1, 1982.

Item II.E.1 Auxiliary Feedwater System Automatic Initiation Flow Indication

Safety-grade flow indication and automatic AFWS initiation systems are installed.

Item II.E.4.2.7 Radiation Signal on Purge Valves

Our containment purge valves isolate on actuation of the high radiation alarm.

II.F.1.3 Containment High Range Radiation Monitor

We expect to comply with all of the requirements of this item by January 1, 1982.

If any additional information is required, we would be pleased to provide it to you.

Very truly yours,

Files Jon m. ?

for A. E. Lundvall, Jr. Vice President-Supply

cc: J. A. Biddison, Esquire G. F. Trowbridge, Esquire Messrs. E. L. Conner, Jr. - NRC R. E. Architzel - NRC