

TEXAS UTILITIES SERVICES INC.

2001 BRYAN TOWER · DALLAS, TEXAS 75201

Log # TXX-3386

File # 822

August 14, 1981

Mr. Spottswood Burwell  
Licensing Project Manager  
U. S. Nuclear Regulatory Commission  
Office of Nuclear Reactor Regulation  
Washington, D.C. 20555



SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION  
SSI SEDIMENTATION MONITORING

Dear Mr. Burwell:

The discussion below is in response to SER "Outstanding Issue" number 2:

Inspections of the service water intake channel for sedimentation buildup will be performed at the frequencies stated in Regulatory Guide 1.127. This inspection will consist of a determination of the elevation at the bottom of the intake channel at three locations along its length. The same location will be used each time the inspection is performed.

If it is determined that, as a result of these inspections, the sediment has accumulated enough to increase the bottom elevation one and one-half (1.5) feet over the entire length of the inspection area, then measures will be employed to remove the sediment from the intake channel. At that time, procedures will be developed and approved to accomplish this task.

This statement on inspection for sedimentation will be added to FSAR Section 2.4.8 by the next amendment.

Sincerely,

*H. C. Schmidt*

H. C. Schmidt

RAW:tls

*Boo  
5/10*