


AUG 5 1981

Distribution

- Docket File
- NRC PDR
- Local PDR
- ORB 1 File
- Eisenhut
- LD
- OI&E (3)
- S. Varga
- D. Chaney
- C. Parrish
- NSIC
- TERA
- ACRS (10)
- L. Phillips
- T. Huang



Docket No. 50-334

Mr. J. J. Carey, Vice President  
 Nuclear Division  
 Duquesne Light Company  
 P. O. Box 4  
 Shippingport, Pennsylvania 15077

Dear Mr. Carey:

SUBJECT: TMI ACTION PLAN ITEM II.F.2.3 (NUREG-0737), WESTINGHOUSE REACTOR  
 VESSEL LEVEL INSTRUMENTATION SYSTEM FOR MONITORING INADEQUATE  
 CORE COOLING

Re: Beaver Valley

The NRC staff has completed its review of the Westinghouse Summary Report on their reactor vessel level instrumentation system for monitoring inadequate core cooling, which was submitted in December 1980. The report was submitted in response to TMI Action Plan II.F.2.3 of NUREG-0737. Enclosed is a request for additional information. Your response is requested before September 1, 1981.

Sincerely,

Original Signed By:

Steven A. Varga, Chief  
 Operating Reactors Branch No. 1  
 Division of Licensing

Enclosure:  
 Request for Additional  
 Information

cc: See next page

8108280553 810805  
 PDR ADOCK 05000334  
 PDR

OFFICE	ORB 1	ORB 5	ORB 5	ORB 1			
SURNAME	DChaney	HSmith/rs	JShea	SVarga			
DATE	8/4/81	8/4/81	8/4/81	8/5/81			

Mr. J. J. Carey  
Duquesne Light Company

cc: Mr. R. J. Washabaugh, QA Manager  
Duquesne Light Company  
Quality Assurance Department  
Post Office Box 4  
Shippingport, Pennsylvania 15077

Mr. J. A. Werling  
Station Superintendent  
Duquesne Light Company  
Beaver Valley Power Station  
Post Office Box 4  
Shippingport, Pennsylvania 15077

Mr. T. D. Jones, Manager  
Nuclear Operations  
Duquesne Light Company  
Post Office Box 4  
Shippingport, Pennsylvania 15077

Mr. F. J. Bissert, Manager  
Nuclear Support Services  
Duquesne Light Company  
Nuclear Division  
Post Office Box 4  
Shippingport, Pennsylvania 15077

B. F. Jones Memorial Library  
663 Franklin Avenue  
Aliquippa, Pennsylvania 15001

Mr. R. M. Mafrice, Nuclear Engineer  
Duquesne Light Company  
435 Sixth Avenue  
Pittsburgh, Pennsylvania 15219

Mr. R. E. Martin  
Duquesne Light Company  
435 Sixth Avenue  
Pittsburgh, Pennsylvania 15219

Mr. N. R. Tonet, Manager  
Nuclear Engineering  
Duquesne Light Company  
Nuclear Division  
Shippingport, Pennsylvania 15077

Gerald Charnoff, Esquire  
Jay E. Silberg, Esquire  
Shaw, Pittman, Potts and Trowbridge  
1800 M Street, N.W.  
Washington, D. C. 20036

Karin Carter, Esquire  
Special Assistant Attorney General  
Bureau of Administrative Enforcement  
5th Floor, Executive House  
Harrisburg, Pennsylvania 17120

Mr. Roger Tappan  
Stone & Webster Engineering Corporation  
P.O. Box 2325  
Boston, Massachusetts 02107

Mr. F. Noon  
R & D Center  
Westinghouse Electric Corporation  
Building 7-303  
Pittsburgh, Pennsylvania 15230

Marvin Fein  
Utility Counsel  
City of Pittsburgh  
313 City-County Building  
Pittsburgh, Pennsylvania 15219

Mr. John A. Levin  
Public Utility Commission  
P.O. Box 3265  
Harrisburg, Pennsylvania 17120

Irwin A. Popowsky, Esquire  
Office of Consumer Advocate  
1425 Strawberry Square  
Harrisburg, Pennsylvania 17108

Charles A. Thomas, Esquire  
Thomas and Thomas  
212 Locust Street  
Box 999  
Harrisburg, Pennsylvania 17108

Mr. J. J. Carey  
Duquesne Light Company

cc: Mr. J. D. Sieber Manager  
Nuclear Safety and Licensing  
Duquesne Light Company  
Nuclear Division  
Post Office Box 4  
Shippingport, Pennsylvania 15077

Resident Inspector  
U. S. Nuclear Regulatory Commission  
Post Office Box 298  
Shippingport, Pennsylvania 15077

E. P. Rahe  
Manager Nuclear Safety Department  
Westinghouse Electric Corporation  
Nuclear Tech Div.  
Box 355  
Pittsburgh, Pennsylvania 15230

REQUEST FOR ADDITIONAL INFORMATION  
ON SUMMARY REPORT  
"WESTINGHOUSE REACTOR VESSEL LEVEL INSTRUMENTATION SYSTEM  
FOR MONITORING INADEQUATE CORE COOLING" (7964 4 44)

---

1. Justify that the single upper head penetration meets the "single failure" requirement of NUREG 0737 and show that it does not negate the redundancy of the two instrument trains.
2. Describe the location of the level system displays in the control room with respect to other plant instrument displays related to ICC monitoring, in particular, the saturation meter display and the core exit thermocouple display.
3. Describe the provisions and procedures for on-line verification, calibration and maintenance.
4. Describe the diagnostic techniques and criteria to be used to identify malfunctioning components.
5. Estimate the in-service life under conditions of normal plant operations and describe the methods used to make the estimate, and the data and sources used.
6. Explain how the value of the system accuracy (given as +/- 5%) was derived. How were the uncertainties from the individual components of the system combined? What were the random and systematic errors assumed for each component? What were the sources of these estimates?
7. Assume a range of sizes for "small break" LOCA's. What are the relative times available for each size break for the operator to initiate action to recover the plant from the accident and prevent damage to the core? What is the dividing line between a "small break" and a "large break"?
8. Describe how the system response time was estimated. Explain how the response times of the various components (differential pressure transducers, connecting lines and isolators) affect the response time.
9. There are indications that the TMI-2 core may be up to 95% blocked. Estimate the effect of partial blockage in the core on the differential pressure measurements for a range of values from 0 to 95% blockage.

10. Describe the effects of reverse flows within the reactor vessel on the indicated level.
11. What is the experience, if any, of maintaining Dp cells at 300% overrange for long periods of time?
12. Five conditions were identified which could cause the Dp level system to give ambiguous indications. Discuss the nature of the ambiguities for 1. accumulator injection into a highly voided downcomer, 2. when the upper head behaves as a pressurizer, 3. upper plenum injection, and 4. periods of void redistribution.
13. No recommendations are made as to the uncertainties of the pressure or temperature transducers to be used, but the choice appears to be left to the owner or AE. What is the upper limit of uncertainties that should be allowed? Describe the effect of these uncertainties on the measurement of level. What would be the effect on the level measurement should these uncertainties be exceeded?
14. Only single RTD sensors on each vertical run are indicated to determine the temperatures of the impulse lines. Where are they to be located? What are the expected temperature gradients along each line under normal operating conditions and under a design basis accident? What is the worst case error that could result from only determining the temperature at a single point on each line?
15. What is the source of the tables or relationships used to calculate density corrections for the level system?
16. The microprocessor system is stated to display the status of the sensor input. Describe how is this indicated and what this actually means with respect to the status of the sensor itself and the reliability of the indication.
17. Describe the provisions for preventing the draining of either the upper head or hot leg impulse lines during an accident. What would be the resultant errors in the level indications should such draining occur?
18. Discuss the effect on the level measurement of the release of dissolved, noncondensable gases in the impulse lines in the event of a depressurization.
19. In some tests at Semi-scale, voiding was observed in the core while the upper head was still filled with water. Discuss the possibility of cooling the core-exit thermocouples by water draining down out of the upper head during or after core voiding with a solid upper head.

20. Describe the behavior of the level measurement system when the upper head is full, but the lower vessel is not.
21. One discussion of the microprocessor system states that water in the upper head is not reflected in the plot. Does this mean that there is no water in the upper head or that the system is indifferent to water in the upper head under these conditions?
22. Describe the details of the pump flow/Dp calculation. Discuss the possible errors.
23. Have tests been run with voids in the vessel? Describe the results of these tests.
24. Estimate the expected accuracy of the system after an ICC event.
25. Describe how the conversion of RTD resistance to temperature made in the analog level system.