NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1	C T H N P 1 (2)	0 0 - 0 0 0 0 0 - 0 0 (3)	4 1 1 1 1 (4)	(5)
	LICENSEE CODE	LICENSE NUMBER	LICENSE TYPE	CAT

CON'T 0 1	REPORT SOURCE L (6)	0 5 0 - 0 2 1 3 (7)	0 8 0 3 8 1 (8)	0 8 1 7 8 1 (9)
		DOCKET NUMBER	EVENT DATE	REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 Following repairs, for inability to phase emergency diesel generator during
0 3 surveillance test, the diesel was being test run for two hours when it was observed
0 4 to have overloaded itself. The normal load rating of 2850 KW was exceeded for
0 5 approximately two minutes and reached a maximum of 3300 KW exceeding our technical
0 6 specification limit of 2850 KW maximum.
0 7
0 8

	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
0 9	E E (11)	X (12)	Z (13)	G E N E R A (14)	D (15)	Z (16)

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	8 1	—	0 1 1	/	0 1	T	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
E (18)	Z (19)	Z (20)	Z (21)	0 0 0 0	N (23)	N (24)	X (25)	G 1 0 0 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Load was manually reduced and adjustments made to stability potentiometer.
1 1 The test run was completed with no further overloading difficulties.
1 2
1 3
1 4

	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
1 5	E (28)	1 0 0 (29)	N/A	C (31)	Testing following repairs

	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
1 6	Z (33)	Z (34)	N/A	N/A

PERSONNEL EXPOSURES

	NUMBER	TYPE	DESCRIPTION (39)
1 7	0 0 0 (37)	Z (38)	N/A

PERSONNEL INJURIES

	NUMBER	DESCRIPTION (41)
1 8	0 0 0 (40)	N/A

LOSS OF OR DAMAGE TO FACILITY (43)

	TYPE	DESCRIPTION
1 9	Z (42)	N/A

PUBLICITY

	ISSUED	DESCRIPTION (45)	NRC USE ONLY
2 0	N (44)	N/A	

8108310330 810817
PDR ADOCK 05000213
S PDR

NAME OF PREPARER: S. T. Fleming PHONE: (203) 267-2556

GPO 917-926