

APPENDIX A

NOTICE OF VIOLATION

Tennessee Valley Authority
Yellow Creek 1

Docket No. 50-566
License No. CPPR-172

As a result of the inspection conducted on June 1-5, 1981, and in accordance with the Interim Enforcement Policy, 45 FR 66754 (October 7, 1980), the following violation was identified.

10 CFR 50, Appendix B, Criterion V and the accepted QA program described in TVA's Topical Report (TVA-TR75-1) Section 17.1A.5 requires that activities affecting quality shall be accomplished in accordance with instructions, procedures or drawings. Procedure RIS and PM M-460 require a frequency for preventive maintenance inspections of NSSS reactor coolant piping assemblies to be conducted every two weeks.

Contrary to the above, Prevent Cards examined in the Document Control Room for CE Reactor Coolant Piping (Contract No. 848402, S/C KNZVY1) for the period January 1981 through May 1981 revealed that no inspections were documented (signature and date) as having been performed at the required frequency for the weeks beginning 3/23, 4/20 and 5/18/81.

This is a Severity Level VI Violation (Supplement II.F).

Pursuant to the provisions of 10 CFR 2.201, you are hereby required to submit to this office within thirty days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violation; (2) the reasons for the violation if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown. Under the authority of Section 182 of the Atomic Energy Act of 1954, as amended, this response shall be submitted under oath or affirmation.

Date: JUL 16 1981