



SMUD

SACRAMENTO MUNICIPAL UTILITY DISTRICT □ 6201 S Street, Box 15830, Sacramento, California 95813; (916) 452-3211

September 11, 1981

R H ENGELKEN, DIRECTOR
REGION V OFFICE OF INSPECTION & ENFORCEMENT
U S NUCLEAR REGULATORY COMMISSION
1990 N CALIFORNIA BLVD
WALNUT CREEK PLAZA SUITE 202
WALNUT CREEK CA 94596



OPERATING LICENSE DPR-54
DOCKET NO. 50-312
REPORTABLE OCCURRENCE 81-40

In accordance with Technical Specification Appendix B, Section 2.3 and Section 5.6.2.c, the Sacramento Municipal Utility District hereby submits a ten-day report of Reportable Occurrence 81-40.

On August 31, 1981, during an end-of-month review of plant water quality records it was learned that the total dissolved solid limit of 34,000 pounds had been exceeded (35,200 pounds of dissolved solids had been discharged). There are high conductivity alarms (indicating high dissolved solids) on the plant effluent inlet and outlet. They did not alarm because the concentration of dissolved solids was within allowable limits. There is also an integrated flow/dissolved solids indication on the plant effluent outlet, but it is not alarmed.

The District is looking into the possibility of installing an alarm on the integrated flow indication. The operators will review this report to prevent any recurrence of this event.

The plant operated at full power, unaffected by this event.

John J. Mattimoe

John J. Mattimoe
Assistant General Manager
and Chief Engineer

cc: I&E Washington (30)
MIPC (3)
EPRI-NSAC

8109230584 810911
PDR ADOCK 05000312
S PDR

IED2
5
1/1

1981 SEP 15 AM 9 59

REGION V OFFICE

RECEIVED
SEP 15 1981