NRC FORM 366
(7-77)

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

Line	Field	Value
01	LICENSEE CODE (2)	NYJAF1
01	LICENSE NUMBER (3)	00-00000-000
01	LICENSE TYPE (4)	41111
01	CAT (5)	
CON'T 01	REPORT SOURCE (6)	L
01	DOCKET NUMBER (7)	0500333
01	EVENT DATE (8)	082481
01	REPORT DATE (9)	091781

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During normal operation, while conducting surveillance to satisfy TS Table 4.2-2,
03 HPCI high steam flow differential pressure switch 23-DPIS-76 was found set at
04 231.5 inches water. TS Table 3.2-2 requires a setpoint of 230.0 inches or less.
05 The redundant switch was set within TS limits. No significant hazard existed.

Line	Field	Value
09	SYSTEM CODE (11)	SF
09	CAUSE CODE (12)	E
09	CAUSE SUBCODE (13)	E
09	COMPONENT CODE (14)	INSTRU
09	COMP. SUBCODE (15)	S
09	VALVE SUBCODE (16)	Z
(17) LER/RO REPORT NUMBER	EVENT YEAR	81
	SEQUENTIAL REPORT NO.	068
	OCCURRENCE CODE	03
	REPORT TYPE	L
	REVISION NO.	0
	ACTION TAKEN (18)	E
	FUTURE ACTION (19)	Z
	EFFECT ON PLANT (20)	Z
	SHUTDOWN METHOD (21)	Z
	HOURS (22)	0000
	ATTACHMENT SUBMITTED (23)	N
	NPRD-4 FORM SUB. (24)	N
	PRIME COMP. SUPPLIER (25)	Z
	COMPONENT MANUFACTURER (26)	B069

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Instrument drift is considered the cause. The instrument was immediately
11 recalibrated and returned to service. No additional action is required.

Line	Field	Value
15	FACILITY STATUS (28)	E
15	% POWER (29)	093
15	OTHER STATUS (30)	NA
15	METHOD OF DISCOVERY (31)	B
15	DISCOVERY DESCRIPTION (32)	Surveillance
16	ACTIVITY RELEASED (33)	Z
16	CONTENT OF RELEASE (34)	Z
16	AMOUNT OF ACTIVITY (35)	NA
16	LOCATION OF RELEASE (36)	NA
17	PERSONNEL EXPOSURES NUMBER (37)	000
17	TYPE (38)	Z
17	DESCRIPTION (39)	NA
18	PERSONNEL INJURIES NUMBER (40)	000
18	DESCRIPTION (41)	NA
19	LOSS OF OR DAMAGE TO FACILITY TYPE (42)	Z
19	DESCRIPTION (43)	NA
20	PUBLICITY ISSUED (44)	N
20	DESCRIPTION (45)	NA

NRC USE ONLY

8109280500 810917
PDR ADOCK 05000333
S PDR

NAME OF PREPARER: W. Verne Childs PHONE: 315-342-3840