NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

Line	Field	Value
01	LICENSEE CODE (2)	C T H N P 1
01	LICENSE NUMBER (3)	0 0 - 0 0 0 0 0 - 0 0
01	LICENSE TYPE (4)	4 1 1 1 1
01	CAT (5)	
CON'T 01	REPORT SOURCE (6)	L
01	DOCKET NUMBER (7)	0 5 0 - 0 2 1 3
01	EVENT DATE (8)	0 9 0 1 8 1
01	REPORT DATE (9)	0 9 1 4 8 1

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 Cooling system tube leak on emergency generator 2B necessitated taking it out of
03 service for repair. This is operating in a degraded mode as per administrative
04 Technical Specifications and reportable per Technical Specification 6.9.2.b(2).
05 Redundant equipment was test run to prove operability. There was no effect on
06 the health and safety of the public.
07
08

Line	SYSTEM CODE (11)	CAUSE CODE (12)	CAUSE SUBCODE (13)	COMPONENT CODE (14)	COMP. SUBCODE (15)	VALVE SUBCODE (16)
09	E E	E	D	H T E X C H	C	Z

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	8 1	—	0 1 4	/	0 3	L	—	0

ACTION TAKEN (18)	FUTURE ACTION (19)	EFFECT ON PLANT (20)	SHUTDOWN METHOD (21)	HOURS (22)	ATTACHMENT SUBMITTED (23)	NPRD-4 FORM SUB. (24)	PRIME COMP. SUPPLIER (25)	COMPONENT MANUFACTURER (26)
B	B	Z	Z	0 0 0 0	N	N	X	Y 0 2 1

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The closed cooling system cooler experienced tube leaks after a test run. The cooler
11 is manufactured by Young Radiator Company Model XF-1303-TR-ZP with 75 PSI shell and
12 tube design pressure. It is normally at approximately 50 psig. The tube failures
13 are being monitored by the Maintenance Department to determine if further action is
14 required.

Line	FACILITY STATUS (28)	% POWER (29)	OTHER STATUS (30)	METHOD OF DISCOVERY (31)	DISCOVERY DESCRIPTION (32)
15	E	1 0 0	N/A	A	Alarm and operator observation

Line	ACTIVITY RELEASED (33)	CONTENT OF RELEASE (34)	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
16	Z	Z	N/A	N/A

PERSONNEL EXPOSURES

Line	NUMBER (37)	TYPE (38)	DESCRIPTION (39)
17	0 0 0	Z	N/A

PERSONNEL INJURIES

Line	NUMBER (40)	DESCRIPTION (41)
18	0 0 0	N/A

LOSS OF OR DAMAGE TO FACILITY (43)

Line	TYPE (42)	DESCRIPTION
19	Z	N/A

PUBLICITY

Line	ISSUED (44)	DESCRIPTION (45)	NRC USE ONLY
20	N	N/A	

8109280544 810914
PDR ADOCK 05000213
S PDR

NAME OF PREPARER: J. H. Ferguson PHONE: (203) 267-2556

GPO 917-926